Final Submittal E. I. HATCH NUCLEAR PLANT EXAM 2002-301 50-321 & 50-366 OCTOBER 16 - 18, 21 - 25, & OCTOBER 30, 2002,

1. As Given Simulator Scenario Operator Actions ES-D-2

	Facility:	E.I.Hatch	1	Scenario No.: 1 Op-Test No.:				
	Examin	ers:	·	Operators:				
		. <u></u>						
	Initial C	onditions: <u>Un</u>	<u>it is at 85% </u>	RTP, B RBCCW Pump tagged OOS for motor replacement,				
	2A RHF Functio	<u>R Pump OOS </u> nal <u>Test surve</u>	3 for maintenance, Instrument Maintenance performing HPCI Channel veillance. (Need to insert malfunction N21_99, E21_202A and R43_62A)					
	<u>SU FW</u>	<u>LC Failure</u> .						
	Turnove for Inbo	er: <u>Hold pow</u> eard MSIV's.	er constant.	In Day 2 of 7 for 1S 3.5.1. Perform Quarterly Surveillance				
	Event No.	Malf. No.	Event Type*	Event Description				
	1		N (BOP) (SRO)	Perform MSIV Surveillance, 34SV-B21-001-2S for the Inboard MSIV's. The Outboard MSIV's are done.				
	2	C11_30A	C (CBO) (SRO)	2A CRD Pump trip.				
	3	RfN21065	C (CBO) (SRO)	Loss of feedwater heating due to 4 th stage heater bypass inadvertent operation.				
	4		R (CBO) (SRO)	Reduce Reactor power due to loss of feedwater heating.				
	5	E41_103	C (BOP) (SRO)	HPCI Inadvertent Start-Up.				
	6	N21_84A	I (BOP) (SRO)	Feedwater Pump Minimum Flow Recirc Valve F117 Failure (open)				
	7	B21_48B	M (ALL)	Steam Line B Break (After Restrictor) (Var)				
		R43_62A E21_202A	C (BOP)	2A D/G, 2A & 2B Core Spray Pumps Fail to Auto Start (Starts manually)				
				SU Water Level Controller Failure				

Op-Test No.:	Scer
--------------	------

nario No.: <u>1</u>

Event No.: 1___

Event Description: <u>Perform 34SV-B21-001-2S, MSIV Exercise and Closure Instrument</u> <u>Funtional Test for the Inboard MSIV's</u>. The surveillance is complete for the Outboard <u>MSIV's</u>.

Time	Position	Applicant's Actions or Behavior
	SRO	Direct the BOP to perform the Quarterly MSIV functional surveillance for the Inboard MSIV's.
		•
	BOP	Review Precautions and Limitations. Instruct RO to monitor Rx Pressure and Main Steam Line Flow during valve stroking.
	BOP	Confirm that applicable relays are energized.
		Confirm that MSIV AC and DC Coil LEDs are illuminated.
	вор	Direst SSS to check relay status on 2H11-P609 & P611
		Place/Confirm applicable MSIV control switch in OPEN.SLOW TEST
	1	
		Take MSIV VIv Test Switch to TEST and HOLD.
	BOP	With CBO monitoring Reactor pressure and MSL flow and SSS monitoring relay status at 2H11-P609 and P611, the BOP will release the Test Switch immediately upon any one of the following:
		1) Relays de-energized on 2H-11-P609 & P611
	1	2) MSL flow change observed
	1	3) Reactor pressure change observed.
		When appropriate relays de-energize OR precaution 5.1.2 is met, THEN release test switch

Time	Position	Applicant's Actions or Behavior
	BOP	Verify appropriate relays are energized.
	BOP	If required, reset the Half Scram.
	SRO	Review completed surveillance Acceptance Criteria.
		· · · · · · · · · · · · · · · · · · ·
		NOTE: During the scenario, the applicant will only be required to perform 2 valves.
	1979- L 77-1	
		· · · · · · · · · · · · · · · · · · ·
Op-Test Event D <u>Lead Ex</u>	No.: S escription: <u>2A</u> aminer.	cenario No.: <u>1</u> Event No.: <u>2</u> Page 3 of CRD Pump Trip. Execute malfunction C11 30A when directed by th
Time	Position	Applicant's Actions or Behavior

	aminer.	
Time	Position	Applicant's Actions or Behavior
	СВО	Dispatches SO to investigate reason for trip OR May immediatel
		start 2B CRD pump per steps 3.1 and 3.3 of procedure <u>34AB-C11-001-2S</u> , Loss of CRD System:
		Step 3.1 - Place CRD Flow Control,2C11-R600, in Manua and DECREASE output to zero.
		Step 3.3 - Attempt to start 2B CRD Pump.
	SRO	After receiving report that 2A CRD pump cannot be restarted, direct operator to start the 2B CRD pump.
	CBO	Per <u>34AB-C11-001-2S</u> , starts and places 2B CRD pump in servi as follows:
		1) Place CRD Flow Control, 2C11-R600, in Manual and DECREASE output to zero.
	<u></u>	2) Start 2B CRD Pump.
		3) Increase system flow to 59 GPM.
		4) Transfer controller to AUTO.
	SRO	Notify on-call personnel. (Operations Duty Manager)

4 de 1

 Op-Test No.:

 Scenario No.:

 Page 5 of 21

 Event Description:
 2A CRD Pump Trip. Execute malfunction C11_30A when directed by the

 Lead Examiner.

Time	Position	Applicant's Actions or Behavior				
	BOP	Assist CBO with plant oversight. Monitor CRD temperatures while both CRD pumps are off.				
	SRO	Reviews Technical Specifications 3.1.5.b Accumulators				
		(Check Accum Lights > 10 T/S Action Statement)				
· ·						

Op-Test	No.: So	cenario No.: 1 Event No.: 3 Page 6 of 21				
Event D <u>Execut</u>	Event Description: <u>Loss of Feedwater Heating due to 4th Stage Heater Bypass opening.</u> Execute malfunction RfN21065 per Lead Examiner direction.					
Time	Time Position Applicant's Actions or Behavior					
	Crew	Recognize Mwe is increasing and investigate.				
		May receive 4 th and 6 th Stage heater high level alarms.				
	Crew	Recognize 4th stage Feedwater Heater outlet temperature				
		decreasing as indicated on SPDS or instr 2N21-R608.				
	SRO	Direct actions of <u>34AB-N21-001-2S</u> , Loss of Feedwater				
		Heating by ordering CBO/STA to:				
		1) Reduce Recirc Flow to stay within Analyzed Region.				
		2) Track Feedwater temperature in accordance with 34SV- SUV-020-0S, Core Parameter Surveillance.				
	СВО	Reduce/ <u>Maintain</u> Rx Power @ the current power level (should be approx. 84%) with Recircs per 34GO-OPS-005-2S, "Power Changes." IAW 34AB-N21-001-2S, Loss of Feedwater (I.O.A.)				
	BOP	Notifies maintenance to investigate cause of heater bypass.coming open. MAINTENANCE will REPORT - They will report that they were working on the wrong valve and accidentally shorted the control switch and it needs to be replaced.				

Execu	te malfunction R	fN21065 per Lead Examiner direction.				
Time	Position Applicant's Actions or Behavior					
	BOP/Crew	Refer to <u>34SO-N21-007-2S</u> , "Condensate and Feedwater System" for operation with a feedwater heater bypassed and actions to restore heater to service.				
	BOP/Crew	Notify Reactor Engineering to implement change to the MAPFAC(p) curve.				
<u></u>						
	· ·					

.

Op-Test Event D	: No.: Sc escription:Rea	cenario No.: <u>1</u> Event No.: <u>4</u> Page 8 of 21 activity Change due to loss of Feedwater Heating.					
Time	Position	Applicant's Actions or Behavior					
	SRO	Direct power reduction due to loss of feedwater heating. (75%)					
	СВО	Reduce reactor power with Recircs as directed by SRO.					
		NOTE: Power may be reduced 10 to 20% depending on severity of					
		feedwater temperature reduction.					
	BOP/Crew	Monitor Power/Flow Map to determine need for inserting Control					
		Rods due to entering Region for Potential Instability.					
	SRO	Notify Load Dispatcher, on-call personnel and Resident Inspector					
	.,	of load drop.					
	SRO	Review Power/Flow map requirements.					
b							

Op-Test No.: _____ Scenario No.: __1 Event No.: __5

Page 9 of 21

Event Description: <u>HPCI Inadvertent Start-up</u>. Enter malfunction E41_103 when directed by Lead Examiner.

Time	Position	Applicant's Actions or Behavior
	BOP/Crew	Recognize and report HPCI has started from an invalid initiation signal.
		Sec SYS Auto Initiation Signal Present 2-34
	СВО	Verify reactor water level stable. May receive APRM Hi Alarm and
		Rx Water Level Hi alarm.
	BOP	Verify Drywell Pressure is normal.
	SRO	Direct operator to secure HPCI per 34SO-E41-001-2S, High Pressure Coolant Injection (HPCI)System.
	BOP	Secure HPCI as follows: (Critical Task)
		 2) When HPCI turbine has stopped, place HPCI Aux Oil Pump in PTL.
		3) When receive "HPCI Turbine Brg Oil Press Low" alarm then, release the HPCI Turbine Trip push-button.
· · · · · · · · · · · · · · · · · · ·	СВО	Monitor reactor water level, pressure and power during the event and keep crew informed.

Op-Test No.: ____ Scenario No.: __1 Event No.: __5

Page 10 of 21

Event Description: <u>HPCI Inadvertent Start-up</u>. Enter malfunction E41 103 when directed by Lead Examiner.

Time	Position	Applicant's Actions or Behavior
	SRO	Direct Instrument Maintenance to stop what they are doing.
		NOTE: The IM's should inform the SRO that they inadvertently caused the initiation and damage has occurred that cannot be immediately repaired.
		Declare HPCI inoperable and determine that Tech Spec action 3.5.1.D is entered due to HPCI and 2A RHR Pump INOP at the same time. NOTE: (May need to ask a follow up question)
		Notify Operations Management and Reactor Engineering of the cold water addition. Initiate work request.
		Recognize that an 8 Hr ENS notification is required due to HPCI being declared INOP. IAW .00ACREG-001-0S, Item 51 (p. 12 of 51) NOTE: (May need to ask a follow up question)
	1	
	t	
<u> </u>	<u> </u>	

Op-Test No.:	Scenario No.:	1	Event No.:	6	Page 11	of	21
Op-Test No.:	Scenario No.:	1	Event No.:	6	Page 11	OT	

Event Description: <u>Feedwater Pump Minimum Flow Recirc Valve F117 (OPEN) Failure.</u> Execute malfunction N21_84B when directed by Lead Examiner.

Applicant's Actions or Behavior		
en.		
ow Recirc		
ישר יישר אין		
and IM's to		
<u></u>		

Op-Test	No.: Sc	enario No.: <u>1</u> Event No.: <u>7</u> Page 12 of 21			
Event D whePag start on E21_20	escription: <u>Ste</u> <u>e 12 of 21n dire</u> an <u>Auto-start</u> 2A shall be ins	am Line B Break after the Flow Restrictor. Execute malfunction ected by Lead Examiner. Failure of 2A D/G, 2A and 2B Core Spray to signal but may be started manually. Malfunctions R43_62A and serted at the beginning of the scenario.			
Time	Position	Applicant's Actions or Behavior			
	Crew	Recognize Drywell pressure and temperature increase.			
		1) High Drywell Pressure alarm @ 0.65 psig.			
		2) Entry into PC-1 and 2 @ Drywell Temp of 150°F.			
		 Enter <u>34AB-T23-002-2S</u>, Small Pipe Break inside Primary Containment. Monitor containment. 			
SRODirect BOP to vent the Drywell per <u>34SO-T48-002-2S</u> , Containment Atmosphere Control and Dilution Systems.					
	вор	Vent the Drywell by performing the following:			
		1) Open SBGT A(B Fltr Inlet from Rx Bldg, 2T46-F001A(B)			
		2)Place SBGT A(B) Fan/Filter, 2T46-D001A(B), in the RUN position.			
3) (7.2.2.3) Confirm that SBGT A(B) Fltr Disch damp 2T46-F002A(B), OPENS.					
	4) (7.2.2.4) Confirm SBGT A(B) HTR on Red Light ILLUMINATED.				

Op-Test	t No.: Sc	enario No.: <u>1</u> Event No.: <u>7</u> Page 13 of 21		
Event D whePag start on E21_20	escription: <u>Ste</u> le 13 of 21n dire an Auto-start 2A shall be ins	am Line B Break after the Flow Restrictor. Execute malfunction ected by Lead Examiner. Failure of 2A D/G, 2A and 2B Core Spray to signal but may be started manually. Malfunctions R43_62A and serted at the beginning of the scenario.		
Time	Position	Applicant's Actions or Behavior		
5) (7.2.2.5) Confirm that Standby Gas Treatment Sy Flow increases to 1500-4000 SCFM(CFM) as indica SBGT A(B) Flow To Main Stack, 2T46				
		6) Open 2T48-F334A(B), Drywell Vent Isol Vlv.		
		7) Open 2T48-F335A(B), Drywell Vent Isol Vlv.		
		8) Open Drywell Vent Flow Cntl Vlv using 2T48-R615A(B), Drywell Flow Controller for F336A(B).		
		Isolate RWCU, <u>if time allows</u> IAW 34SO-G31-003-2S, Section 7.5		
	SRO	Order Reactor SCRAM prior to 1.85 psig Drywell Pressure.		
	СВО	Manually SCRAM the Reactor using SCRAM pushbuttons.		
	<u> </u>	1) Place Mode Switch in S/D.		
		2) Verify and report all rods inserted past position 02.		
		3) Insert IRM's and SRM's.		
		4) Place SDV Isol VIv Switch to "ISOL" and verify closed.		
		5) If not tripped, place Recircs to minimum speed.		
<u> </u>	I BOP	Perform actions of RC-2 and RC-2 after Reactor SCRAM.		

Op-Test	No.: Sc	enario No.: <u>1</u> Event No.: <u>7</u> Page 14 of 21			
Event D whePag start on E21 202	escription: <u>Stea</u> e 14 of 21n dire an Auto-start 2A shall be ins	am Line B Break after the Flow Restrictor. Execute malfunction ected by Lead Examiner. Failure of 2A D/G, 2A and 2B Core Spray to signal but may be started manually. Malfunctions R43_62A and serted at the beginning of the scenario.			
Time	Position	Applicant's Actions or Behavior			
		1) Place RFPT controller in Auto controlling +3 to +15".			
		2) Place SU/LCV controller in Auto controlling +3 to +15".			
		3) Place FWLC Select Switch in Single Element.			
		 If not needed for level control, THEN: Trip 1 RFPT, OPEN 2N21-F125 and CLOSE 2N21 -F110. 			
		5) Monitor Reactor Pressure and maintain 800 -1080 psig.			
	SRO	Enters the following EOP's:			
1) RC, PC-1 and PC-2 when reach 1.85 Pressure		1) RC, PC-1 and PC-2 when reach 1.85 psig in Drywell. Pressure			
		2) PC-1 and PC-2 if reach 150°F Drywell temperature.			
	SRO	Direct BOP and RO to verify automatic actuations occurred when Drywell pressure exceeds 1.85 psig.			
	1				

Op-Test	No.: Sc	enario No.: 1 Event No.: 7 Page 15 of 21			
Event D and 2B (escription: <u>Ste</u> Core Spray to st	eam Line B Break after the Flow Restrictor. Failure of 2A D/G, 2A tart on an Auto-start signal but may be started manually.			
Time	Position	Applicant's Actions or Behavior			
	CBO/BOP	Verify and report the following occurred:			
		1) Failure of both Core Spray pumps to auto-start.			
		2) B, C and D RHR Pumps start.			
	· · · · · · · · · · · · · · · · · · ·	 Diesel Generators start and run unloaded except 2A Diesel Generator fails to start automatically. 			
		4) Group II Isolation successful.			
		5) SBGT System starts.			
	BOP	Preventing Injecting IAW 31-EO-EOP-114-2S: 3.0 OPERATOR ACTIONS			
		NOTE Performance of this procedure is <u>NOT</u> required <u>IF</u> 31EO-EOP-113-2S, TERMINATING AND PREVENTING INJECTION INTO THE RPV, has been performed.			
		3.1 CORE SPRAY 3.1.1. CLOSE:			
		VALVE DESCRIPTION PANEL			
		2E21-F005A INBD DISCHARGE VLV 2H11-P601 2E21-F005B INBD DISCHARGE VLV 2H11-P601 3.1.2 TRIP			
		PUMP DESCRIPTION PANEL			
	<u> </u>	2E21-C001A Core Spray Pump A 2H11-P601 2E21-C001B Core Spray Pump B 2H11-P601			
		CAUTION ANY SUBSEQUENT LOCA SIGNAL WILL CAUSE THE CORE SPRAY PUMPS TO AUTO START AND WILL ALSO ALLOW THE DISCHARGE VALVE TO AUTO OPEN.			
		3.1.3 Perform SYSTEM RESTORATION per Attachment 1 as directed by the Shift Supervisor.			

Op-Test	No.: Sc	enario No.	Ereck offer f	ent No.: <u>7</u>	r Failure of 2	Page 16 of 21
and 2B (Core Spray to st	tart on an /	Auto-start sig	nal but may be sta	arted manually	<u>// 6/0, 2//</u>
Time	Position		Арр	licant's Actions or	Behavior	
		3.2 L				
			\underline{C}		ATEMENT	
			ATE Prevention of LP	Cl injection is required, THEN	perform the following:	
		a) POSITI	ON control switches f	or the following valves to CLC	DSE:	
		<u>VAI</u> 2E1 2E1	<u>.VE</u> 1-F016A (B) 1-F028A (B)	DESCRIPTION CNMT SPRAY OUTBD VL TORUS SPRAY OR TEST	V 2H11-P601 VLV 2H11-P601	
		b) TRIP LF	PCI Pump(s), 2E11-C	002A (B, C, D).		
		3.2.1		J VLV, 2E11-F017A(B), can	be closed using the con	ntrol switch,
		*	THEN CLOSE:	DESCRIPTION	PANEL	
			2E11-F017A 2E11-F017B	RHR OUTBD INJ VL RHR OUTBD INJ VL	✓ 2H11-P601 ✓ 2H11-P601	<u> </u>
				NOTE	<u></u>	
		Keys for op Key cabine	ening Unit 2 cabinets t.	and a pre-staged nutdriver fo	r opening links are loca	ted in the Unit 2
		3.2.2	OPEN the following VLVs, 2E11-F017A	3 LINKS to Override LOCA O	PEN interlocks for RHR	OUTBD INJ
				LINK	PANEL	
			LPCI A LOOP LPCI B LOOP	FF-38 FF-36	2H11-P617B 2H11-P618B	
ļ						

Page 17 of 21 ____ Scenario No.: <u>1</u> Event No.: <u>7</u> Op-Test No.: ___ Event Description: Steam Line B Break after the Flow Restrictor. Failure of 2A D/G, 2A and 2B Core Spray to start on an Auto-start signal but may be started manually. Applicant's Actions or Behavior Time Position NOTE Pre-staged jumpers are located in the EOP jumper book located near the operator's desk. Install the following jumpers to allow RHR OUTBD INJ VLV, 2E11-F017A/B, to be 3.2.3 positioned using the control switch: JUMPERS PANEL 2H11-P617B LPCI A LOOP FF-39 to FF-40 LPCI BLOOP FF-37 to FF-38 2H11-P618B CONFIRM CLOSED OR CLOSE RHR OUTBD INJ VLV, 2E11-F017A&B. 3.2.4 IF RHR OUTBD INJ VLV, 2E11-F017A(B) can <u>NOT</u> be CLOSED, THEN CLOSE RHR INBD INJ VLV, 2E11-F015A(B) by performing the following: 3.2.5 OPEN the following LINKS to Override LOCA OPEN interlocks for RHR INBD INJ VLVs, 2E11-F015A/B: 3,2.5.1 <u>LINK</u> PANEL LPCI A Loop FF-32 2H11-P617B FF-30 2H11-P618B LPCI B Loop Install the following jumpers to allow RHR INBD INJ VLV, 2E11-F015A/B to be 3.2.5.2 positioned using control switch: PANEL JUMPERS 2H11-P617B LPCI A Loop LPCI B Loop FF-33 to FF-34 FF-31 to FF-32 2H11-P618B CONFIRM CLOSED OR CLOSE: 3253 DESCRIPTION PANEL VALVE 2E11-F015A RHR INBD INJ VLV 2H11-P601 2E11-F015B RHR INBD INJ VLV 2H11-P601 Direct BOP to place Torus Sprays in service. SRO

 Op-Test No.:

 Scenario No.:

 Page 18 of 21

 Event Description:

 Steam Line B Break after the Flow Restrictor. Failure of 2A D/G, 2A
 and 2B Core Spray to start on an Auto-start signal but may be started manually.

Time	Position	Applicant's Actions or Behavior		
	BOP	Place Torus Sprays in service by performing the following: Per E11-010.		
		1) Place S17A/B, Cnt Spray VIv Control Switch in MANUAL		
		2) Open 2E11-F028A(B), Torus Spray OR Test vlv.		
		3) Throttle OPEN 2E11-F027A(B), Torus Spray viv.		
		4) Place RHRSW Pump Control Switch in Manual Overide.		
		5) Depress RHRSW Lube Valves pushbutton and allow to operate for 1 minute.		
		6) Throttle disch vlv 2E11-F068A(B) approx. 40% open.		
		7) Start applicable RHRSW Pump.		
		8) Throttle discharge valve to 4400 gpm while maintaining discharge pressure <450 psig.		

Op-Test	No.: Sc	enario No.: <u>1</u> Event No.: <u>7</u> Page 19 of 21
Event D and 2B SU Leve	escription: <u>Ste</u> Core Spray to s Control Valve	eam Line B Break after the Flow Restrictor. Failure of 2A D/G, 2A tart on an Auto-start signal but may be started manually. Feedwater has failed
Time	Applicant's Actions or Behavior	
	SRO	Direct CBO to maintain reactor water level +3 to +50 inches.
	СВО	Determines the <u>Feedwater SU Level Control Valve has failed</u> due to vessel level continueing to decrease. Notifies SS and maintenance. OR Throttles 2N21-E110.
		1) Coordinates with BOP to maintain level band with RCIC OR uses Feedwater manually.
	BOP	Helps maintain level band by controlling RCIC manually as needed by CBO or throttles 2N21-F110 to maintain reactor water level.
	BOP	Reports all automatic actions occurred for +1.85 psig Drywell pressure with the exception that 2A D/G, 2A & 2B Core Spray pumps failed to auto-start.
	SRO	Direct BOP to start 2A D/G and 2A & 2B Core Spray pumps.
	BOP	Start 2A Diesel Generator by performing the following:
		1) RESET the shutdown logic by depressing the Diesel
		2) Momentarily place the Diesel Start switch to START.
		3) Verify Diesel comes up to speed and voltage.
		4) Report the Diesel is running to the SS.
	BOP	:
		Start 2A and 2B Core Spray Pumps by performing the following
		1) Confirm 2E21-F031A(B),Minimum Flow VIv is OPEN.
		2) Start 2A Core Spray Pump.

Op-Test	No.: Sc	enario No.: 1 Event No.: 7 Page 20 of 21
Event D and 2B SU Leve	escription: <u>Ste</u> Core Spray to st Control Valve	eam Line B Break after the Flow Restrictor. Failure of 2A D/G, 2A tart on an Auto-start signal but may be started manually. Feedwater has failed
Time Position Applicant's Actions or Behavior		
		3) Start 2B Core Spray Pump
		4) Confirm room cooler automatically starts.
	BOP/CBO	Keeps SRO informed of trends on containment and reactor
		parameters.
	SRO	Directs BOP to commence a cooldown using bypass valves not to exceed 100°F/hr UNLESS cooldown rate has already been exceeded due to the leak. (Rx Press < 500 psig)
	BOP	Performs ONE of the following to establish <100°F cooldown rate using a Bypass Valve:
		1) Depress the OPEN pushbutton on the Bypass Valve Opening Jack.
	·····	2) Reduce Pressure Regulator Setpoint.
·		
	BOP/CBO	Report to SRO that Torus Pressure is approaching 11 psig OR Drywell Temperature approaching 340°F.
ļ		
ł		

Op-Test No.:	Scenario No.: 1	Event No.: 7_

Event Description: <u>Steam Line B Break after the Flow Restrictor</u>. Failure of 2A D/G, 2A and 2B Core Spray to start on an Auto-start signal but may be started manually.

Time	Position	Applicant's Actions or Behavior		
	SRO	Direct Drywell Spray Initiation when Torus Pressure is above 11 psig OR Drywell Temperature is approaching 340°F.		
		1) Verify Drywell Temperature and Pressure within Drywell Spray Initiation Limit (Graph 8)		
		2) Verify Torus Level is below 215".		
	BOP	Initiate Drywell Sprays by performing the following:		
		1) Verify/Trip Recirc Pumps.		
		2) Trip Drywell Cooling fans.		
		3) Open 2E11-F021A(B), Containment Spray INBD Valve.		
		4) Throttle OPEN 2E11-F016A(B), Containment Spray OTBD Valve. Must provide at least <u>5000 gpm to ensure</u> effective Drywell Pressure reduction. (Critical Task)		
		5) Terminate Drywell and/or Torus Sprays before Drywell negative pressure is sustained. (Critical Task)		
		END SCENARIO WHEN PROPER SPRAY FLOW IS ACHIEVED AND DRYWELL PRESSURE IS DECREASING		
		EAL Classification - Alert based on > 50 gpm leakage.		

Form ES-D-1 (R8, S1) Scenario Outline Appendix D Facility: E.I.Hatch Scenario No.: 2 Op-Test No.: Operator:_____ Examiners: Initial Conditions: Unit is at 100% RTP, "2B" CRD pump is OOS for maintenance, Severe weather is predicted for the upcoming shift. Turnover: Reduce reactor power to 90% RTP for a rod shuffle per Reactor Engineer. Event Malf. No. Event Event Description No. Type* Lower Load to approx. 90% RTP per 34GO-OPS-005-2, R (CBO) 1 (SRO) Power Changes. 2A CRD Flow Control Valve fails CLOSED. C (CBO) 2 C11 31A (SRO) Loss of RPS "2B" with one Control Rod scramming in CBO (N) C71_57B 3 due to blown fuse in other RPS Power supply. & C11 26 BOP Place the RWCU System in operation per RWCU 145 System Quick Recovery. ("2B Pump) N (BOP) 4 pereno . Decreasing condenser vacuum due to in-leakage, C (ALL) N61 73 5 followed by the Loss of "2B" Circ Wtr Pump N71_68B ATWS with control rods able to be inserted manually. 6 C11_211 M (ALL) *Scenario ends when operators begin to re-inject to increase water level after terminating and preventing injection sources. This is a critical task. (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Op-Test No.:	Scenario No.: 22	Event No.: _1	Page <u>1</u> of <u>1</u>
--------------	------------------	---------------	---------------------------

Event Description: <u>Reduce reactor power to 90% RTP per 34GO-OPS-005-0S</u>, Power Changes, for a rod shuffle per Reactor Engineer.

Time	Position	Applicant's Actions or Behavior
	SRO	Directs CBO to reduce reactor power with Recirc flow to
		90% RTP as recommended by STA/Reactor Engineer.
	СВО	Reviews Precautions and Limitations in:
		34GO-OPS-005-0S, POWER CHANGES
		34SO-B31-001-2S, RECIRCULATION SYSTEM
	СВО	Reduces reactor power using Recirc Master Controller to reduce
		the speed of the Recirc pumps no greater than 10 MWe/min.
	СВО	Reports reactor power reduction complete when at 90% RTP
 		

Op-Test No.: \$	Scenario No.: <u>2</u>	Event No.:	2	Page _	1_	of _	_2_
-----------------	------------------------	------------	---	--------	----	------	-----

Event Description: _2A CRD Flow Control Valve fails closed

Time	Position	Applicant's Actions or Behavior			
	Team	Recognizes failure/closure of 2A CRD FCV by:			
		Panel scan			
		Annunciator "CRD HYDRAULIC TEMP HIGH" (P603-140)			
		Drive water DP decrease to near 0 psid			
	СВО	Enters procedures:			
		34AR-603-140-2S, CRD HYDRAULIC TEMP HIGH			
		34AB-C11-001-2S, LOSS OF CRD SYSTEM			
		• 34SO-C11-005-2S, CRD SYSTEM			
	СВО	Dispatches SO to CRD equipment area to:			
		Investigate cause of 2A FCV failure, per 34AB-C11-001-2S			
		Monitor CRD drive temperatures, per 34AR-603-140-2S			
		Shift FCVs if required, per 34SO-C11-005-2S			
	SRO	Contact Maintenance personnel for support			
		REPORT: SO reports to crew that the 2A flow control station has			
		malfunctioned. Maintenance reports that repairs can			
		be made in approximately 2 hours.			
		SO also reports two CRD drives at 255 degrees F,			
		temperature of others is slowly increasing			

Op-Test No.: ____ Scenario No.: _2_ Event No.: _2_ Page _2_ of _2_

Event Description: _2A CRD Flow Control Valve fails closed

Time	Position	Applicant's Actions or Behavior
	SRO	Directs CBO to place 2B FCV into service
	СВО	Transfers CRD FCV 's per 34SO-C11-005-2S by:
		Directs SO to locally shift CRD FCV
		At 2H11-P603, places 2C11-R600 to Manual
		REPORT: SO reports CRD FCV's have been shifted and that
		CRD temperatures are decreasing
	СВО	Returns CRD System to normal configuration by:
		 At 2H11-P603, places 2C11-R600 to AUTO
		Confirming system parameters are normal
		Annunciator "CRD HYDRAULIC TEMP HIGH" clears
	СВО	Reports to SRO that CRD flow control valves have been shifted
		and the CRD System has been restored to normal configuration

Op-Test No.: _____ Scenario No.: _2__ Event No.: _3__ Page _1_ of _4_

Event Description: _Loss of 2B RPS Bus with one control rod scramming in due to a blown fuse in the other power supply._____

Time	Position	Applicant's Actions or Behavior		
	СВО	Stop power decrease, if in progress.		
	TEAM	Recognize loss of 2B RPS bus		
		Dispatches SO to investigate cause of 2B RPS bus loss		
	вор	Enters 34AB-C71-002-2S, Loss of RPS, and verifies the		
		following automatic actions per Att. 3 of 34AB-C71-002-2S:		
		Half scram on RPS Channel B		
		Listed Group 1, 2, and 5 isolation valve closure		
		MCRECS shifts to pressurization mode (calls U1 CBO)		
		Steam Packing Exhausters trip		
	CBO/TEAM	Recognize control rod scram by either:		
		"ROD DRIFT" Annunciator (P603-247)		
		Green full-in light illuminate on full core display		
		OD7 following bus restoration, and scram reset		
	SRO	Contact Maintenance for support in restoration of 2B RPS bus		
		and determination of cause of rod scram		
	SRO	Determine applicable Tech Specs due to loss of 2B RPS		
		(T S 3.4.5)		
		(T S 3.1.3)		

Op-Test No.:	Scenario No.:	<u>_2</u>	Event No.: 3	-
--------------	---------------	-----------	--------------	---

Page _2_ of _4_

Event Description: _Loss of 2B RPS Bus with one control rod scramming in due to a blown fuse in the other power supply._____

Time	Position	Applicant's Actions or Behavior
	SRO	Upon discovery of scrammed rod:
		Contact Maintenance to determine cause and perform
		corrective action
		Direct CBO to enter 34AB-C11-004-2S, Mispositioned
		Control Rods
		REPORT: The SO reports that 2B RPS M/G set has tripped.
-		Workers in the area of the 2D 600VAC bus report that
		a mop handle fell against the local panel causing the
		breaker to the 2B RPS M/G set to trip open.
	SRO	Directs the BOP to transfer 2B RPS to the alternate supply
		OR
		Directs the SO to reclose the breaker and restart the
		2B RPS M/G set
	вор	If directed to transfer 2B RPS to the alternate supply:
		At panel 2H11-P610, CONFIRM that power is available
		Place the Power Source Select switch to ALT B
		on panel 2H11-P610.

Op-Test No.:	Scenario	No.:	_2_	I
--------------	----------	------	-----	---

Event No.: _3 Page _3_ of _4_

Event Description: _Loss of 2B RPS Bus with one control rod scramming in due to a blown fuse in the other power supply._____

Time	Position	Applicant's Actions or Behavior
	BOP	Upon restoration of the 2B RPS bus:
		Reset ½ scram
		Reset ½ Group 1 isolation
		Reset ½ Group 2 isolation
		Reset radiation monitors
		Restore Drywell Floor and Equipment Drain sumps
		Open 2G11-F004 and 2G11-020 (P601)
		Restore Fission Product Monitoring system
		Open 2D11-F052, F053 & F072 (P700)
		Enter 34SO-G31-001-2S to restore RWCU system
		Reset TIP system at 2H11-P607
	SRO	Contacts STA/Reactor Engineering for recommendations for
		control rod recovery
		REPORT: Reactor Engineering recommends that control rod
		02-23 be recovered by continuous withdrawal.
		REPORT: Maintenance reports that fuse in other RPS supply was
		found blown. Fuse will be replaced when directed by
	-	SRO.

Op-Test No.: _____ Scenario No.: _2__ Event No.: _3__ Page _4_ of _4__

Event Description: Loss of 2B RPS Bus with one control rod scramming in due to a blown fuse in the other power supply.

Time	Position	Applicant's Actions or Behavior
	SRO	Directs Maintenance to replace fuse in 2A RPS supply
	SRO	Directs CBO to recover control rod 02-23 upon fuse replacement
		by continuous withdrawal to pre-event position
	СВО	Enters 34GO-OPS-065-0S, Control Rod Movement, and withdraws
		control rod 02-23 to pre-event position by continuous withdrawal
		as recommended by STA/Reactor Engineering
	SRO/CBO	Perform pre-brief per att. 2 of 34GO-OPS-065-0S, Control Rod
		Movement, prior to control rod withdrawal
	СВО	Continuously withdraws control to position 48 by performing the
		following:
		Selects control rod
		Places EMERG IN NOTCH OVERRIDE Sw. to
		OVERRIDE position
		Places ROD MOVEMENT CONTROL Sw to OUT NOTCH
		NOTE: The two steps above are performed simultaneously.
		Performs coupling check after rod has settled at position
		48 by attempting to withdraw the control rod and verifying
		that Annunciator "ROD OVERTRAVEL" (P603-248)
		is not received.

8

I

						· .
		~		A	Dogo 1 of	1
On Toot No 1	Sconaria Nia 1	1	EVentino :	4		
	OUCHAIN NO.	<u> </u>			· • • • • • • • • • • • • • • • • • • •	
					—	

Event Description: <u>Return RWCU system to service per 34SV-G31-001-2S</u>, Section 7.6.2, RWCU System Quick Recovery_____

Time	Position	Applicant's Actions or Behavior
	SRO	Directs the BOP to place the RWCU system into service with the
		"2B" pump in service per 34SO-G31-001-2S, Section 7.6.2,
		RWCU System Quick Recovery.
	вор	Enters 34SO-G31-001-2S, reviews Precautions and Limitations
		Enters section 7.6.2, proceeds to Att. 8 to place "B" pump in service
		Dispatches SO to RWCU equipment area for support activities
		Determines that prewarming is not required
		Throttles open 2G31-F044
		Contacts SSS for installation of jumpers per Att. 4
		Opens 2G31-F001
		Slowly opens 2G31-F004
		Contacts SO locally to monitor fault indicator
		Places 2G31-C001B control switch to START
		With SO locally returns demins to service
		Reports to SRO that RWCU system has been placed in service
]		

Op-Test No.: _____ Scenario No.: __2_ Event No.: __5_ Page _1_ of _2_

Event Description: Decreasing Condenser vacuum due to in-leakage followed by a trip of the 2B Circ Water Pump

Time	Position	Applicant's Actions or Behavior					
	TEAM	Recognizes condenser vacuum is decreasing by:					
		Decrease in generator output					
		Decreasing condenser vacuum trend					
		Annunciators "TURBINE VACUUM LOW" (P650-102)					
		"INLET FLOW TO HOLDUP LINE HIGH" (P600-1-020)					
		"PRETREATMENT O/G RADIATION DOWNSCALE/INOP"					
		(P601-428)					
	SRO	Directs CBO to rapidly reduce reactor power with Recirc flow to					
		restore Condenser vacuum to >25"					
	СВО	Initiates a rapid power reduction with Recirc flow per					
		34GO-OPS-005-0S, Power Changes.					
	<u> </u>						
	SRO	Directs BOP to enter 34AB-N61-002-2S, Main Condenser Vacuum					
		Low, and attempt to determine cause of vacuum decreasing.					
	вор	Dispatches SO to investigate and determine cause of					
		decreasing condenser vacuum					
	SRO	Contacts Maintenance to assist in determination of cause of					
		decreasing condenser vacuum					

Op-Test No.: _____ Scenario No.: __2__ Event No.: __5__ Page _2_ of _2_

Event Description: Decreasing Condenser vacuum due to in-leakage followed by a trip of the 2B Circ Water Pump

Time	Position	Applicant's Actions or Behavior
		REPORT: SO reports that Maintenance has found air
		in-leakage on south end of the condenser.
		NOTE: Power reduction will result in an increase in condenser
		vacuum. When power reduction is stopped, vacuum
		continues to decrease.
	BOP	Reports to SRO that 2B Circ Water Pump has tripped as indicated
		by the following:
		Amber light indication above pump control switch
		Condenser vacuum decreasing more rapidly
	BOP	Dispatches SO to investigate cause of 2B Circ Water Pump trip
	SRO	Determines that Condenser vacuum is deceasing and will reach
		setpoint for a turbine trip before in-leakage can be stopped.
	SRO	Directs CBO to:
		Insert a manual scram
		Place mode switch to shutdown
	СВО	CBO depresses scram pushbuttons and places Reactor Mode
		Switch to SHUTDOWN and reports to the SRO:
		All rods are not inserted (ATWS)

Op-Test No.:	Scenario No.: _	2	Event No.: <u>6</u>	Page _1_ of _5_
• _				

Event Description: <u>Reactor scram ATWS (With capability to manually insert control</u> rods).

Position	Applicant's Actions or Behavior
TEAM/CBO	Recognize failure of all control rods to insert on reactor scram.
SRO	Enters EOP flow charts RCA and CP-3
	Enters EOP flow charts PC-1 and PC-2
	Directs CBO to perform RC-1 actions
	Directs BOP to perform RC-2 and RC-3 actions
СВО	Per RC-1 placard completes the following:
	Insert SRM/IRM detectors
	Shift APRM/IRM recorders
	Range IRM's
BOP	Per RC-2 placard completes the following:
	 Places RFPT controller in auto with setpoint +3" to +15"
	 Places SU/LCV controller in auto with setpoint +3" to +15"
	Place FWLC to single element
	• Open 2N21-F125
	Trip one RFPT
	Position TEAM/CBO SRO SRO CBO BOP BOP

Op-Test No.:	Scenario No.:	2	Event No.:	6	Page	_2_	of .	_5_
--------------	---------------	---	------------	---	------	-----	------	-----

Event Description: <u>Reactor scram ATWS (With capability to manually insert control</u> rods).

Time	Position	Applicant's Actions or Behavior			
	SRO	Directs CBO to:			
		Confirm mode switch in shutdown			
		Confirm ARI initiated			
		Confirm Recirc runback to minimum			
		Trip Recirc pumps if power is >5%			
		Reset ARI and insert control rods per 31EO-EOP-103-2S			
		 Monitor reactor power for peak to peak oscillations >25% 			
	SRO	Directs BOP to:			
		Initiate LLS for pressure control			
		Reduce pressure set to <845 psig if turbine is off-line			
		and any MSL is open			
		Inhibit ADS			
		 Bypass MSIV low RWL isolation interlocks per EOP-100 			
		Override 2P41-F316 isolation per EOP-100			
	СВО	Confirms mode switch in shutdown			
		Confirms ARI initiated			
		Confirms Recirc runback to minimum			
		Trips Recirc pumps if power is >5%			
		Resets ARI			

Op-Test	No.: Se	cenario No.: _2_ Event No.: _6_ Page _3_ of _5_
Event D	escription: <u>Rea</u>	actor scram ATWS (With capability to manually insert control rods).
Time	Position	Applicant's Actions or Behavior
	СВО	Enters 31EO-EOP-103-2S and performs the following:
		Directs SSS to place ARI to TEST locally
		Places reactor mode switch to REFUEL
		 Places RWM bypass switch to BYPASS
		Directs SSS to install jumpers to override auto scrams
		Establishes adequate drive water pressure to drive rods b
		1) Resetting scram and adjusting 2C11-F003, or
		2) Starting second CRD pump and adjusting CRD flow
		Drives selected control rods with Emerg In Notch Override
		Switch in the EMER ROD IN or Rod Movement Switch
		NOTE: Rods selected will be at STA recommendation or central
		Rods in a black-and-white pattern
		Reports control rod insertion in progress to SRO
		Places SDV Isol Test switch to NORM, when scram is res
		When "SCRAM DISCH VOL NOT DRAINED" alarm clears
		Repeats manual scram, observing for rod movement
	вор	Performs the following:
		Places ADS inhibits switches to OVERRIDE
		 Lowers EHC pressure set to <845 psig by depressing PB
		 Reports to SRO EHC pressure set at <845 psig

Time	Position	Applicant's Actions or Behavior
	SRO	Determines that conditions to Terminate and Prevent Injection per
		CP-3 to lower RWL to less than –60" have been met, and orders
		the BOP to:
		 Terminate and Prevent all injection per 31EO-EOP-113-25
		Excepted from:
		-Boron
		-RCIC
		-CRD
		To lower RWL to below –60"
	ВОР	Terminates and Prevents injection per 31EO-EOP-113-2S,by
		performing the following:
		Closes 2N21-F110
		Closes 2N21-F125
		 Reduces speed of running RFPT to lower discharge
		pressure to less than reactor pressure
		Trips HPCI and places Aux Oil pump to PTL
		Directs SSS to perform T&P actions for LPCI and Core
		Spray
		Closes 2E21-F005A & F005B, and trips Core Spray pump
		 Closes 2E11-F017A & F017B
		Beneficial to SBO that Terminate & Prevent actions are complete

Op-Test No.:	Scenario No.: _	_2	Event No.:	<u>6</u>	Page	<u>5</u>	of _	_5_
--------------	-----------------	----	------------	----------	------	----------	------	-----

Event Description: <u>Reactor scram ATWS (With capability to manually insert control</u> rods).

Time	Position	Applicant's Actions or Behavior			
	CBO/BOP	Monitors and reports Reactor Power and RWL to SRO			
	BOP	Reports RWL is below –60"			
	SRO	 Recognizes conditions met to end Terminate and Prevent. 			
		Determines appropriate RWL band.			
		 Directs BOP to end Terminate and Prevent, and 			
		establish injection with table 13 systems to maintain			
		RWL between –185" and –60"			
	BOP	Establish injection to maintain RWL between -185" and -60" by:			
		 Opening 2N21-F110 or 2N21-F125, AND increasing the 			
		speed of a running RFPT to greater than reactor pressure, or			
		Placing HPCI Aux Oil pump in AUTO and placing HPCI			
		into service (Critical Task)			
	вор	Will report to SRO that injection has been established and RWL			
		Is being maintained in the band given			
		Scenario ends when RO begins injection to maintain RWL			
		EAL Classification - Alert based on Failure of RPS to initiate and			
		Complete a Scram, SAE if SBLC is injected.			

••

Appendix D

Scenario Outline Form ES-D-1 (R8, S1)

1	• • • • •					
	Facility:	E.I.Hatcl	1	Scenario No.: 3 Op-Test No.:		
	Examin	ers:		Operators:		
	Initial C predicte G11_21 E41_10 Turnove	onditions: Pland ad for the upco 8A/B Fail to 1 7. er: _Start the 2	6 RTP with 2A RFPT in operation. Severe weather is RCIC Mechanical Overspeed Trip E51_61, G11_63B/D, rp II, P64_193B B DW Chiller trip, HPCI failure to start d increase power to full load.			
Ļ			1			
	Event No.	Malf. No.	Event Type*	Event Description		
	1		N (BOP) (SRO)	Start the 2 nd RFPT per 34SO-N21-007-2S section 7.1.11.		
	2		R (CBO) (SRO)	Commence load increase after starting RFPT.		
	3	C51_14A	I (CBO) (SRO)	"A" APRM fails INOP.		
	4	P64_193C	C(BOP) (SRO)	2A Drywell Chiller Compressor Failure.		
	5	B31_41A	C (CBO)	"A" Recirc Pump high vibes. Operator will trip.		
	6	S11_161 R43_239A	M(ALL) C(BOP)	Loss of off-site power due to storm. 2A D/G Tie Breaker Failure to Auto Close.		
	7	B31_210B	M(ALL)	Recirc suction piping leak. Small enough that crew can control parameters for loss of all high pressure feed.		
				*Scenario ends with Emergency Depressurization and level restored above TAF.		

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Op-Test No.: _____ Scenario No.: __3_ Event No.: __1_ Page _1_ of _1_

Event Description: <u>Start the second RFPT per 34SO-N21-007-2S</u>, "Condensate and <u>Feedwater System</u>," section 7.1.11. 2B RFPT is windmilling and step 7.1.11.4 has been completed.

Time	Position	Applicant's Actions or Behavior				
	SRO	Directs BOP to place 2B RFPT into service per				
		34SO-N21-007-2S, section 7.1.11				
	вор	Enters 34SO-N21-007-2S and reviews Precautions and Limitations,				
		Places 2B RFPT into service by:				
		Confirming status of 2B RFPT				
		Trip & reset RFPT				
		Raise pump speed with the Speed Setter				
		Direct SO to close RFPT drains locally				
		Raise speed to 2100 rpm (+ 100)				
		Transfer control to M/A station				
		Place 2B RFPT into service by increasing pump speed				
		with M/A station in Manual until pump flows are balanced.				
		Transfer M/A station to Auto				
		Report to SRO that 2B RFPT has been placed in service				

<u></u>	Toot No 1	Seenaria Na :	2	Event Ne :	2	Dogo /	<u>،</u>	~f	4
- VI	J-165LINU	Scenano No		EVENLIND	<u> </u>	rage_	۱ <u> </u>	л_	<u>ا_</u>

Event Description: _Commence load increase after placing 2B RFPT in service.

Time Position Applicant's Actions or Behavior							
	SRO	Directs CBO to increase reactor power to RTP by increasing Reci					
		flow. Power increases should be made as recommended by the					
		STA/Reactor Engineering at a rate not to exceed 10 MWe/min.					
	СВО	Enters the following procedures and reviews Precautions and					
		Limitations:					
		34GO-OPS-005-2S, "Power Changes"					
		34SO-B31-001-2S, "Recirculation System"					
		· · · · · · · · · · · · · · · · · · ·					
	СВО	Increases reactor power with Recirc flow increase per					
		Section 7.1.4, of 34SO-B31-001-2S by slowly adjusting					
		Recirc Master Flow Controller.					
	СВО	Monitors power increase by observing APRM and generator					
		output indications.					

Op-Test No.:	Scenario No.:	3	Event No.:	3	Page 1 of 2
	Marco Mar		-		<u> </u>

Event Description: <u>"A" APRM fails INOP</u>

Time	Position	Applicant's Actions or Behavior					
	СВО	Responds to Annunciator alarms:					
		• "APRM/OPRM TRIP" (P603-210)					
-		• "ROD OUT BLOCK" (P603-238)					
		"RMCS/RWM ROD BLOCK OR SYS TROUBLE"					
		(P603-239)					
		Enters 34AR-603-210-2S for "APRM/OPRM TRIP"					
	СВО	Confirms on APRM/OPRM ODA on 2H11-P603					
		2A APRM INOP is indicated					
 		Confirms on APRM/OPRM ODA on 2H11-P608					
		2A APRM INOP is indicated					
 		CPU FAILURE is indicated					
 		Reports that 2B31-R614, Recirc Drive Flow recorder on 2H11-P602					
	ļ	Is indicating downscale					
	ļ						
[

Op-Test No.: _____ Scenario No.: _3__ Event No.: _3__ Page _2_ of _2_

Event Description: <u>"A" APRM fails INOP</u>

Time	Position	Applicant's Actions or Behavior					
	SRO	Directs CBO to bypass "A" APRM with bypass switch on					
		2H11-P603.					
	СВО	Places APRM bypass switch on 2H11-P603 to the "A" position,					
		Reports to the SRO that "A" APRM has been bypassed.					
		NOTE: Alarms (210) and (238) clear when A APRM is bypassed.					
		Alarm (239) does not clear due to RWM					
	SRO	Contacts Maintenance personnel to investigate cause of					
		"A" APRM inoperability.					
	SRO	Enters Tech Specs and TRM to determine applicable RAS					
		for inoperability of "A" APRM.					
		• T. S. Table 3.3.1.1-1 Item (2)					
		• TRM Table 3.3.2-1 Item (3)					

Op-Test No.: _____ Scenario No.: __3_ Event No.: __4_ Page _1_ of _3_

Event Description: 2A Drywell Chiller Compressor Failure.

Time	Position	Applicant's Actions or Behavior					
	ВОР	Recognizes running Drywell Chiller has tripped by the following:					
		Alarm "PANEL 2H11-P700 SYSTEM TROUBLE" (P650- 225)					
		At Panel 2H11-P700, acknowledges alarm "DRWL CHILLED					
		WTR B006A SAFETY S/D" (P700-105) and observes by					
		light indication that chillers are not operating					
	BOP	Reports to SRO that Drywell Chillers are not operating and					
		dispatches SO to attempt local chiller start					
		· · · · · · · · · · · · · · · · · · ·					
	Crew	Recognize increasing Drywell temperature and pressure trend by:					
		SPDS and recorder trends and the following alarms:					
		"PRIMARY CNMT PRESSURE HIGH" (P603-115)					
		"PANEL 2H11-P654 SYSTEM TROUBLE" (P650-214)					
		"PANEL 2H11-P657 SYSTEM TROUBLE" (P650-224)					
		"DRYWELL TEMP HIGH" (P654-066)					
		"DRYWELL TEMP HIGH" (P657-043)					
		Numerous alarms on P654 indicating Drywell Cooling Unit					
		Discharge Air Temp High					

Op-Test No.:	Scenario No.:	<u>_3</u>	Event No.: <u>4</u>	Page	_2_	of	<u>_3</u> _
--------------	---------------	-----------	---------------------	------	-----	----	-------------

Event Description: 2A Drywell Chiller Compressor Failure.

Time	Position	Applicant's Actions or Behavior				
	SRO	Directs BOP to initiate venting of the drywell per 34SO-T48-002-2S				
		utilizing the CAD System				
	BOP	Initiates drywell venting by:				
		• OPENS 2T46-F003A(B) AND/OR 2T46-F001A(B)				
		PLACES SBGT A(B) in RUN position				
		CONFIRMS 2T46-F002A(B) OPENS				
		CONFIRMS SBGT A(B) HTR Red Light ILLUMINATES				
		CONFIRMS SBGT Flow increases to 1500-4000 SCFM				
		• OPENS 2T48-F334A(B)				
		• OPENS 2T48-F335A(B)				
		 OPENS 2T48-F336A(B) 				
		· · ·				

Op-Test No.: _____ Scenario No.: __3__ Event No.: __4__ Event Description: _2A Drywell Chiller Compressor Failure. Page <u>3</u> of <u>3</u>

Time	Position	on Applicant's Actions or Behavior		
	CREW	Recognizes Drywell pressure is increasing with venting in progress		
	SRO	Directs BOP to initiate fast venting per 34SO-T48-002-2S		
	Directs Maintenance to Drywell Chiller room to ass			
		restart of a Drywell Chiller		
		 Directs BOP to enter 34AB-T47-001-2S, Loss of DW Cooling 		
	BOP	Initiates fast venting by performing the following:		
		• OPENS 2T48-F319		
		• OPENS 2T48-F320		
		NOTE: With fast venting in progress, drywell pressure is		
		decreasing, but drywell temperature is increasing		
		REPORT: SO reports that the 2B Drywell Chiller has been started		
		and investigation will continue into cause of 2A trip		
		·		
	SRO	Enters EOP flow charts PC-1 and PC-2 if entry conditions are met		
		due to increasing drywell temperature and/or pressure		
	SRO	Directs BOP to place H2O2 analyzers into service when Drywell		
		Temperature reaches 150 degrees F		

On-Test No	Scenario No ·	3	Event No ·	5	Page 1 of 2
Op-rest No		_ 3	EVENUNU.		

Event Description: "2A" Recirc Pump high vibration. Operator will trip.

Time	Position	Position Applicant's Actions or Behavior					
	СВО	Acknowledges and announces Annunciator alarm "PUMP					
		MOTOR A VIBRATION HIGH" (P602-104)					
	SRO	Directs CBO to terminate power ascension					
	Enters 34AR-602-104-2S						
Depresses vibration A/B Reset Pushbutton							
		 Reports to SRO that alarm does not reset. 					
		 Informs SRO of requirement to reduce the speed of 2A 					
		and 2B together per 34GO-OPS-005-2S					
	SRO	Directs CBO to commence power reduction until vibration alarm					
		can be reset or Recirc pumps are at minimum speed.					
	СВО	Commences power reduction per 34GO-OPS-005-2S and					
		34SO-B31-001-2S.					
	СВО	Reduces Recirc pump speed with Master Flow Controller to					
45% speed. Transfers		45% speed. Transfers to individual M/A stations in manual and					
		reduces speed of pumps together to minimum.					
	СВО	Depresses vibration reset pushbutton periodically during					
		speed/power reduction.					

Op-Test No.:	Scenario No.:	3	Event No.:	5	Page 2 of 2

Event Description: _ "2A" Recirc Pump high vibration. Operator will trip.

Time	Position	Applicant's Actions or Behavior	
CBO Reports to SRO that Recirc is at min		Reports to SRO that Recirc is at minimum speed and vibration	
	alarm has not reset.		
	SRO	Directs CBO to secure the 2A Recirc pump per 34SO-B31-001-2S.	
	СВО	Places 2A Recirc M/G set control switch to trip.	
		Closes 2A Recirc pump discharge valve.	
SRO Directs CBO to enter 34AB-B31-001-2, "Reactor Reci		Directs CBO to enter 34AB-B31-001-2, "Reactor Recirculation	
Pump(s) trip, or Recirc Loops Flow Mismatch." CBO Enters 34AB-B31-001-2 and performs the following:		Pump(s) trip, or Recirc Loops Flow Mismatch."	
		Enters 34AB-B31-001-2 and performs the following:	
	With assistance from STA determine location on the second se		
Power/Flow map		Power/Flow map	
		Inform SRO of proximity to RPI	
		Throttle open 2A Recirc pump discharge valve	
	SRO	Enter Tech Specs and determine applicable RAS for single loop	
		operation of the Recirc system. (3.4.1)	
	SRO Directs CBO to prepare to insert control rods to exit RPI, if		
		operating in the region	
		Notify Management of unit status	

Op-Test No.: _____ Scenario No.: __3_ Event No.: __6_ Page _1_ of _3_

Event Description: <u>LOSP due to storm</u>. 2A EDG output breaker fails to auto close. RCIC and HPCI fail to auto start, 2G11-F019 and 2G11-F020 fail to close on isolation signal.

Time	Position	Applicant's Actions or Behavior	
	TEAM	Recognize LOSP / Reactor Scram	
	SRO	Enters RC flow chart and directs:	
		CBO to perform RC1 and enter 34AB-C71-001-2S	
		BOP to perform RC2 & RC3	
		CBO verify automatic actions for LOSP	
	СВО	Reports:	
		All control rods inserted	
		All EDGs have started.	
		2E 4160 VAC bus is not energized	
		2G 4160 VAC bus is powered from 2C EDG	
	SRO	Directs BOP to enter:	
		34AB-R43-001-2S, "Diesel Generator Recovery"	
		34AB-R22-002-2S, "Loss of 4160V Emergency Buses"	
		34AB-R22-003-2S, "Station Blackout"	
	вор	Reports to SRO that:	
		HPCI and RCIC have failed to start	
		LLS has initiated and is controlling reactor pressure.	
		SO & Maint. to be contacted for HPCI & RCIC recovery	
		2B RHR & 2B Core Spray pumps are running	

Op-Test No.: _____ Scenario No.: __3_ Event No.: __6_ Page _2_ of _3_

Event Description: <u>LOSP due to storm.</u> 2A EDG output breaker fails to auto close. RCIC and HPCI fail to auto start, 2G11-F019 and 2G11-F020 fail to close on isolation signal.

Time	Position	Applicant's Actions or Behavior	
	BOP	Per 34AB-R43-001-2S, "Diesel Generator Recovery"	
		With 2A EDG Speed Adjust lowers frequency to 57 hz	
	With 2A EDG Speed Adjust raises frequency to 60 h		
		Confirms 2A EDG output break closes energizing	
		2E 4160 VAC bus	
		 Reports to SRO that 2E 4160 bus is now energized. 	
		Reports 2A RHR & 2A Core Spray pumps are running	
	SRO	Directs BOP to continue efforts to restore electrical loads.	
Boguests control of 1B EDC from Unit 1		Bequests control of 1B EDG from Unit 1	
	NOTE: 1B EDG will auto tie to 2F 4160V bus on tr		
BOP Dispatches SO locally to: • Restore 125/250 VDC battery chargers • Restart RPS M/G sets		Dispatches SO locally to:	
		Restore 125/250 VDC battery chargers	
		Restart RPS M/G sets	
		Reset breaker for SSAC	
	TEAM	Monitors Primary Containment for EOP entry conditions	
	SRO	Enters EOP flow charts PC-1 and PC-2 when entry conditions	
		are met. (Initial entry on high drywell temperature)	
	SRO	Directs BOP to place RHR in Torus spray mode when primary	
		containment pressure exceeds 1.85 psig	

Op-Test No.: _____ Scenario No.: __3_ Event No.: __6_ Page _3_ of _3_

Event Description: <u>LOSP due to storm</u>. <u>2A EDG output breaker fails to auto close</u>. RCIC and HPCI fail to auto start, <u>2G11-F019</u> and <u>2G11-F020</u> fail to close on isolation signal.

Time	Position	Applicant's Actions or Behavior	
	BOP	Places RHR into Torus spray mode of operation by:	
		PLACES 2E11-S17A(B), Containment Spray VIv Control.	
		switch in the MANUAL position	
		Confirms RHR pump(s) running in selected loop	
		Confirms 2E11-F017A(B) CLOSED	
		Confirms 2E11-F024A(B) CLOSED	
		OPENS 2E11-F028A(B), Torus Spray OR Test VIv.	
		Throttles OPEN 2E11-F027A(B), Torus Spray Vlv.	
		Reports to SRO that RHR is in the Torus spray mode	
	СВО	While performing 34AB-C71-001-2S, attachment 1 for Group	
		Isolations, observes and reports:	
		2G11-F019 and 2G11-F020 have failed to isolate	
		 2G11-F019 and 2G11-F020 will not close with switch 	
		SO to be dispatched locally to attempt closure	
	CBO/BOP	Attempts to restore CRD by performing the following:	
		Depresses Pump A and/or Pump B LOCA reset PB	
		Starts 2A or 2B CRD pump	
		Enters 34SO-C11-005-2S, section 7.3.7 and dispatches	
		SO to CRD equipment area to increase CRD flow	
		Starts standby CRD pump	

Op-Test No.: _____ Scenario No.: _3_ Event No.: _7_ Page _1_ of _4_

Time	Position	Applicant's Actions or Behavior	
	TEAM	A Recognizes leak in primary containment by the any of the followir	
		Primary Containment pressure and temperature rate of	
		change has increased significantly.	
		RWL has begun to trend downward at a higher rate.	
	SRO	Directs BOP to place RHR into Drywell spray mode when the	
		following conditions are met:	
		Torus pressure above 11 psig	
		Torus water level < 215"	
		In safe area of DWSIL curve	
		NOTE: Drywell sprays may not be initiated at this time if,	
		Adequate core cooling is threatened.	
	BOP	If directed by SRO to spray the Drywell will:	
		Verify Recirc pumps are shutdown	
		Shutdown Drywell cooling fans	
		Confirm safe area of the DWSIL curve	
		Secure Torus sprays in loop selected for Drywell sprays	
		• Open 2E11-F021A(B)	
		Throttle open 2E11-F016A(B)	
		Confirm Drywell pressure is decreasing	
1			

Op-Test No.: _____ Scenario No.: __3_ Event No.: __7_ Page _2_ of _4_

Time	Position	Applicant's Actions or Behavior	
	SRO	Determine from RWL trend and injection systems status that RWL	
	cannot be maintained above –155"		
	SRO	Transitions from RC/L to CP-1 Alternate Level Control for RWL	
		control	
	SRO	Directs the following:	
		CBO to Inhibit ADS	
		BOP to align and operate all available table 8 and 2A	
	systems for injection. RHR pumps operating in T		
		Drywell Spray mode are to be aligned in LPCI mode.	
	СВО	Inhibits ADS by:	
		Placing ADS Logic Inhibit switches to INHIBIT position	
		Verify white inhibit lights illuminate	
	BOP	Aligns table 8 and table 2A system for injection by:	
		Confirming 2A and 2B Core Spray Pumps operating	
		Confirming 2A and 2B RHR pumps are operating	
		NOTE: At this time if, RHR pumps are operating in Torus	
		and/or Drywell spray modes, the BOP will align for	
		LPCI injection mode by closing containment	
		spray valves.	

Op-Test No.: _____ Scenario No.: _3_ Event No.: _7_ Page _3_ of _4_

Time	Position	Applicant's Actions or Behavior	
	BOP Will report the following systems aligned and operating:		
		4 table 8 systems	
		1 table 2A system	
	SRO	Wait until RWL drops to below –155" and:	
		Determine that RWL cannot be maintained >-185"	
		Determine that 4 table 8 systems are aligned and operating	
		 Before RWL drops to –185" transition to point G for 	
		Emergency Depress	
	SRO Before RWL drops to –185" SRO will:		
		Determine all control rods are inserted beyond 02	
		Determine that Torus water level is >57.5"	
		Direct CBO to OPEN 7 ADS valves	
	СВО	Open 7 ADS by performing the following at 2H11-P602:	
		 Place control switches for 7 ADS valves to OPEN 	
		 Verify all valves open by amber lights and SPDS 	
		 Verify reactor pressure is decreasing 	
		(Critical Task-First valve open prior to reaching –185" RWL)	
	SRO	Direct BOP to confirm low pressure systems injection upon reactor	
		pressure reduction below shutoff head of pumps	

Op-Test No.: _____ Scenario No.: __3_ Event No.: __7_ Page _4_ of _4_

Time	Position	Applicant's Actions or Behavior	
	BOP	Restores RWL to above TAF by:	
		Confirming injection valves open	
	Confirming RHR and Core Spray system flow incre		
Observing a positive RWL indication on redundan indicators		Observing a positive RWL indication on redundant indicators	
		(Critical Task)	
	BOP	Reports RWL above TAF and trending upward.	
	SRO	Directs BOP to throttle injection as RWL approaches 0" to restore	
		and maintain RWL +5" to +50"	
	BOP	May request EOP-114 actions performed by SSS to allow throttling	
		of RHR injection valves	
		Scenario ends with Emergency Depressurization and	
		level restored above TAF.	
1		EAL Classification - Alert based on > 50 gpm leakage.	

Appendix D

Scenario Outline

Facility: <u>E.I.Hatch</u> Sc			Scenario No.: <u>4 (Spare)</u> Op-Test No.:	
Examin	ers:			
(Operator			
Initial C	onditions: <u>U</u>	<u>nit at 100% </u> 28 Stator (RTP making preparations to S/D for a refueling outage.	
upcomi	ng shift.		Sooning Fullip 003. Severe weather is predicted for the	
Turnove	er: <u>Swap EHC</u>	pumps to ev	ven out run times per System Engineer. When complete	
<u>then init</u>	late Reactor a	S/D for Refue	aing Outage.	
Event	Malf. No.	Event	Event	
NU.		туре		
1		N (BOP)	Swap EHC Pumps from "A" to "B" per 34SO-N32-001-2S, EHC Hydraulic System.	
2		R (CBO)	Commence a normal unit S/D for Refueling Outage.	
3	C51_17A	I(CBO)	RBM "A" failure.	
4	R25_185	C(BOP)	120/208 VAC Inst Bus 2A fault.	
5	N21_87B	C(ALL)	2B RFP Trip.	
6	E41_213	I(BOP)	HPCI Torus Level sensor fails high and suction valves remain open to cause Torus high level.	
	ł	1	1	

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Op-Test No.: ____ Scenario No.: _4 Event No.: _1 Page _1 of _1

Event Description: <u>Swap EHC Pumps from "A" to "B" per 34SO-N32-001-2S, EHC</u> <u>HYDRAULIC SYSTEM.</u>

Time	Position	Applicant's Actions or Behavior	
<u></u>	SRO	Direct BOP to place 2B EHC pump into service and remove 2A	
		EHC Pump from service per 34SO-N32-001-2S, EHC Hydraulic	
		System	
	BOP	Reviews Precautions and Limitations in 34SO-N32-001-2S	
	BOP	Dispatches SO locally to monitor and report EHC system operation	
	BOP	At panel 2H11-P650:	
		Establishes communications with SO locally Places control switch 2B EHC pump to START Directs SO verify discharge pressure locally Places 2A EHC pump control switch to TRIP Places 2A EHC pump control switch to PULL AUTO START Verifies EHC system pressure 1600 to 1800 PSIG	
		Verifies 2B pump motor amps <67.5	
		Reports to SRO that EHC pumps have been swapped	
··			
	<u></u>		
l			

Op-Test No.:	Scenario No.: 4	_ Event No.: <u>2</u>	Page <u>1</u> of <u>1</u>
UD-TESLING			•

Event Description: <u>Commence a normal S/D for Refueling Outage.</u>

Time	Position	Applicant's Actions or Behavior	
<u></u>	SRO	Directs CBO to enter 34GO-OPS 013-2S, NORMAL PLANT	
		SHUTDOWN and commence plant shutdown for refueling outage	
	СВО	Enters the following procedures and reviews the Precautions/	
		Limitations sections:	
		34GO-OPS 013-2S, NORMAL PLANT SHUTDOWN	
		34GO-OPS-005-0S, POWER CHANGES	
		34SO-B31-001-2S, RECIRCULATION SYSTEM	
	СВО	Commence reactor power reduction/Recirc flow reduction by	
		adjusting Recirculation Master Controller in the decrease direction	
		as recommended by STA at no greater than 10 Mwe/min.	
	СВО	Report to SRO that reactor power reduction is in progress	
	<u> </u>		
	1		
 			
1			

Op-Test No.:	Scenario No.:	4	Event No.:	3	Page <u>1</u> of <u>1</u>
--------------	---------------	---	------------	---	---------------------------

Event Description: <u>RBM "A" Failure</u>

ſ

Time	Position	Applicant's Actions or Behavior
	СВО	Acknowledge and report Annunciator alarm "RBM UPSCALE OR
		INOPERATIVE" (P603-202)
	СВО	Enter 34AR-603-202-2S
		At 2H11-P603, determine upscale or inop on ODA
		Determine cause of inoperability
		Reports 2A RBM ODA at P608 indicates CPU Fault
	<u> </u>	
	SRO	Direct CBO to bypass 2A RBM
	<u> </u>	Contact I & C Maintenance to repair RBM
	<u> </u>	Determine Tech Specs requirement for inoperable RBM
		(3.3.2.1)
	СВО	Place RBM Bypass switch to the "A" position
	<u> </u>	
	+	
1	1	

Op-Test No.:	Scenario No.:	4	Event No.:	4	Page <u>1</u> of <u>2</u>	
--------------	---------------	---	------------	---	---------------------------	--

Event Description: <u>120/208 VAC Instrument Bus 2A Trip.</u>

Time	Position	Applicant's Actions or Behavior
	ТЕАМ	Recognize/Diagnose loss of 2A Instrument Bus
		Dispatch SO to 2A Instrument Bus to investigate loss
	SRO	Direct BOP to enter 34AB-R25-002-2S, LOSS OF
		INSTRUMENT BUSES
		Contact Maintenance for support in restoration of 2A
		Instrument Bus
		Determine Tech Specs for:
		Loss of 2A Instrument Bus (TS 3.8.7)
		Loss of Recirc Loop (TS 3.4.1)
	вор	Verify automatic actions per 34AB-R25-002-2S
		Maintain condenser vacuum, if necessary, by:
		Reducing speed of 2A Recirc locally (scoop tube locked)
		Reducing speed of 2B Recirc at M/A station in MANUAL
	SRO	When informed that breaker 27 on 2A Essential Cabinet was
		tripped open during labeling activities, directs SO to reclose breaker

5

ſ

On-Test No ·	Scenario No.:	4	Event No.:	4	Pa
00-1631110	_ Obonano no			<u> </u>	• •

Page <u>2</u> of <u>2</u>

Event Description: <u>120/208 VAC Instrument Bus 2A Trip.</u>

Time	Position	Applicant's Actions or Behavior
	SRO	Upon restoration of 2A Instrument Bus directs BOP to restore 2A
		Instrument Bus loads to normal alignment
	ВОР	Open Stack Valve 2N62-F057
·		Restore PSW temperature controllers to AUTO
		Reset Recirc 2A scoop tube lock
		Restore 2A RFPT control to 2A M/A in AUTO
		Return SJAE to service per 34SO-N61-001-2S
	<u> </u>	
	;=	

Op-Test No.:	Scenario No.:	_4	Event No.: _	5	Page <u>1</u> of <u>1</u>

Event Description: <u>2B RFPT Trip.</u>

Time	Position	Applicant's Actions or Behavior
	CREW	Recognizes trip of 2B RFPT by one of more of the following:
		Annunciator alarm "RFPT 2B TRIP" (P650-326)
		Decreasing RWL
	-	Decreasing RFPT speed
	вор	If 2A RFPT control has not been restored to M/A AUTO, BOP
		will control 2A RFPT with speed setter to maintain RWL
	BOP	If 2A RFPT control has been restored to M/A AUTO, BOP will
		verify speed of 2A RFPT is increasing to maintain RWL
	СВО	If RWL decreases to 32" with TMR RFPT trip:
		Verify Recirc runback
		 Unlock 2A Recirc scoop tube, if locked and 2A instrument
		. is energized
		Reduce power with Recirc to allow 2A RFPT to provide
		makeup at < 7.5 Mlbm/hr feed flow
	BOP	• Enter 34AB-650-326-2S
		Dispatch SO to 2B RFPT room to investigate trip
		Attempt reset of 2B RFPT
	SRO	Direct CBO to manually scram reactor if RWL not stabilized >3"

Op-Test No.:	Scenario No.:	4	Event No.: <u>6</u>	Page <u>1</u> of <u>4</u>
--------------	---------------	---	---------------------	---------------------------

Event Description: <u>HPCI Torus Level sensor fails high and suction valves remain open to cause Torus high level.</u>

BOP	Acknowledges and reports annunciator alarm "TORUS LEVEL
	HIGH" (P601-127)
BOP	Enters 34AR-601-127-2S
	Verifies HPCI suction valve realignment
	Reports torus water level normal
 ВОР	Reports loss of indication on 2E41-F004 as valve was stroking
 	closed
 ТЕАМ	Recognizes torus water level is increasing
 	Dispatches SO to reset 2E41-F004 breaker
 	Directs SO to close 2E41-F004 with handwheel
	 Determines instrument failure cause of initial torus
	water level alarm
	 Contacts I & C Maintenance to assist in diagnosis and repair
 SRO	Evaluates Tech Specs for inop level transmitter (3.3.5.1)
 SRO	Enters EOP charts PC-1/PC-2 on high torus water level of 150"
 	Directs BOP place H2O2 analyzers into service
	Directs BOP to override HPCI & RCIC high torus level
	suction swap per EOP 100

Op-Test No.:	Scenario No.: _	<u>4</u>	Event No.:	6	Page <u>2</u> of <u>4</u>
--------------	-----------------	----------	------------	---	---------------------------

Event Description: <u>HPCI Torus Level sensor fails high and suction valves remain open to cause Torus high level.</u>

Time	Position	Applicant's Actions or Behavior
	ТЕАМ	Tracks and reports increasing torus water level
	SRO	Directs STA to monitor graph 6 (SRVTPLL)
	SRO	Orders reactor scrammed when determined that torus water level
		cannot be maintained below the SRVTPLL
	СВО	Inserts manual scram with scram push buttons
		Places mode switch to SHUTDOWN
		Performs RC-1 actions
		Enters 34AB-C71-001-2S, SCRAM PROCEDURE
	BOP	Perform actions of RC-2 and RC-3 after Reactor SCRAM.
		Place RFPT controller in Auto controlling +3 to +15".
		Place SU/LCV controller in Auto controlling +3 to +15".
		Place FWLC Select Switch in Single Element.
		If not needed for level control, THEN: Trip 1 RFPT, OPEN
		2N21-F125 and CLOSE 2N21-F110.
		 Monitor Reactor Pressure and maintain 800 -1080 psig.
	1	

Op-Test No.: ____ Scenario No.: _4 Event No.: _6 Page _3 of _4

Event Description: <u>HPCI Torus Level sensor fails high and suction valves remain open to cause Torus high level.</u>

Time	Position	Applicant's Actions or Behavior
	SRO	Directs BOP to maintain reactor pressure below 900 psig
		(Safe area of graph 6 until torus water level reaches 193")
	вор	Lowers EHC pressure set to maintain reactor pressure <900 psig
	SRO	Orders termination of injection from sources external to primary
		containment except for systems required for adequate core cooling
		CRD and boron when determined torus water level and reactor
		pressure cannot be maintained below SRVTPLL (graph 6)
	SRO	Directs CBO to open 7 ADS valves when determined
		that torus water level and reactor pressure cannot be
		restored and maintained below the SRVTPLL or maintained
		in 'Safe Region" of the HCTL or PSP (graphs 2 & 7)
	СВО	Places control switches for all 7 ADS valves to open and verifies by
	<u> </u>	multiple indication that valves have opened.
	<u></u>	
	SRO	Directs BOP to restore RWL to +3" to +50" utilizing available
ļ		injection systems

Op-Test No.:

Scenario No.: 4 Event No.: 6 Page 4 of 4

Event Description: <u>HPCI Torus Level sensor fails high and suction valves remain open to cause Torus high level.</u>

Time	Position	Applicant's Actions or Behavior
	вор	Restores RWL to +3" to +50" when reactor pressure decreases to
		below the shutoff head of low pressure injection systems. The
		Following system(s) may be used:
		RHR LPCI
		Core Spray
		Condensate, only if adequate core cooling is threatened.
	·	The scenario will end when Drywell Sprays have been
		secured and the Reactor has been Emergency
		Depressed due to high Torus water level.
	<u></u>	
	<u> </u>	
	<u> </u>	
	+	