

December 10, 2002

Dr. Robert C. Mecredy  
Vice President, Nuclear Operations  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, New York 14649

SUBJECT: Assessment Follow-Up - R. E. Ginna Nuclear Power Plant

Dear Dr. Mecredy:

Recently the NRC staff completed a review of R. E. Ginna Nuclear Power Plant. The assessment evaluated the performance indicators (PIs) and inspection results. The purpose of this letter is to inform you of your safety performance and our plans for a future inspection at your facility.

On October 4, 2002, the NRC staff forwarded a letter concerning the final significance determination of a white inspection finding in the Emergency Preparedness cornerstone. This white finding involved the alert and notification system (ANS), which consists of sirens used to alert members of the public of an emergency at Ginna. Specifically, problems with the ANS siren feedback system prevented Rochester Gas and Electric Corporation (RG&E), Monroe County and Wayne County from being able to identify which, if any, sirens failed to activate. Identifying such failures is necessary so that backup route alerting can be conducted within approximately 45 minutes for the populace covered by the failed sirens. If siren failures should occur, the ability to provide early notification would be compromised, and therefore, was considered a white finding because the deficiency was associated with 10 CFR 50.47(b)(5), a risk significant emergency planning standard.

As a result, we have assessed Ginna's performance to be in the Regulatory Response column of the NRC's Action Matrix. Therefore, we plan to conduct supplemental inspection 95001 during the week of April 14, 2003. This inspection procedure is conducted to provide assurance that the root causes and contributing causes of risk significant performance issues are understood, the extent of condition is identified, and the corrective actions are sufficient to prevent recurrence.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/NRC/ADAMS/index.html> (the Public Electronic Reading Room).

Dr. Robert C. Mecredy

2

Please contact Michele Evans at 610-337-5224 with any questions you may have regarding this letter.

Sincerely,

/RA/

A. Randolph Blough, Director  
Division of Reactor Projects

Docket Nos. 50-244  
Licensee Nos. DPR-18

cc: P. Wilkens, President, Rochester Gas and Electric  
P. Eddy, Electric Division, Department of Public Service, State of New York  
C. Donaldson, Esquire, State of New York, Department of Law  
N. Reynolds, Esquire  
W. Flynn, President, New York State Energy Research  
and Development Authority  
J. Spath, Program Director, New York State Energy Research  
and Development Authority  
D. Stenger, Ballard Spahr Andrews and Ingersoll. LLP  
T. Wideman, Director, Wayne County Emergency Management Office  
M. Meisenzahl, Administrator, Monroe County, Office of Emergency Preparedness  
T. Judson, Central New York Citizens Awareness Network

Distribution: H. Miller, RA/J. Wiggins, DRA (1)  
 A. Blough, DRP  
 W. Lanning, DRS  
 B. Holian, DRP  
 J. Clifford, DRP  
 R. Crlenjak, DRS  
 M. Evans, DRP  
 DRS Branch Chiefs (5)  
 H. Nieh, RI EDO Coordinator  
 R. Laufer, NRR  
 J. Andersen, NRR  
 R. Clark, PM, NRR  
 P. Milano, PM, NRR (Backup)  
 C. Carpenter, NRR  
 R. Pascarelli, NRR  
 D. Screnci, PAO  
 N. Sheehan, PAO  
 K. Kolaczyk, SRI Ginna  
 M. Marshfield, DRP  
 N. Perry, DRP  
 S. Chaudhary, DRS  
 B. Norris, DRS  
 T. Moslak, DRS  
 P. Frechette, DRS  
 D. Silk, DRS  
 B. Platchek, DRP  
 Region I Docket Room (with concurrences)

DOCUMENT NAME: G:\BRANCH1\GINSTUFF\Ginna follow-up letter.wpd  
 After declaring this document "An Official Agency Record" it **will/will not** be released to the Public. **To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy**

OFFICE	RI/DRP		RI/DRP		RI/DRP	
NAME	NPerry/NP		MEvans/MGE		ABlough/AB	
DATE	11/26/02		12/09/02		12/10/02	

OFFICIAL RECORD COPY