

December 11, 2002

Mr. P. E. Katz, Vice President  
Calvert Cliffs Nuclear Power Plant, Inc.  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 -  
REQUEST FOR ADDITIONAL INFORMATION RELATED TO REVISION OF  
TECHNICAL SPECIFICATION 3.7.11 TO ADOPT TECHNICAL  
SPECIFICATION TASK FORCE-51(TAC NOS. MB5414 AND MB5415)

Dear Mr. Katz:

In reviewing your submittal of June 11, 2002, concerning the subject amendment application, the U.S. Nuclear Regulatory Commission staff determined that it needs additional information to continue its review. Please provide your response within 30 days of receipt of this letter so that the staff may complete its review to support your requested approval date.

Sincerely,

*/RA/*

Donna M. Skay, Senior Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosure: As stated

cc w/encl: See next page

December 11, 2002

Mr. P. E. Katz, Vice President  
Calvert Cliffs Nuclear Power Plant, Inc.  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 -  
REQUEST FOR ADDITIONAL INFORMATION RELATED TO REVISION OF  
TECHNICAL SPECIFICATION 3.7.11 TO ADOPT TECHNICAL  
SPECIFICATION TASK FORCE-51(TAC NOS. MB5414 AND MB5415)

Dear Mr. Katz:

In reviewing your submittal of June 11, 2002, concerning the subject amendment application, the U.S. Nuclear Regulatory Commission staff determined that it needs additional information to continue its review. Please provide your response within 30 days of receipt of this letter so that the staff may complete its review to support your requested approval date.

Sincerely,

*/RA/*

Donna M. Skay, Senior Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDI-1 R/F DSkay BPlatchek, RGN -1 RLaufer  
OGC ACRS

ACCESSION NUMBER: ML023450407

\*Input provided by memo dated 11/22/02

OFFICE	PDI-1/PM	PDI-1/LA	SPSB/SC	PDI-1/SC
NAME	DSkay	SLittle	F.M. Reinhart*	RLaufer
DATE	12/4/02	12/4/02	11/22/02	12/6/02

**OFFICIAL RECORD COPY**

Calvert Cliffs Nuclear Power Plant  
Unit Nos. 1 and 2

cc:

President  
Calvert County Board of  
Commissioners  
175 Main Street  
Prince Frederick, MD 20678

James Petro, Esquire  
Counsel  
Constellation Power Source  
111 Market Street  
Baltimore, MD 21202

Jay E. Silberg, Esquire  
Shaw, Pittman, Potts, and Trowbridge  
2300 N Street, NW  
Washington, DC 20037

Mark Geckle  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657-4702

Resident Inspector  
U.S. Nuclear Regulatory  
Commission  
P.O. Box 287  
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager  
Nuclear Programs  
Power Plant Research Program  
Maryland Dept. of Natural Resources  
Tawes State Office Building, B3  
Annapolis, MD 21401

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Kristen A. Burger, Esquire  
Maryland People's Counsel  
6 St. Paul Centre  
Suite 2102  
Baltimore, MD 21202-1631

Patricia T. Birnie, Esquire  
Co-Director  
Maryland Safe Energy Coalition  
P.O. Box 33111  
Baltimore, MD 21218

Mr. Loren F. Donatell  
NRC Technical Training Center  
5700 Brainerd Road  
Chattanooga, TN 37411-4017

## REQUEST FOR ADDITIONAL INFORMATION

### CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2

The proposed changes to the Technical Specifications (TS) create an opportunity for a different release pathway than was previously assumed for a design basis fuel-handling accident (FHA) in the spent fuel pool area. This may increase the radiological consequences in the control room of the design basis FHA over that previously calculated, due to a difference in the atmospheric dispersion factor assumed for a release from that pathway.

- a. With respect to control room habitability, does the intent of 10 CFR Part 50, Appendix A, General Design Criterion 19 continue to be met for the proposed changes to the TSs and the resulting change in the operation of the spent fuel pool exhaust ventilation system after an FHA in the spent fuel pool area, including reconstitution/inspection activities? How is this determined?
- b. If an analysis of the control room habitability for the FHA in the spent fuel pool area has been performed in support of the license amendment request, provide the analysis assumptions, inputs, and results.

Enclosure