FINAL AS-ADMINISTERED ADMINISTRATIVE JPMS

FOR THE KEWAUNEE INITIAL EXAMINATION - AUG/SEP 2002

ES-301

Administrative Topics Outline

Form ES-301-1

Facility: Examina	KEWAUNEE NUCLE ation Level (circle one):	AR PLANT <u>RO</u> / SRO	Date of Examination: 8/26/02 Operating Test Number: 2002301
	Administrative Topic/Subject Description	Describe method of evaluation: ONE Administrative JPM, OR TWO Administrative Questions	
A.1	Conduct of Operations/ Reactor Plant Startup	JPM: Perform a Pre-Critical Checklist.	· · · · · · · · · · · · · · · · · · ·
	Requirements Plant Parameter Verification	JPM: Perform an Estimated Critical Posit	tion (ECP).
A.2	Equipment Control/ Tagging & Clearances	JPM: Review a tagout for accuracy.	
A.3	Radiation Control/ Radiation Exposure Limits.	JPM: Determine a stay-time for a High R	adiation Area.
A.4	Emergency Plan/ Emergency Communications.	JPM: Perform ERO pager activation in re	sponse to a security threat.

NUREG-1021, Revision 8

ES-301

F

Administrative Topics Outline

Form ES-301-1

Facility: Examina	KEWAUNEE NUCLE ation Level (circle one):	Date of Examination: 8/26/02 Operating Test Number: 2002301	
	Administrative Topic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2 TWO Administrative Questions	
A.1	Conduct of Operations/ Reactor Plant Startup	JPM: Perform a Pre-Critical Checklist.	
	Requirements Plant Parameter Verification	JPM: Perform an Estimated Critical Positio	on (ECP).
A.2	Equipment Control/ Tagging & Clearances	JPM: Review a tagout for accuracy.	
A.3	Radiation Control/ Knowledge of Radiation Exposure Limits	JPM: Review/Authorize an Emergency Rac	diation Work Permit (RWP).
A.4	Emergency Plan/ Emergency Action Levels and Classifications	JPM: Make an Emergency Plan Classificati Recommendations (PARS).	on, including Protective Action

NUREG-1021, Revision 8

•

JPM XXXXXX Revision 0 DRAFT Date

PERFORM A PRECRITICAL CHECKLIST

K/A REFERENCE: Gen – 2.1.31 (4.2/3.9) (NUREG-1122)

ç

ALTERNATE PATH JPM YES X NO

PERFORMANCE CHECKLIST:

<u>SAT</u>ISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)</u>

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

X Procedure adequately addresses task elements. Enter identifier here: N-0-02-CLB, Rev. AM

_____ Other document adequately describes necessary task elements. Enter identifier here:

Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH ____ DISCUSSION ____ PERFORM X___ IN-PLANT ____ CONTROL ROOM

VALIDATED TIME FOR COMPLETION: 10 MINUTES

JPM XXXXXX Revision 0 DRAFT Date

PERFORM A PRECRITICAL CHECKLIST

EXAMINEE	_EVALUATOR
START TIME	FINISH TIME
PERFORMANCE 🗌 SAT 🗌 UNSAT	
JOB TITLE: AOT COT SRO	STA STA
TOOLS/EQUIPMENT/REFERENCES:	
N-0-02-CLB, Precritical Checklist	

TASK STANDARDS:

3

i.

Three discrepancies identified in steps, 2.3 and 2.4 of N-0-02-CLB, Precritical Checklist, Rev. AM.

JPM XXXXXX Revision 0 DRAFT Date

PERFORM A PRECRITICAL CHECKLIST

SIMULATOR INFORMATION:

Simulator setup to include:

ì

- "A" SI Accumulator at 22%.
- SI-11B in CLOSED position (indication)
- RHR Pump "B" has NO indicating lights lit (control power failure)

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

JPM XXXXXX Revision 0 DRAFT Date

PERFORM A PRECRITICAL CHECKLIST

ì

READ AND PROVIDE TO THE EXAMINEE

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMS. IT IS NOT REQUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE EXAMINEE.

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

N-0-02-CLB, Precritical Checklist was begun last shift and turned over to your crew.

INITIATING CUES (IF APPLICABLE):

The CRS directs you to complete the remaining portions of steps 2.3 and 2.4 of N-0-02-CLB, Precritical Checklist, Rev. AM as the First Operator and report any discrepancies.

PERFORM A PRECRITICAL CHECKLIST

ì

PERFORMANCE INFORMATION

NOTE: CR ITI	ITICAL STEPS EM CONSTITU'	ARE DENO TES FAILU	OTED WIT RE.	HA "Y". FAILUR	THE TO MEET THE STANDARDS FOR THIS		
START TIME		STEP/S	EQUENC	E/CRITICAL	SAT		
		1	1	Y	UNSAT		
ELEMENT:	Step 2.3.2.b -	Verify prope	er level in b	oth SI Accumulators	S.		
STANDARD:	SI Accumulate	or A is ident	ified as read	ling low (22%). Proj	per level band is 26-50%.		
CUE:	Any reports by the examinee of the abnormal items to supervision should simply be acknowledged, and the examinee prompted to continue with the checklist. This applies throughout the IPM.						
COMMENTS:							
START TIME		STEP/S	EQUENCI	E/CRITICAL	SAT		
		2	2	Y	UNSAT		
ELEMENT:	Step 2.3.4.e –	Verify SI-11	B/MV-320	97 Reac Sfty Inj LP	B Cold Leg Isol MV OPEN.		
STANDARD:	SI-11B is ident	tified as beir	ng CLOSEI) (green indicating li	ght ON, red indicating light OFF).		
CUE:	None.						
START TIME		STEP/SI	EQUENCE	/CRITICAL	SAT		
		3	3	Y	UNSAT		
ELEMENT:	2.4.1 – Verify I	both Residua	al Heat Ren	noval System OPER.	ABLE.		
STANDARD:	RHR Pump B is identified as having no control room indicating lights (loss of control power). Green, white, and red indicating lights are OFF.						
CUE:	Examinee may indication. If e check is necess	v attempt to examinee at sary.	check if a tempts to c	burnt out green ind heck the bulb, info	dicating light is the cause of lack of rm the examinee the bulb is good and no		

TERMINATION CUE: THIS COMPLETES THIS JPM. COMPLETION TIME:

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

K/A REFERENCE: Gen – 2.1.25 (2.8/3.1) (NUREG-1122)

.

ĩ

ALTERNATE PATH JPM _____ YES X NO

PERFORMANCE CHECKLIST:

<u>SAT</u>ISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)</u>

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

X Procedure adequately addresses task elements. Enter identifier here: N-CRD-49D, Calculating Estimated Critical Position for Reactor Startup

Other document adequately describes necessary task elements. Enter identifier here:

X Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH	DISCUSSION	PERFORM	<u>X</u>	_IN-PLANT	CONTROL ROOM	<u> </u>	
----------------------	------------	---------	----------	-----------	--------------	----------	--

VALIDATED TIME FOR COMPLETION: 30 MINUTES

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

EXAMINEE		_EVALUATOR	
PERFORMANCE SAT	UNSAT		
JOB IIILE. 🔲 AOI			

TOOLS/EQUIPMENT/REFERENCES:

Reactor Data Manual N-CRD-49D, Calculating Estimated Critical Position for Reactor Startup, Rev B. Calculator

TASK STANDARDS:

The Estimated Critical Position is completed and critical boron concentration determined to be 944 ppm \pm 13. Maximum and minimum Bank D rod positions is determined to be 171 steps (+0, -1) and 51 steps (+1,-0).

NOTE: A completed ECP calculation is included with this JPM for grading purposes. Some minor differences may exist due to reading of the various graphs in the Reactor Data Manual. When reading graphs, one half of one division above and below the value determined to be correct was allotted.

SIMULATOR INFORMATION:

NONE

ĩ

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

READ AND PROVIDE TO THE EXAMINEE

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMs. IT IS NOT REQUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE EXAMINEE.

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

It is dayshift and you are the Reactor Operator. The reactor tripped at 0600 yesterday. The expected time of criticality is 1200 today (Noon). Prior to the trip, the reactor had operated at 100% steady-state power for 2 weeks. This is Startup No. 101. Core burnup is 8500 MWD/MTU. Current boron concentration is 1000 ppm. T_{AVE} will be 545 °F for the startup. Criticality with Bank D at 100 steps is desired. The computer is unavailable. An updated reactivity plan is being developed.

INITIATING CUES (IF APPLICABLE):

The CRS has directed you to perform an **independent** MANUAL Estimated Critical Position (ECP) calculation for a "Critical Boron – Fixed Rod Height" per step 4.2 of N-CRD-49D.

¥

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

PERFORMANCE INFORMATION

START TIME		STEP/SE	EQUENCE/0 1	CRITICAL N	SAT _ UNSAT _	
ELEMENT:	Heading of ECF	P Datasheet	is filled out.			
STANDARD:	All blocks filled	out with th	e applicable	given informatio	n. (see grading datashee	et for entries).
CUE:						
COMMENTS:						
	·					
		STEP/SE 2	QUENCE/C	RITICAL N	SAT UNSAT –	
ELEMENT:	Determine exces	s core react	ivity based o	n core burnup.		
STANDARD:	Excess reactivity	determined	d to be 9500	pcm ±50 using R	RD 13.2.	
CUE:						
COMMENTS:						
		STEP/SE	QUENCE/C	RITICAL	SAT	
ELEMENT:	Calculate xenon	worth.	1	Ĩ		
STANDARD:	RD 9.2 is used to determine full power equilibrium xenon (-2217.5 pcm ± 2.5). RD 9.1.2 is used to determine fraction of full power xenon present (0.69 \pm .005). These two values are multiplied together to obtain xenon worth (-1530 pcm ± 13)					
CUE:						
COMMENTS:						

5

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

PERFORMANCE INFORMATION

		STEP/SE 4	QUENCE 1	/CRITICAL N	SAT UNSAT	
ELEMENT:	Determine Sama	arium worth				
STANDARD:	Samarium worth	n is determir	ned using R	D 10.1 or 10.2 (-7	48 pcm ±5).	
CUE:						
NOTE:	RD 10.1 will pr	ovide more	accurate	values of Samari	ım worth.	
COMMENTS:						
		STEP/SE	QUENCE/ 1	/CRITICAL N	SAT UNSAT	
ELEMENT:	Determine tempe	erature defe	ct.			
STANDARD:	Temperature defect determined to be $-2 \degree F (545-547 \degree F)$. Isothermal Temperature Coefficient is determined using RD 8.3 (-14.5 pcm/°F ±0.25). These two values are multiplied together to obtain the temperature defect (29 pcm ±0.5).					
CUE:						
COMMENTS:						
		STEP/SEC	QUENCE/ 2	CRITICAL N	SAT UNSAT	
ELEMENT:	Calculate total de	efect.				
STANDARD:	Total defect is de	termined by	v adding all	previously calcul	ated defects and worths (7251 pcm ± 69)	
CUE:					· · /	
COMMENTS:						

•

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

PERFORMANCE INFORMATION

		STEP/SI 7	EQUENCE/ 3	CRITICAL N	SAT UNSAT	
ELEMENT:	Determine rod v	worth at req	uired rod he	ight.		
STANDARD:	RD 5.1.1.1 or R	RD 5.1.1.2 is	s used to det	ermine rod worth	for Bank D at 100 steps (-621 pcm ±0)).
CUE:						
COMMENTS:						
			·····			
		STEP/SE 8	EQUENCE/ 4	CRITICAL N	SAT UNSAT	
ELEMENT:	Determine net re	eactivity.				
STANDARD:	Rod worth is ad-	ded to the to	otal defect to	o obtain net reactiv	ity (6630 pcm ±69).	
CUE:						
COMMENTS:						
		STEP/SE	QUENCE/	CRITICAL N	SAT	
ELEMENT:	Determine critic	al reactivity		1		
STANDARD:	Net reactivity ob	otained in at	pove step is	multiplied by -1.0	(sign change, -6630 pcm ±69).	
CUE:						
COMMENTS:						

,

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

PERFORMANCE INFORMATION

		STEP/SE 10	CQUENCE/CH 6	RITICAL N	SAT UNSAT	
ELEMENT:	Determine diffe	rential boro	n worth.			
STANDARD:	Differential bor	on worth is a	determined usi	ng RD 6.2 (-7.	02 pcm/ppm ±0.025).	
CUE:						
COMMENTS:						
					<u></u>	
		STEP/SE	QUENCE/CF	RITICAL V	SAT UNSAT	
DI DRAIDNIT.	Determine critic	-11	, , .:	I		
ELEWIEN I:	Determine critic	al boron coi	ncentration.			
STANDARD:	Critical boron co worth (a value o	oncentration f 944 ppm 1	is determined 13 is required	by dividing th).	e critical reactivity by	the differential boron
	NOTE: A value indicates a DIL	e of 944 ppr UTION wil	n for critical l ll be required	ooron concent to adjust boro	ration as compared t on concentration.	o the existing 1000 ppm
CUE:						
COMMENTS:						
		STEP/SE	QUENCE/CR 8	ITICAL Y	SAT UNSAT	
ELEMENT:	Determine maxim	mum Bank I	O rod position.			
STANDARD:	Using the rod we pcm. Using RD :	orth for Ban 5.1.1.1 or R	k D found prev D 5.1.1.2, a ma	viously (-621 p aximum Bank l	cm), 400 pcm is addec D position of 171 step	l to obtain a value of -221 s is obtained (171+0,-1).
CUE:						
COMMENTS:						

.

JPM XXXXXXX **Revision 0 DRAFT** Date

PERFORM A MANUAL ESTIMATED CRITICAL POSITION CALCULATION

PERFORMANCE INFORMATION

CRITICAL STEPS ARE DENOTED WITH A "Y". FAILURE TO MEET THE STANDARDS FOR THIS NOTE: ITEM CONSTITUTES FAILURE.

		STEP/SEQUENCE/CRITICAL			SAT	
		13	8	· Y	UNSAT	
ELEMENT:	Determine minin	mum Bank	D rod pos	ition.		
STANDARD:	D: Using the rod worth for Bank D found previously (-621 pcm), 400 pcm is subtracted to obtain a value -1021 pcm. Using RD 5.1.1.1 or RD 5.1.1.2, a minimum Bank D position of 51 steps is obtained (5)					
CUE:						
COMMENTS:						
COMMENTS:						

TERMINATION CUE: THIS COMPLETES THE JPM. **COMPLETION TIME:**

JPM XXXXX Revision 0 DRAFT Date

REVIEW A TAGOUT

`

K/A REFERENCE: Gen – 2.2.13 (3.6/3.8) (NUREG-1122)

ALTERNATE PATH JPM _____ YES X NO

PERFORMANCE CHECKLIST:

<u>SAT</u>ISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

X Procedure adequately addresses task elements. Enter identifier here: GNP-03.03.01, Rev. L

_____ Other document adequately describes necessary task elements. Enter identifier here:

X Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH _____DISCUSSION ____PERFORM X___IN-PLANT _____CONTROL ROOM _____

VALIDATED TIME FOR COMPLETION: 20 MINUTES

JPM XXXXX Revision 0 DRAFT Date

REVIEW A TAGOUT	
EXAMINEE	EVALUATOR
START TIME	FINISH TIME
PERFORMANCE SAT UNSAT	
JOB TITLE: AOT COT SR	O 🗌 STA
TOOLS/EQUIPMENT/REFERENCES:	

Tag Number 02-9999 GNP-03.03.01, Tagout Processing, Rev. L PMP 35-09, CVC-QA-1 Charging Pump Pulsation Dampener Maintenance, Rev Q N-CVC-35B-CL, Charging and Volumn Control Prestartup Checklist, Rev AK Drawing OPERXK-100-36, Flow Diagram Chemical and Volumn Control Sys., Rev AU

TASK STANDARDS:

,

.

Two discrepancies identified during the review of Tagout.

JPM XXXXX Revision 0 DRAFT Date

REVIEW A TAGOUT

SIMULATOR INFORMATION:

Admin JPM – No simulator information needed.

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

REVIEW A TAGOUT

READ AND PROVIDE TO THE EXAMINEE

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMS. IT IS NOT REQUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE EXAMINEE.

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

Charging Pump B pulsation dampener maintenance is scheduled to be performed. The computerized tagout system is out of service. A handwritten tagout has been developed to isolate Charging Pump B.

INITIATING CUES (IF APPLICABLE):

The CRS directs you to perform a Tagout Placement Adequacy/Accuracy Verification for Tag Number 02-9999 and report any discrepancies.

REVIEW A TAGOUT

.

PERFORMANCE INFORMATION

NOTE: CRITICAL STEPS ARE DENOTED WITH A "Y". FAILURE TO MEET THE STANDARDS FOR THIS ITEM CONSTITUTES FAILURE.

START TIME		STEP/SI	EQUENCE	/CRITICAL	SAT	
		1	1	Ν	UNSAT	
ELEMENT:	Obtain and revi	ew referenc	es as neede	d to determine tag	gging series adequacy.	
STANDARD:	As above. Refer	rences inclu	de those on	coversheet of the	JPM.	
NOTE:	The examiner s (i.e. plant walk not necessary).	should keep -down, rev	p the exami iew of requ	nee focused on t lesting individua	he tag series review us l documentation, or re	sing available references eview of individual tags is
CUE:						

COMMENTS:

		STEP/S	EQUENCE	E/CRITICAL	SAT		
		2	1	Y	UNSAT		
ELEMENT:	Determine if sp	pecified tag	series bound	daries are adequate	for worker safety and scope of work.		
STANDARD:	Examinee identifies that the identified breaker for Charging Pump B is incorrect. Breaker equipment number and card location is identified as MCC62E-A5, and should be MCC62-A6.						
CUE:	CVC-28B, Suc tag has been a examinee if C questioned, in is ready for pl	ction Pulsat added at Op VC-28B ap dicate that acement.	tion Dampe perations D pearing on the Shift M	ener Drain, is NOT epartment discreti the tagout is quest lanager will deterr	required to be tagged per PMP 35-09. This on and may be indicated as such to the ioned. Also, if lack of a specified sequence is nine any required sequence when the tagout		
COMMENTS.	questioned, in is ready for pl	dicate that acement.	the Shift M	lanager will deterr	nine any required sequence when the tag		

REVIEW A TAGOUT

PERFORMANCE INFORMATION

NOTE: CRITICAL STEPS ARE DENOTED WITH A "Y". FAILURE TO MEET THE STANDARDS FOR THIS ITEM CONSTITUTES FAILURE.

		STEP/SE 3	EQUENCE/ 1	CRITICAL Y	SA UNSA	Г
ELEMENT:	Determine if sp	ecified tag s	eries bound	aries are adequa	ate for worker safety a	nd scope of work.
STANDARD:	Examinee deter reversed. Placer for CVC-30B is	mines that the the the the ment position is the second sec	he required j n for CVC-3 LOSED (sho	placement and 1 30B is listed as puld be OPEN).	restoration position for OPEN (should be CLC	CVC-30B Casing Vent is OSED). Restoration position
CUE:						
NOTE:	When examined	e has indica	ted and disc	cussed the iden	tified discrepancies, th	he JPM can be terminated.
COMMENTS:						

TERMINATION CUE: THIS COMPLETES THIS JPM. COMPLETION TIME:

JPM XXXXXXX Revision 0 DRAFT Date

DETERMINE A STAY TIME FOR A HIGH RADIATION AREA

K/A REFERENCE: Gen – 2.3.1 (2.6/3.0) (NUREG-1122)

ALTERNATE PATH JPM _____ YES X NO

PERFORMANCE CHECKLIST:

<u>SAT</u>ISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

Procedure adequately addresses task elements. Enter identifier here:

_____ Other document adequately describes necessary task elements. Enter identifier here:

X Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH ____ DISCUSSION ____ PERFORM _X_IN-PLANT ____ CONTROL ROOM _X___

VALIDATED TIME FOR COMPLETION: 5 MINUTES

KEWAUNEE NUCLEAR POWER PLANT JPM XXXXXXX TRAINING JOB PERFORMANCE MEASURES **Revision 0 DRAFT** Date DETERMINE A STAY TIME FOR A HIGH RADIATION AREA EVALUATOR EXAMINEE START TIME FINISH TIME _____ PERFORMANCE SAT UNSAT **JOB TITLE:** П СОТ SRO STA TOOLS/EQUIPMENT/REFERENCES: Calculator

TASK STANDARDS:

The maximum time that can be spent hanging tags in the General Area is determined to be 40 minutes.

SIMULATOR INFORMATION:

NONE

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

JPM XXXXXXX Revision 0 DRAFT Date

DETERMINE A STAY TIME FOR A HIGH RADIATION AREA

READ AND PROVIDE TO THE EXAMINEE

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMs. IT IS NOT REQUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

EXAMINEE.

- An extensive tagout containing a large number of tags is required to be hung in an area posted as a High Radiation Area.
- The General Area dose rate in the HRA is 30 mR/hr.
- The first value on the tagout (a value which has to be manually closed) is located in a 360 mR/hr field. It is estimated that 5 minutes will be required to close this value based on previous performance history.
- The remainder of the items on the tagout are located in the General Area dose rate.
- Radiation Protection (RP) has placed a dose limit of 50 mR on this task.

INITIATING CUES (IF APPLICABLE):

You are to determine the **maximum** time that can be spent hanging the remaining tags in the General Area without exceeding the dose limit for this task.

DETERMINE A STAY TIME FOR A HIGH RADIATION AREA

PERFORMANCE INFORMATION

START TIME		_ STEP/SI	EQUENCE	/CRITICAL	SAT	
		1	1	Y	UNSAT	
ELEMENT:	Determine total	dose receiv	ved closing	the valve in the H	RA (360 mR/hr field).	
STANDARD:	The total dose r	eceived is d	letermined t	to be 30 mR. (360) mR/hr * 5 min / 60 mi	n/hr = 30 mR)
CUE:						
COMMENTS:						
		STEP/SF	QUENCE	/CRITICAL	SAT UNSAT	
FI EMENT.		<u>م</u> د د اد د	<i>4</i>		UNDAL	
ELEMENT:	Available dose i	or hanging	tags in the	General Area is d	etermined.	
STANDARD:	Dose available f mR)	or hanging	tags in the (General Area is de	etermined to be 20 mR.	(50 mR - 30 mR = 20)
CUE:						
COMMENTS:						
		STEP/SE	QUENCE/	CRITICAL	SAT	
		3	3	Y	UNSAT	
ELEMENT:	Determine maxim	num time to	o hang tags	in the General Ar	ea.	
STANDARD:	Maximum time t min/hr)	o be spent i	n the Gener	al Area is determ	ined to be 40 minutes.	(20 mR / 30 mR/hr * 60
CUE:						
COMMENTS:						
TERMINATION	NCUE: THIS	COMPLET	ES THE JP	M. C	OMPLETION TIME	

EMERGENCY RWP APPROVAL

K/A REFERENCE:	Gen - 2.3.1 (2.6/3.0)
(NUREG-1122)	2.3.4 (2.5/3.1)

ALTERNATE PATH JPM _____ YES __X NO

PERFORMANCE CHECKLIST:

<u>SAT</u>ISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

X Procedure adequately addresses task elements. Enter identifier here: EP-AD-11, Emergency Radiation Controls

Other document adequately describes necessary task elements. Enter identifier here:

X Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH ____ DISCUSSION ___ PERFORM _X_IN-PLANT _X_CONTROL ROOM _X_

VALIDATED TIME FOR COMPLETION: <u>10</u> MINUTES

JPM XXXXXX Revision 0 DRAFT Date

EMERGENCY RWP APPROVAL

EXAMINEE	_EVALUATOR
START TIME	FINISH TIME
PERFORMANCE SAT UNSAT	
JOB TITLE: AOT COT SRO	□ STA

TOOLS/EQUIPMENT/REFERENCES:

EPIP-AD-11, Emergency Radiation Controls EPIPF-AD-11-01, Emergency Radiation Work Permit

TASK STANDARDS:

The Emergency RWP is NOT approved due to the high dose expected to be received for the given activity.

SIMULATOR INFORMATION:

TIME	FAIL	COMPONENT	OPTION	VALUE	RAMP	DELAY	ACT	COND
NONE								
:								

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

EMERGENCY RWP APPROVAL

READ AND PROVIDE TO THE EXAMINEE

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMs. IT IS NOT REQUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE EXAMINEE.

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- You are the Emergency Director.
- The plant has experienced a large break LOCA.
- Containment sump recirculation has been established with RHR Train B per ES-1.3, Transfer To Containment Sump Recirculation.
- RHR Train A is still lined up to the RWST.
- Prior to the event, RHR Pump A Pit Covers were removed for maintenance.
- The suction pressure gauge for RHR Pump A is reported to have blown off and is leaking into RHR Pump A pit.
- The gauge can be isolated by closing valve RHR-11276.
- The pump is in danger of being damaged by the rising water level.
- In lieu of shutting down and isolating the pump, an Auxiliary Operator has been directed to enter the RHR Pump pit and isolate the valve to prevent pump damage.
- The task should take 5-6 minutes to perform.
- The radiation level in the general area of RHR Pump A is 200,000 mr/hr (200 R/hr).

INITIATING CUES (IF APPLICABLE):

Evaluate the Emergency Radiation Work Permit for closing RHR-11276 and approve or deny the permit.

EMERGENCY RWP APPROVAL

PERFORMANCE INFORMATION

START TIME		STEP/SE(1	QUENCE/CRI 1	TICAL N	SATUNSAT	
ELEMENT:	Refer to EP-AD-	11, Emerger	ncy Radiation (Controls.		
STANDARD:	EP-AD-11 is refe	erenced.				
CUE:						
COMMENTS:						
<u></u>						
		STEP/SEQ 2	UENCE/CRI 1	TICAL N	SAT UNSAT	
ELEMENT:	Review/Verify Elinitial conditions.	PIPF-AD-11	1.01, Emergenc	y Radiation Work	Permit, for accuracy as compared to give	ven
STANDARD:	EPIPF-AD-11.01	is determin	ed to accuratel	y reflect the given	initial conditions.	
CUE:						
COMMENTS:						

EMERGENCY RWP APPROVAL

•

.

PERFORMANCE INFORMATION

NOTE: CRITICAL STEPS ARE DENOTED WITH A "Y". FAILURE TO MEET THE STANDARDS FOR THIS ITEM CONSTITUTES FAILURE.

		STEP/SE	EQUENCE/	CRITICAL	SAT	
		3	2	Y	UNSAT	
ELEMENT:	Compare dose f	for the task t	to the limits	of EPIP-AD-11.		
STANDARD:	Determines that Radiation Dose limit.	the exposu Guidelines	re limit for p Table (EPA	protection of valuab 400). Dose estima	le property (equipment) is 10 Rem ted for the task is GREATER than	from EPA the allowed
CUE:						
COMMENTS:						
		STEP/SE	QUENCE/	CRITICAL	SAT	
		4	3	Y	UNSAT	
ELEMENT:	Evaluate approv	al of EPIPF	-AD-11-01	Emergency Radiat	ion Work Permit.	
STANDARD:	The Emergency for equipment p	Radiation V rotection.	Work Permit	t is DENIED based	on the radiation levels exceeding the	he allowable
CUE:	If examinee der for denial be ex	nies approv xplained.	al without	providing justifica	tion (step 3), request that the jus	tification
COMMENTS:						
· · · · ·						

<u>TERMINATION CUE</u>: THIS COMPLETES THE JPM.

COMPLETION TIME:

,

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM ERO PAGER ACTIVATION IN RESPONSE TO A SECURITY THREAT

K/A REFERENCE: Gen – 2.4.35 (3.3/3.5) (NUREG-1122)

ALTERNATE PATH JPM _____ YES X NO

PERFORMANCE CHECKLIST:

<u>SAT</u>ISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

 X
 Procedure adequately addresses task elements.

 Enter identifier here:
 EPIP AD-07, Initial Emergency Notifications

 Rev AR

_____ Other document adequately describes necessary task elements. Enter identifier here:

X Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH ____ DISCUSSION ___ PERFORM _X_IN-PLANT ____ CONTROL ROOM __X_

VALIDATED TIME FOR COMPLETION: <u>5</u> MINUTES

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM ERO PAGER ACTIVATION IN RESPONSE TO A SECURITY THREAT

EXAMINEE	EVALUATOR	
START TIME	FINISH TIME	
PERFORMANCE SAT] UNSAT	
JOB TITLE: AOT	COT SRO STA	

TOOLS/EQUIPMENT/REFERENCES:

EPIP-AD-07, Initial Emergency Notifications, Rev AR. EPIP-AD-20, KNPP Response To A Security Threat, Rev C.

TASK STANDARDS:

Pager notifications are made per EPIP-AD-07 Section 5.4.

SIMULATOR INFORMATION:

A PBX telephone should be set up for use - ENSURE THE PHONE IS UNPLUGGED.

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

PERFORM ERO PAGER ACTIVATION IN RESPONSE TO A SECURITY THREAT

READ AND PROVIDE TO THE EXAMINEE

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMs. IT IS NOT REQUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE EXAMINEE.

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

You are an extra operator on shift.

An on-going security event has resulted in the Shift Manager declaring an ALERT emergency classification.

INITIATING CUES (IF APPLICABLE):

The Shift Manager (SM) has directed you to activate the pagers for appropriate emergency response personnel in accordance with Step 5.4 of EPIP-AD-07, Initial Emergency Notifications. The following information is provided by the SM:

- The pager access code for a "Credible Security Threat Alert" classification should be used.
- The event (message) code for this classification should be used instead of a return phone number.

PERFORM ERO PAGER ACTIVATION IN RESPONSE TO A SECURITY THREAT

PERFORMANCE INFORMATION

START TIME	S	STEP/SEC	QUENCE/O	CRITICAL	SAT	
		1	1	Ν	UNSAT	
ELEMENT:	Determine if KNPI	P paging s	ystem is ava	ailable.		
STANDARD:	Paging system is de 388-XXXX phone	etermined number)	to be availa	ble. (NOTE: A	PBX telephone is any j	phone that has a
CUE:	A normal dial ton	e is heard	l if a PBX p	ohone receiver	is picked up.	
	CAUTION: DO N FUNCTIONAL P	IOT ALL HONE D	OW EXAN URING TH	AINEE TO AC HIS JPM.	CTUALLY DIAL THE	NUMBERS ON A
COMMENTS:						
·····				·		
	S	TEP/SE(2	QUENCE/C	CRITICAL Y	SAT UNSAT	
		-	•	•		
ELEMENT:	Determine appropri	iate pager	access code	е.		
STANDARD:	Pager access code '	'9255" is	selected for	a "Credible Se	curity Threat – Alert".	
CUE:	If examinee solicit that the Shift Man	s informa nager has	tion from t already inc	the Shift Mana dicated which	iger for which codes to codes should be used.	select, inform examinee
COMMENTS:						
	S	TEP/SEQ	QUENCE/C	CRITICAL	SAT	
		3	1	Y	UNSAT	
ELEMENT:	Determine appropri	iate event	code.			
STANDARD:	Event (message) co	de ''44777	" is selected	d.		
CUE:						
COMMENTS:						

JPM XXXXXXX Revision 0 DRAFT Date

PERFORM ERO PAGER ACTIVATION IN RESPONSE TO A SECURITY THREAT

.

PERFORMANCE INFORMATION

		STEP/S 4	EQUENCE 2	/CRITICAL Y	SATUNSAT			
ELEMENT:	Dial pager sys	tem activatio	on extension	on a PBX phone.				
STANDARD:	Extension "52	Extension "5213" is dialed from a PBX phone.						
CUE:	After "5213" beep.	is dialed, in	form exami	inee the phone has	answered and has responded with a sing			
COMMENTS:								
		etter /et	FOUENCE					
		5 5	3	Y	UNSAT			
ELEMENT:	Enter pager acc	cess code fo	r a Credible	Security Threat – A	lert.			
STANDARD:	Pager access co	ode "9255"	is entered or	the PBX phone.				
CUE:	After "9255" i	is dialed, in	form exami	nee the phone has	responded with three beeps.			
COMMENTS.								

PERFORM ERO PAGER ACTIVATION IN RESPONSE TO A SECURITY THREAT

.

JPM XXXXXXX Revision 0 DRAFT Date

COMPLETION TIME:

PERFORMANCE INFORMATION

NOTE: CRITICAL STEPS ARE DENOTED WITH A "Y". FAILURE TO MEET THE STANDARDS FOR THIS ITEM CONSTITUTES FAILURE.

		STEP/SEQUENCE/CRITICAL			SAT				
		6	4	Y	UNSAT				
ELEMENT:	Enter event (message) code for a Credible Security Threat – Alert.								
STANDARD:	Event (message) code "44777" is entered on the PBX phone followed by pressing the "#" key.								
CUE:	After the "#" is pressed, inform examinee the phone has responded with five beeps.								
COMMENTS:									
		STEP/SEQUENCE/CRITICAL			SAT				
		7	5	N	UNSAT				
ELEMENT:	Phone call is terr	minated.							
STANDARD:	The phone receiver for the phone being used is hung up.								
CUE:	When the phone is hung up, the JPM may be terminated.								
COMMENTS:									
-									

TERMINATION CUE: THIS COMPLETES THE JPM.

Page 6 of 6

JPM XXXXXXX **Revision 0 DRAFT** Date

CLASSIFY AN EVENT PER THE EMERGENCY PLAN

K/A REFERENCE: Gen - 2.4.41 (2.3/4.1) (NUREG-1122) Gen - 2.4.44 (2.1/4.0)

ALTERNATE PATH JPM YES X NO

SRO E-Plan-

PERFORMANCE CHECKLIST:

SATISFACTORY - Properly performed critical step(s) and/or in sequence (if applicable)

<u>UNSAT</u>ISFACTORY - Improperly performed critical step(s) and/or out of sequence (if applicable)

X Procedure adequately addresses task elements. Enter identifier here: EPIP-AD-02

Other document adequately describes necessary task elements. **Enter identifier here:**

X Task elements described as attached.

DESIRED MODE OF EVALUATION:

APPLICABLE EVALUATION SETTING:

SIMULATE/WALKTHROUGH X DISCUSSION PERFORM IN-PLANT CONTROL ROOM X

VALIDATED TIME FOR COMPLETION: 20 MINUTES

JPM XXXXXXX Revision 0 DRAFT Date

CLASSIFY AN EVENT PER THE EMERGENCY PLAN

EXAMINEE	EVALUATOR						
START TIME	FINISH TIME						
PERFORMANCE SAT UNSAT							
JOB TITLE: AOT COT SRO	STA STA						
TOOLS/EQUIPMENT/REFERENCES:							

EPIP-AD-02, Emergency Class Determination, Rev AC EPIPF-AD-07-01, Rev S

TASK STANDARDS:

A General Emergency is declared. Identified critical sections of EPIPF-AD-07-01 are completed correctly and within the required time frame.

SIMULATOR INFORMATION:

NONE

- NOTE: If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.
- NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

CLASSIFY AN EVENT PER THE EMERGENCY PLAN

READ AND PROVIDE TO THE EXAMINEE ********

THIS SECTION IS READ ONCE FOR THE ENTIRE PACKAGE OF JPMs. IT IS NOT REOUIRED TO REVIEW THIS SECTION FOR EVERY JPM BEING PERFORMED IN THE PACKAGE. THE INITIAL CONDITIONS AND INITIATING CUE(S)/TASKS TO BE PERFORMED SHOULD BE READ AND THEN PROVIDED TO THE EXAMINEE.

After I read you the initial conditions and initiating cue(s)/task to be performed for this JPM and provide you a copy of the same, you may review and begin. Once you have completed the task, indicate completion by handing back this form to the evaluator unless otherwise told.

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

For all two and three-way communications, make your report to me, the JPM evaluator. I will reply to your reports with the statement, "acknowledge." All actions in the plant are to be simulated and all actions in the simulator will be performed. Ensure you make it clear to me, the evaluator, of all actions you are taking so that credit may be given for completing each step of the task.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

You are the Shift Manager.

The plant was manually tripped due to an RCS leak, which exceeded the makeup capacity of the charging pumps. A complete loss of off-site power occurred after the trip, coupled with failures of both A and B Emergency Diesel Generators. RCS pressure is 50 psig and lowering. Pressurizer level is off-scale low. Core Exit Thermocouples indicate 550 °F. Containment pressure is 27 psig and rising. Containment High Range Radiation Monitors R-40 and R-41 are indicating 200 R/hr. Steam Generator A Narrow Range is at 20%, Steam Generator B Narrow Range level is at 16%. Auxiliary feedwater flow is 300 gpm. Wind speed and direction (both inland and at site) is 10 mph and 180°.

The control room crew is implementing the appropriate emergency procedures.

INITIATING CUES (IF APPLICABLE):

You are implementing EPIP-AD-02 and are to perform the following:

- Per step 5.1 of EPIP-AD-02, classify the event based only on the above conditions.
- After classifying the event, complete Event Notice form EPIPF-AD-07-01 per step 5.1.7 of either EPIP-AD-03 or EPIP-AD-04 (procedure selection as appropriate based on the classification). This portion of the JPM is time critical.

CLASSIFY AN EVENT PER THE EMERGENCY PLAN

PERFORMANCE INFORMATION

NOTE: CRITICAL STEPS ARE DENOTED WITH A "Y". FAILURE TO MEET THE STANDARDS FOR THIS ITEM CONSTITUTES FAILURE.

START TIME		STEP/SE 1	QUENCE/ 1	CRITICAL Y	S. UNS	AT			
ELEMENT:	Determine the ca	ategory of th	he event usi	ng Table 2-1 EF	PIP-AD-02.				
STANDARD:	 Examinee determines that a General Emergency declaration is required based on Table EPIP-AD-02, Chart C. A LOCA has occurred. The SI and RHR pumps are not running (all de-energized). Containment pressure is greater than 23 psig with loss of all containment fan coil units and both trains of containment spray (all de-energized). 								
CUE:									
COMMENTS:									
		STEP/SE 2	QUENCE/0 2	CRITICAL Y	S. UNS.	АТ АТ			

ELEMENT: Appropriate sections of Event Notice form EPIPF-AD-07-01 filled out correctly.

STANDARD: EPIPF-AD-07-01 completed consistent with given conditions and within required time frame (< 15 minutes). Time critical portion starts at the time of declaration and ends when the Emergency Director approval is requested.</p>
A completed Event Notice form is attached for grading purposes. Critical step items of the form include items 3, 4, and 9. (Note: EAL # for Block 4 is NOT considered critical.)

CUE: When the examinee requests approval from the Emergency Director (Shift Manager), the JPM is complete.

COMMENTS:

<u>TERMINATION CUE</u>: THIS COMPLETES THE JPM.

COMPLETION TIME: