FINAL AS-ADMINISTERED SCENARIOS

FOR THE KEWAUNEE INITIAL EXAMINATION - AUG/SEP 2002

Appendix D

5

3

Scenario Outline

Form ES-D-1

Facility	KNPP		Scenario No.: <u>1</u>	OP-Test No.: 2002301
Examine	rs:	····	Operators:	
Initial C for repain 100%. To Turnove • 'A' H durin • 'B' N wate • LT-4 repla	onditions: s to the 'A' oday is Sun r: The follo Residual He ag a schedu Motor Drive r in the lube 72 'B' S/G cement is b	The plant is Main Feedy day, present owing equipr eat Removal led surveillar e Auxiliary F e oil. A lube Water Leve peing develop	at 50% power, BOC, equilibrium xenon condition water Pump. The pump has been repaired and the clock time is real time. A normal shift complement ment is inoperable and has been properly remove Pump – tagged out 36 hours ago due to high beat accer run. Maintenance is on-site and a crew is wo eedwater Pump – tagged out last shift due to independent of the poil cooler leak is suspected. Maintenance has be Channel – tagged out due to suspected transmitted. A-MI-87 has been completed to remove this	ons. Power was reduced two days ago e plant is ready to raise power to ent is available. ed from service: aring temperatures and vibration orking to repair the pump. dications of a significant amount of een notified. tter failure. A plan for transmitter s channel from service.
		t is begin the	power ramp to 100% per N-0-03.	
Event No.	Malf. No.	Event Type*	Event Descriptio	n
1		R - RO N - SRO BOP	Perform a power increase per N-0-03.	
2		I - BOP SRO	LT-461 'A' S/G Water level channel fails low	(controlling channel).
3		C – BOP SRO	Trip of running CW pump.	
4		C - ALL	RCS leak develops on 'A' RCS loop requiring	reactor trip.
5		M - ALL	RCS leak increases to a large break LOCA foll	owing reactor trip.
6		C - RO SRO	RHR Pump 'B' fails to auto-start.	
7		C - RO SRO	RHR Pump B shaft/coupling failure occurs upo	on restart for sump recirculation.
			(Note: Time compression required to acceler	rate lowering level in RWST)
(N)ormal,	(R)eacti	vity, (I)nstrument, (C)omponent, (N	()aior

NUREG-1021, Revision 8, Supplement 1

Revision 0 DRAFT

DYNAMIC EXAM SCENARIO ID#: SES-2002301: #1

SIMULATOR SHIFT TURNOVER:

Per Scenario Outline.

ř. 3.

SIMULATOR SCENARIO SET UP

STEP COUNTERS ON	
INIT into IC	
NTP-6410, Communicator Telephone Log, available	
NTP 6411, Simulator Setup Checklist, completed	
NTP-6412, Simulator Book Preparation Checklist, completed	
NTP-4 Attachment 10, Simulator Scenario Briefing Sheet, completed	
NTP-4, Attachment 13, KNPP Simulator Security Checklist, completed	

SCENARIO GUIDE:

۰.

; .

- 1. Initialize to a 50% Power IC or saved specific SES IC.
- 2. Place RHR Pump A control switch in pullout and place a Hold Card on the switch.
- 3. Place AFW Pump B control switch in pullout and place a Hold Card on the switch.
- 4. Place an "Out of Service" sticker on S/G B Level Indicator LI-472.
- 5. Ensure Circulating Water Pump A is running, CW Pump B is OFF.
- 6. Preload (or verify preloaded) and verify active the following simulator codes:

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER
Preload	Malfunction	SER0966, Beta Annunciator Driver Override				Block	
Preload	Annunciator	47034-O, SER1670 Source Range High Flux at Shutdown Alarm Blocked				Block	
Preload	Malf	RH04B - Failure to Auto Start, RHR Pump 1B					
Preload	Meter	MCA, AO-41052-02, LI-472				0	
Preload	Remote Function	RP191, 472A, Lo/Lo Level Logic				TRIP	
Preload	Remote Function	RP192, 472B, Hi Level Logic				TRIP	
Preload	Remote Function	RP193, 472C, Lo Level Logic				TRIP	
Preload	Annunciator	47065-F, SER0812, AMSAC in Test				Crywolf	
Preload	Lights	MVB, DO-47033:0401, TLA- 16 AMSAC Channel Abnormal				ON	

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

٠.

÷.,

Revision 0 DRAFT

Use the Instructor Summary Station to verify the simulator codes in the table below are assigned to the appropriate Trigger with the appropriate value(s).

These events will be input as shown in the guidance following the table.

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER**
Event 2	System Override	RX211, LT-461, SG Level	44	5		0	1
Event 2 – (A-MI-87)	Remote Function	RP170, 461B – Lo/Lo Level Logic				TRIP	2
Event 2 – (A-MI-87)	Remote Function	RP169, 461A – Hi Level Logic			30	TRIP	2
Event 3	Malfunction	CW04A, Timed/Inst Overcurrent, CW Pump 1A	As found			75	3
Event 4	Malfunction	RC08, Reactor Coolant System Leaks				2	4
Event 4a	Malfunction	RC08, Reactor Coolant System Leaks	As found			6	
Event 5-7	Malfunction	RC04A, Loss of Coolant Accident – Cold Leg(1A)				100	5
Event 5-7 (ES-1.3)	System Override	SI101, LT- RWST level	As found			36	6
Event 5-7 (ES-1.3)	Meter	MCC, AO-41303-02, FI-928				0	7
Event 5-7 (ES1.3)	Meter	MCC, AO-41306, PI-628				0	7
Event 5-7 (ES-1.3)	Meter	MCC, AO-41336				9.5	8
Event 5-7 (ES-1.3)	Malfunction	SI101, LT- RWST level	As found			9	

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

** See following page for specific guidance on Trigger activation.

Simulator Operator Guidance:

ډ ,

- Trigger 1 Activate when requested by Lead Examiner to fail LT-461 low.
- Trigger 2 Activate to trip bistable 461A and 461B per A-MI-87 (I&C) Note: 461B will trip after a 30 second delay.
- Trigger 3 Activate when requested by Lead Examiner to trip CW Pump A. NOTE: Due to the nature of this malfunction, the pump will not trip for about 5 minutes..
- Trigger 4 Activate when requested by Lead Examiner to initiate a 50 gpm RCS leak. NOTE: Modify this malfunction (RC08), when requested by lead examiner, to the values shown in Event 4a (Increase RC08 leak to 6%).
- Trigger 5 Activate immediately upon manual reactor trip to cause LBLOCA.
- Trigger 6 Activate when requested by Lead Examiner to lower RWST level to 36% NOTE: AFTER ACTIVATING THIS TRIGGER, THE SYSTEM OVERRIDE (SI101) MUST BE REMOVED USING THE INSTRUCTOR STATION SUMMARY.
- Trigger 7 Activate AFTER RHR Pump B is stopped in ES-1.3.
- Trigger 8 Activate IMMEDIATELY when control switch for RHR Pump B is taken to START.
- OTHER (if required) Insert last system override (SI101) shown on page 3 to lower RWST level to 9%. NOTE: AFTER INSERTING THIS OVERRIDE, IT MUST BE REMOVED USING THE INSTRUCTOR STATION SUMMARY.

ANTICIPATED BOOTH COMMUNICATION/GUIDANCE:

Event 1: This event is a normal up-power. The field operators should be informed of the power escalation, with an acknowledgement by the communicator.

Event 2: This event is a failure of Steam Generator 'A' Level Transmitter LT-461 (fails low). This failure will cause S/G 'A' Feedwater Flow Control Valve to fully open, requiring the operator to take manual control of the valve by placing the controller in manual and adjusting to lower and maintain level. After stabilizing the plant, A-MI-87 will be utilized to remove the channel from service. The CRS will request SP 47-316A to check redundant channel bistables. The communicator should inform the CRS that SP 47-316A is complete and no redundant channel bistables were found tripped. I&C will also be requested to trip the bistables associated with the level channel. The paperwork (A-MI-87) should be obtained from the CRS and the bistables tripped per this simulator guide. After tripping the bistables, the A-MI-87 paperwork should be signed off as appropriate and returned to the control room.

٠.

۰.

Event 3: This event is a failure of the running CW pump (CW Pump 'A'). The standby pump must be started to prevent a turbine trip on lowering vacuum. After starting the standby CW pump, a field operator may be contacted to align Service Water to CW Pump 'B', as well as to verify seal water and oil levels. This request should be acknowledge and reported back as complete after allowing sufficient time to complete the task (5-10 minutes). If an operator is dispatched to the breaker for CW Pump A, it should be reported back that the breaker has tripped on overcurrent. If local investigation of the tripped pump/motor is requested, it should be reported that all appears normal. Local checks of the travelling screens will also be requested. It should be reported that there are no problems with the screens and they are operating normally. Forebay level should be reported as normal if asked.

Event 4: This event is a small RCS leak (50 gpm) inside containment. The small break failure should be inserted at the request of the lead examiner. A-RM-45 and A-RC-36D will be entered due to the RCS leak. After plant conditions have stabilized, letdown is isolated (for leak location diagnosis), and the determination made that the leak still exists, the leak size will be increased such that charging flow is unable to maintain sufficient pressurizer level. A manual reactor trip should be directed prior to pressurizer level going off-scale low. When Radiation Protection is notified of the event, acknowledge the report. No additional communications are foreseen. When the reactor is tripped, proceed to the next event series.

Event 5, 6, 7: This series of events includes the initiation of a Large Break LOCA upon tripping of the reactor, a failure of RHR Pump B to Auto-start, and a subsequent failure of RHR Pump B (broken coupling) upon restart of RHR Pump B after alignment for Containment Sump Recirculation. A field operator may be requested to investigate RHR Pump B when started after alignment for Sump Recirculation. If requested, the report back should indicate that local discharge pressure is zero and there is no flow noise from the RHR piping. No additional booth communications are expected.

Op-Test No: _20023	01	Scenario No: <u>1</u> Event No: <u>1</u> Page <u>1</u> of <u>2</u>				
Event Description:	Event Description: Perform Normal Up-Power (Reactivity Manipulation).					
Time/Notes	Position	Applicant's Actions or Behavior				

۰.

F

At the discretion of the entering the simulator.	lead examiner	, the normal up-power brief may be conducted in the classroom prior to
	CRS	Brief crew on evolution, including discussion of N-0-03 (Plant Operation Greater Than 35% Power) precautions and limitations, for commencing uppower.
	CRS	Implement actions of N-0-03
	RO	Perform reactivity estimate based on planned load increase.
	CRS	Direct increase to 100% power.
	BOP	 Increase load per N-TB-54: Review applicable Precautions & Limitations. Determine maximum loading rate based on fuel performance (40 MW/hr) Determine maximum load rate based on turbine operating limits per Figures 2 & 3. Adjust turbine controls to clear Valve Position Limiter: Lower the setter to ≤ value stated on EH Panel Plaque. Set loading rate to ≤ 5% per minute. Depress GO pushbutton. When VPL light goes out, push the HOLD pushbutton. Verify/set Valve Position Limit to 100%. Set setter to desired load. Verify/set loading rate to 0.25% per min (minimum loading rate of 0.25% per min is normal plant practice). Verify loading rate is less than maximum allowable rate. Inform Energy Supply & Control of rate and amount of load pickup. Depress GO. Verify load increases.

Op-Test No: 2002	301	Scenario No: <u>1</u> Event No: <u>1</u> Page <u>2</u> of <u>2</u>
Event Description:	Perform Normal	Up-Power (Reactivity Manipulation).
Time/Notes	Position	Applicant's Actions or Behavior

	RO	Perform reactivity adjustments:
		Rod Control (rod motion at 1.5 °F difference Tave-Tref)
		AND/OR
		Boron Concentration Control (initiate dilution) per N-CV-35A:
		 Review applicable Precautions & Limitations Verify at least one RXCP in operation
		• Determine rate and magnitude of dilution
		 Position Reactor Makeup Mode Selector to DILUTE or ALT DIL. Adjust MU-1022/CV-31095, Blender Control Rx Mu Flow, to required flow rate
		• Set Rx Make-up Totalizer to required quantity
		Position Reactor Makeup Control switch to START
		• Verify required change has been achieved by monitoring:
		1. Rod Position
		2. Boron Concentration
		3. Tave
		• When dilution is complete:
		 When dilution is complete: Position Reactor Makeun Mode Selector to AUTO
		2. Position Reactor Makeup Control switch to START
		 Adjust CVC-403/CV-31092, Blender Control BA Flow, to current RCS boron concentration
		• If RCS boron concentration has been changed by >50 ppm, operate Przr heaters as necessary to equalize RCS and Przr boron.
	BOP	Adjust Heater Drain Pump speed as required to maintain equal loading on pumps.
Once power has been ra		for at the discretion of the Load Examinan proceed to the most

Once power has been raised 5% and/or at the discretion of the Lead Examiner, proceed to the next event (Event #2).

Op-Test No: _2002	301	Scenario No: _1 Event No: _2 Page _1_ of _2
Event Description:	Steam Generat	tor 'A' level control channel LT-461 fails low.
Time/Notes	Position	Applicant's Actions or Behavior
	BOP	Identify/report failed S/G A level channel LT-461. Available indications:
		 Annunciator "S/G A Program Level Deviation" (47062-A). Appunciator "S/G A Program CVU and Deviation" (47062 P)

f

	 Annunciator "S/G A Program Level Deviation" (47062-A). Annunciator "S/G A Bypass CV Level Deviation" (47062-B). Annunciator "S/G A Level Low Low", (47064-A). Level indicator LI-461 failed to zero.
BOP	Refer to above annunciator response procedures, place FW-7A, S/G 'A' Main FW Flow Control Valve to MANUAL, and adjust to restore level to 44%.
	NOTE: Level control of the 'A' S/G will be required to be controlled in Manual for the remainder of the scenario when using Main Feedwater.
CRS	Direct power ramp be placed on hold.
CRS	 Implement A-MI-87 "Bistable Tripping for Failed Reactor Protection or Safeguards Inst.", to remove LT-461 from service – bistable tripping must be performed within 6 hours per A-MI-87. NOTE: A-FW-05A, Abnormal Feedwater System Operation, may be referenced but no additional actions are required by this procedure.
CRS	 Direct actions to remove LT-461 from service: Direct I&C to perform SP 47-316A to check redundant channel bistable contacts for LT-461 removal from service. (NOTE: Communicator will inform Control Room that SP 47-316A is complete.)
BOP	 Perform/verify prerequisite lineup of "Removal From Service". Ensure FW-7A, S/G 'A' Main FW Flow Control Valve, is in MANUAL. Ensure FW-10A, S/G 'A' Bypass FW Flow Control Valve, to MANUAL.
CRS	Direct I&C to trip associated bistables for LT-461.

Op-Test No: 200230	1	_ Scenario No: _1	Event No: 2	Page <u>2</u> of <u>2</u>
Event Description: S	team Generator	· 'A' level control chai	nnel LT-461 fails lo	w.
Time/Notes	Position	Appl	icant's Actions or B	ehavior

۰.

Γ

NOTE: Simulator Booth Operator bistable tripping when directed. W returned to the CRS/BOP.	will obtain A-MI-87 paperwork from CRS/BOP and perform the /hen complete, the applicable pages and steps of A-MI-87 will be
ВОР	 Complete verification steps of A-MI-87 following bistable tripping. Ensure the following annunciators/status lights are ON: Annunciator "S/G A LEVEL LOW LOW" (47064-A) Annunciator "S/G A LEVEL HIGH" (47064-B) Status Light "S/G A Low-Low Level" (44907-1101) Status Light "S/G A Hi-Hi Level" (44908-0801)
CRS	 Review Technical Specification 3.5.b & c: Table 3.5-2: No. 12 - Lo-Lo Steam Generator Water Level Determines continued operation acceptable (2 channels/loop required OPERABLE) Table 3.5-3: No. 4.a - MDAFW Pumps - Either S/G LO-LO level No. 5.a - TDAFW Pump - Both S/G LO-LO level Determine continued operation acceptable (2 channels/loop required OPERABLE) Table TS 3.5-4: No. 4.a - Hi-Hi Steam Generator Level Main Feedwater Isolation Determine continued operation acceptable (2 channels required OPERABLE)
CRS	Inform I&C to investigate Steam Generator level channel LT-461 failure/status.
At the discretion of the	Lead Examiner, proceed to the next event (Event #3).

Op-Test No:2002.	301	Scenario No: _1 Event No: _3 Page _1_ of _2
Event Description:	The running (start of the sta	Circulating Water Pump trips on overcurrent requiring manual ndby pump.
Time/Notes	Position	Applicant's Actions or Behavior
	BOP	 Identify/report trip of Circulating Water Pump 'A'. Available indications: Annunciator "Bus 3 Feeder Bkr Trip" (47082-C). Annunciator "Bus 3 Feeder Bkr Overload", (47083-C). Annunciator "TLA-20 - 4160V Stator Temp Hi" (47033-45). White disagreement light on CW Pump 'A'.
	RO/BOP	Refer to above annunciator response procedures, inform CRS of required actions (GO TO E-CW-04).
	CRS	Implement required actions of E-CW-04, Loss of Circulating Water. NOTE: N-CW-04 and A-CW-04 are also referenced by the above annunciator response procedures. These may be referenced for any additional actions, however, plant conditions require entry to E-CW-04.
	BOP	Check annunciator 47051-M, "CW Pumps Low Low Level Trip" not lit. (Continuous Action Step)
	BOP	 Verify at least one CW pump running (Continuous Action). No CW pumps are running, the standby 'B' CW pump is started. Forebay level is adequate.
	ВОР	Check number of CW pumps running - NOT CHANGED (Continuous Action). The crew has no information to inform them of a liquid discharge in progress. Any liquid discharge is required to be secured due to the change in CW flow.
	ВОР	 Check condenser vacuum normal. No condenser vacuum PPCS alarms. Condenser back pressure ≤ 2.5 inches HG abs. NOTE: A condenser vacuum PPCS alarm may be received during this transient depending on timing of procedural actions. A slight reduction in turbine load may be required.

		100 million 100 1 200 million 1 age 01
Event Description:	The running (start of the sta	Circulating Water Pump trips on overcurrent requiring manual andby pump.
Time/Notes	Position	Applicant's Actions or Behavior
	BOP	Verify CW Pump discharge valve position.
		 CW Pump discharge check valve is OPEN for any running CW pump. CW Pump discharge check valve is SHUT for any idle CW pump.
	BOP	Verify condenser waterbox inlet valves OPEN.
	BOP	Locally verify traveling screen operation.
		 Auxiliary operator contacted to: 1. Verify spray flow pressure is > 60 psig. 2. Check if any traveling screens are running
	BOP	Check traveling screens NOT fouled.
		 Check annunciator 47054-Q, "Traveling Water Screen DP High" – Not Lit. Check traveling screens DP ≤ 6 inches water. Locally monitor traveling screens.
	BOP	Monitor condenser parameters.
		 Condenser CW delta-T normal. Condenser back pressure normal.
	ВОР	Locally verify Forebay level stable OR increasing.
	ВОР	Check Forebay level normal
		 Check Forebay level > 64% Check Forebay level stable or increasing.
	CRS	Return to procedure and step in effect (N-0-03 is the plant procedure currently in effect for plant startup). Also, N-CW-04 should be referenced to ensure SW-143B, Thrust Bearing Cooler Isolation, is opened, as well as verification of proper seal water flow and oil levels.

۰.

l

At the discretion of the Lead Examiner, proceed to the next event (Event #4).

Op-Test No: _2002.	301	Scenario No:	Event No: _4	Page 1 of 3
Event Description:	Reactor coolant leading to reacto	leak develops inside co or trip.	ontainment on the '	A' RCS loop, eventually
Time/Notes	Position	Арр	licant's Actions or B	ehavior

	RO	 Identify/report elevated readings on Radiation Monitors R2 and R7. Available indications: Annunciator "Radiation Indication Alert" (47012-B). Annunciator "Radiation Indication High" (47011-B). Annunciator "TLA-15 – RMS Above Normal" (47033-35). Individual radiation monitor readings on rad monitor drawers.
	RO/BOP	Refer to above annunciator response procedures, inform CRS of required actions (GO TO A-RM-45).
	CRS	Implement required actions of A-RM-45, Abnormal Radiation Monitoring System.
	RO/BOP	 IMMEDIATE ACTIONs of A-RM-45: Announce event using plant Gaitronics. Actuate the Containment Evacuation alarm.
	CRS	Transition to A-RC-36D, Reactor Coolant Leak, per A-RM-45 steps 4.3.1 and 4.7.1.
	RO	Identify lowering pressurizer level and increasing charging pump speed.
	RO	IMMEDIATE ACTIONs of A-RC-36D: IF RCS subcooling based on CETs is < 30 °F OR If Pressurizer level cannot be maintained > 5% THEN Trip the reactor and Actuate Safety Injection.
·	RO	Increase charging pump speed to maintain pressurizer level.
	RO	Position pressurizer heater switches to ON to maintain RCS pressure.

Op-Test No: _2002	301	_ Scenario No: _1	Event No: _4	Page <u>2</u> of <u>3</u>
Event Description:	Reactor coolant l leading to reactor	eak develops inside co r trip.	ontainment on the '	'A' RCS loop, eventually
Time/Notes	Position	Appl	icant's Actions or E	Behavior

120	
RO	Isolate Letdown if required by closing the following valves:
	LD-2, Letdown Isolation
	• LD-3, Letdown Isolation
	LD-4A, Letdown Orifice A Isolation
	LD-4B, Letdown Orifice B Isolation
	LD-4C, Letdown Orifice C Isolation
 RO	Verify Reactor Makeup System operating.
CREW	Using available indications and Section 2.0 of A-RC-36D, determine source of leakage.
	NOTE: No indications to positively identify the source of leakage will be available. However, after letdown is isolated, the crew should determine that the leak is still present.
RO	Perform a charging versus letdown flow balance to determine leak rate.
	NOTE: Actual leak rate is 40-50 gpm.
	NOTE: Sump A alarms (HI and HI-HI) will indicate an approximation of the leak rate at 75gpm.
CRS	Notify HP/RP of existing conditions.
CRS	Initiate SP 36-082, Reactor Coolant System Leak Rate Check.
CRS	Technical Specifications should be referenced at some point. TS 3.1.d.3 is applicable due to > 10 gpm RCS leakage requiring the plant be placed in Hot Shutdown within 12 hours. TS 3.1.d.4 may also be deemed applicable, however, TS 3.1.d.3 is more limiting.

Op-Test No: _2002	p-Test No: _2002301		_1	Event No: 4	Page <u>3</u> of <u>3</u>
Event Description: Reactor coolant le leading to reactor		eak develops ins r trip.	side co	ntainment on the '	'A' RCS loop, eventually
Time/Notes	Position		Appl	icant's Actions or E	Behavior

•.

۰.

Γ

NOTE: After the crew isolates leto be increased (at the direction of th	down and determines that the leak is NOT isolated, the leak size will ne Lead Examiner) such that pressurizer level cannot be maintained > 5%.			
RO	Identify leak has increased by observing charging pump speed rising,			
	pressurizer level lowering.			
	NOTE: RO and/or Crew may determine that the required Charging			
	flow is in excess of normal Reactor Makeup capacity (VCT level lowering) and trip the unit based on this fact			
	iowering, and trip the unit based on this fact.			
	NOTE: Rods may step out to maintain temperature due to the large			
	slightly higher than initial RCS boron).			
NOT	E: The following step is a Critical Task.			
RO/CRS	Implement Immediate Action of A-RC-36D due to inability to maintain Pressurizer Level > 5%.			
	Reactor Trip and SI required to be ordered prior to pressurizer level going off-scale low.			
When a reactor trip and SI is ordered, proceed to the next event (Event #5, 6, and 7).				

Op-Test No: _2002	301	Scenario No: <u>1</u> Event No: <u>5,6,7</u> Page <u>1</u> of <u>7</u>
Event Description:	Large break L 'B' to Auto-sta for sump recir	OCA occurs upon initiating reactor trip with failure of RHR Pump art and subsequent RHR Pump 'B' coupling failure upon re-start cculation.
Time/Notes	Position	Applicant's Actions or Behavior
	CRS	Implement E-0 "REACTOR TRIP OR SI"
	RO	Verify reactor trip:
		 Reactor trip & bypass breakers open Rod Position Indicators read ZERO Rod bottom lights LIT Neutron flux decreasing
	BOP	 Verify Turbine Trip: HP turbine impulse pressure PI-485/486 trending toward ZERO All turbine STOP VALVES closed Verify power to Emergency AC Buses Bus 5 energized Bus 6 energized
	RO	 Determine if SI needed/actuated: SI will be actuated due to LBLOCA. Annunciator 47021-A "SI TRAIN A ACTUATED lit" Annunciator 47021-B "SI TRAIN B ACTUATED lit" RO should also identify failure to start of RHR Pump 'B'. After the SI Sequencer and immediate actions are complete, an attempt may be made to start RHR Pump 'B'.
	BOP	 Verify Feedwater Isolation: FW-7A and FW-7B Main FW Flow Control Valves closed. FW-10A and FW-10B Main FW Bypass Flow Control Valves closed. FW-12A and FW-12B, Feedwater to SG A/B Isolation Valves closed. Both Feedwater Pumps off.
	CREW	 RXCPs should be tripped per E-0 Quick Reference Foldout (QRF) Step 1: After verifying ECCS flow and inadequate subcooling, both RXCPs should be stopped.

ſ

Op-Test No: _2002	301	Scenario No:	_1	Event No: <u>5,6,7</u>	Page _2_ of _7_
Event Description:	Large break LO 'B' to Auto-start for sump recircu	CA occurs upon and subsequent lation.	initia t RHR	ting reactor trip wit Pump 'B' coupling	h failure of RHR Pump failure upon re-start
Time/Notes	Position		App	icant's Actions or Be	havior

٠,

BOP	Make plant announcement for Safety Injection.
BOP	Check Main Steamline Isolation:
	 Main Steamline isolation is required due to high containment pressure – MSIVs and MSIV Bypass Valves should be verified shut.
RO/BOP	Verify Containment Spray NOT required:
	• Containment Spray is required due to high containment pressure and will be functioning normally.
BOP	Verify Containment Cooling:
	• Fan Coil Units running
	 Verify SW-903A-D CFCU SW Return Isolation valves open
	• Verify RBV-150A-D CFCU Emergency Dampers OPEN.
BOP	Verify Aux Bldg Special Vent running:
	 Annunciator 47052-G "ZONE SV BNDRY DAMPER NOT CLOSED" not lit.
	• Verify Zone SV fans running.
BOP	Verify Service Water Alignment
	• Verify all Service Water Pumps (A1, A2, B1, B2) running.
	• Verify SW Header selected on Turbine Bldg selector switch is > 82.5 psig.
BOP	Verify AFW Pumps running:
	 Verify Motor Driven AFW Pump 'A' is running. Since BOTH Motor Driven AFW Pumps are not available, the Turbine Driven AFW Pump is NOT secured at this time. (TDAFWP should be secured when the RCS temperature control step is reached).

Op-Test No: 200230	01	Scenario No: 1 Event No: 5,6,7 Page 3 of 7
Event Description:	Large break L 'B' to Auto-sta for sump recir	OCA occurs upon initiating reactor trip with failure of RHR Pump art and subsequent RHR Pump 'B' coupling failure upon re-start eculation.
Time/Notes	Position	Applicant's Actions or Behavior
	RO	Verify Containment and Containment Ventilation Isolation:Verify all CI Active Status Panel Lights lit.
NOTE: 1	The following h	nighlighted step to start RHR Pump 'B' is a Critical Task.
	RO	 Verify ESF Equipment running: SI pumps – both should be running. <i>RHR pumps – 'A' Pump is tagged out and unavailable. RHR Pump 'B' must be manually started at this time if not previously started.</i> CC Pumps – both should be running, one should be stopped and placed in pullout. SI Active Status Panel – all lights will be lit with the exception of the previously tagged out equipment.
	RO	 Verify SI flow: SI flow indicated on F925. RHR Flow indicated on F928.
	BOP	 Verify total AFW flow > 200 gpm. Adequate AFW flow is available
	RO	 Check RXCP Seal Cooling: CC Supply for Thermal Barrier Isolation Valves CC-600, CC-601A(B), CC-610A(B) and CC-612A(B) open Thermal Barrier temperatures T610 and T614 normal RXCP Bearing Temperatures T125 and T132 normal
	RO	Check RCS temperatures:RCS Average Temperature will be lowering due to the LBLOCA.

٠,

۰,

ſ

Op-Test No: <u>2002</u>	301	Scenario No: <u>1</u> Event No: <u>5,6,7</u> Page <u>4</u> of <u>7</u>
Event Description:	Large break LC 'B' to Auto-star for sump recircu	OCA occurs upon initiating reactor trip with failure of RHR Pump t and subsequent RHR Pump 'B' coupling failure upon re-start ulation.
Time/Notes	Position	Applicant's Actions or Behavior

۰,

۰,

POD	
DUr	Due to lowering KCS temperature, the following actions are required:
	 Stop dumping steam. Place the Turbine Driven AFW Pump control switch in pullout since Motor Driven AFW Pump 'A' is running. If S/G levels are > 4% (15% adverse), then AFW flow should be reduced. MSIVs and MSIV Bypass valves should be verified shut.
RO	Check Pressurizer PORVs and Spray Valves closed:
	 Both PORVs closed. Normal Pressurizer Spray valves closed. CVC-15 Aux Spray Valve closed.
RO	Check if RXCPs should be tripped:
	• If not previously performed per E-0 Quick Reference Foldout (QRF) Step #1, then both RXCPS should be stopped at this time.
BOP	Check if Steam Generators are faulted:
	• There are no indications of any faulted Steam Generators. S/G pressures may be lowering but should be consistent with RCS temperatures.
CREW	Check that Steam Generator tubes are NOT ruptured.
	• There are no indications of any S/G tube leakage.
CREW	Check if RCS is intact.
	RCS determined NOT to be intact based on RCS pressure, Containment parameters, and ECCS flows.
CRS	Based on the RCS not being intact, transition is made to E-1, Loss of
	Reactor or Secondary Coolant.

Op-Test No: _2002	301	Scenario No: _1 Event No: _5,6,7 Page _5_ of _7							
Event Description: Large break LOCA occurs upon initiating reactor trip with failure of RHR Pump 'B' to Auto-start and subsequent RHR Pump 'B' coupling failure upon re-start for sump recirculation.									
Time/Notes	Position	Applicant's Actions or Behavior							
NOTE: Upon tran Imminent Press should then be exit	sition to E-1, a surized Therma ted at step 1 bas should	Red Path may be identified requiring entry to FR-P.1, Response To al Shock Condition. The transition to FR-P.1 should be made, but sed on RCS pressure < 150 psig and RHR flow > 375 gpm. The CRS d then return to E-1 at the step in effect.							
NOTE: Upon retur used to lower RWS Room, ti	rn to E-1 from T T level. The fol me compression	FR-P.1, the crew should be informed that time compression is being llowing statement should be given to the crew: "Attention in Control n is being used to lower RWST level." Repeat if necessary.							
	RO	Check if RXCPs should be tripped:							
		• Both RXCPs should have already been secured per E-0.							
		NOTE: Transition may be made to ES-1.3 prior to E-1 implementation based on the Quick Reference Foldout Page (RWST <37%).							
	RO	Check RWST level > 37%:							
		NOTE: Due to time compression, RWST level is < 37%.							
	CRS Based on the information provided to the crew regarding RWST level, a transition should be made to ES-1.3, Transfer To Containment Sump Recirculation.								
	RO	Check Containment Sump B Level > 1ft.							
	• Adequate sump level exists.								
	RO	Reset SI – depress both SI reset pushbuttons. Reset Containment Spray – depress both CS reset pushbuttons.							

۲.

Op-Test No: _2002	301	Scenario No: _1	Event No: <u>5,6,7</u>	Page <u>6</u> of <u>7</u>
Event Description:	Large break LC 'B' to Auto-star for sump recircu	CA occurs upon initiat t and subsequent RHR ulation.	ing reactor trip with Pump 'B' coupling f	failure of RHR Pump ailure upon re-start
Time/Notes	Position	Appl	icant's Actions or Beh	avior

RO/BOP	Establish Component Cooling flow to the RHR Heat Exchangers
Ro, Dol	Establish Component Cooming now to the Kritt fleat Exchangers.
	• Verify both CC Pumps running the CC Pump providually accurat
	should now be started
	Open SW-1300A CC Heat Exchanger A Outlat
	Open SW 1300R, CC Heat Exchanger R Outlet.
	• Open CC 400A, CC Te DUD HX A
	• Open CC 400P, CC To KHK HX A.
	• Open CC-400B, CC TO KHK HX B.
RO	Verify LD-6, letdown line isolation closed.
RO	Align Charging Pumps to the VCT.
	• Verify Makeup Boric Acid Controller set to 11.0.
	• Verify Makeup Mode Selector in Auto.
	• Verify VCT level > 5%
	If VCT level is < 5%, re-alignment of Charging Pump suction is NOT
	performed. IF VCT level is $> 5\%$, the following steps are performed.
	• Open CVC-1, VCT to Charging Pumps Isolation.
	Close CVC-301, Refueling Water Emergency Makeup to Charging
	Pump.
	Since no Charging Pumps are currently running, none are started. A
	transition to the next step should be made.
- PO	Check BCS Pressure <2100 rais (1000 rais for a house Cout)
KO	Check RCS Pressure <2100 psig (1900 psig for adverse Cont.).
RO	Close Both SI Recirculation to RWST Valves
	• SI-208 and SI-209.
RO	Verify Train A Injection Flow.
	Safety Injection Pump A will indicate flow, RHR Pump A is tagged
	out.
RO	Check ICS Pump A Running – it is running.

Op-Test No:	2002301	Scenario No: <u>1</u> Event No: <u>5,6,7</u> Page <u>7</u> of <u>7</u>						
Event Description: Large break LOCA occurs upon initiating reactor trip with failure of RHR Pump 'B' to Auto-start and subsequent RHR Pump 'B' coupling failure upon re-start for sump recirculation.								
Time/No	otes Position	Applicant's Actions or Behavior						
	RO	 Stop Train B Pumps. RHR Pump B. SI Pump B. ICS Pump B. 						
NOTE: Ar RWST leve	RO RO additional cue from any be necessary a informed that time	 Align the operating train ('B' Train) for Sump Recirculation. SI-350B, Containment Sump B Supply To RHR Pump B, is opened. SI-300B, RWST Supply To RHR Pump B, is closed. SI-351B, Containment Sump B Supply to RHR Pump B, is opened. RHR-8B, RHR Heat Exchanger Flow CV, is closed. RHR Pump 'B' is started – NOTE: Upon start of RHR Pump 'B', a pump/motor coupling break will occur – indications are as follows: Minimum amps. No indicated pump flow. No indicated discharge pressure. If the RHR Pump B failure is not recognized, an attempt may be made to adjust flow by opening RHR-8B At this time, recognition of pump failure should occur since there will be no flow from the pump. the Floor Instructor or Lead Examiner to accelerate lowering of t this time. When Step 14 of ES-1.3 is reached, the crew should be e compression is being used and RWST level is 9%						
	CRS	 Dependent upon the time of recognition of the RHR Pump B failure, a transition to either Step 13 or Step 14 of ES-1.3 should occur. It should be recognized that Step 13 should NOT be performed as this will align SI Pump B to RHR Pump B suction. Step 14 is unable to be performed as well since RHR Pump A is tagged out and unavailable. The Contingency Action of Step 14 requires a transition to ECA-1.1, Loss of Emergency Coolant Recirculation. 						

•

•.

Appendix D	Scenario Outline	Form ES-D-1		
Facility : KNPP	Scenario No.: <u>2</u>	OP-Test No.: 2002301		
Examiners:	Operators:			

Initial Conditions: The plant is at 100% power, MOC, equilibrium xenon conditions. Testing of the turbine stop and governor valves is scheduled for later in the shift. Today is Sunday, present clock time is real time. A normal shift complement is available.

Turnover: The following equipment is inoperable and has been properly removed from service:

- 'A' Residual Heat Removal Pump tagged out 36 hours ago due to high bearing temperatures and vibration during a scheduled surveillance run. A maintenance crew is on-site and working to repair the pump.
- 'B' Motor Drive Auxiliary Feedwater Pump tagged out last shift due to indications of a significant amount of water in the lube oil. A lube oil cooler leak is suspected. Maintenance has been notified.
- LT-472 'B' S/G Water Level Channel tagged out due to suspected transmitter failure. A plan for transmitter replacement is being developed. A-MI-87 has been completed to remove this channel from service.

The goal for the shift is reduce power to < 390 Mwe per N-0-03 for testing of the turbine stop and governor valves (SP-54-086)

Event No.	Malf. No.	Event Type*	Event Description
1		R - RO N - BOP SRO	Perform a power reduction per N-0-03
2		I - RO SRO	Controlling pressurizer pressure channel PT-431 fails high.
3		I - BOP SRO	Generator Hydrogen temperature controller drifts shut.
4	-	C - RO SRO	S/G 'A' tube leak develops leading to reactor trip.
5		C - BOP SRO	S/G 'A' blowdown fails to isolate.
6		M - ALL	Tube leak increases to rupture following reactor trip.
7		C – BOP SRO	Main turbine fails to auto-trip.
* ((N)ormal,	(R)eactiv	vity, (I)nstrument, (C)omponent, (M)ajor

NUREG-1021, Revision 8, Supplement 1

Revision 0 DRAFT

DYNAMIC EXAM SCENARIO ID#: SES-2002301: #2

SIMULATOR SHIFT TURNOVER:

Per Scenario Outline.

2

.

-

SIMULATOR SCENARIO SET UP

STEP COUNTERS ON	
INIT into IC	
NTP-6410, Communicator Telephone Log, available	
NTP 6411, Simulator Setup Checklist, completed	
NTP-6412, Simulator Book Preparation Checklist, completed	
NTP-4 Attachment 10, Simulator Scenario Briefing Sheet, completed	
NTP-4, Attachment 13, KNPP Simulator Security Checklist, completed	

SCENARIO GUIDE:

:

- 1. Initialize to a 100% Power IC or saved specific SES IC.
- 2. Place RHR Pump A control switch in pullout and place a Hold Card on the switch.
- 3. Place AFW Pump B control switch in pullout and place a Hold Card on the switch.
- 4. Place an "Out of Service" sticker on S/G B Level Indicator LI-472.
- 5. Verify Trigger 1 is set to the following: Event "hwztct6155". Command "dmf tc07".
- 6. Preload (or verify preloaded) and verify active the following simulator codes:

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER
Preload	Malfunction	SER0966, Beta Annunciator Driver Override				Block	
Preload	Annunciator	47034-O, SER1670 Source Range High Flux at Shutdown Alarm Blocked				Block	
Preload	Malfunction	TC07, Turbine Fails To Trip					
Preload	Lights	MCA, DO-46131-G, BT2A				OFF	
Preload	Lights	MCA, DO-46131-R, BT2A				ON	
Preload	Lights	MCA, DO-46132-G, BT3A				OFF	
Preload	Lights	MCA, DO-46132-R, BT3A	'			ON	
Preload	Meter	MCA, AO-41052-02, LI-472				0	
Preload	Remote Function	RP191, 472A, Lo/Lo Level Logic				TRIP	
Preload	Remote Function	RP192, 472B, Hi Level Logic				TRIP	
Preload	Remote Function	RP193, 472C, Lo Level Logic				TRIP	

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

Preload Table is continued on the next page.

÷

.

Revision 0 DRAFT

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER
Preload	Annunciator	47065-F, SER0812, AMSAC in Test				Crywolf	
Preload	Lights	MVB, DO-47033:0401, TLA- 16 AMSAC Channel Abnormal				ON	

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

Use the Instructor Summary Station to verify the simulator codes in the table below are assigned to the appropriate Trigger with the appropriate value(s).

These events will be input as shown in the guidance following the table.

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER**
Event 2	System Override	RX203, PT-431, PRZ Press	2235	5		2500	3
Event 2 - (A-MI-87)	Remote Function	RP141, 407C – Over Temp Trip				TRIP	4
Event 2 - (A-MI-87)	Remote Function	RP142, 407D – Rod Stop			20	TRIP	4
Event 2 - (A-MI-87)	Remote Function	RP164, 431A – Hi Press Trip			40	TRIP	4
Event 2 - (A-MI-87)	Remote Function	RP167, 431J – Lo Press Trip			60	TRIP	4
Event 2 - (A-MI-87)	Remote Function	RP166, 431I – Unblock SI			80	TRIP	4
Event 2 - (A-MI-87)	Remote Function	RP165, 431G - SI			100	TRIP	4
Event 3	Controllers	MCA, AI-43001-R1, SW- 2602 Setpt Adj	As found	1200		100	5
Event 4	Malfunction	SG02A, Steam Generator Tube Leak, Inlet Tubesheet				75	6
Event 4	Switches	MCA, DI-43012-01-Auto, FW-7A	-			ON	7
Event 4	Controllers	MCA, AI-43012-01-R1, FW- 7A Setpt Adj	As found	60		0	7
Event 5-7	Malfunction	SG01A, Steam Generator Tube Leak, Inlet Tubesheet				8	8

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

** See following page for specific guidance on Trigger activation.

Page 4 of 6

Simulator Operator Guidance:

- Trigger 1 DO NOT MANUALLY ACTIVATE. This is an Automatic trigger this trigger will deactivate the Auto Turbine Trip Failure (TC07) when the manual turbine trip pushbutton is depressed.
- Trigger 2 Not Used.

5

- Trigger 3 Activate when requested by Lead Examiner to fail PT-431 high.
- Trigger 4 Activate to trip all bistables associated with PT-431 per A-MI-87 (I&C) Note: All bistables will trip in procedure sequence in 20 sec. intervals.
- Trigger 5 Activate when requested by Lead Examiner to fail SW-2602 closed (ramp closed).
- Trigger 6 Activate when requested by Lead Examiner to initiate ≈30 gpm tube leak. NOTE: Monitoring of the BOP operator is required and all preloaded "Light" malfunctions (4) associated with SG A blowdown valves BT-2A AND BT-3A deleted when the control switches are taken to close. Use the Instructor Station Summary page.
- Trigger 7 Activate when requested by Lead Examiner to fail Main Feedwater Control Valve closed (in order to initiate a reactor trip).
- Trigger 8 Activate immediately following the manual tripping of the Main Turbine by the BOP operator.

ANTICIPATED BOOTH COMMUNICATION/GUIDANCE:

Event 1: This event is a normal down-power. The field operators should be informed of the power decrease, with an acknowledgement by the communicator.

Event 2: This event is a failure of Pressurizer Pressure Transmitter PT-431 (fails high). This failure will cause the pressurizer spray valves to fully open, as well as turning off all heaters. This will require the operator to swap pressurizer pressure control channels or take manual control of the spray valves. After stabilizing the plant, A-MI-87 will be utilized to remove the channel from service. The CRS will request SP 47-316C to check redundant channel bistables. The communicator should inform the CRS that SP 47-316C is complete and no redundant channel bistables were found tripped. I&C will also be requested to trip the bistables associated with the level channel. The paperwork (A-MI-87) should be obtained from the CRS and the bistables tripped per this simulator guide. After tripping the bistables, the A-MI-87 paperwork should be signed off as appropriate and returned to the control room.

Revision 0 DRAFT

Event 3: This event is a slow failure of SW-2602, Generator Hydrogen Temperature Control Valve. to the closed position. A "Hydrogen Panel Trouble" alarm will be the first alarm received, and a field operator will be contacted to investigate the alarm. After investigation, it should be reported back that the local alarm is "Hydrogen Temperature High" (alarm 3-2). Required actions are to:

- 1) Verify proper operation of SW-2602.
- 2) If required, throttle open SW-2603 Temperature Control Valve Bypass.
- 3) GO TO A-EG-43A.

The above 3 items should be provided back to the requesting control room operator. If the control room requests SW-2603 be manually opened, it should be reported that an attempt was made to open the valve but seems to be stuck shut. If inquiry about SW-2602 is made, it should be reported that the valve is slowly going to the closed position. The control room has manual control of SW-2602 available, and this should be utilized to control hydrogen gas temperature.

Event 4, 5: This event is a tube leak in SG A. The initial leakrate is approximately 30 gpm. A-RM-45 and E-0-14 will be utilized for this event. Verification of HS-17-1, Humidification Steam Inlet CV, closure will be requested. The valve should be reported as being shut. After determination that Action Level 3 is met in E-0-14, failure of SG A Main Feedwater Control Valve occurs (manual control is NOT an option) and this will cause a reactor trip on low SG level.

Event 6, 7: Following the trip, the main turbine will not trip and will be required to be manually tripped. Also, the initial tube leak in SG A will increase to a full tube rupture. Main Steam Header A Trap 20 inlet and outlet valves, TD-1-20 and TD-3-20, will be requested to be manually closed. They should be reported as being closed after allowing sufficient time to perform task. If RP/HP is requested to survey steamlines, indicate that SG A is indicating above background, SG B is indicating normal background.

Op-Test No: _2002	2301	Scenario No: 2 Event No: 1 Page 1 of 3
Event Description:	Perform Norma	Down-Power (Reactivity Manipulation).
Time/Notes	Position	Applicant's Actions or Behavior
At the Jimmetian Ct		

ſ

At the discretion of the l entering the simulator.	ead examiner,	, the normal up-power brief may be conducted in the classroom prior to
	CRS	Brief crew on evolution, including discussion of N-0-03 (Plant Operation Greater Than 35% Power) precautions and limitations, for commencing down-power.
	CRS	Implement actions of N-0-03
	RO	Perform reactivity estimate based on planned load increase.
	CRS	Direct power reduction to < 390 MWe.
	ВОР	 Reduce load per N-TB-54: Review applicable Precautions & Limitations. Determine maximum unloading rate based on turbine operating limits per Figures 2 & 3. Adjust turbine controls to clear Valve Position Limiter: Lower the setter to ≤ value stated on EH Panel Plaque. Set loading rate to ≤ 5% per minute. Depress GO pushbutton. When VPL light goes out, push the HOLD pushbutton. Set setter to desired load. Verify/set unloading rate to 0.25% per min (minimum unloading rate of 0.25% per min is normal plant practice). Inform Energy Supply & Control of rate and amount of load reduction. Depress GO pushbutton

Op-Test No: _2002	301	_ Scenario No: _2	Event No: 1	Page <u>2</u> of <u>3</u>
Event Description: Perform Normal I		Down-Power (Reactiv	vity Manipulation).	
Time/Notes	Position	Appl	icant's Actions or B	ehavior

Γ

	 Rod Control (rod motion at 1.5 °F difference Tave-Tref) AND/OR Boron Concentration Control (initiate boration) per N-CVC-35A Review applicable Precautions & Limitations. Determine rate and magnitude of boration. Position Reactor Makeup Mode Selector to BORATE. Adjust CVC-403/CV-31092, Blender Control BA Flow, to required flow rate. Set Boric Acid Totalizer to required quantity. Position Reactor Makeup Control switch to START. Verify required change has been achieved by monitoring:
	 Rod Position Boron Concentration Tave When boration is complete: Close CVC-406/CV-31904 BA Blender to VCT. Perform 20 gallon Alternate Dilute Position CVC-406 to AUTO
	 Alternate Dilution actions (to flush lines): Position Reactor Makeup Mode Selector to ALT DIL. Adjust MU-1022/CV-31095, Blender Control Rx Mu Flow, to desired flow rate. Set Rx Make-up Totalizer to 20 gal. Position Reactor Makeup Control switch to START. When dilution is complete: Position Reactor Makeup Mode Selector to AUTO. Position Reactor Makeup Control switch to START. Adjust CVC-403/CV-31092, Blender Control BA Flow, to current RCS boron concentration.

op-rest 140200250	<u>S</u>	cenario No: 2	Event No: 1	Page 3 of 3
Event Description:]	Perform Normal Dov	vn-Power (Reacti	vity Manipulation).	

••

.

BOP	Adjust Heater Drain Pump speed as required to maintain equal loading on pumps.
Once power has been raised 5% event (Event #2).	and/or at the discretion of the Lead Examiner, proceed to the next

Op-Test No: 2002	301	Scenario No: 2 Event No: 2 Page 1 of 3
Event Description:	Controlling pr spray valves to	essurizer pressure channel PT-431 fails high causing pressurizer o open.
Time/Notes	Position	Applicant's Actions or Behavior
	RO	Identify/report failed pressurizer pressure channel PT-431. Available indications:
		 Annunciator "Pressurizer Pressure 2385" (47041-C). Annunciator "Pressurizer Control Press Abnormal" (47043-C). Status Light "Pressurizer 2385 psig" (44907-0307) Pressurizer pressure indicator PI-431 failing high.
	RO	Refer to above annunciator response procedures, position the Pressurizer Pressure Control Channel Selector to position "2-1" to remove the failed instrument.
		NOTE: Other acceptable actions in lieu of immediately manipulating the Pressurizer Control Channel Selector include either placing both Pressurizer Spray Valve Controllers to manual and shut or placing the Master Pressurizer Pressure Controller in manual and adjusting to control pressure.
11	CRS	Direct power decrease be placed on hold.
	CRS	Implement A-MI-87 "Bistable Tripping for Failed Reactor Protection or Safeguards Inst.", to remove PT-431 from service – bistable tripping must be performed within 6 hours per A-MI-87.
	CRS	Direct actions to remove PT-431 from service:
		• Direct I&C to perform SP 47-316C to check redundant channel bistable contacts for PT-431 removal from service. (NOTE: Communicator will inform Control Room that SP 47-316C is complete.)
	RO	Perform/verify prerequisite lineup of "Removal From Service".
		 Position/Verify Pressurizer Pressure Control Channel Selector switch to position "2-1" (this places pressurizer channel PT-429 in service as the controlling channel). Position Pressurizer Pressure Recorder Input Selector switch to position "1".
	CRS	Direct I&C to trip associated bistables for PT-431.

Op-Test No: _2002	301	Scenario No: _2	Event No: 2	Page <u>2</u> of <u>3</u>
Event Description:	Controlling pre- spray valves to o	ssurizer pressure chan open.	nel PT-431 fails hig	h causing pressurizer
Time/Notes	Position	Арр	licant's Actions or B	ehavior

...

ſ

ſ

NOTE: Simulator Booth Operator will obtain A-MI-87 paperwork from CRS/BOP and perform the bistable tripping when directed. When complete, the applicable pages and steps of A-MI-87 will be returned to the CRS/RO.			
returned to the CRS/F	RO	 Complete verification steps of A-MI-87 following bistable tripping: Ensure the following annunciators/status lights are ON: Annunciator "PZR PRESs SI CHANNEL ALERT" (47041-D) Annunciator "OTΔT High" (47033-C) Annunciator " Pressurizer Pressure 2385" (47041-C) Annunciator " Pressurizer Pressure <1900" (47042-D) Annunciator "OTΔT CHANNEL RNBACK/RDSTP ALERT (47041-R) Status Light "Pressurizer 1815 psig" (44908-0203) Status Light "Pressurizer >2000" (44908-0103) Status Light "Pressurizer 1900 psig" (44907-0207) Status Light "Pressurizer 1900 psig" (44907-0307) 	
		11. Status Light Loop & Channel 5 $O1\Delta I$ (44904-0202)	

Op-Test No: _2002	301	Scenario No:	Event No: 2	Page 3 of 3
Event Description:	Controlling pres spray valves to o	surizer pressure chan pen.	nel PT-431 fails hig	h causing pressurizer
Time/Notes	Position	Арр	licant's Actions or B	ehavior

÷

٠

Γ

CRS	 Review Technical Specification 3.5.b & c: Table 3.5-2: No. 5 – Overtemperature ΔT No. 7 – Low Pressurizer Pressure No. 8 – High Pressurizer Pressure Determines continued operation acceptable (3 channels required operable for No. 5 and 7, 2 channels required operable for No.8.) Table 3.5-3: No. 1.d – Pressurizer Low Pressure Determine continued operation acceptable (2 channels required operable)
CRS	Inform I&C to investigate Pressurizer Pressure channel PT-431 failure/status.
At the discretion of the	Lead Examiner, proceed to the next event (Event #3).

Op-Test No: 2002301		Scenario No: 2 Event No: 3 Page 1 of 2
Event Description:	Generator Hy manual operat	drogen Temperature Control Valve SW-2602 drifts closed requiring tion (controller failure).
Time/Notes	Position	Applicant's Actions or Behavior
	BOP	Review annunciator response procedure for "Hydrogen Panel Trouble" (47071-E)
	BOP	 Dispatch operator to investigate alarm. Local Alarm Response (H2 Panel 3-2) requires the following actions: Verify proper operation of SW-2602. If required, throttle open SW-2603. Temperature Control Valve Bypass, to reduce temperature. Go to A-EG-43A. NOTE: At this time, a failure of SW-2602 controller may not be readily apparent due to the slow failure. Manual operation of SW-2603 will not be allowed as an option. Further monitoring of SW-2602 should identify its failure.
	CRS	Implement A-EG-43A, Main Electric Generator Faults.
	RO/BOP	 Check if reactor should remain operating: Check "Generator Stator Temperature, TLA-13" OFF. Check max/min slot gas discharge temperature difference < 8 °F using PPCS Group 84 & 85 and Periodic Log 16.
	BOP	 Check max/min generator slot temperatures ≤ limits on Figure 1: Check computer point T0382G.
	BOP	Check Main Generator loading normal: Operating parameters are within bounds of Generator Capability Curve of N-TB-54, Figure 5.

Op-Test No: _2002.	301	Scenario No: 2	Event No: 3	Page <u>2</u> of <u>2</u>
Event Description: Generator Hydrog manual operation		ogen Temperature Co n (controller failure).	ntrol Valve SW-260	2 drifts closed requiring
Time/Notes	Position	Appl	licant's Actions or Be	ehavior

BOP	Verify Main Generator Cooling Normal:
	 H₂ Cooler Cold Gas Temp RTDs 86-95 °F (Recorder #42525 points 12,13,16,and 17.) NAO may be dispatched to vent the hydrogen coolers.
	 H₂ Cooler Warm Gas Temp RTDs normal (Recorder #42525 points 14 and 15.)
	 SW-2602 maintaining cold gas temperature 30-36 °C (86-95 °F) NOTE: By this time, the on-going monitoring of SW-2602 position/control signal should indicate abnormal operation to the examinee. Per the Contingency Action, SW-2602 controller should be placed in manual to establish normal cold gas temperatures (Opening of local valve SW-2603 will not be available to the crew due to valve failure).
NOTE: The remainder of thi	s procedure (A-EG-43A) provides steps for further diagnostics and

monitoring of generator parameters. These steps are not listed here. When SW-2602 controller is placed in manual and adjusted to lower hydrogen temperature, then proceed to the next event (Event #4) at the discretion of the Lead Examiner.

Op-Test No: 20	002301
----------------	--------

Scenario No: 2 Event No: 4, 5

Page <u>1</u> of <u>2</u>

Event Description: Steam Generator 'A' Tube leak develops, followed by failure of the 'A' Main Feedwater Control Valve resulting in reactor trip.

Time/Notes	Position	Applicant's Actions or Behavior	
	RO RO/BOP	 Identify/report elevated readings on Radiation Monitor R-15. Available indications: Annunciator "Radiation Indication High" (47011-B). Annunciator "Radiation Indication Alert" (47012-B). Annunciator "TLA-15 – RMS Above Normal" (47033-35). Individual radiation monitor reading on rad monitor drawer. Refer to above annunciator response procedures, inform CRS of required 	
	CRS	actions (GO TO A-RM-45). Implement required actions of A-RM-45, Abnormal Radiation Monitoring System.	
	BOP	 IMMEDIATE ACTIONS of A-RM-45: Verify the following automatic actions: AR-6 Air Ejector Disch Vent positions to DUCT. Verify the following valves close: BT-2A, S/G 'A' Blowdown Isolation A1 BT-3A, S/G 'A' Blowdown Isolation A2 BT-2B, S/G 'B' Blowdown Isolation B1 BT-3B, S/G 'B' Blowdown Isolation B2 BT-31A S/G A Sample Isolation BT-32A S/G A Sample Isolation BT-32B S/G B Sample Isolation BT-32B S/G B Sample Isolation NOTE: BT-2A and BT-3A will NOT automatically close and must be closed using their respective control switches. 	
	CRS	Transition to E-0-14, Steam Generator Tube Leak.	

Op-Test No: 2002	301	Scenario No: 2 Event No: 4, 5 Page 2 of 2
Event Description:	Steam Generato Feedwater Cont	'A' Tube leak develops , followed by failure of the 'A' Main ol Valve resulting in reactor trip.
Time/Notes	Position	Applicant's Actions or Behavior

-

RO	Verify pressurizer level stable or increasing:
	verify pressurizer level stable of increasing.
	• Pressurizer will be lowering at this time – the following actions are directed for lowering level.
	 Increase Charging flow to maintain pressurizer level. Operate pressurizer heaters to maintain RCS pressure. Verify Reactor Makeup system operable.
	• If pressurizer level continues to lower, then letdown is isolated by closing the following valves:
	 LD-2, Letdown Isolation LD-3, Letdown Isolation LD-4A, Letdown Orifice A Isolation
	 LD-4B, Letdown Orifice B Isolation LD-4C, Letdown Orifice C Isolation
	NOTE: The tube leak at this time is approximately 30 gpm. A reactor trip is not required by procedure provided charging flow is increased. However, at the discretion of the CRS, a reactor trip may be ordered due to the large leak.
CREW	Check if entry into Action Level 3 is required.
	• Using conversion graph, leakage is in excess of 100 gpd.
	• R-19 increase is > 5%.
	Crew should determine that entry into Action Level 3 IS required.
NOTE: When crew determines the Examiner insert malfunction to fai trip. When a reactor	at entry to Action Level 3 is required, at the discretion of the Lead I SG 'A' Main Feedwater Control Valve closed to initiate a reactor r trip occurs, proceed to the next events (events 6-7).

BOP	Manual control of the 'A' Main Feedwater Control Valve may be attempted but will be unsuccessful.

Op-Test No:	2002301	Scenario No: 2 Event No: 6,7 Page 1 of 9		
Event Description: Tube leak on S/G 'A' increases to rupture following reactor trip with a failure of the main turbine to auto-trip.				
Time/Not	es Position	Applicant's Actions or Behavior		
	CRS	Implement E-0 "REACTOR TRIP OR SI"		
	RO	 Verify reactor trip: Reactor trip & bypass breakers open Rod Position Indicators read ZERO Rod bottom lights LIT Neutron flux decreasing 		
	BOP	 Verify Turbine Trip: HP turbine impulse pressure PI-485/486 trending toward ZERO All turbine STOP VALVES closed NOTE: Turbine is NOT tripped – a manual turbine trip is required. Verify power to Emergency AC Buses Bus 5 energized Bus 6 energized 		
	RO	 Determine if SI needed/actuated: Depending on the timing of the crew, SI may not be automatically actuated at this time. However, SI should be manually actuated based on lowering pressurizer level. 1. Annunciator 47021-A "SI TRAIN A ACTUATED lit" 2. Annunciator 47021-B "SI TRAIN B ACTUATED lit" 		
	BOP	 Verify Feedwater Isolation: FW-7A and FW-7B Main FW Flow Control Valves closed. FW-10A and FW-10B Main FW Bypass Flow Control Valves closed. FW-12A and FW-12B, Feedwater to SG A/B Isolation Valves closed. Both Feedwater Pumps off. 		
	BOP	Make plant announcement for Safety Injection.		

• •

-

Op-Test No:2002	301	_ Scenario No:		Event No:	6,7	Page 2	of <u>9</u>
Event Description:	Tube leak on S/G the main turbine	'A' increases to to auto-trip.	o rupt	ure followin _į	g reactor (trip with a	failure of
Time/Notes	Position		Appl	icant's Actio	ns or Beha	wior	<u> </u>

.,

-

ſ

BOP	 Check Main Steamline Isolation: Main Steamline isolation is NOT required at this time. NOTE: If Manual turbine trip is delayed, a MSL isolation may occur.
RO/B	OP Verified Containment Spray NOT required:
	• Containment Spray is NOT required at this time.
BOP	Verify Containment Cooling:
	• Fan Coil Units running
	• Verify SW-903A-D CFCU SW Return Isolation values open.
	• Verify RBV-150A-D CFCU Emergency Dampers OPEN.
BOP	Verify Aux Bldg Special Vent running:
	 Annunciator 47052-G "ZONE SV BNDRY DAMPER NOT CLOSED" not lit. Verify Zone SV fans running.
BOP	Verify Service Water Alignment
	 Verify all Service Water Pumps (A1, A2, B1, B2) running. Verify SW Header selected on Turbine Bldg selector switch is > 82.5 psig.
BOP	Verify AFW Pumps running:
	 Verify Motor Driven AFW Pump 'A' is running. Since BOTH Motor Driven AFW Pumps are not available, the Turbine Driven AFW Pump is NOT secured at this time.
RO	Verify Containment and Containment Ventilation Isolation:
	• Verify all CI Active Status Panel Lights lit.

Op-Test No: _2002	301	Scenario No: 2	Event No: <u>6,7</u>	Page <u>3</u> of <u>9</u>
Event Description:	Tube leak on S/C the main turbine	G 'A' increases to rupt e to auto-trip.	ure following reactor	trip with a failure of
Time/Notes	Position	Appl	icant's Actions or Beh	avior

.,

.

Γ

RO	Verify ESE Equipment game is a
NU	verny Lor Equipment running:
	 SI pumps - both should be running. RHR pumps - RHR Pump 'B' should be running, 'A' is tagged out. CC Pumps - both should be running, one should be stopped and placed in pullout. SI Active Status Panel - all lights will be lit with the exception of the previously tagged out equipment.
 P.O.	Marife, OI fl
ĸo	 SI flow indicated on F925. RHR flow is not checked due to high RCS pressure.
BOP	Verify total AFW flow > 200 gpm.
	Adequate AFW flow is available
RO	Check RXCP Seal Cooling:
	 CC Supply for Thermal Barrier Isolation Valves CC-600, CC-601A(B), CC-610A(B) and CC-612A(B) open Thermal Barrier temperatures T610 and T614 normal RXCP Bearing Temperatures T125 and T132 normal

Op-Test No: 2002.	301	Scenario No:		Event No: <u>6,7</u>	Page <u>4</u> of <u>9</u>
Event Description:	Tube leak on S/C the main turbine	G 'A' increases to to auto-trip.) ruptı	ire following reactor	trip with a failure of
Time/Notes	Position		Appl	icant's Actions or Bel	navior

. .

	RO	Check RCS temperatures:
		• RCS Average Temperature will be lowering due to SI injection flow and Auxiliary Feedwater flow.
	BOP	Due to lowering RCS temperature, the following actions are required:
		 Stop dumping steam. Place the Turbine Driven AFW Pump control switch in pullout since Motor Driven AFW Pump 'A' is running. If S/G levels are > 4% (15% adverse), then AFW flow should be reduced. MSWs and MSW Pumper Values may be also a bit and bit.
		• MSIV's and MSIV Bypass valves may be closed if cooldown continues
	RO	Check Pressurizer PORVs and Spray Valves closed:
		 Both PORVs closed. Normal Pressurizer Spray valves closed. CVC-15 Aux Spray Valve closed.
	RO	Check if RXCPs should be tripped:
		• RXCPs should not require tripping.
5	BOP	Check if Steam Generators are faulted:
		• There are no indications of any faulted Steam Generators. S/G pressures may be lowering but should be consistent with RCS temperatures.
	CREW	Check that Steam Generator tubes are NOT ruptured.
		 Multiple indications of S/G tube leakage is available. 1. Air Ejector Exhaust Radiation Monitor R-15. 2. 'A' Main Steamline Radiation Monitor R-31 3. S/G 'A' level rising in an uncontrolled manner.

Op-Test No: _2002	301	_ Scenario No: _2 Event No: _6,7 Page _5 of _9
Event Description:	Tube leak on S/G the main turbine	'A' increases to rupture following reactor trip with a failure of to auto-trip.
Time/Notes	Position	Applicant's Actions or Behavior

. .

CRS RO	 Based on indications of a S/G tube leak, transition is made to E-3, Steam Generator Tube Rupture. Critical Safety Function Status Trees Should be evaluated. Direct actions of E-3. Check if RXCPs should be tripped: SI flow indicated on FI-925 RCS subcooling based on CETs < 15 °F
	RXCPS should NOT require tripping.
 CREW	 Identify ruptured SG: Unexpected rise in level High radiation on any steamline monitor for S/G A [R-31] or S/G B [R-33] on SPDS Radiation levels above background indicated on hand-held monitor on S/G Blowdown Ion Exchange Resin Column Increase in S/G Blowdown cation Conductivity on secondary analytical panel recorder 61438 High radiation on R-19 when S/Gs aligned for sampling per Attachment A Identify/report S/G A as the ruptured generator.
CREW	 Determine one S/G must remain available: Required for steam supply to T/D AFW Pump Required for cooldown Determine S/G B is available for RCS cooldown.

Op-Test No: _2002	301	Scenario No:	Event No: <u>6,7</u>	Page <u>6</u> of <u>9</u>
Event Description:	Tube leak on S/C the main turbine	G 'A' increases to rupt to auto-trip.	ure following react	or trip with a failure of
Time/Notes	Position	Appl	icant's Actions or B	ehavior

••

ſ

ſ

NOTE: The follo	owing step for isolation of S/G 'A' is a critical task.
BOP	Isolate the faulted Steam Generator (SG A):
	 Verify BT-2A and BT3A, SG A Blowdown Isolation Valves, are closed. Set SD-3A, SG A PORV controller at 1050 psig. Verify SD-3A, SG A PORV, is closed when SG A pressure is < 1050 psig. Close MS-100A, SG A Steam Supply to T/D AFW Pump. Direct operator to locally close Main Steam Header A, Trap 20 inlet and outlet valves TD-1-20 and TD-3-20. Close SG A MSIV MS-1A and MSIV Bypass Valve MS-2A.
ВОР	Check ruptured S/G level (SG A):
	• Narrow Range (NR) level > 4%.
	• If not, then maintain feed now to S/G A until NK level is $> 4\%$, then stop feed.
	 Feed to SG A is stopped by closing BOTH of the following valves: 1. AFW Pump 2A Flow Control Valve, AFW-2A 2. AFW Train A Crossover Valve, AFW-10A 3.
	• To continue to provide AFW flow to SG B (the intact SG), the Turbine Driven AFW Pump will have to be re-started.
BOP	Check S/G A pressure > 200 psig
RO	Reset SI by depressing both SI RESET pushbuttons.
CREW	Initiate RCS Cooldown:
	• Determine required CET temperature based on S/G A pressure.
	S/G A pressure psig Reg CET temp °F

Op-Test No: 2002	301	Scenario No:	Event No: <u>6,7</u>	Page <u>7</u> of <u>9</u>
Event Description:	Tube leak on S/O the main turbing	G 'A' increases to rupt e to auto-trip.	ure following reacto	r trip with a failure of
Time/Notes	Position	App	icant's Actions or Be	havior
			1944	

. •

Ï

BOP	 Dump steam from S/G B: Select STM PRESS on Main Steam Dump Mode Selector C/S Dump steam at maximum rate. When RCS temperature reaches 540 °F, place Steam Dump Interlock Selector C/Ss to BYPASS INTLK.
	When the required target CET temperature is reached, then the cooldown is stopped and CET temperature maintained less than the required target temperature.
CRS	Continues with actions of E-3 with cooldown in progress.
BOP	 Check intact SG Levels (SG B): Feed flow is controlled to maintain level 4%-50%. At least 200 gpm must be maintained to SG B until level is > 4%.
RO	 Check Pressurizer PORVs and PORV Block Valves Both Pressurizer PORVS should be shut and both Block Valves open.
RO	Isolate Letdown: Control switches for LD-4A, 4B, and 4C Letdown Orifice Isolation Valves placed in CLOSE.
RO	Reset SI by depressing both SI RESET pushbuttons.
RO	Reset CI by depressing both CI RESET pushbuttons.
BOP	 Verify Instrument Air to Containment established: At least one Air Compressor running. Air header pressure >60 psig. Instrument Air to Containment Isolation IA-101 open.

Op-Test No: _2002	301	Scenario No:	Event No: _6,7	Page <u>8</u> of <u>9</u>
Event Description:	Tube leak on S/C the main turbine	G 'A' increases to rupti to auto-trip.	ire following reactor	trip with a failure of
Time/Notes	Position	Appl	icant's Actions or Beh	avior

. .

RO	Check if RHR pumps should be stopped.
	• Based on RCS pressure, RHR Pump B should be stopped and placed in Auto. (RHR Pump A is tagged out)
RO	Establish Charging Flow.
	• Two Charging Pumps should be started and flow maximized. NOTE: This will require aligning Charging to the RWST.
RO	Check if RCS cooldown should be stopped:
	• At this point, the crew must wait until CETs are < required target temperature. Further steps in E-3 CANNOT be performed until this occurs.
BOP	Check ruptured Steam Generator pressure stable or increasing.
	• SG A pressure should be relatively stable (Note: SG pressures lowering due to the cooldown are considered stable).
RO	Check RCS subcooling based on CETs > 50 °F.
	Adequate subcooling should be available.
RO	Depressurize the RCS to minimize break flow and refill the pressurizer:
	 Pressurizer heaters manually controlled to maintain saturation conditions. BOTH spray valves fully opened until ONE of the following conditions satisfied, then close the spray valves: Pressurizer level > 74%. RCS subcooling < 30 °F. RCS pressure < Ruptured SG pressure AND pressurizer level > 5%.

Op-Test No: _2002	301	Scenario No:	Event No: <u>6,7</u>	Page <u>9</u> of <u>9</u>
Event Description:	Tube leak on S/0 the main turbine	G 'A' increases to rupt e to auto-trip.	ure following reacto	or trip with a failure of
Time/Notes	Position	Appl	icant's Actions or B	ehavior

53

ſ

NOTE: The following step for S	SI termination is a critical task. SI termination is required PRIOR to SG A Wide Range Level going off-scale high.
CREW	 Check if SI flow should be terminated: RCS subcooling based on CETs > 30°F RCS pressure stable or increasing. Przr level > 5%. Secondary heat sink: Total feed flow to S/Gs > 200 gpm available OR NR level in S/G B > 4% Above conditions should be met and BOTH SI pumps stopped and placed in Auto at this time.
NOTE: At the discretion o	f the Lead Examiner, the scenario may be terminated at this point.

	x D		Scenario Outline	Form ES-D-1
Facility	: KNPP	<u></u>	Scenario No.: <u>3</u>	OP-Test No.: 2002301
Examine	rs:		Operators:	
Initial C days ago A norma	onditions: due to failu l shift comp	The plant is are of the 'A' plement is av	at 20% power, BOC, with a startup in progress Main Feedwater Regulating Valve. Today is a ailable.	s. The plant tripped from 100% power Sunday, present clock time is real time
Turnove	r: The follo	owing equipr	nent is inoperable and has been properly remo	ved from service:
 'A' l durin 'B' l 	Residual He ng a schedu Motor Drive	eat Removal led surveillar e Auxiliary F	Pump – tagged out 36 hours ago due to high bonce run. A maintenance crew is on-site and wo reedwater Pump – tagged out last shift due to in	earing temperatures and vibration rking to repair the pump. ndications of a significant amount of
wate	r in the lub	e on. A tube	on cooler leak is suspected. Maintenance has t	been noumed.
wate LT-4 repla The goal 	f in the lub 72 'B' S/G acement is b for the shif	Water Leve being develop	l Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required).
wate LT-4 repla The goal Event	F in the lub 72 'B' S/G acement is b for the shif Malf.	Water Leve being develop t is to continu Event	l Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required).
wate LT-4 repla <u>The goal</u> Event No.	F In the lub F72 'B' S/G acement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type*	l Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required).
wate • LT-4 repla <u>The goal</u> Event No. 1	F In the lub 72 'B' S/G accement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP	I Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02.	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required).
wate • LT-4 repla <u>The goal</u> Event No. 1	F In the lub 72 'B' S/G acement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO	I Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02.	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required).
wate • LT-4 repla <u>The goal</u> <u>Event</u> <u>No.</u> 1 2	F In the lub F72 'B' S/G accement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP	l Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT	Seen notified. hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required). t ion T-468 fails high.
wate • LT-4 repla The goal Event No. 1 2 3	Ar in the lub Ar2 'B' S/G accement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP SRO	l Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT VCT level transmitter LT-141 fails high (div	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required). t ion
wate • LT-4 repla <u>The goal</u> <u>Event</u> No. 1 2 3	F In the lub F72 'B' S/G for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP SRO I - RO SRO I - RO SRO	I Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT VCT level transmitter LT-141 fails high (div	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required). t ion
wate • LT-4 repla <u>The goal</u> <u>Event</u> <u>No.</u> 1 2 3 4	for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP SRO I - RO SRO I - RO SRO I - RO	I Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT VCT level transmitter LT-141 fails high (div S/G 'B' level transmitter LT-473 fails low (a	Seen notified. nitter failure. A plan for transmitter nis channel from service. SP-54-064 is NOT required). t ion '-468 fails high. ert). nuto trip should occur, but does not).
wate • LT-4 repla <u>The goal</u> <u>Event</u> No. 1 2 3 4	Ar in the lub The for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP SRO I - RO SRO I - RO SRO I - RO	l Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT VCT level transmitter LT-141 fails high (div S/G 'B' level transmitter LT-473 fails low (a	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required). is ion
wate • LT-4 repla <u>The goal</u> <u>Event</u> <u>No.</u> 1 2 3 4 5	F In the lub F72 'B' S/G accement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP SRO I - RO SRO I - RO SRO I - RO SRO C - ALL	I Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT VCT level transmitter LT-141 fails high (div S/G 'B' level transmitter LT-473 fails low (a Both Reactor Trip Breakers fail to open.	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required). t ion -468 fails high. ert). uto trip should occur, but does not).
wate • LT-4 repla <u>The goal</u> <u>Event</u> No. 1 2 3 4 5 6	Ar in the lube Ar2 'B' S/G accement is b for the shif Malf. No.	Water Leve being develop t is to continu Event Type* R - RO N - BOP SRO I - BOP SRO I - BOP SRO I - RO SRO I - RO SRO I - RO SRO C - ALL M - ALL	I Channel – tagged out due to suspected transn bed. A-MI-87 has been completed to remove th ue with plant startup per N-0-02 at step 4.34 (S Event Descript Perform a power increase per N-0-02. Steam Generator 'A' Pressure transmitter PT VCT level transmitter LT-141 fails high (div S/G 'B' level transmitter LT-473 fails low (a Both Reactor Trip Breakers fail to open. S/G 'B' fault occurs inside containment.	hitter failure. A plan for transmitter his channel from service. SP-54-064 is NOT required). in ion

s. .

NUREG-1021, Revision 8, Supplement 1

Revision 0 DRAFT

DYNAMIC EXAM SCENARIO ID#: SES-2002301: #3

SIMULATOR SHIFT TURNOVER:

а. — Э.

Per Scenario Outline.

SIMULATOR SCENARIO SET UP

STEP COUNTERS ON	
INIT into IC	
NTP-6410, Communicator Telephone Log, available	
NTP 6411, Simulator Setup Checklist, completed	
NTP-6412, Simulator Book Preparation Checklist, completed	
NTP-4 Attachment 10, Simulator Scenario Briefing Sheet, completed	
NTP-4, Attachment 13, KNPP Simulator Security Checklist, completed	

SCENARIO GUIDE:

4

÷

- 1. Initialize to a 20% Power IC or saved specific SES IC.
- 2. Place RHR Pump A control switch in pullout and place a Hold Card on the switch.
- 3. Place AFW Pump B control switch in pullout and place a Hold Card on the switch.
- 4. Place an "Out of Service" sticker on S/G B Level Indicator LI-472.
- 5. Preload (or verify preloaded) and verify active the following simulator codes:

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER
Preload	Malfunction	SER0966, Beta Annunciator Driver Override				Block	
Preload	Annunciator	47034-O, SER1670 Source Range High Flux at Shutdown Alarm Blocked				Block	
Preload	Malfunction	RD11, Reactor Trip Breakers fail to open on trip signal.					
Preload	Malfunction	FW16A, Failure to Auto Start, AFW Pump 1A					
Preload	Malfunction	FW20C, AFW Pump Suction Strainer Plugged (Turb)				100	
Preload	Meter	MCA, AO-41052-02, LI-472				0	
Preload	Remote Function	RP191, 472A, Lo/Lo Level Logic				TRIP	
Preload	Remote Function	RP192, 472B, Hi Level Logic				TRIP	

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

Preload Table is continued on the next page.

4

÷

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER
Preload	Remote Function	RP193, 472C, Lo Level Logic				TRIP	
Preload	Annunciator	47065-F, SER0812, AMSAC in Test				Crywolf	-
Preload	Lights	MVB, DO-47033:0401, TLA- 16 AMSAC Channel Abnormal				ON	

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

;

.

Use the Instructor Summary Station to verify the simulator codes in the table below are assigned to the appropriate Trigger with the appropriate value(s).

These events will be input as shown in the guidance following the table.

TIME	TYPE	DESCRIPTION	RAMP START VALUE	RAMP TIME	DELAY TIME	VALUE*	TRIGGER**
Event 2	System Override	RX213, PT-468, MS SG Press	As found			1400	1
Event 2 – (A-MI-87)	Remote Function	RP185, 468A, Lo/Lo SAL				TRIP	2
Event 2 – (A-MI-87)	Remote Function	RP186, 468B, Lo Press			20	TRIP	2
Event 2 – (A-MI-87)	Remote Function	RP182, 466C, FWF <sf< td=""><td></td><td></td><td>40</td><td>TRIP</td><td>2</td></sf<>			40	TRIP	2
Event 2 – (A-MI-87)	Remote Function	RP181, 466B, FWF>SF			60	TRIP	2
Event 3	System Override	CV203, LT-141, VCT LVL	As found			100	3
Event 4	System Override	RX212, LT-473, SG LVL	As found		 '	0	4
Event 5-7	Malfunction	MS02B, Main Steam Line Rupture Inside Containment (1B)				4	5
Event 5-7	Remote Function	RD102, MG Set 1A				STOP	6
Event 5-7	Remote Function	RD103, MG Set 1B			60	STOP	6

* The input under the "VALUE" column includes Severity Value, Analog Value, Digital Value, Remote Value, and Malfunction Value inputs as appropriate for each action.

** See following page for specific guidance on Trigger activation.

Simulator Operator Guidance:

1

- Trigger 1 Activate when requested by Lead Examiner to fail PT-468 high.
- Trigger 2 Activate to trip all bistables associated with PT-468 per A-MI-87 (I&C) Note: All bistables will trip in procedure sequence in 20 sec. intervals.
- Trigger 3 Activate when requested by Lead Examiner to fail LT-141 high.
- Trigger 4 Activate when requested by Lead Examiner to fail LT-473 low. (Meets Rx trip criteria, however, Rx does not trip).
- Trigger 5 Activate to initiate steam leak when BOP operator is de-energizing Bus 33 and 43 supply breakers.
- Trigger 6 NOTE: When requested by the control room, remove Malfunction RD11, RX Trip Breakers Fail To Open On Trip Signal, PRIOR to activating Trigger 6. Activate Trigger 6 when requested by the control room to position the Rod Drive MG Set Control Switches to trip.

ANTICIPATED BOOTH COMMUNICATION/GUIDANCE:

Event 1: This event is a normal up-power. The field operators should be informed of the power escalation, with an acknowledgement by the communicator.

Event 2: This event is a failure of Steam Generator A Pressure Transmitter PT-468 (fails high). This failure will cause the Main Feedwater Regulating valve to open, and also the SG PORV to open. This will require the operator to take manual control of the Main Feedwater Regulating Valve and also the SG PORV. If the PORV is not closed expeditiously, the resulting temperature swings will necessitate placing Rod Control in Manual to stabilize RCS temperature. After stabilizing the plant, A-MI-87 will be utilized to remove the channel from service. The CRS will request SP 47-316A to check redundant channel bistables. The communicator should inform the CRS that SP 47-316A is complete and no redundant channel bistables were found tripped. I&C will also be requested to trip the bistables associated with the pressure channel. The paperwork (A-MI-87) should be obtained from the CRS and the bistables tripped per this simulator guide. After tripping the bistables, the A-MI-87 paperwork should be signed off as appropriate and returned to the control room.

Event 3: This event is a failure of VCT Level Transmitter LT-141 (high). This will cause letdown to divert to the hold-up tanks, effectively resulting in an RCS leak. Implementation of A-CVC-35C is required and manual control of LD-27 is necessary.

;

Event 4-7: This event begins with a failure of SG B level transmitter LT-473. This will result in the crew manually tripping the reactor since an automatic trip should have occurred but did not. A manual trip is not successful and it will be necessary to de-energize Bus 33 and 43 to trip the reactor. Entry to FR-S.1 is NOT required. A field operator will be requested to locally open the RTBs and locally position the MG set switches (see Trigger 6 directions). Completion of this activity should be reported back to the control room. A manual turbine trip is also required due to the RPS failure. While de-energizing Bus 33 and 43, a fault will develop on SG A inside containment. Motor Driven AFW Pump B will fail to auto start and will need to be manually started. The Turbine Driven AFW pump will start but will not run due to a plugged suction line. If requested to investigate the Turbine AFW pump, report back that everything appears normal.

Time/Notes	Position	App	plicant's Actions or 1	Behavior
 Event Description:	Perform Normal	Up-Power (Reactivit	y Manipulation).	
Op-Test No: 2002301		Scenario No:	Event No: 1	Page <u>1</u> of <u>2</u>

: •

Γ

ſ

CRS	Brief crew on evolution, including discussion of N-0-02 (Plant Startup From Hot Shutdown To 35% Power) precautions and limitations, for
 	commencing up-power.
 CRS	Implement actions of N-0-02.
 RO	Perform reactivity estimate based on planned load increase.
CRS	Direct increase to 35% power (first hold point for MSR and air ejector alignment).
BOP	 Increase load per N-TB-54: Review applicable Precautions & Limitations. Determine maximum loading rate based on fuel performance is 5% per minute when < 35% power (NOTE: Based on turnover information, the ramp rate will lower to 16 MW/hr at 35%). Determine maximum load rate based on turbine operating limits per Figures 2 & 3. Adjust turbine controls to clear Valve Position Limiter: Lower the setter to ≤ value stated on EH Panel Plaque. Set loading rate to ≤ 5% per minute. Depress GO pushbutton. When VPL light goes out, push the HOLD pushbutton. Verify/set Valve Position Limit to 100%. Set setter to desired load. Verify/set loading rate to 0.25% per min (minimum loading rate of 0.25% per min is normal plant practice). Verify loading rate is less than maximum allowable rate. Inform Energy Supply & Control of rate and amount of load pickup. Depress GO. Verify load increases.

Op-Test No: 20023	01	Scenario No: 3	Event No: 1	Page <u>2</u> of <u>2</u>
Event Description:	Perform Normal	Up-Power (Reactivity	Manipulation).	
Time/Notes	Position	Appl	icant's Actions or B	ehavior

;

.

RO	Perform reactivity adjustments:
	Rod Control (rod motion at 1.5 °F difference Tave-Tref)
	AND/OR
	 Boron Concentration Control (initiate dilution) per N-CV-35A: Review applicable Precautions & Limitations Verify at least one RXCP in operation Determine rate and magnitude of dilution Position Reactor Makeup Mode Selector to DILUTE or ALT DIL. Adjust MU-1022/CV-31095, Blender Control Rx Mu Flow, to required flow rate Set Rx Make-up Totalizer to required quantity Position Reactor Makeup Control switch to START Verify required change has been achieved by monitoring: Rod Position Boron Concentration
	 When dilution is complete: Position Reactor Makeup Mode Selector to AUTO Position Reactor Makeup Control switch to START Adjust CVC-403/CV-31092, Blender Control BA Flow, to current RCS boron concentration If RCS boron concentration has been changed by >50 ppm, operate Przr heaters as necessary to equalize RCS and Przr boron.
BOP	Adjust Heater Drain Pump speed as required to maintain equal loading on
 DOI	pumps.

Once power has been raised 5% and/or at the discretion of the Lead Examiner, proceed to the next event (Event #2).

Op-Test No: 2002301	L	Scenario No: <u>3</u> Event No: <u>2</u> Page <u>1</u> of <u>3</u>
Event Description: S tr	team Generat ansient and S	tor 'A' pressure transmitter fails high causing main feedwater S/G PORV to open.
Time/Notes	Position	Applicant's Actions or Behavior
	BOP	 Identify/report failed S/G A pressure channel PT-468. Available indications: Annunciator "S/G A Program Level Deviation" (47062-A). Annunciator "S/G A Bypass CV Level Deviation" (47062-B). Annunciator "S/G A Level High", (47064-B). Pressure indicator PI-468 is failed high.
	BOP	 Refer to above annunciator response procedures. Place FW-7A, S/G 'A' Main FW Flow Control Valve to Manual and adjust to restore level to 44%. Close S/G 'A' PORV by placing its controller in Manual and minimum.
	CRS	Direct power ramp be placed on hold. NOTE: Depending on the length of time the PORV remains open, it may be necessary to place Rod Control in Manual is order to stabilize the plant.
	CRS	Implement A-MI-87 "Bistable Tripping for Failed Reactor Protection or Safeguards Inst.", to remove PT-468 from service – bistable tripping must be performed within 6 hours per A-MI-87. NOTE: A-FW-05A, Abnormal Feedwater System Operation, may be referenced but no additional actions are required by this procedure.
	CRS	 Direct actions to remove PT-468 from service: Direct I&C to perform SP 47-316A to check redundant channel bistable contacts for PT-468 removal from service. (NOTE: Communicator will inform Control Room that SP 47-316A is complete.)

; •

Op-Test No: 2002301		Scenario No: <u>3</u> Event No: <u>2</u> Page <u>2</u> of <u>3</u>
Event Description:	Steam Generato transient and S/4	r 'A' pressure transmitter fails high causing main feedwater G PORV to open.
Time/Notes	Position	Applicant's Actions or Behavior
	······································	

÷

.

BOP	 Perform/verify prerequisite lineup of "Removal From Service". Position Steam Flow Channel Selector switch for S/G A to 465/White. Verify SD-3A, S/G A PORV, is in Manual. NOTE: FW Flow selector switch for S/G A may also be positioned to 467/White
CRS	Direct I&C to enter Relay Rack RR-109 and trip associated bistables for PT-468.

NOTE: Simulator Booth Operator will obtain A-MI-87 paperwork from CRS/BOP and perform the bistable tripping when directed. When complete, the applicable pages and steps of A-MI-87 will be returned to the CRS/BOP.

BOP	Complete verification steps of A-MI-87 following histable tripping				
	• Ensure the following annunciators/status lights are ON:				
	1. Annunciator "Steam Gen Pressure Low" (47064-I)				
	2. Annunciator "Steam Gen A Low Low Press SI Alert (47061-I)				
	3. Annunciator "S/G A Feed Flow Excessive" (47061-C)				
	4. Annunciator "S/G A SF .> FF" (47061-B)				
	5. Status Light "MS Hdr A Low-Low Press" (44908-0701)				
	6. Status Light "S/G A SF . FF" (44907-0901)				

Op-Test No: _2002	301	Scenario No: <u>3</u> Event No: <u>2</u> Page <u>3</u> of <u>3</u>
Event Description:	Steam Generator transient and S/C	'A' pressure transmitter fails high causing main feedwater PORV to open.
Time/Notes	Position	Applicant's Actions or Behavior

: •

····	r*	
	CRS	Review Technical Specification 3.5.b & c:
		 Table 3.5-2: 1. No. 16 - Steam Flow/Feedwater Flow Mismatch. 2. Determines continued operation acceptable (1 channel/loop required OPERABLE)
		 Table 3.5-3: 1. No. 1.c – Low Steam Pressure/Line 2. Determine continued operation acceptable (2 channels/line required OPERABLE)
		NOTE: Due to tripping of SF/FF bistable, a Reactor Trip would occur if level lowered to 25% (low level) instead of the normal low-low level trip of 17%.
	CRS	Direct FW-7A, S/G 'A' Main FW Flow Control Valve, be returned to Auto.
	BOP	Place FW-7A, S/G 'A' Main FW Flow Control Valve, to Auto.
		Note: N-FW-05A, Feedwater System Normal Operation, may be referenced for guidance.
	CRS	Inform I&C to investigate Steam Generator pressure channel PT-468 failure/status.
At the disc	cretion of the	Lead Examiner, proceed to the next event (Event #3).

Op-Test No: _20023	801	Scenario No: <u>3</u> Event No: <u>3</u> Page <u>1</u> of <u>2</u>				
Event Description:	Volume Contro	ol Tank (VCT) level transmitter LT-141 fails high causing letdown				
	to divert to hol	ldup tank.				
Time/Notes	Position	Applicant's Actions or Behavior				
						
	RO	Available indications:				
		• Level Indicator LI-141 failed high				
		 Annunciator "VCT Level High/Low" (47043-L) 				
	RO	Refer to above annunciator response procedures, inform CRS of required actions (GO TO A-CVC-35C).				
	CRS	Implement A-CVC-35C, Abnormal VCT Level.				
	RO/CRS	Check at least one VCT level channel operable (Continuous Action Step).				
		VCT level channel LI-112 determined to be operable based on plant conditions.				
	RO	Check at least one operable VCT level channel > 5% (Continuous Action Step).				
		• LI-112 is operable and will indicate actual VCT level which is > 5%.				
		NOTE: The crew should realize that the automatic swap of charging pump suction to the RWST when VCT level is < 5% will NOT occur with LT-141 failed high.				
	RO	Check VCT level channel LI-112 operable – it is operable.				
	RO	Check VCT level channel LI-141 operable – it is NOT operable.				
		• Position LD-27, VCT/Holdup Tank Divert Valve, control switch to V.C.Tk.				
		• Manually control LD-27 as necessary to maintain VCT level < 56%.				
	RO Check actual VCT level $\geq 17\%$.					
		• If < 17%, proper Reactor Make-up operation is verified.				

; ;

Op-Test No:2002	2301	_ Scenario No: <u>3</u> Event No: <u>3</u> Page <u>2</u> of <u>2</u>
Event Description:	Volume Control to divert to hold	Fank (VCT) level transmitter LT-141 fails high causing letdown p tank.
Time/Notes	Position	Applicant's Actions or Behavior

; •

Γ

	RO	Check actual VCT level < 28%.
		• If ≥ 28%, automatic Reactor Make-up is stopped.
		• Charging Pump speed adjusted as desired to maintain pressurizer level.
	RO	Check actual VCT level < 56%.
		 If ≥ 56%, Reactor Make-up is secured, LD-27 is used to divert to the CVC Holdup Tank.
	RO	Check Reactor Make-up control functioning normally.
		• Proper make-up control is unaffected by failure of LT-141.
	CRS	Return to procedure and step in effect (N-0-02).
At the dise	cretion of the	Lead Examiner, proceed to the next event (Event #4).

.

Op-Test No: 2002301

;

Scenario No: 3 Event No: 4-7

Page 1 of 6

Event Description: S/G 'B' level channel LT-473 fails low which should cause an auto trip, but does not. A manual trip is also unsuccessful leading to ATWS conditions with full control rod insertion accomplished by de-energizing the rod drive MG sets. A fault on S/G 'B' also occurs upon manual tripping of the turbine and the 'A' Motor Driven AFW Pump fails to start.

Time/Notes	Position	Applicant's Actions or Behavior

BOP	Identify failed level channel as S/G B level transmitter LT-473. Available indications:
	• LI-473 failing low.
RO/CRS	Identify an automatic reactor trip should have occurred but did not.
	• Annunciator "S/G B Low Low Level Reactor Trip" (47031-F)
CRS	Directs a manual reactor trip and enters E-0, Reactor Trip or Safety Injection.
RO	Manual Reactor Trip initiated – the reactor does NOT trip.
BOP	Manual Reactor Trip initiated using second Reactor Trip pushbutton – the reactor does NOT trip.

NOTE: Insertion of negative reactivity via EITHER of the following two steps is a critical task.

RO	Manually inserts control rods.
BOP	Opens Bus 33 and 43 supply breakers to de-energize the rod drive MG sets – this action results in all control rods inserting.
RO/BOP	Operator dispatched to locally open the reactor trip breakers and locally position the rod drive MG set motor and generator switches to trip.
ВОР	When the reactor trip breakers and the MG set breakers are open, then Bus 33 and Bus 43 are re-energized (supply breakers closed).

Op-Test No: _2002	301	Scenario No:	3 Event No:		Page 2	of <u>6</u>
Event Description:	S/G 'B' level cha not. A manual th rod insertion act 'B' also occurs u Pump fails to sta	annel LT-473 fails rip is also unsucce complished by de- ipon manual tripp art.	low which shoul ssful leading to A energizing the ro bing of the turbin	d cause an au ATWS conditi od drive MG s e and the 'A'	ito trip, b ions with sets. A fai ' Motor D	ut does full control ılt on S/G riven AFW
Time/Notes	Position		Applicant's Acti	ons or Behavi	ior	

\$

~

NOTE: S/G 'B' Fa	ult inside	containment will be initiated upon manual trip of the turbine.
BO	OP	Verify turbine trip.
		• A manual turbine trip is required due to the RPS failure – a manual trip will be successful.
		Verify power to Emergency AC Buses
		• Bus 5 energized
		• Bus 6 energized
RO	С	Determine if SI needed/actuated:
		• SI will be actuated due to the steam leak in containment.
		1. Annunciator 47021-A "SI TRAIN A ACTUATED lit"
		2. Annunciator 47021-B "SI TRAIN B ACTUATED lit"
BC	OP	Verify Feedwater Isolation:
		• FW-7A and FW-7B Main FW Flow Control Valves closed.
		• FW-10A and FW-10B Main FW Bypass Flow Control Valves closed.
		 FW-12A and FW-12B, Feedwater to SG A/B Isolation Valves closed. Both Feedwater Pumps off.
BC	OP	Make plant announcement for Safety Injection.
BC	OP	Check Main Steamline Isolation:
		 Main Steamline isolation is required due to high containment pressure – MSIVs and MSIV Bypass Valves should be verified shut.

Op-Test No: _2002	301	Scenario No:	3	Event No:	4-7	Page <u>3</u> of <u>6</u>
Event Description:	S/G 'B' level ch not. A manual t rod insertion ac 'B' also occurs u Pump fails to st	annel LT-473 fail rip is also unsucc complished by de 1pon manual trip art.	s low essfu -ener ping	which should l leading to A gizing the ro of the turbind	d cause TWS c d drive e and th	an auto trip, but does onditions with full control MG sets. A fault on S/G he 'A' Motor Driven AFW
Time/Notes	Position		Ap	plicant's Acti	ons or E	ehavior

•

Ω····································		
	RO/BOP	Verify Containment Spray NOT required:
		• Containment Spray is required due to high containment pressure and will be functioning normally.
		NOTE: Depending on crew timing, Containment Pressure may not quite be at the initiation setpoint of 23 psig. Also, CS may be manually initiated at this time due to approaching 23 psig.
	BOP	Verify Containment Cooling:
		 Fan Coil Units running. Verify SW-903A-D CFCU SW Return Isolation valves open. Verify RBV 150A D CFCU Framework Description ODEN.
		• Venity RBV-150A-D CFCU Emergency Dampers OPEN.
	BOP	Verify Aux Bldg Special Vent running:
		 Annunciator 47052-G "ZONE SV BNDRY DAMPER NOT CLOSED" not lit. Verify Zone SV fans running.
	BOP	Verify Service Water Alignment
		 Verify all Service Water Pumps (A1, A2, B1, B2) running. Verify SW Header selected on Turbine Bldg selector switch is > 82.5 psig.
	BOP	Verify AFW Pumps running:
		• Verify Motor Driven AFW Pump 'A' is running ('B' AFW Pump is tagged out) – AFW Pump 'A' will not be running at this time and will be required to be started manually. The Turbine Driven AFW Pump will start but will trip on low discharge pressure (debris in suction line).
······································	RO	Verify Containment and Containment Ventilation Isolation:
		• Verify all CI Active Status Panel Lights lit.

Op-Test No: _2002	301	Scenario No: _3 Event No: _4-7 Page _4 of _6
Event Description:	S/G 'B' level ch not. A manual t rod insertion ac 'B' also occurs u Pump fails to st	annel LT-473 fails low which should cause an auto trip, but does rip is also unsuccessful leading to ATWS conditions with full control complished by de-energizing the rod drive MG sets. A fault on S/G upon manual tripping of the turbine and the 'A' Motor Driven AFW art.
Time/Notes	Position	Applicant's Actions or Behavior

ĩ.

٠

ſ

	RO	Verify ESF Equipment running:
		 SI pumps - both should be running. RHR pumps - RHR Pump 'B' is running normally, RHR Pump 'A' is tagged out. CC Pumps - both should be running, one should be stopped and placed in pullout. SI Active Status Panel - all lights will be lit with the exception of the previously tagged out equipment.
	RO	Verify SI flow:
		 SI flow verified on F925 if RCS pressure is < 2100 psig. RHR flow will not be checked due to RCS pressure > 150 psig.
	BOP	Verify total AFW flow > 200 gpm.
		• Adequate AFW flow is available
	RO	Check RXCP Seal Cooling:
		 CC Supply for Thermal Barrier Isolation Valves CC-600, CC-601A(B), CC-610A(B) and CC-612A(B) open Thermal Barrier temperatures T610 and T614 normal RXCP Bearing Temperatures T125 and T132 normal
	RO	Check RCS temperatures:
e de la companya de l La companya de la comp		• RCS Average Temperature will be lowering due to the faulted S/G.
	BOP	Due to lowering RCS temperature, the following actions are required:
		 Stop dumping steam. Place the Turbine Driven AFW Pump control switch in pullout since Motor Driven AFW Pump 'A' is running. If the 'A' S/G level is > 4% (15% adverse), then AFW flow should be reduced. AFW flow should be isolated to the 'B' S/G at this time. MSIVs and MSIV Bypass valves should be verified shut.

Op-Test No: _2002	301	Scenario No: <u>3</u> Event No: <u>4-7</u> Page <u>5</u> of <u>6</u>
Event Description:	S/G 'B' level channot. A manual t rod insertion ac 'B' also occurs u Pump fails to sta	nnel LT-473 fails low which should cause an auto trip, but does rip is also unsuccessful leading to ATWS conditions with full control complished by de-energizing the rod drive MG sets. A fault on S/G upon manual tripping of the turbine and the 'A' Motor Driven AFW art.
Time/Notes	Position	Applicant's Actions or Behavior

\$

ſ

	RO	Check Pressurizer PORVs and Spray Valves closed:
		• Both PORVs closed.
		Normal Pressurizer Spray valves closed.
		• CVC-15 Aux Spray Valve closed.
	RO	Check if RXCPs should be tripped:
an an Albert State and Albert		• RXCP trip criteria is NOT met.
E		NOTE: RXCP 'B' may require tripping during this event due to elevated Motor Stator Temperatures (locally elevated Containment temperature).
	BOP	Check if Steam Generators are faulted:
		• S/G 'B' determined to be faulted due to pressure lowering in an uncontrolled manner.
	CRS	Transition made to E-2, Faulted Steam Generator Isolation.
	BOP	Verify Main Steamline Isolation
		• Main Steamline isolation is required due to high containment pressure – MSIVs and MSIV Bypass Valves should be verified shut.
	BOP	Check if any steam generator is NOT faulted
		• S/G 'A' should be determined to be intact and available for cooldown.
	BOP	Identify the faulted S/G.
		• Based on lowering pressure, S/G 'B' is identified as being faulted.

Op-Test No: _2002.	301	_ Scenario No: <u>3</u> Event No: <u>4-7</u> Page <u>6</u> of <u>6</u>
Event Description:	S/G 'B' level cha not. A manual ta rod insertion ac 'B' also occurs u Pump fails to sta	nnel LT-473 fails low which should cause an auto trip, but does ip is also unsuccessful leading to ATWS conditions with full control omplished by de-energizing the rod drive MG sets. A fault on S/G pon manual tripping of the turbine and the 'A' Motor Driven AFW rt.
Time/Notes	Position	Applicant's Actions or Behavior

BOP	Isolate the faulted Steam Generator (S/G 'B'):
	• Verify BT-2B and BT3B, SG B Blowdown Isolation Valves, are closed.
	• Verify SD-3B, SG B PORV, is closed.
	Close AFW-2B, AFWP B Flow Control Valve.
	Close MS-100B, SG B Steam Supply to T/D AFW Pump.
	• Verify BT-31B and BT-32B, SG B Sample Isolation Valves, are closed.
	Close FW-12B, SG B Feedwater Isolation Valve.
 	Close AFW-10B, AFW Train B Crossover Valve.
BOP	Check CST level > 4%.
	• Adequate CST level is available.
RO/BOP	Check secondary radiation normal.
	There are no indications of increasing radiation levels on any secondary systems.
BOP	Set steam dump to minimize heatup.
	• Intact SG MSIV (A) is shut – condenser is NOT available.
	• SG A PORV must be used but CANNOT be placed in auto due to the previous PT-468 failure. SG A PORV should be operated in manual to stabilize RCS temperature.
 CRS	Transition to E-1, Loss of Reactor or Secondary Coolant.