



P.O. Box 4, Route 168
Shippingport, PA 15077

November 26, 2002

DMR Clerk
Department of Environmental Protection
Bureau of Water Quality Management
400 Waterfront Drive
Pittsburgh, PA 15222

NPDES Permit PA0025615, Notice of Non-Compliance
Outfall 211

Dear Sir or Madam:

During the month of October, Outfall 211 (Oil/Water Separator 23) exceeded the monthly maximum pH effluent limit of 9.0 and the daily maximum Oil and Grease effluent limit of 20.0 mg/L. The pH was determined to be 10.16 S.U. and the Oil and Grease determined to be 22.0 mg/L on October 14, 2002.

The oil/water separator receives water from the Unit 2 turbine building and equipment drains. During a cold weather verification test on October 13, 2002, water from a manhole collecting rainwater and groundwater was pumped to the oil/water separator. The water had a high pH caused by the rainwater passing through gravel containing calcium carbonate. The manhole also contained oil collected in the manhole from a nearby transformer.


Upon discovery of the problem, the pumping was terminated. Corrective action including addition of sodium bicarbonate to the inlet of the oil/water separator was initiated to bring the pH back to within permit effluent limits. Samples collected on October 24, 2002 were all within NPDES permit effluent limits.

IE25

Attn: DMR Clerk
Page 2

Beaver Valley has initiated corrective actions to prevent future occurrences. All water movement outside of its normal intended flowpath will be sampled and reviewed by chemistry staff prior to discharge. If you have any questions, contact me at 724 682-5113.

Sincerely,



James H. Lash
Plant Manager

DJS

C: E. Hubley
S.F. Brown
Central File

NAME FIRST ENERGY CORP

ADDRESS PA ROUTE 16B
SHIPPINGPORT

PA 15077-0004

PA0025615
PERMIT NUMBER

011 A
DISCHARGE NUMBER

MAJOR (SUBR 05)
F - FINAL
DIESEL GEN & TURBINE DRAINS

FACILITY BEAVER VALLEY POWER STATION

LOCATION SHIPPINGPORT

PA 15077-0004 FROM

MONITORING PERIOD					
YEAR	MO.	DAY	YEAR	MO.	DAY
02	10	02	02	10	02

*** NO DISCHARGE 1 1 ***

ATTN: MATTHEW J HARTMAN

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	0.00A	0.00A	(03)	*****	*****	*****	*****	****	1/7	EST	
	PERMIT REQUIREMENT	NO AMD	DAILY	MGD				****			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
JAMES LACH
PLANT MANAGER
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
724 622 5123
AREA CODE NUMBER
DATE
02 11 19

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
 NAME FIRST ENERGY CORP
 ADDRESS PA ROUTE 168
 SHIPPINGPORT PA 15077-0004

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 PA002515
 PERMIT NUMBER
 110 A
 DISCHARGE NUMBER

MAJOR (SUBR 05)
 F - FINAL
 UNIT 2 SERVICE WATER BACKWASH

FACILITY BEAVER VALLEY POWER STATION
 LOCATION SHIPPINGPORT PA 15077-0004 FROM
 ATTN: MATTHEW J HARTMAN

MONITORING PERIOD						
YEAR	MO.	DAY	TO	YEAR	MO.	DAY


*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALVE				(GPD)							
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY PE	MGD					****		
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 JAMES LACH
 PLANT MANAGER
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT


TELEPHONE
 AREA CODE NUMBER
 724 692-5117
 DATE
 YEAR MO DAY
 02 11 18

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME FIRST ENERGY CORP.

ADDRESS PA ROUTE 168
SHIPPINGPORT

PA 15077-0004

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PA0020013

012 A

PERMIT NUMBER

DISCHARGE NUMBER

MAJOR (SUBR 05)

F - FINAL

BLOWDOWN FROM THE HVAC UNIT

FACILITY BEAVER VALLEY POWER STATION

LOCATION SHIPPINGPORT

PA 15077-0004 FROM

ATTN: MATTHEW J HARTMAN

MONITORING PERIOD						
YEAR	MO.	DAY	TO	YEAR	MO.	DAY

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		8.33		8.33	(12)	0	1/31	GRAB
	PERMIT REQUIREMENT	*****	*****	***				SU		MONTH	
01034 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****			0.002	0.004	(14)	0	1/7	GRAB
	PERMIT REQUIREMENT	*****	*****	***				MG/L			
01042 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****			0.061	0.078	(17)		1/7	GRAB
	PERMIT REQUIREMENT	*****	*****	***				MG/L			
01092 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****			2.11	3.45	(17)	4	1/7	GRAB
	PERMIT REQUIREMENT	*****	*****	***				MG/L			
50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	20.001	20.001	(03)						1/31	ET
	PERMIT REQUIREMENT	MD AVG	DAILY MD	MGD				****		MONTH	
70295 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****			622	680	(17)		1/7	GRAB
	PERMIT REQUIREMENT	*****	*****	***				MG/L			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James Lash
Plant Manager
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

724.682.513
AREA CODE NUMBER YEAR MO DAY
02 11 15

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE ATTACHED LETTER FOR DETAILS ON EXCURSION

Paperwork Reduction Act Notice

Public reporting burden for this collection of information is estimated to vary from a range of 10 hours as an average per response for some minor facilities, to 110 hours as an average per response for some major facilities, with a weighted average for major and minor facilities of 18 hours per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding the burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Chief, Information Policy Branch, PM-223, U.S. Environmental Protection Agency, 401 M Street, SW, Washington, DC 20460; and to the Office of Information and Regulatory Affairs, Office of Management and Budget, Washington, DC 20503.

General Instructions

1. If form has been partially completed by preprinting, disregard instructions directed at entry of that information already preprinted.
2. Enter "Permittee Name/Mailing Address (and facility name/location, if different)," "Permit Number," and "Discharge Number" where indicated. (A separate form is required for each discharge.)
3. Enter dates beginning and ending "Monitoring Period" covered by form where indicated.
4. Enter each "Parameter" as specified in monitoring requirements of permit.
5. Enter "Sample Measurement" data for each parameter under "Quantity" and "Quality" in units specified in permit. "Average" is normally arithmetic average (geometric average for bacterial parameters) of all sample measurements for each parameter obtained during "Monitoring Period"; "Maximum" and "Minimum" are normally extreme high and low measurements obtained during "Monitoring Period." (Note to municipals with secondary treatment requirement: Enter 30-day average of sample measurements under "Average," and enter maximum 7-day average of sample measurements obtained during monitoring period under "Maximum.")
6. Enter "Permit Requirement" for each parameter under "Quantity" and "Quality" as specified in permit.
7. Under "No Ex" enter number of sample measurements during monitoring period that exceed maximum (and/or minimum or 7-day average as appropriate) permit requirement for each parameter. If none, enter "0."
8. Enter "Frequency of Analysis" both as "Sample Measurement" (actual frequency of sampling and analysis used during monitoring period) and as "Permit Requirement" specified in permit. (e.g., Enter "Cont," for continuous monitoring, "1/7" for one day per week, "1/30" for one day per month, "1/90" for one day per quarter, etc.)
9. Enter "Sample Type" both as "Sample Measurement" (actual sample type used during monitoring period) and as "Permit Requirement," (e.g., Enter "Grab" for individual sample, "24HC" for 24-hour composite, "N/A" for continuous monitoring, etc.)
10. Where violations of permit requirements are reported, attach a brief explanation to describe cause and corrective actions taken, and reference each violation by date.
11. If "no discharge" occurs during monitoring period, enter "No Discharge" across form in place of data entry.
12. Enter "Name/Title of Principal Executive Officer" with "Signature of Principal Executive Officer of Authorized Agent," "Telephone Number," and "Date" at bottom of form.
13. Mail signed Report to Office(s) by date(s) specified in permit. Retain copy for your records.
14. More detailed instructions for use of this Discharge Monitoring Report (DMR) form may be obtained from Office(s) specified in permit.

Legal Notice

This report is required by law (33 U.S.C. 1318; 40 C.F.R. 125.27). Failure to report or failure to report truthfully can result in civil penalties not to exceed \$10,000 per day of violation; or in criminal penalties not to exceed \$25,000 per day of violation, or by imprisonment for not more than one year, or by both.