

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



Dominion™

NOV 25 2002

Docket Nos. 50-336
50-423
B18808

RE: Technical Specification 6.9.2

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Power Station, Unit Nos. 2 and 3
Special Report for Inoperable Meteorological Monitoring Instrumentation Channels

In accordance with the reporting requirements of the Millstone Unit Nos. 2 and 3 Technical Requirements Manuals (TRMs), Dominion Nuclear Connecticut, Inc. (DNC) hereby submits a special report for one or more required channels of meteorological monitoring instrumentation inoperable for more than seven days.

On November 14, 2002, the meteorological monitoring instrumentation channels were declared inoperable due to planned modifications. These modifications included a complete replacement of the primary meteorological tower temperature sensor system and a partial replacement of the tower wind sensor system. Measures were taken to minimize the unavailability time of the tower instrumentation, however, due to unfavorable weather conditions, the modifications continued until November 22, 2002, at which time the instrumentation channels were declared operable. However, this outage duration exceeded both Unit TRMs allowed inoperability time of 7 days at which time a special report is required to be prepared and submitted to the NRC within the next 10 days. Since the meteorological monitoring instrumentation is restored to operable status, no additional corrective actions are planned.

There are no regulatory commitments contained within this letter.


IB22

U.S. Nuclear Regulatory Commission
B18808/Page 2

Should you have any questions regarding this submittal, please contact Mr. Raviandra Joshi at (860) 447-1791, extension 2080.

Very truly yours,

DOMINION NUCLEAR CONNECTICUT, INC.



J. Alan Price
Site Vice President - Millstone

cc: H. J. Miller, Region I Administrator
R. B. Ennis, NRC Senior Project Manager, Millstone Unit No. 2
V. Nerses, NRC Senior Project Manager, Millstone Unit No. 3
Millstone Senior Resident Inspector