



South Texas Project Nuclear Operating Company P.O. Box 289 Wadsworth, Texas 77483

December 12, 2002
NOC-AE-02001436
File No.: G02
10CFR50.71
STI: 31530389

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

South Texas Project
Units 1 and 2
Docket Nos. STN 50-498, STN 50-499
Monthly Operating Reports for November 2002

Pursuant to 10CFR50.71(a) and South Texas Project Electric Generating Station (STPEGS) Technical Specification 6.9.1.5, attached are the Monthly Operating Reports for November 2002. If you should have any questions on this matter, please contact R.L. Hill at (361) 972-7667.

F.H. Mallen
F.H. Mallen
Manager, Planning &
Controls

Attachments: 1) STPEGS Unit 1 Monthly Operating Report – November 2002
2) STPEGS Unit 2 Monthly Operating Report – November 2002

JE24

cc:
(paper copy)

Ellis W. Merschoff
Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Cornelius F. O'Keefe
U. S. Nuclear Regulatory Commission
P. O. Box 289, Mail Code: MN116
Wadsworth, TX 77483

C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

(electronic copy)

A. H. Gutterman, Esquire
Morgan, Lewis & Bockius LLP

M. T. Hardt/W. C. Gunst
City Public Service

Mohan C. Thadani
U. S. Nuclear Regulatory Commission

R. L. Balcom/D. G. Tees
Texas Genco, LP

A. Ramirez
City of Austin

C. A. Johnson/A. C. Bakken III
AEP - Central Power and Light Company

Jon C. Wood
Matthews & Branscomb

SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION
UNIT 1
MONTHLY OPERATING REPORT
NOVEMBER 2002
STP NUCLEAR OPERATING COMPANY
NRC DOCKET NO. 50-498
LICENSE NO. NPF-76

Approved By:

E.D. Halpin by R. R. Rode 12-11-02
E.D. HALPIN Date

MONTHLY SUMMARY

South Texas Project Unit 1 began the reporting period operating at full power.

On November 16, at 2042 hours, Unit 1 was manually tripped in response to a perceived loss of all pressure associated with the Open Loop Cooling Water System. The apparent loss of pressure in the Open Loop Cooling Water system was induced by a failure of the pump casing on Circulating Water Pump 11. A pressure spike that occurred when the pump discharge valve failed closed caused the pump casing failure.

Repairs were made and the unit was returned to service on November 24, at 1520. Full power was achieved on November 25, at 1154.

OPERATING DATA REPORT

DOCKET NO. 50-498
 UNIT 1
 DATE Dec. 11, 2002
 COMPLETED BY R.L. Hill
 TELEPHONE 361.972.7667

OPERATING STATUS

1. REPORTING PERIOD: 11/1/02-11/30/02 GROSS HOURS IN REPORTING PERIOD: 720
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 3,853
 MAXIMUM DEPENDABLE CAPACITY (MWe-Net): 1,250.6
 DESIGN ELECTRICAL RATING (MWe-Net): 1,250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR CRITICAL	<u>539.2</u>	<u>7,835.2</u>	<u>97,785.1</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>533.4</u>	<u>7,829.4</u>	<u>96,149.1</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>1,998,978</u>	<u>29,812,275</u>	<u>359,110,615</u>
10. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>666,723</u>	<u>9,914,392</u>	<u>117,262,506</u>
11. REACTOR SERVICE FACTOR (%)	<u>74.9</u>	<u>97.7</u>	<u>78.2</u>
12. REACTOR AVAILABILITY FACTOR (%)	<u>74.9</u>	<u>97.7</u>	<u>78.2</u>
13. UNIT SERVICE FACTOR (%)	<u>74.1</u>	<u>97.7</u>	<u>76.9</u>
14. UNIT AVAILABILITY FACTOR (%)	<u>74.1</u>	<u>97.7</u>	<u>76.9</u>
15. UNIT CAPACITY FACTOR - Using MDC (%)	<u>74.0</u>	<u>98.9</u>	<u>75.0</u>
16. UNIT CAPACITY FACTOR - Using DER (%)	<u>74.0</u>	<u>98.9</u>	<u>75.0</u>
17. UNIT FORCED OUTAGE RATE (%)	<u>25.9</u>	<u>2.3</u>	<u>13.4</u>

18. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, & DURATION OF EACH):

Scheduled 22-day outage to allow scheduled refueling to begin on March 26, 2003.

19. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-498
UNIT 1
DATE Dec. 11, 2002
COMPLETED BY R.L. Hill
TELEPHONE 361.972.7667

MONTH NOVEMBER

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1279</u>	17	<u>0</u>
2	<u>1280</u>	18	<u>0</u>
3	<u>1281</u>	19	<u>0</u>
4	<u>1280</u>	20	<u>0</u>
5	<u>1281</u>	21	<u>0</u>
6	<u>1274</u>	22	<u>0</u>
7	<u>1278</u>	23	<u>0</u>
8	<u>1283</u>	24	<u>44</u>
9	<u>1282</u>	25	<u>1052</u>
10	<u>1282</u>	26	<u>1279</u>
11	<u>1283</u>	27	<u>1273</u>
12	<u>1286</u>	28	<u>1267</u>
13	<u>1287</u>	29	<u>1268</u>
14	<u>1287</u>	30	<u>1270</u>
15	<u>1285</u>		
16	<u>1101</u>		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-498
 UNIT 1
 DATE Dec. 11, 2002
 COMPLETED BY R L Hill
 TELEPHONE 361.972.7667

REPORT MONTH NOVEMBER

No.	Date	1 Type	Duration (Hours)	2 Reason	3 Method of Shutting Down Reactor	Licensee Event Report #	4 System Code	5 Component Code	Cause & Corrective Action to Prevent Recurrence
02-02	021116	F	186.6	A	2	01-02-003	NN	P	Manual reactor trip in response to a perceived loss of all pressure associated with the Open Loop Cooling Water System. The apparent loss of pressure in the Open Loop Cooling Water system was induced by a failure of the pump casing on Circulating Water Pump 11. A pressure spike that occurred when the pump discharge valve failed closed caused the pump casing failure.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont. of Existing
 Outage
 5-Reduction
 9-Other

4
 IEEE 805-1983


5
 IEEE 803-1983


PORVS AND SAFETY VALVE SUMMARY

There were no PORV or Safety Valves challenged during the reporting period.

SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION
UNIT 2
MONTHLY OPERATING REPORT
NOVEMBER 2002
STP NUCLEAR OPERATING COMPANY
NRC DOCKET NO. 50-499
LICENSE NO. NPF-80

Approved By:


E.D. HALPIN


Date

MONTHLY SUMMARY

South Texas Project Unit 2 remained shutdown during the reporting period for scheduled refueling and steam generator replacement.

OPERATING DATA REPORT

DOCKETNO. 50-499
 UNIT 2
 DATE Dec. 11, 2002
 COMPLETED BY R.L. Hill
 TELEPHONE 361.972.7667

OPERATING STATUS

1. REPORTING PERIOD: 11/1/02-11/30/02 GROSS HOURS IN REPORTING PERIOD: 720
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3,800
 MAXIMUM DEPENDABLE CAPACITY (MWe-Net): 1,250.6
 DESIGN ELECTRICAL RATING (MWe-Net): 1,250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR CRITICAL	<u>0</u>	<u>6,480.3</u>	<u>94,294.3</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0</u>	<u>6,426.8</u>	<u>92,054.5</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>0</u>	<u>24,457,687</u>	<u>343,618,219</u>
10. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>7,962,417</u>	<u>111,920,538</u>
11. REACTOR SERVICE FACTOR (%)	<u>0.0</u>	<u>80.8</u>	<u>80.0</u>
12. REACTOR AVAILABILITY FACTOR (%)	<u>0.0</u>	<u>80.8</u>	<u>80.0</u>
13. UNIT SERVICE FACTOR (%)	<u>0.0</u>	<u>80.2</u>	<u>78.1</u>
14. UNIT AVAILABILITY FACTOR (%)	<u>0.0</u>	<u>80.2</u>	<u>78.1</u>
15. UNIT CAPACITY FACTOR - Using MDC (%)	<u>0.0</u>	<u>79.4</u>	<u>75.9</u>
16. UNIT CAPACITY FACTOR - Using DER (%)	<u>0.0</u>	<u>79.4</u>	<u>75.9</u>
17. UNIT FORCED OUTAGE RATE (%)	<u>0.0</u>	<u>2.3</u>	<u>13.2</u>

18. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, & DURATION OF EACH): N/A

19. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: 12/5/02

AVERAGE DAILY UNIT POWER LEVEL

DOCKETNO. 50-499
UNIT 2
DATE Dec. 11, 2002
COMPLETED BY R.L. Hill
TELEPHONE 361.972.7667

MONTH NOVEMBER

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>		
16	<u>0</u>		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-499
 UNIT 2
 DATE Dec. 11, 2002
 COMPLETED BY R.L. Hill
 TELEPHONE 361.972.7667

REPORT MONTH NOVEMBER

No.	Date	1 Type	Duration (Hours)	2 Reason	3 Method of Shutting Down Reactor	Licensee Event Report #	4 System Code	5 Component Code	Cause & Corrective Action to Prevent Recurrence
02-03	021002	S	720.0	C	1	N/A	N/A	N/A	Scheduled outage to allow refueling and steam generator replacement.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Exam
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Cont. of Existing
 Outage
5-Reduction
9-Other

4
IEEE 805-1983

5
IEEE 803-1983

PORVS AND SAFETY VALVE SUMMARY

There were no PORV or Safety Valves challenged during the reporting period.