

Davis-Besse Nuclear Power Station



New Containment Emergency Sump Design

1

Opening Remarks Gary Leidich
New Containment Emergency Sump Jim Powers
Closing Comments Gary Leidich

Opening Remarks



**Gary Leidich,
Executive Vice President - FENOC**

Desired Outcome

- Present the new Containment Sump Design/Modification at Davis-Besse
- Obtain NRC comments on Davis-Besse approach




**CEO of FirstEnergy
has set the standard of returning
Davis-Besse
back to service in a safe
and reliable manner**

**We must do the job right the
first time and regain the
confidence of our customers,
regulators, and investors in our
nuclear program**

**We are committed to meeting
this challenge**

Return to Service Plan


Restart Overview Panel



Return to Service Plan

- New Containment Emergency Sump Design is part of the Containment Health Assurance Building Block from the Davis-Besse Return to Service Plan
- Restore operability as well as add margin to Containment Emergency Sump
- Containment Emergency Sump Intake Screen is on the Davis-Besse IMC 0350 Restart List

Containment Emergency Sump Background



Jim Powers
Director - Nuclear Engineering

8


Strainer Function

- 10CFR50.46 (b)(5) and Appendix A to 10CFR50, Criterion 35 require long term emergency cooling
- Strainer protects Low Pressure Injection (LPI), High Pressure Injection (HPI) and Containment Spray(CS) systems from debris intrusion during a LOCA event


Original Containment Emergency Sump Configuration

- Nominally 14 ft. X 5 ft. X 2 ft. (L x W x H)
- Approximately 50 sq. ft. available (vertical) surface area
- 1/4" square screen openings, galvanized wire - 53.4% open area
- Vortex Suppression with existing grating qualified by testing

Containment Building Drawing



Incore Tunnel



Original Containment Emergency Sump



13

Original Containment Emergency Sump Strainer



14

Original Containment Emergency Sump Strainer



15

Containment Emergency Sump Modification

Increase Net Positive Suction Head (NPSH) margin for
Emergency Core Cooling System under design
basis accident conditions

Containment Emergency Sump Discovery Action Plan

- Conduct reviews of the design basis of the sump
- Identify debris sources (NEI 02-01 guidance):
 - Containment walkdowns,
 - Coating evaluations, and,
 - Foreign material evaluations
- Evaluate the transport of debris to the sump screen
- Develop corrective actions to reduce debris sources
- Develop plan to significantly increase sump intake surface area

Preliminary Design Parameters for New Strainer

- Flow Rates

- Low Pressure Injection (LPI) 4000 gpm per train
- Containment Spray (CS) 1500 gpm per train
- Total Strainer Design Flow 11,000 gpm

- Minimum Water Level

- Small Break LOCA Elevation 566.76 ft. (1.76 ft. above floor)
- Limiting Large Break LOCA Elevation 566.83 ft. (1.83 ft. above floor)

Preliminary Design Parameters for New Strainer

- Net Positive Suction Head (NPSH) Margin
(NPSH Margin = NPSH Available - NPSH Required)
 - Approximately 3 feet for LPI (before adding strainer/debris head loss)
 - Approximately 5 feet for CS (before adding strainer/debris head loss)

Note: No credit taken for containment over pressure above vapor pressure of water (Licensing Basis)


Design Goal

- Increase NPSH available
- Increase strainer surface area
 - Lower approach velocity
 - Lower head loss
- Increase margin
- Design based on conservative approach for debris generation, transport and head loss

New Strainer Design

- Available surface area ~ 1200 sq. ft.
 - Upper strainer ~ 400 sq. ft.
 - Lower Strainer ~ 800 sq. ft.
- Strainer and supporting structure made from stainless steel
- Strainer made from 10 gauge perforated plate with 3/16" diameter holes with 41% open area
- Strainer designed to ASME Section III, Subsection NF Code to withstand 5 psi differential pressure
- Vortex suppression designed to the guidance of RG 1.82, Rev.2


New Strainer Design




New Strainer Design

Containment Floor, 565' elev.

“Upper Strainer”



New Strainer Design



New Strainer Design

- New design facilitates two controlling pipe break scenarios
 - Hot Leg break at top of OTSG (Case I)
 - Hot Leg break at RPV (Case II)
- Case I generates largest volume of debris
 - Both upper and lower strainer sections available
- Case II generates smaller volume of debris
 - Upper strainer section available
 - No credit taken for lower strainer due to potential damage from pipe break blowdown

Debris Source Term

- NEI 02-01, “Condition Assessment Guideline: Debris Sources Inside Containment”
 - Conducted field walkdowns to collect plant specific data
- Methodology used:
 - BWROG Utility Resolution Guidance methodology (plus NRC comments)
 - Conservative Zone of Influence (ZOI)
 - 100% destruction of fibrous insulation in ZOI
 - 42% destruction of Reflective Metal Insulation (RMI) in ZOI
- Unqualified Coatings
 - Assumed 100% failure²⁶ under Design Basis

Debris Source Term


- Pipe Breaks
 - Loss-of-Coolant-Accident (LOCA) locations per NRC's Standard Review Plan (MEB 3-1)
 - Pipe breaks on Reactor Coolant System included
 - Critical pipe breaks
 - Hot Leg break at top of OSTG (Case I)
 - Hot Leg break at RPV (Case II)

Debris Source Term

(Preliminary Results)

<u>Debris Type</u>	<u>Case I</u>	<u>Case II</u>
Fiber	42 ft ³	3ft ³
RMI Foils	67,700 ft ²	11,900 ft ²
Dust, Dirt, Concrete	475 lbs.	
Rust	159 lbs.	
Coatings		
Inorganic Zinc	9620 ft ²	
(577 lbs.)		
Epoxy	9620 ft ² (481 lbs.)	
Alkyds	3500 ft ² (105 lbs.)	


Sample Davis-Besse Debris Transport Logic Tree (Per NUREG/CR-6369) (RMI Transport)



Debris Transport

CFD Modeling of Davis-Besse Incore Tunnel


- All Significant flow paths modeled
- Interactions between access tunnels and containment floor
- Strainers incorporated
- Models movement and settling of debris
- Computational cells ~ 2,000,000



Debris Transport

CFD Modeling of Davis-Besse Containment Floor

- All significant flow obstructions modeled
- Interactions between containment floor and incore tunnel
- Emergency sump and strainers incorporated
- Movement and settling of debris is modeled
- Computational cells ~ 500,000




Example

RMI Transport Model - Turbulence

CFD Analysis of Davis-Besse Containment Floor


- Red: Turbulence > RMI debris suspended
- Break on lower right
- Flow: 11,000 gpm
- Pool height: 2 feet
- Elevation: +1.5 inches above floor level



Design Summary

- New strainer features greatly increased surface area
- Preliminary calculations indicate that Emergency Core Cooling System pumps will have NPSH margin under Design Basis Accident debris loading

Closing Remarks



**Gary Leidich,
Executive Vice President - FENOC**