

# ***Davis-Besse Nuclear Power Station***



## **Reactor Vessel Incore Nozzles**


Opening Remarks . . . . . Gary Leidich

Reactor Vessel Incore Nozzles..... Bob Schrauder

- Incore Nozzle Configuration
- Recent Inspection and Evaluation at Davis-Besse
- Actions Prior to Returning the Plant to Service
- Contingency Repair Concept
- FLÜS Online Leak Monitoring System

Closing Comments..... Gary Leidich

# Opening Remarks



**Gary Leidich**  
**Executive Vice President - FENOC**

# Desired Outcome

- Brief the NRC Staff on the status of the Davis-Besse Reactor Vessel Incore Monitoring Instrumentation Nozzles and future plans
- Obtain NRC comments on Davis-Besse approach

**CEO of FirstEnergy  
has set the standard of returning  
Davis-Besse  
back to service in a safe  
and reliable manner.**




**We must do the job right the  
first time and regain the  
confidence of our customers,  
regulators, and investors in our  
nuclear program.**

**We are committed to meeting  
this challenge.**

# Return to Service Plan


## Restart Overview Panel



# Return to Service Plan

Inspection of the Incore Nozzles is part of the Containment Health Assurance Building Block in the Davis-Besse Return to Service Plan

# Reactor Vessel Incore Nozzles



**Bob Schrauder**  
**Director - Support Services**

# Incore Nozzles Configuration

- Babcock & Wilcox reactor vessel has 52 Incore Nozzles
- Incore nozzles are ~ 1 inch in diameter
- Original incore nozzles fabricated from Alloy 600 material
- Welds - Alloy 182 (stress relieved)
- Incore nozzles modified following Oconee 1 1972 Hot Functional Testing Failure



**Incore Nozzles  
at Bottom of Reactor Vessel  
(Post-cleaning)**

# Incore Nozzle Modification



**Repair in Process**



1




**Completed Repair**

# Industry Experience


## Incore Nozzles

- Incore nozzles are exposed to lower temperature (558°F) than Control Rod Drive Mechanism nozzles (605°F) and are less susceptible to stress corrosion cracking
- Visual inspections of the incore nozzles have not been routinely conducted in United States plants
- Inspections/testing of incore nozzles at 13 French plants have not discovered cracking or leaking

# EDF vs. B&W Nozzle Configuration



**EDF Nozzle Configuration**



**B&W Current Nozzle Configuration**

1

# Inspection of Reactor Vessel




- Visual Inspections performed as part of the Extent of Condition Program

## Inspection of Bottom of Reactor Vessel

# Inspection Conclusions

Inspection results:

- Boron and rust deposit trails were observed on the sides and bottom of the reactor vessel
- Similar deposits observed on several incore nozzles
- Tape remnants and residue observed on incore nozzles
- No build-up of boric acid or corrosion products on top of insulation
- No evidence of wastage on bottom of reactor vessel



**Bottom of Reactor Vessel**

# Incore Nozzles



**Incore Nozzle #42**



**Incore Nozzle #45**

# Deposit Sampling Summary

## AREAS:


- Reactor vessel flow trail and incore nozzle deposits

## OBJECTIVE:


- Determine through chemical analysis whether flow trails and incore nozzle deposits had common source

## SAMPLE POPULATION:

- 2 from flow trails observed on under reactor vessel sides
- 12 from incore nozzles
- Analysis by Framatome-ANP




**Bottom of Reactor Vessel**



**Incore Nozzle #45**

# Sampling of Deposits

- Sample locations (●) chosen were nozzles




INCORE INSTRUMENT CORE LOCATION MAP  
BOTTOM HEAD INSIDE VIEW

# Deposit Characterization Summary

- Boron and Lithium were higher at several incore nozzle locations than in flow trails and more comparable with previously analyzed upper head deposit samples (shown next slide)
- Minor species (Uranium, Barium, Thorium, Strontium, & Zirconium) were higher at several incore nozzle locations than in the flow trails. However, the lack of activity associated with these species did not support reactor coolant as the source
- Cobalt ( $\text{Co}^{60}$ ) and Iron ( $\text{Fe}^{59}$ ) were higher in the flow trails than at the incore nozzle locations
- Inconsistent concentration gradients along possible flow trail paths

# Deposit Characterization Summary

Comparison of Normalized Boron and Lithium Concentrations  
(Flow trails at bottom of reactor head and incore nozzle deposits)




# Deposit Characterization Conclusion

From the results of the analysis,  
it is inconclusive whether the flow trails at the bottom of the  
reactor head and nozzle deposits had a common source

# Reactor Vessel Bottom Inspection Plan

- FENOC and Framatome-ANP developed inspection plan
- Bottom of reactor vessel thoroughly cleaned 9/2002
- Planned visual inspections prior to startup:
  - Raise Reactor Coolant System to normal operating pressure and temperature (hold for 3-7 days)
  - Potential use of hot optics (visual inspection aid)
  - Lower temperature and pressure
  - Perform bare metal reactor vessel visual inspection
  - Perform bare metal reactor vessel visual inspection during the next scheduled outage

# **Boron Deposit Rate For 2000 ppm Boron Reactor Coolant Leakage (Unchoked Flow) 100% Deposition Rate For a Given Number of Days**



# Reactor Vessel Bottom Inspection Plan

- Inspections will be sufficient to detect leakage
- Absence of boric acid will confirm that the deposits found in in 2002 were not from incore nozzle leaks

# Laboratory Leak Rate Testing

- Program Objectives
  - Measure leak rate as a function of simulated and/or actual flaw geometry
    - Benchmark analytical models for bounding leak rate calculations
    - Identify residue deposit chemistry and any volatile chemicals that exit the crevice
    - Investigate effect of annulus on leakage rates
  - Verify methods for detecting very small leaks
    - Visible evidence of boron residue
    - In-situ monitoring techniques

# Technical Approach

- Framatome-ANP Hot Leak Test Facility will be used to provide primary fluid:
  - $T_c = 558^\circ \text{ F}$ ;  $p = 2200 \text{ psig}$
  - Primary chemistry (boron & lithium concentration)
- Mockup assembly will be connected to existing high temperature/ high pressure supply system
- Leak rates measured from  $10^{-6}$  to  $0.25 \text{ gpm}$




# Mockup Design & Test Description

- Mockup is being designed and built to measure leak rates through simulated (SCC) flaws
- Leak rate bounding tests will be conducted for 8 hours each
- Final test with a selected leak rate will be run for 5 days

# Contingency Repair Concept

- Insert mechanical plug and cut existing incore nozzle
- Deposit 1/2" - 5/8" weld pad
- Bore out incore nozzle remnant into reactor vessel to 1" maximum depth
- Fit-up replacement nozzle and complete new weld
- Remove mechanical plug




# Additional Regulatory Interfaces

- If repairs are necessary, a meeting to discuss final design will be held with the NRC
- 10CFR50.55a alternative code (ASME Code Section XI) requests will be necessary to permit implementation of repairs
- Alternative code request will be similar to those submitted to NRC for the repair of Control Rod Drive Mechanism nozzles at other plants


# FLÜS Online Leak Monitoring

- Davis-Besse plans to install FLÜS Online Leak Monitoring System
- Ability to detect and locate leakage with significantly higher sensitivity than other available systems
- Leak detection system measures the moisture penetrating a sensor tube
- Installed or being installed in 12 units in a variety of European countries and Canada
- Operational history of 10 years

# FLÜS Sensor Tube




# Proposed FLÜS Installation



- Install sensor tube between the reactor vessel insulation and reactor vessel
- Simple installation
- Expected sensitivity of approximately 4E-3 to 2E-2 gpm
- System sensitivity is dependent on the air tightness of reactor vessel insulation

# Closing Comments



**Gary Leidich**  
**Executive Vice President - FENOC**