

**Susquehanna Learning Center**  
769 Salem Boulevard  
Berwick, PA 18603-0467  
570-542-3353



December 3, 2002

Mr. Alan Blamey  
USNRC Chief Examiner  
USNRC Region 1  
475 Allendale Road  
King of Prussia, PA 19406-1415

Susquehanna Learning Center  
**Examination Outline/Materials/References**  
PLA 005568 File A14-13D

Dear Alan:

Enclosed are the Examination Materials for the Susquehanna Steam Electric Station Operator Examination scheduled for December 11, 2002. This information is being provided in accordance with NUREG 1021 Operating Examination Standards for Power Reactors, Rev 8, Supplement 1.

- JPMs as per ES-301-2 Control Room Systems and Facility Walkthrough Test Outline
- Applicable Procedure references which facilitate execution of the JPMs

Susquehanna Steam Electric Station requests that the enclosed materials be withheld from public disclosure until after the December 2002 examination process is complete.

If you have any questions, please feel free to contact me at 570-542-3553.

Sincerely,

A handwritten signature in cursive script that reads "Richard E. Chin".

Richard E. Chin  
Examination Coordinator

Response: No

Enclosures

cc: J. M. Helsel  
K. M. Roush  
Ops Letter File  
Nuc Records-Site

Rcnrcexamoutlineletter6

REC/vah

Facility: <u>Susquehanna</u>		Date of Examination: <u>12/11/2002</u>	
Exam Level <b>SRO(U)</b>		Operating Test No.: <u>1</u>	
<b>B.1 Control Room Systems</b>			
System / JPM Title		Type Code*	Safety Function
B1-1	202002 A2.05 (3.8/4.0)  RESET Recirc Pump Limiter #2 Runback in accordance with ON-164-002	S, M, A	4
B1-2	206000 A2.17 (3.9/4.3)  Override an Inadvertent Start of HPCI in accordance with OP-152-001	S, M A	2
B1-3	295016 AA 1.06 (4.0/4.1)  Perform Immediate Operator Actions for Control Room Evacuation in accordance with ON-100-009	S, D	7
<b>B.2 Facility Walk -Through</b>			
B2-1	201001 A2.07 (3.2/3.1)  Shift The CRD Flow Stations From A To B in accordance with OP-255-001	D, R	1
B2-2	264000 A2.09 (3.7/ 4.1)  Transfer DG "E for "C" during Station Blackout in accordance with OP-024-004 Attachment C	N, L	6
Type Codes: (D)irect from bank, (M)odified from bank, (N)ew, (A)lternate Path, (C)ontrol Room, (S)imulator, (L)ow-Power, (R)CA			