



- NOTES
1. INSTALL LAYER OF 1/2" FELT BETWEEN INSIDE WEETS AND EXISTING INTAKE STRUCTURE WALL.
 2. CAULK AROUND SPAN DECK AFTER IT HAS BEEN INSTALLED.
 3. FUEL LEVEL SIGHT GLASS SHALL BE AN AUTOMATIC OIL LEVEL 1 1/2" WITH BURNER VALVE BODY, OIL RESISTANT HOPEWELL SEALS, AND COMPLETE WITH GAUGE GLASS & GROUND RODS. SEE DETAIL.
 4. REMOVE EXISTING SIGHT LEVEL INDICATOR AND INSURE 2" PLUG.
 5. THE OPENING AROUND PIPES PENETRATING SLEEVES SHALL BE PACKED WITH A MOISTURE RESISTANT MATERIAL AND COMPLETELY SEALED.

Fort Calhoun Station

ENCLOSURE FOR DIESEL DRIVEN FIRE PUMP FUEL TANK @ West Side Of INTAKE STRUCTURE

REV. NO.	DATE	BY	CHKD.	APP'D.
1	10/21/00	SMW		

PE	SCALE	1" = 1'-0"
OMAHA PUBLIC POWER DISTRICT OMAHA, NEBRASKA		
D-4045	REV.	