


- NOTES
1. INSTALL LAYER OF 1/2" FELT BETWEEN INSIDE WEETS AND EXISTING INTAKE STRUCTURE WALL.
 2. CAULK AROUND SPAN DECK AFTER IT HAS BEEN INSTALLED.
 3. FUEL LEVEL SIGHT GLASS SHALL BE AN AUTOMATIC OIL LEVEL 1 1/2" WITH BUSHING W/AMP BODY, OIL RESISTANT HOPEWELL SEALS, AND COMPLETE WITH GAUGE GLASS & GROUND RODS. SEE DETAIL.
 4. REMOVE EXISTING SIGHT LEVEL INDICATOR AND INSURE 2" PLUG.
 5. THE OPENING AROUND PIPES PENETRATING SLEEVES SHALL BE PACKED WITH A MOISTURE RESISTANT MATERIAL AND COMPLETELY SEALED.



| | | | | |
|----------|--------|----|-------|--------|
| REV. NO. | DATE | BY | CHKD. | APP'D. |
| 1 | 3/7/89 | DM | DM | DM |
| 2 | 10/91 | DM | DM | DM |

OMAHA PUBLIC POWER DISTRICT
OMAHA, NEBRASKA

ENCLOSURE FOR DIESEL
DRIVEN FIRE PUMP FUEL
TANK @ West Side Of
INTAKE STRUCTURE

PE SCALE 1/4" = 1'-0"

D-4045