

## 5.0 Environmental Impacts of Postulated Accidents

Environmental issues associated with postulated accidents were discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999a).<sup>(a)</sup> The GEIS included a determination of whether the analysis of the environmental issues could be applied to all plants and whether additional mitigation measures would be warranted. Issues were assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristic.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and therefore, additional plant-specific review of these issues is required.

This chapter describes the environmental impacts from postulated accidents that might occur during the license renewal term.

### 5.1 Postulated Plant Accidents

Two classes of accidents are evaluated in the GEIS. These are design-basis accidents (DBAs) and severe accidents, as discussed in the following sections.

---

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

## Environmental Impacts of Postulated Accidents

### Design-Basis Accidents

To receive NRC approval to operate a nuclear power facility, an applicant for an initial operating license must submit a Safety Analysis Report (SAR) as part of its application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The staff reviews the application to determine whether the plant design meets the Commission's regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

DBAs are those accidents that both the licensee and the staff evaluate to ensure that the plant can withstand normal and abnormal transients, and a broad spectrum of postulated accidents without undue hazard to the health and safety of the public. A number of these postulated accidents are not expected to occur during the life of the plant but are evaluated to establish the design basis for the preventive and mitigative safety systems of the facility. The acceptance criteria for DBAs are described in 10 CFR Part 50 and 10 CFR Part 100.

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the operating license (OL). The results of these evaluations are found in license documentation such as the applicant's Final Safety Analysis Report (FSAR), the staff's Safety Evaluation Report (SER), and the Final Environmental Statement (FES). A licensee is required to maintain the acceptable design and performance criteria throughout the life of the plant including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximum exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirements that continuous acceptability of the consequences and aging management programs be in effect for license renewal, the environmental impacts as calculated for DBAs should not differ significantly from initial licensing assessments over the life of the plant, including the license renewal period. Accordingly, the design of the plant relative to DBAs during the extended period is considered to remain acceptable and the environmental impacts of those accidents were not examined further in the GEIS.

The Commission has determined that the environmental impacts of DBAs are of SMALL significance for all plants because the plants were designed to successfully withstand these accidents. Therefore, for the purposes of license renewal, design-basis events are designated as a Category 1 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue, applicable to McGuire Nuclear Station, Units 1 and 2 (McGuire), is listed in Table 5-1. The early resolution of the DBAs makes them a part of the current licensing basis of the plant; the current

licensing basis of the plant is to be maintained by the licensee under its current license and, therefore, under the provisions of 10 CFR 54.30, is not subject to review under license renewal.

**Table 5-1.** Category 1 Issue Applicable to Postulated Accidents During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
POSTULATED ACCIDENTS	
Design-basis accidents (DBAs)	5.3.2; 5.5.1

Based on information in the GEIS, the Commission found that

The NRC staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants.

In its Environmental Report (ER), Duke Energy Corporation (Duke) stated that “no new information existed for the issues that would invalidate the GEIS conclusions (Duke 2001).” The staff has not identified any significant new information during its independent review of the McGuire ER (Duke 2001), the staff’s site visit, the scoping process, or its evaluation of other available information. Therefore, the staff concludes that there are no impacts related to this issue beyond those discussed in the GEIS.

Severe Accidents

Severe nuclear accidents are those that are more severe than DBAs because they could result in substantial damage to the reactor core, whether or not there are serious offsite consequences. In the GEIS, the staff assessed the impacts of severe accidents during the license renewal period, using the results of existing analyses and site-specific information to conservatively predict the environmental impacts of severe accidents for each plant during the renewal period.

Severe accidents initiated by external phenomena such as tornadoes, floods, earthquakes, and fires have not traditionally been discussed in quantitative terms in FESs and were not considered specifically for the McGuire site in the GEIS (NRC 1996). However, in the GEIS, the staff did evaluate existing impact assessments performed by the NRC and by the industry at 44 nuclear plants in the United States and concluded that the risk from beyond-design-basis earthquakes at existing nuclear power plants is SMALL. Additionally, the staff concluded that the risks from other external events are adequately addressed by a generic consideration of internally initiated severe accidents.

## Environmental Impacts of Postulated Accidents

Based on information in the GEIS, the Commission found that

The probability-weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to groundwater, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives.

Therefore, the Commission has designated mitigation of severe accidents as a Category 2 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue, applicable to McGuire, is listed in Table 5-2.

**Table 5-2.** Category 2 Issue Applicable to Postulated Accidents During the Renewal Term

<b>ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1</b>	<b>GEIS Sections</b>	<b>10 CFR 51.53(c)(3)(ii) Subparagraph</b>	<b>SEIS Section</b>
<b>POSTULATED ACCIDENTS</b>			
Severe Accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	L	5.2

The staff has not identified any significant new information with regard to the consequences from severe accidents during its independent review of the McGuire ER (Duke 2001), the staff's site visit, the scoping process, or its evaluation of other available information. Therefore, the staff concludes that there are no impacts of severe accidents beyond those discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(ii)(L), the staff has reviewed severe accident mitigation alternatives (SAMAs) for McGuire. The results of its review are discussed in Section 5.2.

## 5.2 Severe Accident Mitigation Alternatives (SAMAs)

10 CFR 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's plant in an EIS or related supplement or in an environmental assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with the potential for improving severe accident safety performance are identified and evaluated. SAMAs have not been previously considered for McGuire; therefore, the remainder of Chapter 5 addresses those alternatives.

### 5.2.1 Introduction

Duke submitted an assessment of SAMAs for McGuire as part of the ER (Duke 2001). The assessment was based on Revision 2 of the McGuire Probabilistic Risk Assessment (McGuire PRA, Revision 2) (Duke 1998), which is a full scope Level 3 PRA that includes the analysis of both internal and external events. The internal events analysis is an updated version of the Individual Plant Examination (IPE) model (Duke Power 1991), and the external events analysis is based on the Individual Plant Examination for External Events (IPEEE) model (Duke Power 1994). In identifying and evaluating potential SAMAs, Duke took into consideration the insights from the McGuire PRA, as well as other studies, such as the Watts Bar Severe Accident Mitigation Design Alternatives (SAMDA) Analysis (NRC 1995a) and NUREG-1560 (NRC 1997c). Duke concluded that none of the candidate SAMAs evaluated were cost effective for McGuire.

Based on a review of the initial SAMA assessment, the staff issued a request for additional information (RAI) to Duke by letter dated November 19, 2001 (NRC 2001). Key questions concerned (1) further information on several candidate SAMAs, especially those that mitigate the consequences of a station blackout (SBO) event; (2) details on the PRA used for the SAMA analysis, including results as they pertain to containment failure and releases; and (3) the impact of including elements of averted risk that were omitted in the ER. By a letter dated January 31, 2002, Duke submitted additional information (Duke 2002a), which provided details on the updated PRA, the requested PRA results, and other information identified in the RAI (NRC 2001). Duke provided additional clarification in a conference call on February 25, 2002 (NRC 2002a). In these responses, Duke included supplemental tables showing the impacts of including averted replacement power costs for SAMAs that have the potential to reduce core damage frequencies and averted offsite property damage costs for SAMAs that have the potential to improve containment performance, both of which were omitted in the original analysis. Also, Duke presented its position on the value of providing back-up hydrogen control capability during SBO events. Duke's responses addressed the staff's concerns and reaffirmed that none of the SAMAs would be cost-beneficial. However, based on review of the cost and benefit information provided by Duke, the staff concludes that one SAMA is cost-beneficial under the assumptions presented. This SAMA, which involves plant and procedure modifications to enable the existing hydrogen control (igniter) system to be powered from an ac-independent power source in SBO events, has not been implemented at McGuire. This issue is currently being addressed by the NRC as part of the resolution of Generic Safety Issue 189 – Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident (NRC 2002b).

The staff's assessment of SAMAs for McGuire is presented below.

## 5.2.2 Estimate of Risk for McGuire Units 1 and 2

Duke's estimates of offsite risk at McGuire are summarized below. The summary is followed by the staff's review of Duke's risk estimates.

### 5.2.2.1 Duke's Risk Estimates

The McGuire PRA model, which forms the basis for the SAMA analysis, is a Level 3 risk analysis; i.e., it includes the treatment of core damage frequency, containment performance, and offsite consequences. The model, which Duke refers to as PRA, Revision 2 (Duke 1998), consists of an internal events analysis based on an updated version of the original IPE (McGuire PRA, Revision 1) (Duke Power 1991) and an external events analysis based on the current version of the IPEEE (Duke Power 1994). The calculated total core damage frequency (CDF) for internal and external events in Revision 2 of the McGuire PRA is  $4.9 \times 10^{-5}$  per year.

The McGuire PRA is a "living" PRA. The original version of the IPE has been updated to reflect various design and procedural changes, such as those related to the improvements identified in the IPE, and to reflect operational experience since 1991. The CDF for internal and external events was reduced from  $7.4 \times 10^{-5}$  per year (Revision 1) to  $4.9 \times 10^{-5}$  per year (Revision 2). The Level 1 PRA changes associated with the McGuire PRA Revision 2 model included

- incorporation of updated data for component reliability, unavailabilities, initiating event frequencies, common cause failures, and human error probabilities
- conversion from a sequence based solution to a single top fault tree
- modifications to reflect changes to the plant configuration.

The most significant data changes are those related to diesel generator (DG) performance. Following the IPE, Duke proceeded with a program to improve the DG reliability at McGuire. The reliability improvement that occurred significantly reduced the CDF contributed by the loss of offsite power (LOOP) and tornado initiators. To a lesser extent, the seismic results are also impacted by the DG reliability data. The net effect is that the total CDF for SBO sequences (internal and external events) was reduced from approximately  $4.1 \times 10^{-5}$  per year in the IPE and IPEEE to  $2.3 \times 10^{-5}$  per year in PRA Revision 2. Another important change occurred in the interfacing system loss-of-coolant accident (ISLOCA) evaluation. The generic database adopted for the Revision 2 analysis had significantly higher failure rates for valve ruptures. This resulted in a significant increase in the CDF contributed by the ISLOCA, an important risk contributor.

The breakdown of the CDF from Revision 2 to the PRA is provided in Table 5-3. Internal event initiators represent about 57 percent of the total CDF and are composed of transients (31 percent of total CDF), loss-of-coolant accidents (LOCAs) (22 percent of total CDF), and reactor pressure vessel rupture (2 percent of total CDF). Remaining contributors together account for less than 3 percent of total CDF. External event initiators represent about 43 percent of the total CDF and are composed of seismic initiators (22 percent of total CDF), tornado initiators (13 percent of total CDF), and fire initiators (6 percent of the total CDF). Although not explicitly reported in Table 5-3, SBO events account for 47 percent of the total CDF for internal and external events in Revision 2 of the PRA.

**Table 5-3.** McGuire Core Damage Frequency (Revision 2 of PRA)

Initiating Event	Frequency (per year)	% of Total CDF
Transients	$1.5 \times 10^{-5}$	31
Loss-of-coolant accident (LOCA)	$1.1 \times 10^{-5}$	22
Internal flood	$8.7 \times 10^{-7}$	2
Anticipated transient without scram (ATWS)	$1.5 \times 10^{-7}$	<1
Steam generator tube rupture (SGTR)	$7.8 \times 10^{-10}$	<1
Reactor pressure vessel rupture (RPV)	$1.0 \times 10^{-6}$	2
Interfacing system LOCA (ISLOCA)	$2.2 \times 10^{-7}$	<1
<b>CDF from internal events</b>	<b><math>2.8 \times 10^{-5}</math></b>	<b>57</b>
Seismic	$1.1 \times 10^{-5}$	22
Tornado	$6.5 \times 10^{-6}$	13
Fire	$2.9 \times 10^{-6}$	6
<b>CDF from external events</b>	<b><math>2.1 \times 10^{-5}</math></b>	<b>43</b>
<b>Total CDF</b>	<b><math>4.9 \times 10^{-5}</math></b>	<b>100</b>

The Level 2 (also called containment performance) portion of the McGuire PRA model, Revision 2, is essentially the same as the IPE Level 2 analysis. However, the following changes were made:

- modifications to reflect an emergency operating procedure change that reduced the likelihood of restarting a reactor coolant pump following core damage, thus reducing the potential for thermally induced steam generator tube rupture
- modification of the containment event tree (CET) logic regarding the potential for corium contact with the containment liner
- modification of the CET logic and quantification to reflect that the refueling water storage tank inventory would drain through a failed reactor vessel in some sequences (e.g., SBO).

## Environmental Impacts of Postulated Accidents

These changes resulted in a large decrease in the potential for thermally-induced steam generator tube ruptures, a slight increase in the potential for early containment failure as a result of corium contact with the containment liner and a reduction in basemat melt-through due to reactor cavity flooding via the reactor vessel breach.

The offsite consequences and economic impact analyses (i.e., Level 3 PRA Analyses) were carried out using the NRC-developed MELCOR Accident Consequence Code System 2 (MACCS2) code. Inputs for this analysis include plant and site specific input values for core radionuclide inventory, source term and release fractions, meteorological data, projected population distribution, and emergency response evacuation modeling.

Duke estimated the dose to the population within 80 km (50 mi) of the McGuire site from all initiators (internal and external) to be about 0.135 person-sieverts (Sv) (13.5 person-rem) per year (Duke 2001). The breakdown of the total population dose by containment end-state is summarized in Table 5-4. Internal events account for approximately 0.060 person-Sv (6.0 person-rem) per year, and external events account for approximately 0.075 person-Sv (7.5 person-rem) per year. As can be seen from this table, early and late containment failures account for the majority of the population dose.

**Table 5-4.** Breakdown of Population Dose by Containment End-State  
(Total dose = 0.135 person-Sv [13.5 person-rem] per year)

Containment End State	% of Total Dose Internal Initiators	% of Total Dose External Initiators	% of Total Dose All Initiators
SGTR <sup>(a)</sup>	<0.1	<0.1	<0.1
ISLOCA <sup>(a)</sup>	19.4	0.0	19.4
Containment isolation failure	0.1	0.3	0.4
Early containment failure	8.5	32.1	40.6
Late containment failure	15.9	23.3	39.2
Basemat melt-through	<0.1	<0.1	<0.1
No containment failure	0.3	0.1	0.4
<b>Total</b>	<b>44.2</b>	<b>55.8</b>	<b>100</b>

(a) Containment bypass events



### 5.2.2.2 Review of Duke's Risk Estimates

Duke's estimate of offsite risk at McGuire is based on the Revision 2 of the McGuire PRA and a separate MACCS2 analysis. For the purposes of this review, the staff considered the following major elements:

- the Level 1 and 2 risk models that form the bases for the November 1991 IPE submittal (Duke 1991)
- the major modifications to the IPE models that have been incorporated in Revision 2 of the PRA (Duke 1998)
- the external events models that form the basis for the June 1994 IPEEE submittal (Duke 1994)
- the analyses performed to translate fission product release frequencies from the Level 2 PRA model into offsite consequence measures (Duke 2001).

The staff reviewed each of these analyses to determine the acceptability of Duke's risk estimates for the SAMA analysis, as summarized below.

The staff's review of the McGuire IPE is described in a staff report dated June 30, 1994 (NRC 1994). In that review, the staff evaluated the methodology, models, data, and assumptions used to estimate the CDF and characterize containment performance and fission product releases. The staff concluded that Duke's analysis met the intent of Generic Letter 88-20 (NRC 1988), which means the IPE was of adequate quality to be used to look for design or operational vulnerabilities. The staff's review primarily focused on the licensee's ability to examine McGuire for severe accident vulnerabilities and not specifically on the detailed findings or quantification estimates. Overall, the staff concluded that the McGuire IPE was of adequate quality to be used as a tool in searching for areas with high potential for risk reduction and to assess such risk reductions, especially when the risk models are used in conjunction with insights, such as those from risk importance, sensitivity, and uncertainty analyses.

The staff's review of the McGuire IPEEE is described in an evaluation report dated February 16, 1999 (NRC 1999b). Duke did not identify any fundamental weaknesses or vulnerabilities to severe accident risk with regard to the external events. In the safety evaluation report, the staff concluded that the IPEEE met the intent of Supplement 4 to Generic Letter 88-20 (NRC 1991) and that the licensee's IPEEE process is capable of identifying the most likely severe accidents and severe accident vulnerabilities.

## Environmental Impacts of Postulated Accidents

In a RAI (NRC 2001), the staff questioned why the CDF for steam generator tube rupture events in Revision 2 to the PRA is so low relative to other pressurized-water reactor (PWR) PRAs. In response (Duke 2002a), Duke stated that

The McGuire SGTR model incorporated in both the IPE and in the 1997 update relied upon success criteria established during the IPE development. Where applicable, the system success criteria were established with the then current version of the MAAP [Modular Accident Analysis Program] code. Furthermore, a sequence was categorized as a success because core damage occurred beyond 24 hours, even though a safe stable state had not been attained, this is inconsistent with what is now the generally accepted industry practice. As a result of comments received during the McGuire peer review process, these success criteria were revisited. The new MAAP results showed core damage to occur where the original analysis did not. The outdated success criteria are judged to be the most significant contributors to the comparatively low SGTR initiated CDF previously reported. The SGTR analysis is being completely revisited in Revision 3 to the McGuire PRA, which is still in development. This new analysis estimates the CDF for SGTR at  $5.3 \times 10^{-7}$  per year, which is more in line with similar plants.

In a February 7, 2002, telephone conference with Duke, the staff questioned the impact that other Revision 3 PRA results might have on the conclusions drawn in the McGuire ER, because the change for the SGTR event was not trivial. In response (Duke 2002b), Duke provided the CDF values from Revision 3 of the McGuire Level 1 PRA, broken out by the major contributors. Peer review of the Level 2 and 3 portions of the PRA Revision 3 had not yet been completed. Thus, revised Level 2 and 3 information was not provided. A comparison of the CDF results from the various versions of the McGuire PRA is provided in Table 5-5. Duke's SAMA assessment was based on PRA Revision 2 since the Revision 3 results available at the time of the analysis (and reported in the draft SEIS) were preliminary. Results from the final approved version of Revision 3, completed subsequent to the draft SEIS, were provided by Duke by letter dated August 2, 2002 (Duke 2002b) and are included in Table 5-5. The differences between the final Revision 3 results and the preliminary Revision 3 results reported in the draft SEIS are not significant and do not have any impact on the staff's analysis or conclusions. The staff based its assessment on the CDF and offsite doses derived from PRA Revision 2, but also considered the impact that the use of CDF estimates from Revision 3 of the PRA might have on the risk results. Note that the CDF values for Revision 1 were not broken out for the individual internal event categories in Table 5-5 because Revision 2 was used as the basis of the staff's evaluation.

Based on a comparison of the frequency of major contributors to CDF, the following key differences were noted:

## Environmental Impacts of Postulated Accidents

- The SGTR frequency in Revision 3 is more than a factor of 600 larger than in Revision 2 ( $5.3 \times 10^{-7}$  per year versus  $7.8 \times 10^{-10}$  per year). This increase is due to the use of revised, more technically-supported success criteria as discussed above.
  
- The SBO frequency in Revision 3 is more than a factor of two smaller than in Revision 2 ( $1.0 \times 10^{-5}$  per year versus  $2.3 \times 10^{-5}$  per year). This reduction is due to credit taken for installing improved reactor coolant pump O-ring seals that would be capable of withstanding higher temperatures and would have a higher likelihood of remaining intact under loss of seal-cooling conditions.

**Table 5-5.** Comparison of CDF Results by Accident Initiator or Sequence

Accident Initiator/Sequence	PRA, Rev. 1 (IPE)	PRA, Rev. 2	PRA, Rev. 3
Internal Floods	--	$8.7 \times 10^{-7}$	$5.4 \times 10^{-6}$
Transients	--	$1.5 \times 10^{-5}$	$2.9 \times 10^{-6}$
LOCAs	--	$1.1 \times 10^{-5}$	$8.8 \times 10^{-6}$
RPV	--	$1.0 \times 10^{-6}$	$1.0 \times 10^{-6}$
SGTR	--	$7.8 \times 10^{-10}$	$5.3 \times 10^{-7}$
ATWS	--	$1.5 \times 10^{-7}$	$5.3 \times 10^{-7}$
ISLOCA	--	$2.2 \times 10^{-7}$	$9.8 \times 10^{-7}$
<b>CDF from internal events</b>	<b><math>4.0 \times 10^{-5}</math></b>	<b><math>2.8 \times 10^{-5}</math></b>	<b><math>2.0 \times 10^{-5}</math></b>
	(IPEEE)		
Seismic	$1.1 \times 10^{-5}$	$1.1 \times 10^{-5}$	$8.9 \times 10^{-6}$
Tornado	$1.9 \times 10^{-9}$	$6.5 \times 10^{-6}$	$1.6 \times 10^{-6}$
Fire	$2.3 \times 10^{-7}$	$2.9 \times 10^{-6}$	$6.3 \times 10^{-6}$
<b>CDF from external events</b>	<b><math>3.0 \times 10^{-5}</math></b>	<b><math>2.0 \times 10^{-5}</math></b>	<b><math>1.7 \times 10^{-5}</math></b>
<b>Total CDF</b>	<b><math>7 \times 10^{-5}</math></b>	<b><math>4.8 \times 10^{-5}</math></b>	<b><math>3.7 \times 10^{-5}</math></b>
SBO (internal & external events) <sup>(a)</sup>	$4.1 \times 10^{-5}$	$2.3 \times 10^{-5}$	$1.0 \times 10^{-5}$

(a) the internal and external event frequencies above include contributions from SBO events; the CDF for SBO events is broken out here separately for illustrative purposes.

The impact of the revised SGTR and SBO frequencies on the risk reduction estimates for related SAMAs was considered in the staff's review (see Sections 5.2.4 and 5.2.6.2). The frequency of other CDF contributors was impacted to a much lesser degree, and these changes are not expected to alter results of the SAMA analysis.

The staff reviewed the process used by Duke to extend the containment performance (Level 2) portion of the IPE to the offsite consequence (Level 3) assessment. This included consideration of the source terms used to characterize fission product releases for each

## Environmental Impacts of Postulated Accidents

containment release category and the major input assumptions used in the offsite consequence analyses. This information is provided in Section 6 of Duke's IPE submittal. Duke used the MAAP code to analyze postulated accidents and develop radiological source terms for each of 31 containment release categories used to represent the containment end-states. These source terms were incorporated as input to the MACCS2 analysis. The MACCS2 code is the current standard for assessing consequences of accidents at nuclear power plants. The staff reviewed Duke's source term estimates for the major release categories and found these predictions to be in reasonable agreement with estimates from NUREG-1150 (NRC 1990) for the closest corresponding release scenarios. The staff concludes that the assignment of source terms is acceptable.

The plant-specific input to the MACCS2 code includes the McGuire reactor core radionuclide inventory, emergency response evacuation modeling based on McGuire evacuation time estimate studies, release category source terms from the McGuire PRA, Revision 2 analysis (same as the source terms used in the IPE), site-specific meteorological data, and projected population distribution within a 80 km (50 mi) radius for the year 2040.

MACCS2 requires a file of hourly meteorological data consisting of wind speed, wind direction, atmospheric stability category, and precipitation. For the McGuire SAMA analysis, meteorological data was obtained from the meteorological tower located on the McGuire site; the meteorological data used in MACCS2 contained data for one year, January 1 through December 31, 1999.

The McGuire PRA, Revision 2 and the SAMA offsite consequence analyses use three distinct evacuation schemes in order to adequately represent evacuation time estimates for the permanent resident population, the transient population, and the special facility population (e.g., schools, hospitals, etc.). The three groups are defined by the time delay from initial notification to start of evacuation. For each evacuation scheme, the fraction of the population starting their evacuation is included. For the permanent resident evacuation schemes, it was assumed that 5 percent of the population would delay evacuation for 24 hours after being warned to evacuate. The delay time and fraction of population for the remaining two schemes were developed from information given in the latest update to the McGuire evacuation time estimate study for the 16-km (10-mi) Emergency Planning Zone (EPZ). The evacuation schemes include additional information such as evacuation distance, average evacuation speed, sheltering, and shielding considerations. In the McGuire evacuation model, only the 10-mile EPZ is assumed to be involved in the initial evacuation. The MACCS2 model assumes that persons outside of the 10-mile EPZ will wait 24 hours before evacuating (provided that radiological conditions warrant evacuation).

The staff reviewed the Duke responses (Duke 2002a) to questions regarding meteorological data, population data and emergency planning. Those responses confirmed that Duke used appropriate values for the consequence analysis.

The staff concludes that the methodology used by Duke to estimate the CDF and offsite consequences for McGuire provides an acceptable basis from which to proceed with an assessment of the risk reduction potential for candidate SAMAs. Additionally, the risk profile used is similar to other PWRs with ice condenser containments. The staff based its assessment of offsite risk on the CDF and offsite doses reported by Duke, but also considered the impact that the use of CDF estimates from Revision 3 of the PRA might have on the risk results.

### **5.2.3 Potential Plant Improvements**

This section discusses the process for identifying potential design improvements, the staff's evaluation of this process, and the design improvements evaluated in detail by Duke.

#### **5.2.3.1 Process for Identifying Potential Plant Improvements**

Duke's process for identifying potential plant improvements consisted of the following elements:

- The core damage cut sets from Revision 2 of the McGuire PRA were reviewed to identify potential SAMAs that could reduce CDF.
- The Fussell-Vesely (F-V) importance measures were evaluated for the basic events (including initiating events, random failure events, human error events, and maintenance and testing unavailabilities), and the importance ranking was examined to identify any events of significant F-V importance.
- Potential enhancements to reduce containment failure modes of concern for McGuire (including early containment failure, containment isolation failure, and containment bypass) were reviewed for possible implementation.

In addition, Duke reviewed the Watts Bar SAMDA analysis (NRC 1995a) and insights from the staff's report on the IPE (NRC 1997c) to identify additional SAMAs.

As a starting point for the core damage cut set review, Duke developed a listing of the top 100 cut sets (severe accident sequences) based on internal initiators and the top 100 cut sets for external initiators. These 200 sequences include all potential core damage sequences with at least a 0.06 percent contribution to the total CDF. Additionally, some cut sets contributing as little as 0.05 percent to the total CDF were considered. Duke reviewed the cut sets to identify potential SAMAs that could reduce CDF. A cutoff value of  $3.5 \times 10^{-7}$  per year (for internal and

## Environmental Impacts of Postulated Accidents

external event initiators) was used to screen events. To account for the cumulative effect of cut sets below this cutoff value, the basic events importance measure was also used to identify potential enhancements, as discussed below. Duke indicated in responses to the RAIs (Duke 2002) that the estimated CDF for the 200 cut sets is  $4.4 \times 10^{-5}$  per year, which is about 90 percent of the total CDF.

For each seismic initiator cut set, Duke calculated the associated offsite risk based on the population dose and CDF for the plant damage states (PDSs) attributable to the seismic initiator. Duke conservatively assumed that the implementation of plant enhancements for seismic events would completely eliminate the seismic risk and calculated the present worth of the averted risk based on a \$200,000 per person-Sv (\$2000 per person-rem) conversion factor, a discount factor of 7 percent, and an additional 20-year license renewal period. This process was repeated for each of the remaining seismic initiator cutsets above the cutoff frequency. The present worth of averted risk for all of the seismic cutsets combined was estimated to be about \$275,000 (not including the cost of replacement power and offsite property damage, the significance of which is discussed in Section 5.2.6.2). On the basis of the small risk reduction achievable [0.041 person-Sv (4.1 person-rem)] and the large costs associated with substantial seismic upgrades (estimated at several million dollars), Duke eliminated seismic SAMAs from further consideration.

Duke reviewed the F-V Basic Event Importance Ranking presented in the McGuire PRA report, Revision 2, and identified several basic events for further consideration. These included internal event initiators, seismic-related events, equipment failures, and human-error events. Seismic-related events were not evaluated further for the reasons discussed above. Seven potential enhancements to reduce CDF were identified through this process and are presented in Table 5-6.

In the ER, Duke identified the installation of back-up power to the igniters and the installation of back-up power to air return fans as two separate SAMAs. However, in responses to staff RAIs, Duke indicated that the availability of air return fans would be essential to the effective operation of igniters in an SBO; therefore, Duke treated the combined modification as a single SAMA. Accordingly, these two hydrogen control related SAMAs are shown as a single SAMA in Table 5-7. This effectively reduces the number of containment-related SAMAs to eight.

Duke also considered potential alternatives to reduce containment failure modes of concern for McGuire. These alternatives included nine containment-related improvements evaluated as part of the staff's assessment of SAMDAs for Watts Bar (NRC 1995a) and five containment-related improvements (e.g., procedures for reactor coolant system depressurization and procedures to cope with and reduce induced SGTR) derived from the staff's generic report on the individual plant examination program (NRC 1997c). Duke eliminated those alternatives that are either (1) already implemented at McGuire or (2) not applicable to the McGuire containment

**Table 5-6.** SAMA Cost/Benefit Screening Analysis – SAMAs That Reduce CDF

Potential Alternative	Sequences/Failures Addressed	Risk Reduction		Total Benefit	Cost of Enhancement
		CDF <sup>(a)</sup>	Population Dose <sup>(b)</sup> (person-rem <sup>(c)</sup> )		
Man standby shutdown facility (SSF) 24 hours/day with trained operator	<p>Loss of service water (RN), failure of operators to align safe shutdown (SS) system for operation, filter (standby makeup pump) restricts flow, failure to align containment ventilation cooling water system (RV) cooling/other Unit RN</p> <p>Vital instrumentation and control (I&amp;C) Fire causes a Loss of RN, failure of operators to align SS system for operation, failure to use other Unit or remote control during fire</p> <p>Loss of 4160V essential bus and failure to align SS system for operation</p> <p><u>AND</u></p> <p>Tornado causes LOOP, DG 1A and 1B fail to fun, operators fail to initiate SS system operation</p>	1.1×10 <sup>-5</sup>	3.2	\$380,000	>\$2.5 M <sup>(d)(e)</sup>

(a) Total CDF = 4.9×10<sup>-5</sup> per year

(b) Total population dose = 13.5 person-rem per year

(c) One person-Sv = 100 person-rem

(d) Cost estimates for manning the standby shutdown system apply on a per-site rather than a per-unit basis. To provide a consistent basis for comparison with the estimated benefits (which are per unit), the estimated site costs were divided by two.

(e) M =millions

**Table 5-6. (contd)**

Potential Alternative	Sequences/Failures Addressed	Risk Reduction		Total Benefit	Cost of Enhancement
		CDF <sup>(a)</sup>	Population Dose <sup>(b)</sup> (person-rem <sup>(c)</sup> )		
Install automatic swap over to high-pressure recirculation	LOCA cut sets with failure of operators to establish high pressure recirculation	$1.0 \times 10^{-5}$	0.4	\$291,000	>\$1 M <sup>(e)</sup>
Install automatic swap to RV/other unit RN system upon loss of RN	Loss of RN, failure of operators to align SS system for operation, filter (Standby Makeup Pump) restricts flow, failure to align RV/other Unit RN	$8.8 \times 10^{-6}$	1.2	\$275,000	>\$1 M
Install third diesel generator	Tornado causes LOOP, DG 1A and 1B fail, and operators fail to initiate SS system operation	$8.4 \times 10^{-6}$	3.1	\$304,000	>\$2 M
Install automatic swap to other unit	Vital I&C Fire causes a Loss of RN, failure of operators to align SS system for operation, failure to use other Unit or remote control during fire	$2.9 \times 10^{-6}$	1.1	\$106,000	>\$1 M
Increase test frequency of standby makeup pump flow path (currently tested quarterly)	Loss of RN, failure of operators to align SS system for operation, filter (Standby Makeup Pump) restricts flow, failure to align RV cooling/other Unit RN	$1.8 \times 10^{-6}$	0.5	\$62,000	>\$0.4 M
Replace reactor vessel with stronger vessel	Failure of reactor pressure vessel with failure to prevent core damage following a reactor pressure vessel breach	$1.0 \times 10^{-6}$	<0.1	\$30,000	>\$1 M

(a) Total CDF =  $4.9 \times 10^{-5}$  per year

(b) Total population dose = 13.5 person-rem per year

(c) One person-Sv = 100 person-rem

(e) M = millions



**Table 5-7.** SAMA Cost/Benefit Screening Analysis – SAMAs That Improve Containment Performance

Potential Alternative	Risk Reduction		Total Benefit (per unit)	Cost of Enhancement (per unit)
	CDF	Population Dose (person-rem <sup>(a)</sup> )		
Install independent containment spray system	NA	10.8	\$349,000 <sup>(b)</sup>	>\$1 M <sup>(c)</sup>
Install filtered containment vent system	NA	10.8	\$349,000 <sup>(b)</sup>	>\$1 M
Install back-up power to igniters and install back-up power to air return fans	NA	10.8	\$349,000 <sup>(b)</sup>	\$540,000
Install containment inerting system	NA	10.8	\$349,000 <sup>(b)</sup>	>\$1 M
Install additional containment bypass instrumentation	NA	2.6	\$84,000	>\$1 M
Add independent source of feedwater to reduce induced SGTR	NA	< 0.1	< \$3,200	>\$1 M
Install reactor cavity flooding system	NA	5.6	\$181,000	>\$1 M
Install core retention device	NA	< 0.1	< \$3,200	>\$1 M

(a) One person-Sv = 100 person-rem

(b) Total benefit based on eliminating all early and late containment failures

(c) M = millions

design. Based on the screening, Duke designated nine of the containment- related SAMAs for further study. The list of the potential enhancements to improve containment performance is presented in Table 5-7.

### 5.2.3.2 Staff Evaluation

It should be noted that Duke has made extensive use of PRA methods to gain insights regarding severe accidents at McGuire. Risk insights from various McGuire risk assessments have been identified and implemented to improve both the design and operation of the plant. For example, using the IPE process, Duke (1) modified procedures to better cope with a loss of nuclear service water event and to better prioritize operator actions in a loss of alternating current (ac) power event; (2) added procedures to exercise the nuclear service water cross-connect valves between Unit 1 and 2 during each refueling outage; (3) fitted expansion joints in the nuclear service water piping located in the auxiliary feedwater pump room with a collar to limit the leak rate; (4) made a number of changes to enhance the reliability of the Emergency Diesel Generator System; (5) performed training exercises to ensure that the operators can

## Environmental Impacts of Postulated Accidents

| activate the standby shutdown facility (SSF) within 10 minutes; and (6) expanded the refueling water storage tank (FWST) level instrumentation span to the full range to reduce the potential for operator error during switchover to sump recirculation. Examples of plant improvements being planned for implementation by Duke based on IPEEE findings include:

- | (1) adding spacers between the Unit 1 DG batteries and racks
- | (2) adding grout between component cooling heat exchangers saddle base and concrete curb
- | (3) trimming the grating around the steam vent valves
- | (4) replacing some missing bolts on the Unit 2 upper surge tanks
- | (5) adding some additional procedural guidelines to secure movable equipment and structures to prevent potential seismic interactions.

The implementation of such improvements reduced the risk associated with the major contributors identified by the McGuire PRA and contributed to the reduced number of candidate SAMAs identified as part of Duke's application for license renewal.

Duke's effort to identify potential SAMAs focused on areas found to be risk-significant in the McGuire PRA. The SAMAs listed generally coincide with accident categories that are dominant CDF contributors or with issues that tend to have a large impact on a number of accident sequences at McGuire. Duke made a reasonable effort to use the McGuire PRA to search for potential SAMAs and to review insights from other plant-specific risk studies and previous SAMA analyses for potential applicability to McGuire. The staff reviewed the set of potential enhancements considered in Duke's SAMA identification process. These include improvements oriented toward reducing the CDF and risk from major contributors specific to McGuire and improvements identified in the previous SAMDA review for Watts Bar (NRC 1995a) that would be applicable to McGuire.

The staff notes that most of the SAMAs involve major modifications and significant costs and that less expensive design improvements and procedure changes could conceivably provide similar levels of risk reduction. The staff requested additional information (NRC 2001) from Duke on less expensive alternatives that would yield similar benefits. In response, Duke provided additional information on alternative power to hydrogen igniters for SBO and passive autocatalytic recombiners (PARs) as an alternative to igniters. Duke also provided an estimate of the cost to install a dedicated line from the Cowan's Ford hydroelectric station, as an alternative source of ac power. This information was responsive to the staff's requests and provided additional depth to the SAMAs considered. These additional alternatives are further evaluated, along with the other SAMAs, in the sections that follow.

The staff concludes that Duke has used a systematic process for identifying potential design improvements for McGuire and that the set of potential design improvements identified by Duke is reasonably comprehensive and, therefore, acceptable.

#### 5.2.4 Risk Reduction Potential of Plant Improvements

Section 4.3 of Attachment K to the ER describes the process used by Duke to determine the risk reduction potential for each enhancement.

For each seismic initiator cut set, Duke calculated the associated offsite risk based on the population dose and CDF for the PDSs attributable to the seismic initiator. Implementation of the plant enhancement was assumed to completely eliminate the seismic risk associated with the cut set. For each (non-seismic) sequence/enhancement, Duke evaluated the severe accident sequences. In general, where an alternative impacted more than one severe accident sequence, Duke determined the cumulative risk reduction achievable by each SAMA. This was performed by identifying which basic events in the cut sets would be affected by the implementation of the particular SAMA and assuming that the implementation of the SAMA would eliminate the basic event. For each containment-related improvement, Duke assumed that all of the population dose associated with the release categories impacted by the SAMA would be eliminated. For those alternatives that benefit more than one containment failure mode (i.e., independent containment spray system, filtered containment vent, back-up power to igniters and air return fans, containment inerting system, and reactor cavity flooding system), the total population dose for all affected failure modes was assumed to be completely eliminated by implementing the alternative. For example, installation of a standpipe in containment for reactor cavity flooding, which could reduce the likelihood of both early containment failure associated with reactor vessel breach and late containment failure due to basemat melt-through, was assumed to completely eliminate the associated early and late containment failures.

In responses to follow-up RAIs (NRC 2002a), Duke noted that the risk reduction estimates had changed in some instances when the PRA was updated to Revision 3. The final Revision 3 CDF results are summarized in Section 5.2.2.2 (Duke 2002b). One significant change was an increase in the CDF for SGTR events. According to Duke, this change yielded an estimated increase in population dose of approximately 0.04 person-Sv (4 person-rem). Duke reassessed the benefits of completely eliminating SGTR based on this new information, and calculated a maximum benefit of approximately \$101,000 (present worth for the 20-year license renewal period). It is Duke's position that it is unlikely that a cost-beneficial alternative could be implemented to further reduce the SGTR risk based on such a low benefit estimate. The staff concurs with this assessment. Use of the PRA Revision 3 CDF estimates in lieu of the PRA Revision 2 CDF values would not appear to introduce any other significant changes to the risk profile that would make any of the other candidate SAMAs more cost-beneficial and might make some SAMAs less cost-beneficial, particularly SAMAs related to SBO events.

## Environmental Impacts of Postulated Accidents

The staff questioned Duke regarding why the SAMA involving addition of a third DG was estimated to provide only a small (about 36 percent) reduction in the CDF for SBO sequences (NRC 2001). Duke indicated that the risk reduction was based on eliminating all failures to start, failures to run, and common-cause failures of the existing two diesels. However, it was assumed that the third DG would not be seismically qualified; therefore, it would not be effective in seismic events. Because seismic events account for approximately half of the SBO CDF, the limited risk reduction estimated for the third DG appears reasonable. Duke also considered the additional benefit if the third DG were seismically qualified, similar to the existing DGs. Duke estimated that an additional reduction in CDF of about  $1.3 \times 10^{-6}$  per year would be achieved by eliminating all random failures of DGs in seismic events. This risk reduction is limited because the seismic results are dominated by seismic failures in the 4-kV power system for which improving DG availability provides no benefit. The staff concludes that Duke's risk reduction estimates for this SAMA are reasonable.

An estimate of the risk reduction for the SAMA involving installation of a dedicated power line from the Cowan's Ford hydroelectric station was not provided in Duke's RAI response. However, the risk reduction would be comparable to that for adding a third DG, because the seismic fragility of the hydroelectric unit is expected to be similar to that for the seismically qualified DGs.

The staff notes that Duke evaluated the risk reduction potential for each SAMA, including the dedicated power line, in a bounding fashion. Each SAMA was assumed to completely eliminate all sequences that the specific enhancement was intended to address; therefore, the benefits are generally overestimated and conservative. The staff also notes that use of the PRA Revision 3 CDF estimates in lieu of the PRA Revision 2 CDF values would not appear to introduce any significant changes to the risk profile that would make any of the candidate SAMAs cost-beneficial, including SAMAs related to SGTR events. Accordingly, the staff based its estimates of averted risk for the various SAMAs on Duke's risk reduction estimates.

### **5.2.5 Cost Impacts of Candidate Plant Improvements**

Duke's estimated costs for each potential design enhancement are provided in Table 4-2 and Section 5.3 of Attachment K to the ER. For most of the SAMAs, Duke estimated the cost of implementation to be greater than \$1 million based on cost estimates developed in previous industry studies. For two SAMAs, Duke developed plant-specific cost estimates because there was no readily available information on the estimated cost to implement similar alternatives and because the basic events associated with these alternatives were found to have a high importance in the McGuire PRA. These SAMAs involve (1) installing a third DG, and (2) increasing the test frequency of the standby makeup pump flow path. The costs to implement these SAMAs were estimated to be on the order of \$2 million and \$435,000, respectively. Because the benefits of the potential SAMAs were significantly less than their estimated implementation costs (by a factor of three or more), none of the cost estimates were further

refined. Specifically, the benefit of adding a third DG was about \$304,000 while the benefit of increasing the test frequency was about \$62,000 (see Table 5-6).

The staff compared Duke's cost estimates with estimates developed elsewhere for similar improvements, including estimates developed as part of the evaluation of SAMDAs for operating reactors and advanced light-water reactors (LWRs). The staff notes that Duke's estimated implementation costs of \$1 million dollars or greater are consistent with the values reported in previous analyses for major hardware changes of similar scope and are not unreasonable for the SAMAs under consideration, given that these enhancements involve major hardware changes and impact safety-related systems. For example, Duke estimated the cost to install a third DG to be approximately \$2 million; this value is less than the cost estimates reported in previous SAMDA analyses for a similar design change.

Duke's estimate of the cost to install a dedicated line from the Cowan's Ford hydroelectric station as an alternate source of ac power also appears reasonable. This line would be buried to eliminate weather-related common-cause failures. The estimated cost (\$3 million) is comparable to the cost estimate provided by Dominion Power (NRC 2002c) for a similar modification at the Surry Nuclear Power Station (\$2 million to \$5 million), but is far greater than the calculated benefit of \$300K for McGuire.

The staff questioned Duke regarding the costs of less expensive alternatives that could offer similar risk reduction benefits, particularly with regard to hydrogen control in SBO events. In a January 31, 2002, response to staff RAIs (Duke 2002a), Duke provided additional information on the costs associated with installing a passive hydrogen control system based on the use of PARs in lieu of the present ac-dependent hydrogen igniters, and the costs of powering a subset of the current hydrogen igniters from a back-up generator. For scoping purposes, Duke provided supplementary information regarding the cost of back-up power to the igniters and air return fans in response to a follow-up RAI (NRC 2002a).

Duke's estimate of the cost to establish a capability to power a subset of igniters from a back-up generator was \$205,000 for each unit. This modification, as defined by Duke, would involve prestaging a single, dedicated generator for each unit outdoors on a concrete pad (for ventilation and exhaust considerations) and supplying the necessary power cables and circuit breakers to enable connection to the igniter branch circuits. The breakdown of this cost is: \$5,000 for engineering, \$50,000 for materials, \$110,000 for installation labor, and \$40,000 for maintenance and operation. This cost estimate does not include an enclosure, tornado protection for the generator, or any seismic design. Duke further noted that providing electric power to hydrogen igniters during a SBO will not be effective without also powering at least one of the containment air return fans and that this will further increase the cost of this option. When one air return fan is added to this estimate, the combined cost is \$540,000. The breakdown of this cost is: \$50,000 for engineering, \$210,000 for materials \$240,000 for installation labor, and \$40,000 for maintenance and operation. Duke points out there will be additional costs not included in these estimates.

## Environmental Impacts of Postulated Accidents

The staff requested additional information on PARs, because PARs are to be installed in French PWRs by 2007 to mitigate the consequences of hydrogen combustion events. In response (Duke 2002a), Duke estimated that the installation of PARs would cost more than \$750,000 per unit, which is well above the estimated benefit (see Table 5-8, Section 5.2.6.2). This cost estimate is consistent with independent staff cost estimates for installing PARs.

The staff asked for further information on the basis for the greater than \$1 million cost estimate for two other SAMAs: (1) install automatic swap-over to high pressure recirculation, and (2) install automatic swap-over to the containment ventilation cooling water system or the other unit's service water system upon loss of the service water system. Duke (NRC 2002a) referenced NUREG-0498, Supp. 1 (NRC 1995a), which estimated a cost of about \$2.1 million for a similar alternative, i.e., "automate the alignment of emergency core cooling system (ECCS) recirculation to the high-pressure charging and safety injection pumps." This would reduce the potential for related human errors made during manual realignment. This cost estimate applies to both of these candidate SAMAs and is considerably higher than the estimated averted risk benefits for McGuire of about \$291,000 and \$275,000 respectively. (Benefits are discussed further in Section 5.2.6.)

The staff concludes that the cost estimates provided by Duke are reasonable and adequate for the purposes of this SAMA evaluation. As noted in Section 5.2.6.2, further attention will be placed on the costs associated with SBO-related plant improvements by the NRC as part of the resolution of Generic Safety Issue 189 - Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident (NRC 2002b).

### 5.2.6 Cost-Benefit Comparison

The cost-benefit comparison as evaluated by Duke and the staff evaluation of the cost-benefit analysis are described in the following sections.

#### 5.2.6.1 Duke Evaluation

In the analysis provided in the McGuire ER, Duke did not include the following factors in its cost-benefit evaluation: replacement power costs for SAMAs that have the potential to reduce CDF and averted offsite property damage costs for SAMAs that have the potential to improve containment performance. In view of the significant impact of these averted costs on the estimated benefit for a SAMA, the staff requested that Duke include these factors in the cost-benefit analysis for each affected SAMA. In response to the RAI (Duke 2002a), Duke updated the benefit estimates to include averted replacement power costs (ARPC) and averted offsite property damage costs (AOC).

The methodology used by Duke was based primarily on NRC's guidance for performing cost-benefit analysis in NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997b). The guidance involves determining the net value for each SAMA according to the following formula:

$$\text{Net Value} = (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE}$$

where APE = present value of averted public exposure (\$)  
 AOC = present value of averted offsite property damage costs (\$)  
 AOE = present value of averted occupational exposure costs (\$)  
 AOSC = present value of averted onsite costs (\$)  
 COE = cost of enhancement (\$)

If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the benefit associated with the SAMA and it is not considered cost-beneficial. Duke's derivation of each of the associated costs is summarized below.

Averted Public Exposure (APE) Costs

The APE costs were calculated using the following formula:

$$\begin{aligned} \text{APE} = & \text{Annual reduction in public exposure } (\Delta \text{ person-rem/reactor year}) \\ & \times \text{monetary equivalent of unit dose } (\$2000 \text{ per person-rem}) \\ & \times \text{present value conversion factor } (10.76 \text{ based on a 20-year period with a} \\ & \text{7-percent discount rate}) \end{aligned}$$

As stated in NUREG/BR-0184 (NRC 1997b), it is important to note that the monetary value of the public health risk after discounting does not represent the expected reduction in public health risk due to a single accident. Rather, it is the present value of a stream of potential losses extending over the remaining lifetime (in this case, the renewal period) of the facility. Thus, it reflects the expected annual loss due to a single accident, the possibility that such an accident could occur at any time over the renewal period, and the effect of discounting these potential future losses to present value. Duke used the following expression when calculating the APE for the 20-year license renewal period:

$$\text{APE} = \$2.20 \times 10^4 \times (\text{Change in public exposure})$$

Averted Offsite Property Damage Costs (AOC)

For SAMAs that reduce CDF, the AOCs were calculated using the following formula:

$$\begin{aligned} \text{AOC} = & \text{Annual CDF reduction} \\ & \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ & \times \text{present value conversion factor} \end{aligned}$$

## Environmental Impacts of Postulated Accidents

Duke derived the values for averted offsite property damage costs based on information provided in Section 5.7.5 of NUREG/BR-0184 (NRC 1997b). A discount factor of 7 percent and a 4-percent rate of inflation were used. Duke used the following expression when calculating the AOC for the 20-year license renewal period:

$$\text{AOC} = \$3.92 \times 10^9 \times (\text{Change in annual CDF})$$

Originally, as part of the ER, Duke did not include the AOC for containment-related SAMAs. In response to staff RAIs, Duke incorporated AOC as follows (Duke 2002a).

For containment-related SAMAs (which impact population dose but not CDF), Duke estimated the combined AOC and averted public exposure costs (APE) based on a conversion factor of \$3000/person-rem, which was attributed to NUREG/CR-6349 (NRC 1995b). Duke used the following expression when calculating these costs (for containment-related SAMAs) for the 20-year license renewal period:

$$\text{AOC} + \text{APE} = \$3.23 \times 10^4 \times (\text{Change in public exposure})$$

### Averted Occupational Exposure (AOE) Costs

The AOE costs were calculated using the following formula:

$$\begin{aligned} \text{AOE} = & \text{Annual CDF reduction} \\ & \times \text{occupational exposure per core damage event} \\ & \times \text{monetary equivalent of unit dose} \\ & \times \text{present value conversion factor} \end{aligned}$$

Duke derived the values for averted occupational exposure based on information provided in Section 5.7.3 of NUREG/BR-0184 (NRC 1997b). Best-estimate values provided for immediate occupational dose [33 person-Sv (3300 person-rem)] and long-term occupational dose [200 person-Sv (20,000 person-rem) over a 10-year cleanup period] were used. The present value of these doses was calculated using the equations provided in NUREG/BR-0184 in conjunction with a monetary equivalent of unit dose of \$2000 per person-rem, a discount rate of 7 percent, and a time period of 20 years to represent the license-renewal period. Duke used the following expression when calculating the AOE for the 20-year license renewal period:

$$\text{AOE} = \$3.1 \times 10^8 \times (\text{Change in annual CDF})$$

### Averted Onsite Costs (AOSC) (Not Including Replacement Power Costs)

The AOSCs, as calculated by Duke, include averted cleanup and decontamination costs. NUREG/BR-0184, Section 5.7.6.2, states that long-term replacement power costs must also be



considered (NRC 1997b). Duke did not include this cost in the ER. However, Duke did add this cost in the responses (Duke 2002a) to the staff's RAIs.

Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

$$\begin{aligned} \text{ACC} &= \text{Annual CDF reduction} \\ &\quad \times \text{present value of cleanup costs per core damage event} \\ &\quad \times \text{present value conversion factor} \end{aligned}$$

The total cost of cleanup and decontamination subsequent to a severe accident is estimated in NUREG/BR-0184 (NRC 1997b) as  $\$1.5 \times 10^9$  (undiscounted). This value was converted to present costs over a 10-year cleanup period and integrated over the term of the proposed license extension. Duke used the following expression when calculating the ACC for the 20-year license renewal period:

$$\text{ACC} = \$1.18 \times 10^{10} \times (\text{Change in annual CDF})$$

#### Averted Power Replacement Cost (APRC)

The Duke estimate of the annual power replacement cost for McGuire is based on an assumed discount rate of 7 percent for the 20-year license renewal period.

The estimated present power replacement costs of a severe accident occurring in each year of the license renewal period is given by (equation from NUREG/BR-0184):

$$PV_{RP} = [\$1.2 \times 10^8 / 0.07][1 - \exp(-0.07 \times 20)]^2$$

$$PV_{RP} = \$9.73 \times 10^8$$

Then, to estimate the net present value of power replacement over the 20-year license renewal (equation from NUREG/BR-0184, p. 5.44):

$$U_{RP} = [PV_{RP} / 0.07][1 - \exp(-0.07 \times 20)]^2$$

$$U_{RP} = \$7.89 \times 10^9$$

$$\text{APRC} = U_{RP} \times (\text{Change in annual CDF})$$

Because the averted power replacement cost from the NUREG is in 1990 dollars, an assumption is made to include a 4 percent inflation rate over 11 years to bring the value into 2001 dollars; therefore,

$$\text{APRC} = \$1.21 \times 10^{10} \times (\text{Change in annual CDF})$$

### Duke Results

The total benefit associated with each of the 15 SAMAs evaluated by Duke (seven that reduce CDF and eight that improve containment performance) is provided in Tables 5-6 and 5-7. One of the SAMAs has a positive net value (i.e., the total benefit is greater than the cost of the enhancement). All of the remaining SAMAs have a negative net value, even given the bounding risk-reduction benefits inherent in these estimates.

#### **5.2.6.2 Staff Evaluation**

The cost-benefit analysis provided by Duke (Duke 2001, 2002) was based primarily on NRC's *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997b). In the original ER, Duke did not include averted replacement power costs for SAMAs that reduce CDF or averted offsite property damage costs for SAMAs that improve containment performance. However, the impact of these factors was included in supplemental analyses provided by Duke in response to the staff's RAIs (Duke 2002a; NRC 2002a). The averted replacement power costs were assessed appropriately and the values calculated by Duke are consistent with independent staff assessments.

Duke used a conversion factor of \$3,000/person-rem to determine the averted offsite property damage and averted public exposure costs. This effectively assumes a \$1,000/person-rem conversion factor as a surrogate for averted offsite property damage, in addition to the accepted \$2,000/person-rem conversion factor for averted offsite public exposure costs.

Because offsite property damage costs are plant- and site-specific, it would be more consistent with standard practice to actually calculate the property damage using the MACCS code. Nevertheless, the averted offsite costs values (for health effects and property damage) calculated by Duke provide reasonably good agreement with typical site values and are acceptable for purposes of estimating the value of containment-related SAMAs. Inclusion of averted replacement power and offsite property damage costs did not result in identification of any additional cost-beneficial SAMAs, and would not call into question Duke's decision to eliminate seismic SAMAs from consideration, given the large costs associated with seismic SAMAs.

For most of the candidate SAMAs, the staff agrees with Duke that the SAMAs would clearly not be cost-beneficial because they have costs that are substantially (typically a factor of three or more) higher than the dollar equivalent of the associated benefits. This difference is considered to provide ample margin to cover uncertainties in the risk and cost estimates because estimates for these factors were generally evaluated in a conservative manner. This is true even when considering the 3 percent versus 7 percent discount rate sensitivity case or the use of a 40-year versus 20-year time period. However, the cost-benefit analyses for some of the SAMAs related to hydrogen control in SBO events have benefits that are similar in magnitude to the costs. The frequency of SBO events for McGuire account for 47 percent of the total CDF of

$4.9 \times 10^{-5}$  per year based on Revision 2 of the PRA and 27 percent of the total CDF of  $3.7 \times 10^{-5}$  per year based on Revision 3 of the PRA. Also, ice condenser containments have a higher degree of vulnerability to hydrogen combustion in SBO events, as described in NUREG/CR-6427 (NRC 2000).

NUREG/CR-6427 provided a simplified Level 2 analysis that studied the direct containment heating (DCH) issue for plants with ice condenser containments (NRC 2000) and found that early containment failure is dominated by hydrogen combustion events rather than DCH events, and that no ice condenser plant is inherently robust to all credible DCH or hydrogen combustion events in station blackout. The study concluded that all plants, especially McGuire, would benefit from reducing SBO frequency or from providing some means of hydrogen control that is effective in SBO events. It should be noted that the NUREG contains several assumptions that may be justified for purposes of dispositioning the DCH issue but are not necessarily consistent with the best-estimate philosophy or PRA (such as a bounding assumption that random ignition prior to vessel breach will not occur). Accordingly, the NUREG is useful for understanding the uncertainties associated with early containment failure probabilities, but should not be interpreted as providing a realistic or best-estimate evaluation of the potential for early containment failure as a result of hydrogen combustion during SBO events.

In light of the issues raised in NUREG/CR-6427 concerning the likelihood of early containment failure in SBO events, the staff requested Duke to provide a reevaluation of the benefits associated with the hydrogen control measures (install back-up power to igniters and air return fans) assuming a containment response consistent with the findings in NUREG/CR-6427 (i.e., using the containment failure probabilities for DCH and non-DCH events reported in the study, in place of the conditional failure probabilities implicit in the baseline PRA). Under these assumptions, Duke estimated that the averted population dose risk from eliminating early containment failures would rise from a base case value of 0.055 person-Sv (5.5 person-rem) per year to 0.21 person-Sv (21 person-rem) per year. The benefit values based on use of the NUREG/CR-6427 containment failure probability for McGuire are reported in Table 5-8. Also shown are the benefits values for the sensitivity cases involving use of a 3-percent discount rate compared to a 7-percent discount rate in the base case and use of the SBO CDF estimates from Revision 3 of the PRA rather than Revision 2. All of the values in Table 5-8 include averted offsite property damage.

A number of points are worth noting regarding the Duke base case results and these sensitivity assessments:

- Not all early and late releases can be eliminated by providing hydrogen control. For example, late failures due to long-term containment over-pressure could still occur. Also, the non-safety related, non-seismic back-up power source may not be available in large seismic and tornado events, if it is not designed to withstand such events. An upper bound estimate can be provided by assuming that all containment failures – early and late – would be eliminated. More realistically, most of the early and some of

## Environmental Impacts of Postulated Accidents

the late releases would be eliminated. The assumption that hydrogen control would eliminate all early failures is considered to provide a reasonable estimate of the risk reduction benefit. Accordingly, the estimated benefits shown in Table 5-8 are based on eliminating all early containment failures.

**Table 5-8.** Sensitivity Results for Hydrogen Control SAMAs (all benefits based on eliminating early failures only)

SAMA	Estimated Cost (per unit)	Estimated Benefits for Hydrogen Control SAMAs Under Various Assumptions			
		Based on Revision 2 of the PRA	Based on conditional containment failure probabilities from NUREG/CR-6427	Based on a 3% discount rate compared to a 7% discount rate in the base case	Based on SBO values from Revision 3 of the PRA
Back-up power to igniters & air return fans	\$540,000	\$178,000	\$678,000	\$248,000	\$76,000
PARs	\$750,000	\$178,000	\$678,000	\$248,000	\$76,000
Back-up power to igniters only	\$205,000	Duke: no benefit, since air-return fans are needed	Duke: no benefit, since air-return fans are needed	Duke: no benefit, since air-return fans are needed	Duke: no benefit, since air-return fans are needed

- It is Duke's position that powering the igniters without also powering the air-return fans would not achieve effective hydrogen control. According to Duke, in order to realize the stated benefits, the air-return fans must also have a back-up power source. More than half of the cost of the SAMA to provide back-up power to igniters and air-return fans comes from powering the fans. Based on available technical information, it is not clear that operation of an air-return fan is necessary to provide effective hydrogen control. If only the igniters need to be powered during SBO, a less expensive option of powering a subset of igniters from a back-up generator, addressed by Duke in responses to RAIs (Duke 2002a; NRC 2002a), is within the range of averted risk benefits and would warrant further consideration.
- If a 3-percent discount rate is assumed in contrast to the 7-percent discount rate assumed in the base case analysis, the benefits are similar in magnitude to the costs if

back-up power to the air-return fans is not needed. This further supports the position that the benefits are large and that a hydrogen-related SAMA may be cost-beneficial.

- The effect of implementing the SAMA in the near term rather than delaying implementation until the start of the license renewal period (i.e., use of a 40-year rather than a 20-year, period in the value impact analyses) is bounded by the sensitivity study that assumed a 3-percent discount rate.
- The Revision 3 PRA results would reduce the averted risk benefits by about half. While this is a substantial reduction, it does not eliminate the generic concern that the benefits of additional hydrogen control are large.

The NRC has recognized that ice condenser containments like McGuire's are vulnerable to hydrogen burns in the absence of power to the hydrogen ignitor system. This issue is sufficiently important for all PWRs with ice condenser containments that NRC has made the issue a Generic Safety Issue (GSI), GSI-189 – Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident (NRC 2002b). As part of the resolution of GSI-189, NRC is evaluating potential improvements to hydrogen control provisions in ice condenser plants to reduce their vulnerability to hydrogen-related containment failures in SBO. This will include an assessment of the costs and benefits of supplying igniters from alternate power sources, such as a back-up generator, as well as containment analyses to establish whether air-return fans also need an ac-independent power source, as part of this modification. The need for plant design and procedural changes will be resolved as part of GSI-189 and addressed for McGuire and other ice condenser plants as a current operating license issue.

### **5.2.7 Conclusions**

Duke completed a comprehensive effort to identify and evaluate potential cost-beneficial plant enhancements to reduce the risk associated with severe accidents at McGuire. As a result of this assessment, Duke concluded that no additional mitigation alternatives are cost-beneficial and warrant implementation at McGuire.

Based on its review of SAMAs for McGuire, the staff concurs that none of the candidate SAMAs are cost-beneficial with the possible exception of one SAMA related to hydrogen control in SBO events. This conclusion is consistent with the low level of risk indicated in the McGuire PRA and the fact that Duke has already implemented numerous plant improvements identified from previous plant-specific risk studies. Duke's position is that SAMAs that provide hydrogen control in SBO events are not cost-effective because back-up power would also need to be supplied to the air-return fans from ac-independent power sources in order to ensure mixing of the containment atmosphere; the cost of powering both the igniters and the air-return fans would exceed the expected benefit. However, based on available technical information, it is not clear that operation of an air-return fan is necessary to provide effective hydrogen control. If

## Environmental Impacts of Postulated Accidents

only the igniters need to be powered during SBO, a less-expensive option of powering a subset of igniters from a back-up generator, addressed by Duke in responses to RAIs (Duke 2002a; NRC 2002a), is within the range of averted risk benefits and would warrant further consideration. Even if air-return fans are judged to be necessary to ensure effective hydrogen control in SBOs, the results of sensitivity studies suggest that this combined SAMA might also be cost-beneficial.

The staff concludes that one of the SAMAs related to hydrogen control in SBO sequences (supplying existing hydrogen igniters with back-up power from an independent power source during SBO events) is cost-beneficial under certain assumptions, which are being examined in connection with resolution of GSI-189. However, this SAMA does not relate to adequately managing the effects of aging during the period of extended operation. Therefore, it need not be implemented as part of license renewal pursuant to 10 CFR Part 54. The need for plant design and procedural changes will be resolved as part of GSI-189 and addressed for McGuire and all other ice condenser plants as a current operating license issue.

### 5.3 References

10 CFR Part 50. Code of Federal Regulations, Title 10, *Energy*, Part 50, "Domestic Licensing of Production and Utilization Facilities."

10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

10 CFR Part 100. Code of Federal Regulations, Title 10, *Energy*, Part 100, "Reactor Site Criteria."

Duke Power Company (Duke Power). 1991. Letter from T. C. McMeekin, DPC to NRC. Subject: Evaluation of the McGuire Units 1 and 2 Individual Plant Examination (IPE) – Internal Events, dated November 4, 1991.

Duke Power Company (Duke Power). 1994. Letter from T. C. McMeekin, DPC to NRC. Subject: Individual Plant Examination of External Events (IPEEE) Submittal, McGuire Nuclear Station, dated June 1, 1994.

Duke Energy Corporation (Duke). 1998. Probabilistic Risk Assessment, Individual Plant Examination, McGuire Nuclear Station, dated March 19, 1998.

Duke Energy Corporation (Duke). 2001. *Applicant's Environmental Report—Operating License Renewal Stage, McGuire Nuclear Station Units 1 and 2*. Charlotte, North Carolina.

Duke Energy Corporation (Duke). 2002a. Letter from M. S. Tuckman of Duke Energy Corporation to U.S. Nuclear Regulatory Commission. Subject: Response to Request for Additional Information in Support of the Staff Review of the Application to Renew The Facility Operating Licenses of McGuire Nuclear Station Units 1 and 2 and Catawba Nuclear Station Units 1 and 2, January 31, 2002.

Duke Energy Corporation (Duke). 2002b. Letter from M.S. Tuckman of Duke Energy Corporation to U.S. Nuclear Regulatory Commission. Subject: Comments on draft plant-specific Supplement 8 to NUREG-1437, Generic Environmental Impact Statement for License Renewal of Nuclear Power Plants, McGuire Nuclear Station, Docket Nos. 50-369 and 50-370, August 2, 2002.

U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant Examination for Severe Accident Vulnerabilities," November 23, 1988.

U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks - An Assessment for Five U.S. Nuclear Power Plants*. NUREG-1150, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1991. Supplement 4 to Generic Letter 88-20, "Individual Plant Examination for Severe Accident Vulnerabilities," June 28, 1991.

U.S. Nuclear Regulatory Commission (NRC). 1994. Letter from V. Nerses (NRC) to T. C. McMeekin (Duke Power Company), Subject: Staff Evaluation of the McGuire Nuclear Station, Units 1 and 2, Individual Plant Examination - Internal Events Only, June 30, 1994.

U.S. Nuclear Regulatory Commission (NRC). 1995a. *Final Environmental Statement Related to the Operation of Watts Bar Nuclear Plant Units 1 and 2*. NUREG-0498, Supplement 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1995b. *Cost-Benefit Considerations in Regulatory Analysis*. NUREG/CR-6349. U.S. Nuclear Regulatory Commission, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1997a. *SECPOP90: Sector Population, Land Fraction, and Economic Estimation Program*. NUREG/CR-6525, Washington, D.C.

## Environmental Impacts of Postulated Accidents

U.S. Nuclear Regulatory Commission (NRC). 1997b. *Regulatory Analysis Technical Evaluation Handbook*. NUREG/BR-0184, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1997c. *Individual Plant Examination Program: Perspectives on Reactor Safety and Plant Performance*. NUREG-1560, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1999a. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3—Transportation, Table 9.1 Summary of findings on NEPA issues for license renewal of nuclear power plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1999b. Letter from F. Rinaldi (NRC) to H. B. Barron (Duke Energy Corporation), Subject: Review of McGuire Nuclear Station, Units 1 and 2 - Individual Plant Examination of External Events Submittal, February 16, 1999.

U.S. Nuclear Regulatory Commission (NRC). 2000. *Assessment of the DCH Issue for Plants with Ice Condenser Containments*. NUREG/CR-6427, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2001. Letter from J. H. Wilson (NRC) to M. S. Tuckman (Duke Energy Corporation), Subject: Request for Additional Information Related to the Staff's Review of the Severe Accident Mitigation Alternatives Analysis for McGuire Nuclear Station Units 1 and 2, November 19, 2001.

U.S. Nuclear Regulatory Commission (NRC). 2002a. Note to File from J. H. Wilson (NRC). Subject: Information Provided by Duke Energy Corporation Related to Severe Accident Mitigation Alternatives in its License Renewal Application for McGuire Nuclear Station, Units 1 and 2, March 14, 2002 (Accession No. ML0207450318).

U.S. Nuclear Regulatory Commission (NRC). 2002b. Memorandum from F. Eltawila (NRC) to A. Thadani (NRC), Subject: Generic Issue Management Control System Report - First Quarter FY 2002, February 13, 2002.

U.S. Nuclear Regulatory Commission (NRC). 2002c. Note to File from A. Kugler (NRC). Subject: Information Provided by VEPCo in Relation to Severe Accident Mitigation Alternatives in Its License Renewal Application for the Surry Nuclear Power Station, Units 1 and 2, January 23, 2002 (Accession No. ML020250545).