



Operated by Nuclear Management Company, LLC

December 13, 2002

Technical Specification 6.7.A.3

US Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Submittal of Monticello Monthly Operating Report for November 2002

In accordance with Monticello Technical Specification 6.7.A.3, the report of operating statistics for the Monticello Nuclear Generating Plant for the month of November is enclosed.

Please contact Paul Hartmann at (763) 271-5172 if you require further information.

Jeffrey S. Forbes Site Vice President Monticello Nuclear Generating Plant

Enc.

c: Regional Administrator – III, NRC NRR Project Manager, NRC Sr. Resident Inspector, NRC Minnesotà Dept. of Commerce

IEDY



DOCKET NO. 50-263
UNIT NAME Monticello
DATE December 2, 2002
COMPLETED BY H. H. Paustian
TELEPHONE 763-295-1317

OPERATING DATA REPORT

REPORTING PERIOD: November 2002

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating (Mwe-Net)	600 0	600.0	600.0
2. Maximum Dependable Capacity (Mwe-Net)	578.1	578.1	578.1
3. Number of Hours the Reactor Was Critical	720.0	7,928 0	228,097.6
4. Number of Hours the Generator Was On Line	~ 720.0	7,876.1	224,674.8
5. Unit Reserve Hours	0.0	0.0,	0.0
6. Net Electrical Energy (MWH)	424,937.3	4,577,393.3	115,727,378.3

UNIT SHUTDOWNS

REPORTING PERIOD: November 2002

No.	Date	Type F:Forced S:Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions Comments
	None					
				1		
		,				
		,		•		
					1	
	+ 1			1.5		
				7.1	,	
		,	t		ı	, , , , , , , , , , , , , , , , , , ,

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulator Restriction
- E Operator Training & Licensing Examination
- F Administrative
- G Operational Error (Explain)
- H Other (Explain)

Method:

- 1 Manual
- 2 Manual Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

SUMMARY: The plant operated a	at essentially 100% power the entire month, except for a small reduction to 98% for about 1 hour on November 9 for a control rod
pattern adjustment.	
