

BAW-10241
Revision 0

**BHTP DNB Correlation
Applied with LYNXT**

December 2002

Framatome ANP, Inc.

ISSUED IN FRA-ANP ON-LINE
DOCUMENT SYSTEM
DATE: 12-19-02

BAW-10241
Revision 0

**BHTP DNB Correlation
Applied With LYNXT**

Contributing Analysts: D. Farnsworth and K. R. Greene

Prepared: Ken Greene 17 Dec 2002
K. R. Greene, Principal Engineer
Systems Analysis Methods Date

Reviewed: R. B. Macduff det 17 Dec 2002
R. B. Macduff, Advisory Engineer
Systems Analysis Methods Date

Concurred: See attached page _____
R. L. Harne, Team Leader
Thermal-Hydraulic Technology Team Date

Approved: D. W. Pruitt 18 DEC 2002
D. W. Pruitt, Manager
Systems Analysis Methods Date

Approved: R. E. Collingham 18 Dec 2002
R. E. Collingham, Manager
Methods Development Date

Approved: See attached page _____
D. M. Brown, Manager
PWR Engineering Date

Approved: J. Mahay 12/18/02
J. Mahay, Director
Regulatory Affairs Date

kah

Framatome ANP, Inc.

BAW-10241
Revision 0

**BHTP DNB Correlation
Applied With LYNXT**

Contributing Analysts: D. Farnsworth and K. R. Greene

Prepared:	_____	_____
	K. R. Greene, Principal Engineer Systems Analysis Methods	Date
Reviewed:	_____	_____
	R. B. Macduff, Advisory Engineer Systems Analysis Methods	Date
Concurred:	<u>R. L. Hame</u>	<u>12/18/02</u>
	R. L. Hame, Team Leader Thermal-Hydraulic Technology Team	Date
Approved:	_____	_____
	D. W. Pruitt, Manager Systems Analysis Methods	Date
Approved:	_____	_____
	R. E. Collingham, Manager Methods Development	Date
Approved:	<u>Davis M. Brown</u>	<u>12/18/02</u>
	D. M. Brown, Manager PWR Engineering	Date
Approved:	_____	_____
	J. Mallay, Director Regulatory Affairs	Date

kah

**U.S. Nuclear Regulatory Commission
Report Disclaimer**

Important Notice Regarding the Contents and Use of This Document

Please Read Carefully

This technical report was derived through research and development programs sponsored by Framatome ANP, Inc. It is being submitted by Framatome ANP, Inc. to the U.S. Nuclear Regulatory Commission as part of a technical contribution to facilitate safety analyses by licensees of the U.S. Nuclear Regulatory Commission which utilize Framatome ANP, Inc. fabricated reload fuel or technical services provided by Framatome ANP, Inc. for light water power reactors and it is true and correct to the best of Framatome ANP, Inc.'s knowledge, information, and belief. The information contained herein may be used by the U.S. Nuclear Regulatory Commission in its review of this report and, under the terms of the respective agreements, by licensees or applicants before the U.S. Nuclear Regulatory Commission which are customers of Framatome ANP, Inc. in their demonstration of compliance with the U.S. Nuclear Regulatory Commission's regulations.

Framatome ANP, Inc.'s warranties and representations concerning the subject matter of this document are those set forth in the agreement between Framatome ANP, Inc. and the Customer pursuant to which this document is issued. Accordingly, except as otherwise expressly provided in such agreement, neither Framatome ANP, Inc. nor any person acting on its behalf:

- a. makes any warranty, or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method, or process disclosed in this document will not infringe privately owned rights;

or

- b. assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this document.

Nature of Changes

Item	Page	Description and Justification
1.	All	This is a new document.

Contents

1.0	Introduction and Summary	1-1
1.1	Range of Applicability	1-2
1.2	Comparison of BHTP Correlation Predictions to Experimental Measurements	1-2
2.0	The BHTP DNB Correlation.....	2-1
2.1	Base Correlation.....	2-1
2.2	Fuel Design Factor	2-2
2.3	Non-Uniform Axial Power Distribution Correction Factor.....	2-4
3.0	Qualification of the BHTP DNB Correlation	3-1
3.1	Thermal Hydraulic Models of Test Assemblies	3-1
3.2	Calculation Results and Analysis of Residuals.....	3-1
4.0	Statistical Characterization of the BHTP DNB Correlation	4-1
5.0	References.....	5-1

Tables

1.1	BHTP Correlation Range of Applicability: Coolant Conditions	1-3
1.2	BHTP Correlation Range of Applicability: Fuel Design Parameters	1-3

Figures

Nomenclature

<u>Acronym</u>	<u>Definition</u>
AOO	Anticipated Operational Occurrence
BHTP	Designation for the principal correlation described in this report
DHYD DNB	[] equivalent diameter Departure from Nucleate Boiling
[[]
[HTP]
	The Framatome ANP pressurized water reactor fuel assembly design for which the BHTP DNB correlation is developed.
IFM	Intermediate Flow Mixer
[[LYNXT]
	Computer code for performing core DNBR analysis
[PWR]
	Pressurized Water Reactor
[[]
[XCOBRA-IIIC]
	Computer code for performing core DNBR analysis
[[]

1.0 Introduction and Summary

This document describes the Framatome ANP, Inc., Departure from Nucleate Boiling (DNB) correlation, HTP (Reference 1), and its proposed use with the LYNXT computer code (Reference 2). The HTP correlation has been used for the HTP fuel designs since 1994. The HTP correlation was reviewed and approved by the Nuclear Regulatory Commission (Reference 1). The HTP correlation is presently used with the XCOBRA-IIIC computer code (Reference 3).

The database for the HTP correlation was obtained in a high pressure test loop at Columbia University's Heat Transfer Research Facility. [

] The HTP DNB data

base is fully described in Reference 1.

The HTP correlation is an empirically derived function of the local coolant thermodynamic state and mass flux at which DNB is observed to occur in experiment. The heat flux at which DNB occurs is predicted using local coolant quality, local mass flux, and [] pressure. A minor [] dependence is also present. The HTP correlation contains factors to account for the effects of [

]

DNB correlations are applied with a specified computer code in order to obtain local conditions.

[

]

The correlation predictions of the measured data are summarized in the following sub-sections. The BHTP correlation is described in detail in Section 2.0 of this document. The qualification of the correlation against the experimental database is discussed in Section 3.0. The statistical characterization of the correlation is presented in Section 4.0.

1.1 **Range of Applicability**

The BHTP correlation application range of coolant conditions are provided in Table 1.1. The coolant conditions commonly encountered during steady-state operation and Anticipated Operational Occurrences (AOO) in PWRs are also within this range. The range of fuel design parameters are provided in Table 1.2. These are unchanged from Reference 1. [

]

1.2 **Comparison of BHTP Correlation Predictions to Experimental Measurements**

The BHTP correlation is used to predict the DNB heat flux for each test point in the database. The distribution is characterized [] A statistical summary of the P/M ratios for the individual test sections is provided in

A comparison of predicted DNB heat flux to measured DNB heat flux for the entire database is given in Figure 1.1. Upper and lower dashed lines on this plot enclose a band [] about the measured value.

The frequency distribution of the P/M ratios for the entire database is depicted in Figure 1.2. The 95/95 safety limit for the BHTP correlation is 1.132, derived using a [] as discussed in Section 4.0.

Table 1.1 BHTP Correlation Range of Applicability: Coolant Conditions



Variable	Minimum Value	Maximum Value
Pressure (psia)	1775	2425
Local Mass Flux (Mlb/h/ft ²)	0.897	3.549
Inlet Enthalpy (Btu/lb)	383.9	644.3
Local Quality	-0.130	0.344

Table 1.2 BHTP Correlation Range of Applicability: Fuel Design Parameters

Parameter	Value
Fuel Rod Diameter, in	0.360 – 0.440
Fuel Rod Pitch, in	0.496 – 0.580
Axial Spacer Span, in	10.5 – 26.2
Hydraulic Diameter, in	0.4571 – 0.5334
Heated Length, ft.	9.8 – 14.0







2.0 The BHTP DNB Correlation

The BHTP correlation is based on the HTP correlation that was approved in Reference 1. [

]

2.1 *Base Correlation*

The BHTP correlation is a [] function of [

]

Q_{base} is the predicted DNB heat flux (MBtu/h/ft²) prior to application of the [] factors and the [] factor.

[

]

[

]

2.2 ***Fuel Design Factor***

The predicted DNB heat flux obtained from Equation (2.1) is modified by terms which account for the effects of the []

[

]

The DNB heat flux including [] effects, Q_{pred} , is obtained from Equation (2.1) and the factor FDF defined above: [

]

2.3 ***Non-Uniform Axial Power Distribution Correction Factor***

The predicted DNB heat flux obtained from the base correlation is modified as follows for [

]

3.0 **Qualification of the BHTP DNB Correlation**

The [] data points supporting the BHTP DNB correlation are obtained from [] programs performed at the Columbia University Heat Transfer Research Facility. The test data and test sections are fully described in Reference 1. The correlation comparison to data and the thermal hydraulic models employed in the LYNXT (Reference 2) simulations of the tests are presented in this section.


3.1 ***Thermal Hydraulic Models of Test Assemblies***

The local coolant conditions for each statepoint in the DNB data base are computed with the approved LYNXT computer code (Reference 2). The LYNXT simulation includes a specification of the test assembly geometry and power peaking, single phase friction and component loss coefficient correlations, two-phase flow correlations, a turbulent mixing correlation, and appropriate calculation control parameters. The standard LYNXT models (Reference 2, Appendix B) are used with the BHTP correlation.


3.2 ***Calculation Results and Analysis of Residuals***

[

]



















































4.0 Statistical Characterization of the BHTP DNB Correlation

The BHTP DNB correlation safety limit is derived using the ratio of the [] DNB heat flux to the [] DNB heat flux []. The correlation safety limit is the value of the [] ratio [] which, with 95% confidence, 95% of the population of P/M values fall. The correlation safety limit is derived using a []

To evaluate the safety limit, the data sample is sorted in descending order of [] ratio. There are [] data points in the sample. [] defines the degree of confidence, g , associated with the fractional probability, P , that [] values chosen [] This degree of confidence, g , is defined in terms of []

[] 1.132. Hence, the value of the correlation safety limit is 1.132. With 95% confidence, at least 95% of the population of [] ratios will be [] than this value.

5.0 References

1. EMF-92-153(P)(A) and EMF-92-153(P)(A) Supplement 1, *HTP: Departure From Nucleate Boiling Correlation for High Thermal Performance Fuel*, Siemens Power Corporation, March 1994.
2. BAW-10156-A Revision 1, *LYNXT – Core Transient Thermal-Hydraulic Program*, B&W Fuel Company, August 1993.
3. XN-NF-75-21(P) (A) Revision 2, *XCOBRA-IIIC: A Computer Code to Determine the Distribution of Coolant During Steady State and Transient Operation*, Exxon Nuclear Company, January 1986.
4. []
5. []

Distribution

K. R. Greene, RC18 (1)
J. S. Holm/USNRC, RC18 (5)