

Exelon Nuclear  
200 Exelon Way  
Kennett Square, PA 19348

www.exeloncorp.com

December 9, 2002

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington DC 20555

Peach Bottom Atomic Power Station, Unit 2  
Facility Operating License No. DPR- 44  
NRC Docket No. 50-277

Subject: Submittal of Analytical Evaluation of Reactor  
Pressure Vessel Closure Head Indications

Dear Sir/Madam:

In accordance with the ASME Boiler and Pressure Vessel Code, Section XI, IWB-3134(b), Exelon Generation Company, LLC, is submitting an analytical evaluation of indications identified in the Peach Bottom Atomic Power Station (PBAPS), Unit 2 reactor pressure vessel (RPV) closure head.

As a result of Ultrasonic Testing (UT) examinations conducted during the recently concluded refueling outage at PBAPS, Unit 2, ASME Section XI reportable indications were identified in a meridional weld of the reactor pressure vessel closure head. The meridional weld is an Examination Category B-A, Item No. B1.22 weld, as identified in ASME Section XI, 1989 Edition (no addenda). The UT examinations were performed in accordance with ASME Section XI, Appendix VIII, 1995 Edition with the 1996 Addenda, using approved Performance Demonstration Initiative (PDI) procedures. Analytical evaluation of the reported indications was conducted in accordance with IWB-3600, as allowed by IWB-3132.4.

Periodic Inservice Inspection (ISI) examinations were initially conducted on six (6) meridional welds and one (1) circumferential weld on the vessel closure head and on two (2) meridional welds on the bottom head. As a result of the reportable indications identified in one (1) meridional closure head weld, additional examinations were performed in accordance with ASME Section XI, IWB-2430(a). This additional scope included manual UT examination on four (4) additional meridional welds in the reactor vessel bottom head.

The results of all RPV head weld examinations identified sixteen (16) reportable indications in one (1) weld in the closure head (weld CH-MB). These indications did not meet the ASME Section XI acceptance standards as specified in Table IWB-3510-1. No reportable indications were identified in the other RPV head welds. Based on the analytical evaluation provided in the


A047

PBAPS, Unit 2 - Submittal of Analytical Evaluation of Reactor  
Pressure Vessel Closure Head Indications Analytical Evaluation  
December 9, 2002  
Page 2

attachment, it is concluded that the indications found in the PBAPS, Unit 2 vessel closure head, during the most recently concluded refueling outage, are acceptable by the flaw acceptance criteria of IWB-3600 of the ASME Section XI Code.

If you have any questions, please do not hesitate to contact us.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael P. Gallagher". The signature is fluid and cursive, with the first name "Michael" being the most prominent part.

Michael P. Gallagher  
Director, Licensing and Regulatory Affairs  
Mid-Atlantic Regional Operating Group

Attachment

cc: H. J. Miller, Administrator, Region I, USNRC  
A. C. McMurtry, USNRC Senior Resident Inspector, PBAPS  
J. Boska, Senior Project Manager, USNRC

# THE EVALUATION OF INDICATIONS IN PEACH BOTTOM UNIT 2 VESSEL CLOSURE HEAD FOR CONTINUED OPERATION

September 2002

Prepared by: Shawn A. Kleinsmith  
S. Kleinsmith, Engineer  
Structural Mechanics & Materials

Verified by: Matthew C. O'Connor for H. Mehta Matthew  
H.S. Mehta, Engineering Fellow O'Connor  
Structural Mechanics & Materials

Approved by: R.M. Horn  
R.M. Horn, Manager  
Structural Mechanics & Materials

**DISCLAIMER OF RESPONSIBILITY**  
**Important Notice Regarding the Contents of this Report**  
**Please Read Carefully**

The only undertakings of the General Electric Company (GE) respecting information in this document are contained in the contract between Exelon Corporation and GE, Purchase Order 01026357 Revision 5, effective 8/28/02, as amended to the date of transmittal of this document, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than Exelon Corporation, or for any purpose other than that for which it is furnished by GE, is not authorized; and with respect to any unauthorized use, GE makes no representation or warranty, express or implied, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document, or that its use may not infringe privately owned rights.

Copyright, General Electric Company, 2002.

## Table of Contents

<u>Subject</u>	<u>Page No.</u>
1. EXECUTIVE SUMMARY .....	1
1.1. REFERENCE .....	1
2. INTRODUCTION AND REPORT OUTLINE .....	2
2.1. REFERENCE .....	2
3. UT INSPECTION RESULTS & FLAW GEOMETRY FOR EVALUATION .....	4
3.1. UT INSPECTION RESULTS .....	4
3.2. FLAW GEOMETRIES CONSIDERED IN EVALUATION .....	4
3.3. FABRICATION REVIEW .....	5
3.4. REFERENCES .....	5
4. FRACTURE MECHANICS EVALUATION .....	12
4.1. ASSUMPTIONS .....	12
4.2. APPLIED AND WELD RESIDUAL STRESSES .....	12
4.3. K CALCULATION METHODOLOGY .....	13
4.4. FATIGUE CRACK GROWTH .....	14
4.5. ALLOWABLE K VALUES .....	14
4.6. DISPOSITION OF INDICATIONS .....	15
4.7. REFERENCES .....	16
5. SUMMARY AND CONCLUSIONS .....	20
APPENDIX A .....	A
APPENDIX B .....	B

## 1. EXECUTIVE SUMMARY

The reactor pressure vessel closure head at Peach Bottom Atomic Power Station, Unit 2 (PBAPS-2) was ultrasonically examined during refueling outage fourteen (2R-14). Each of the six meridional welds was examined. Several indications were noted at these welds. Other than the CH-MB weld, the detected indications at the other meridional welds were acceptable as-is by the acceptance standards IWB-3510 of ASME Section XI (1989 Edition without Addenda). At the CH-MB weld numerous recordable indications were noted out of which eighteen (18) indications/flaws displayed tip signals and possessed a through-wall dimension. Sixteen (16) of these flaws did not meet the acceptance standards. The Section XI Code allows for the acceptance of such flaws for continued service if they meet the requirements of Paragraph IWB-3600, Analytical Evaluation of Flaws. The analysis involves the use of fracture mechanics procedures in accordance with Appendix A of Section XI. The objective of this report is to document the results of such evaluation.

The use of surface proximity rules of Section XI indicated that all sixteen (16) indications need to be characterized as surface flaws for the purposes of fracture mechanics evaluation. Two conditions were determined to be governing: bolt-up and system pressure test. The bounding membrane and bending stress values for the fracture mechanics evaluation for the two conditions were obtained through a review of previous stress analyses of the closure heads. The bolt-up temperature was assumed as 70°F [1-1 & 1-2] at a pressure of 0 psi and the pressure test temperature was assumed as 169°F [1-1] with a pressure of 1050 psi [1-1]. The stress intensity factors for the characterized surface flaws were calculated for various flaw depth ( $a$ ) to flaw length ( $l$ ) ratios (or, aspect ratios). It was determined that the pressure-test condition was governing. The limiting flaw was found to be acceptable per ASME Section XI Code even after accounting for projected crack growth for the life of the plant including license renewal (60 total years).

Based on this evaluation it is concluded that all of the indications found in PBAPS-2 vessel closure head during Refueling Outage (2R-14) are acceptable by the flaw acceptance criteria of the ASME Section XI Code.

### 1.1. REFERENCE

- [1-1] Exelon Nuclear, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-680-2, Rev. 6: Reactor Pressure Vessel (Class 1) Hydrostatic Pressure Test.
- [1-2] PECO Energy Company, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-500-2, Rev. 7: Recording and Monitoring Reactor Vessel Temperature and Pressure.


## 2. INTRODUCTION AND REPORT OUTLINE

The reactor pressure vessel closure head at Peach Bottom, Unit 2 (PBAPS-2) was ultrasonically examined during the 2R14 refueling outage. Figure 2-1 shows the geometry of the vessel head. The inside radius of the head is 125.69 inches and the minimum specified thickness is 4.00 inches [2-1]. However, the measured thickness reported during the UT examination is 4.25 inches, the value used in the evaluations conducted for this report [2-2]. The inside surface of the closure head is unclad. Meridional welds were examined. Several flaws were noted in the meridional weld CH-MB. All of the flaws are not ID connected (i.e. sub surface) as confirmed by surface examination conducted at the ID surface. However, portions of the flaws are less than 0.4d from the ID surface, thus they were classified as surface flaws for fracture mechanics analysis. The observed flaws were first characterized and compared with the acceptance standards provided in Table IWB-3500-1 of Section XI, ASME Code [2-3]. Some of the flaws did not meet the acceptance standards. Section XI, subparagraph IWB-3132.4 allows for the acceptance of such flaws for continued service if they meet the requirements of Paragraph IWB-3600, Analytical Evaluation of Flaws. The analysis involves the use of fracture mechanics procedures in accordance with Appendix A of Reference 2-3. The objective of this report is to document the results of such evaluation.

Section 3 of this report summarizes UT inspection results and describes the flaw geometries considered in the evaluation. The results of the fracture mechanics evaluation are presented in Section 4. A comparison with the allowable flaw values is presented. Finally, summary and conclusions are presented in Section 5.

### 2.1. REFERENCE

- [2-1] Babcock & Wilcox CO. Pressure Boundary Drawing, "Closure Head Assembly" for Peach Bottom Unit 2, Drawing # 129392 E R7, GE VPF# 1896-67-8.
- [2-2] GE Nuclear Energy, Peach Bottom Unit 2 – 2R14 UT Examination Report # 008900 for Weld ID – CH-MB Meridional Weld @ 60 Degrees. September 27, 2002.
- [2-3] ASME Boiler and Pressure Vessel Code, Section XI, Rules for In-Service Inspection of Nuclear Power Plant Components, ASME, 1989 Edition without Addenda.



### Figure 2-1 PBAPS 2 Vessel Closure Head Geometry



### 3. UT INSPECTION RESULTS & FLAW GEOMETRY FOR EVALUATION

This section discusses the UT results and the flaw geometries considered in the subsequent fracture mechanics evaluation. Appendix B shows the evaluation sheets for the limiting/bounding case flaws that were found to exceed acceptance standards and required fracture mechanics evaluation. A brief discussion on the origin of the indications is also provided.

#### 3.1. UT INSPECTION RESULTS

Automated 0°L, 2.25 MHz, 45°S, 1.0 MHz, 60°L, 2.0 MHz, 70°L, 2.0 MHz scans were performed on the closure head meridional weld CH-MB. The scans and calibrations were performed in accordance with procedure GE-UT-704 Version 4 DRR# P3-001, that is qualified to the Performance Demolition Initiative (PDI). All of the detected flaws were sub-surface but in close proximity to the surface, thus they were classified as surface flaws for the analysis [Appendix A & B].

There were sixty-five (65) recordable indications detected in the CH-MB weld. Eighteen (18) indications displayed tip signals and possessed a through wall dimension. Forty-seven (47) indications without through wall dimension have been evaluated as being acceptable to the requirements of Table IWB-3510-1 [2-3]. Of the eighteen (18) remaining separate flaws, two (2) of the recorded flaws have been evaluated as being acceptable to the requirements of Table IWB-3510-1 [2-3]. Sixteen (16) of flaws have been evaluated as being rejectable to the requirements of Table IWB-3510-1. These Sixteen (16) flaws are characterized in Table 3-2. The GERIS 2000 Indication Data Sheets for each indication can be found in the Appendix A. The GERIS 2000 Indication Evaluation Data Sheets for each flaw can be found in the Appendix B.

Figures 3-1-1 thru 3-1-3 shows the approximate locations of the indications relative to the CH-MB weld centerline.

#### 3.2. FLAW GEOMETRIES CONSIDERED IN EVALUATION

Table 3-2 shows the criteria used to determine if the indications that are to be evaluated need to be characterized as surface or sub-surface type flaws for the purpose of fracture mechanics analysis. The guidance for this characterization is provided in Article IWA-3000 [2-3]. Figure 3-2 shows the parameters used for surface proximity evaluation. It is seen in Table 3-2 that all of the indications are to be characterized as surface. In view of the varying aspect ratio ( $a/l$ ), the stress intensity factors in the next section were calculated for different  $a/l$  values: 0.0, 0.1, 0.2, 0.3, .04, and 0.5.

### 3.3. *FABRICATION REVIEW*

All the indications in question are sub surface, in close proximity to the surface and are not service induced, but were considered as surface flaws for the fracture mechanics evaluation. A fabrication review (Reference 3-1) concluded the following:

- The flaws detected during 2R14 have existed since the closure head was fabricated.
- These flaws do not indicate "abnormal degradation of the pressure boundary" as defined by the USNRC.
- These flaws should be considered newly discovered flaws, rather than newly developed flaws.

Indications at vessel welds of the type seen in the Peach Bottom Unit 2 top head welds are not uncommon and have been found in other reactor pressure vessel welds in other plants. In most cases, the new finding is attributed to the ability of current UT techniques to detect flaws that would have been undetectable using inspection techniques available during the time of fabrication of the Peach Bottom vessel. Thus, as long as the required fracture margins are demonstrated, the indications are judged to be benign and have no impact on structural integrity.

### 3.4. *REFERENCES*

- [3-1] Miller, W.F., "Investigation into the Origin of Ultrasonic Indications in RPV Closure Head Welds for the Peach Bottom 2R14 Outage," GE Report No. GENE-955-004-0902 Rev. 1, September 2002.

**Table 3-1 Listing of Ultrasonic Indications in RPV Closure Head Weld CH-MB at Peach Bottom Unit 2**

Weld ID	Location	Number of Recordable Indications	Number of Indications / flaws with through wall dimension	Acceptable per Table IWB-3510-1
CH-MB	60° Azimuth	65	18 ( See description below )	2 ( #10 & #39 )

**CH-MB**

IND # 5 Flaw length = 0.75" Flaw depth (a) = 0.17" S = 0"

IND # 6 Flaw length = 1.00" Flaw depth (a) = 0.20" S = 0"

IND # 10 Flaw length = 0.75" Flaw depth (a) = 0.10" S = 0"

IND # 14 Flaw length = 1.75" Flaw depth (a) = 0.16" S = 0"

IND # 16 Flaw length = 3.75" Flaw depth (a) = 0.25" S = 0"

IND # 20 Flaw length = 1.25" Flaw depth (a) = 0.17" S = 0"

IND # 24 Flaw length = 1.00" Flaw depth (a) = 0.17" S = 0"

IND # 34 Flaw length = 0.75" Flaw depth (a) = 0.16" S = 0"

IND # 38 Flaw length = 0.75" Flaw depth (a) = 0.19" S = 0"

IND # 39 Flaw length = 0.40" Flaw depth (a) = 0.16" S = 0"

IND # 42 Flaw length = 1.75" Flaw depth (a) = 0.19" S = 0"

IND # 44 Flaw length = 0.75" Flaw depth (a) = 0.17" S = 0"

IND # 50 Flaw length = 1.00" Flaw depth (a) = 0.12" S = 0"

IND # 53 Flaw length = 0.75" Flaw depth (a) = 0.14" S = 0"

IND # 56 Flaw length = 1.00" Flaw depth (a) = 0.17" S = 0"

IND # 57 Flaw length = 1.00" Flaw depth (a) = 0.17" S = 0"

IND # 61 Flaw length = 1.00" Flaw depth (a) = 0.12" S = 0"


IND # 63 Flaw length = 1.50" Flaw depth (a) = 0.17" S = 0"

Note: Values reported are taken directly from Appendix A & B.


Table 3-2 Characterization of Flaws

Weld ID	IND #	<i>l</i> (in.)	<i>a</i> (in.)	<i>S</i> (in.)	$S < 0.4a^*$	$a/l$
CH-MB	5	0.75	0.17	0.0	Yes	0.2267
CH-MB	6	1.00	0.20	0.0	Yes	0.2
CH-MB	10	0.75	0.10	0.0	Yes	0.1334
CH-MB	14	1.75	0.16	0.0	Yes	0.0914
CH-MB	16	3.75	0.25	0.0	Yes	0.0667
CH-MB	20	1.25	0.17	0.0	Yes	0.136
CH-MB	24	1.00	0.17	0.0	Yes	0.17
CH-MB	34	0.75	0.16	0.0	Yes	0.2133
CH-MB	38	0.75	0.19	0.0	Yes	0.2534
CH-MB	39	0.40	0.16	0.0	Yes	0.4
CH-MB	42	1.75	0.19	0.0	Yes	0.1086
CH-MB	44	0.75	0.17	0.0	Yes	0.2267
CH-MB	50	1.00	0.12	0.0	Yes	0.12
CH-MB	53	0.75	0.14	0.0	Yes	0.1867
CH-MB	56	1.00	0.17	0.0	Yes	0.17
CH-MB	57	1.00	0.17	0.0	Yes	0.17
CH-MB	61	1.00	0.12	0.0	Yes	0.12
CH-MB	63	1.50	0.17	0.0	Yes	0.1134


\* Flaw characterized as surface flaw if  $S < 0.4a$ .



**Figure 3-1-1 Plot displaying Approx. Location of Indications with No Throughwall Dimension**



**Figure 3-1-2 Plot displaying Approx. Location of Acceptable Indications with Throughwall Dimension**



**Figure 3-1-3 Plot displaying Approx. Location of Unacceptable UT Indications with Throughwall Dimension**




Figure 3-2 Parameters for Surface Proximity Evaluation



## 4. FRACTURE MECHANICS EVALUATION

The fracture mechanics evaluation was conducted for several surface flaw shape geometries using the procedures outlined in Appendix A of Section XI [4-1]. Two conditions were found to be limiting for the determination of allowable flaw sizes: (1) bolt-up, and (2) system pressure test.

### 4.1. ASSUMPTIONS

The following values were used for the pressure and temperature conditions during the bolt-up and system pressure test conditions. These values remain unchanged for power uprate conditions, but can change when new PT curves are licensed.

- The bolt-up temperature is 70°F [4-2 & 4-3].
- The pressure test pressure and temperature are 1050 psi and 169°F [4-4].
- The limiting  $RT_{NDT}$  value for the closure head side plate (torus) region is 10°F. [4-3]

The number of bolt-up, pressure test and start up-shut down events assumed in the fatigue crack growth calculation was based on [Reference 4-5], and is discussed in Subsection 4.4.

### 4.2. APPLIED AND WELD RESIDUAL STRESSES

The applied stresses in the vessel closure head to flange region are primarily from the following sources: bolt preload, internal pressure and weld residual stress. The internal pressure is zero during the bolt-up. Since all of the flaws are in the meridional direction welds, the circumferential or hoop stress is of interest for the purpose of this evaluation. Due to the complex geometry of the flange region, only a detailed finite element analysis of PBAPS Unit 2 closure head geometry can provide a complete picture of the stress distribution due to bolt-up and internal pressure. Since such an analysis was unavailable, the results from finite element analyses conducted for other BWR vessels of similar size on file with GENE were reviewed to conservatively determine a set of membrane and bending stresses. The determination took into account the differences in the R/t ratios between the available finite element model geometry and the PBAPS, Unit 2 closure head geometry.

During bolt-up large hoop bending stresses are introduced in the head near the flange junction but they attenuate rapidly as one moves away from the flange meridionally. These bending stresses are compressive at the ID surface near the flange junction. The hoop membrane stress is tensile but attenuates less rapidly. The longest

flaw extends 3.75 inches in the meridional direction beginning approximately 41 inches above the top surface of the flange. Therefore, the hoop membrane and bending stress distributions corresponding to the meridional length of this indication were reviewed to determine the following conservative values for hoop membrane and bending stresses:

$$\begin{aligned}\sigma_m &= 14.0 \text{ ksi} \\ \sigma_b &= -8.0 \text{ ksi}\end{aligned}$$

During the pressure test, the internal pressure stresses are superimposed over those induced by the bolt-up condition. Since some of the discontinuity related internal pressure stresses cancel those due to bolt-up, the overall stress level is lower than the simple addition of the bolt-up and the nominal pressure stresses in the vessel head. The same approach as that used for bolt-up case was also used to determine the following set of conservative membrane and bending stress values for the pressure test case:

$$\begin{aligned}\sigma_m &= 25.0 \text{ ksi} \\ \sigma_b &= 0 \text{ ksi}\end{aligned}$$

It should be noted that the nominal value of hoop or meridional stress from an internal pressure of 1050 psi is 15.5 ksi. Thus, the difference between this value and the 25.0 ksi reported above represents the discontinuity effects from bolt-up and pressurization.

After the torus section plates are welded together, residual stresses remain due to thermal expansion and contraction. The post-weld heat treatment effectively reduces these residual stresses. A bending stress of 8.0 ksi was assumed in this analysis to model the remaining residual stresses. This bending stress closely approximates the measured cosine stress distribution for welds with PWHT reported in [Reference 4-6]. The 8 ksi magnitude was added algebraically to the calculated bending stresses due to bolt-up and pressure. Figures 4-1 and 4-2 graphically show the stress distributions used for the bolt-up and pressure test cases, respectively.

#### 4.3. K CALCULATION METHODOLOGY

Since all of the analyzed indications have been characterized as surface flaws (Table 3-2), the stress intensity factor (K) calculation procedures specified for surface flaws in Appendix A of Section XI [4-1] were used. Table 4-1 shows the calculated values of K as a function of 'a' values for the pressure test cases for an assumed aspect ratio of 0.0. Similar calculations were also conducted for aspect ratios of 0.1, 0.2, 0.3, 0.4 and 0.5.

#### 4.4. *FATIGUE CRACK GROWTH*

Since all the flaws are characterized as surface flaws, they are assumed as being exposed to the reactor water environment. Thus, the crack growth analysis was performed using the Section XI fatigue crack growth rates for water environment.

The current analyzed reactor pressure vessel cycles for the 40-year design life are listed in [Reference 4-5]. Only the bolt-up (66), hydrostatic test (130) and heatup-cooldown (161) events are significant from the perspective of fatigue crack growth in the vessel closure head. The stress range for the heatup-cooldown cycle is bounded by that for the pressure test, and therefore, the cycles for the two events were lumped together for the fatigue crack growth calculation purposes. The number of cycles for these events were increased by 50% to account for operation during the license renewal period. Thus, the number of events assumed for the bolt-up were  $66 \times 1.5$  or 100. The number of events assumed for the pressure test were  $\{(130+161) \times 1.5\}$  or  $\sim 440$ . This approach is conservative since it does not take any credit for the number of cycles already used so far. The highest applied K values listed in Tables 4-2 and 4-3 were used for the fatigue crack growth calculations. The predicted crack growth was calculated as 56.2 micro inches per cycle. Which results in a crack growth of 0.025" for 440 cycles.

#### 4.5. *ALLOWABLE K VALUES*

The first step in the allowable flaw calculation is to determine the  $K_{Ia}$  value at the temperature appropriate for the operating condition being analyzed. The 1989 version of Section XI [4-1] does not provide an explicit mathematical equation for the calculation of  $K_{Ia}$  at a given temperature and  $RT_{NDT}$ . However, Reference 4-7 gives the following equation that was used to calculate the  $K_{Ia}$  curve given in Figure A-4200-1[4-1]:

$$K_{Ia} = 26.78 + 1.233 * \text{Exp} ( 0.0145 * ( T - RT_{NDT} + 160 ) )$$

where, T and  $RT_{NDT}$  are in °F and  $K_{Ia}$  is in ksi $\sqrt{\text{in}}$ .

Paragraph IWB-3613 of Section XI [4-1] also indicates that for flange region a safety factor of  $\sqrt{2}$  can be used for bolt-up condition. Thus, a safety factor of  $\sqrt{2}$  was used for the bolt-up condition to obtain  $K_{Ia}$  allowable. For the pressure test condition, a safety factor of  $\sqrt{10}$  was used as specified in IWB-3613[4-1]. The following summarizes the numerical values:

Bolt-up

Applied K =	14.3	(ksi $\sqrt{\text{in}}$ ) at 0 (psi) and 70 (°F)
Allowable K =	40.1	(ksi $\sqrt{\text{in}}$ )

Pressure test

Applied K =	34.8	(ksi $\sqrt{\text{in}}$ ) at 1050 (psi) and 169 (°F)
Allowable K =	48.3	(ksi $\sqrt{\text{in}}$ ) at 1050 (psi) and 169 (°F)

**4.6. DISPOSITION OF INDICATIONS**

Tables 4-2 and 4-3 show comparisons of the K values for the limiting flaw being evaluated and the allowable values for bolt-up and pressure test conditions, respectively. It is seen that the calculated K values for all of the indications are less than the allowable values.

The calculated primary stresses after subtracting the area lost to indications, satisfied the primary stress limits specified in the original Code of construction for the reactor vessel.

Based on the preceding, it is concluded that the subject flaws are acceptable for continued operation in as-is condition.

#### 4.7. REFERENCES

- [4-1] ASME Boiler and Pressure Vessel Code, Section XI, Rules for In-Service Inspection of Nuclear Power Plant Components, ASME, 1989 Edition without Addenda.
- [4-2] PECO Energy Company, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-500-2, Rev. 7: Recording and Monitoring Reactor Vessel Temperature and Pressure.
- [4-3] L. Tilly, "Pressure-Temperature Curves for Exelon Peach Bottom Unit 2" GE Nuclear Energy, San Jose, CA, GE-NE-B13-02118-00-01 Rev. 0, September 2002.
- [4-4] Exelon Nuclear, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-680-2, Rev. 6: Reactor Pressure Vessel (Class 1) Hydrostatic Pressure Test.
- [4-5] PECO Energy Company, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-940-2, Rev. 6: Reactor Pressure Vessel Transients Cycles Record.
- [4-6] D.A. Ferrill, et al, "Measurement of Residual Stresses in Heavy Weldment," Welding Journal Research Supplement, Vol 45, Nov. 1966.
- [4-7] EPRI Report No. NP-719-SR, "Flaw Evaluation Procedures: ASME Section XI," August 1978.

**Table 4-1 Calculated K values for Pressure test Cases**

Calculation of Stress Intensities (ksi-sqrt[in])

---

$a =$	0.25 (in)	$t =$	4.25 (in)
$l =$	3.75 (in)	$\sigma_{YS} =$	45.0 (ksi)
$\sigma_m =$	25.0 (ksi)	$\sigma_b =$	8.0 (ksi)

$A_p$ (psi)	$a/l$	Q	$M_m$	$M_b$	$K_m$ (ksi)	$K_b$ (ksi)	$K_{TOTAL}$ (ksi)	$\Delta K$ (ksi)
1050	0.0	0.879	1.147	1.057	27.100	7.991	35.091	27.100
1050	0.1	0.989	1.117	1.016	24.889	7.242	32.131	24.889
1050	0.2	1.212	1.105	0.985	22.236	6.340	28.577	22.236
1050	0.3	1.521	1.10	0.963	19.740	5.538	25.277	19.740
1050	0.4	1.904	1.10	0.953	17.660	4.896	22.556	17.660
1050	0.5	2.356	1.10	0.937	15.880	4.329	20.209	15.880


**Table 4-2 Comparison of Calculated and Allowable K values for bolt-up**

Weld ID:	CH-MB		
IND #:	16		
a (initial) =	0.25 (in)	t =	4.25 (in)
l =	3.75 (in)	$\sigma_{YS}$ =	45.0 (ksi)
$\sigma_m$ =	14.0 (ksi)	$\sigma_b$ =	0.0 (ksi)
TEMP =	70 (°F)	$A_p$ =	0 (psi)
a / l =	0.067		
Applied K =	13.6 (ksi $\sqrt{\text{in}}$ )	Assumes no crack growth	
Applied K =	14.3 (ksi $\sqrt{\text{in}}$ )	Includes an increase of 5% to account for fatigue crack growth	
Allowable K =	40.1 (ksi $\sqrt{\text{in}}$ )		

**Table 4-3 Comparison of Calculated and Allowable K values for pressure tests**


Weld ID:	CH-MB		
IND #:	16		
A (initial) =	0.25 (in)	t =	4.25 (in)
l =	3.75 (in)	$\sigma_{YS}$ =	45.0 (ksi)
$\sigma_m$ =	25.0 (ksi)	$\sigma_b$ =	8.0 (ksi)
TEMP =	169 (°F)	$A_p$ =	1050 (psi)
a / l =	0.067		
Applied K =	33.2 (ksi $\sqrt{\text{in}}$ )	Assumes no crack growth	
Applied K =	34.8 (ksi $\sqrt{\text{in}}$ )	Includes an increase of 5% to account for fatigue crack growth	
Allowable K =	48.3 (ksi $\sqrt{\text{in}}$ )		

### BOLTUP LOAD CONDITION



**Figure 4-1 Through-Wall Stress Distribution Assumed for Bolt-up Condition**

### PRESSURE TEST LOAD CONDITION



**Figure 4-2 Through-Wall Stress Distribution Assumed for Pressure Test Condition**



## 5. SUMMARY AND CONCLUSIONS

The reactor pressure vessel closure head at Peach Bottom Atomic Power Station, Unit 2 (PBAPS-2) was ultrasonically examined during refueling outage fourteen (2R-14). Each of the six meridional welds was examined. Several indications were noted at these welds. Other than the CH-MB weld, the detected indications at the other meridional welds were acceptable as-is by the acceptance standards IWB-3510 of ASME Section XI (1989 Edition without Addenda). At the CH-MB weld numerous recordable indications were noted out of which eighteen (18) indications/flaws displayed tip signals and possessed a through-wall dimension. Sixteen (16) of these flaws did not meet the acceptance standards. The Section XI Code allows for the acceptance of such flaws for continued service if they meet the requirements of Paragraph IWB-3600, Analytical Evaluation of Flaws. The analysis involves the use of fracture mechanics procedures in accordance with Appendix A of Section XI. The objective of this report is to document the results of such evaluation.

The use of surface proximity rules of Section XI indicated that all sixteen (16) indications need to be characterized as surface flaws for the purposes of fracture mechanics evaluation. Two conditions were determined to be governing: bolt-up and system pressure test. The bounding membrane and bending stress values for the fracture mechanics evaluation for the two conditions were obtained through a review of previous stress analyses of the closure heads. The bolt-up temperature was assumed as 70°F at a pressure of 0 psi and the pressure test temperature was assumed as 169°F with a pressure of 1050 psi. The stress intensity factors for the characterized surface flaws were calculated for various flaw depth ( $a$ ) to flaw length ( $l$ ) ratios (or, aspect ratios). It was determined that the pressure-test condition was governing. The limiting flaw was found to be acceptable per ASME Section XI Code even after accounting for projected crack growth for the life of the plant including license renewal (60 total years).

Based on this evaluation it is concluded that all of the indications found in PBAPS-2 vessel closure head during Refueling Outage (2R-14) are acceptable by the flaw acceptance criteria of the ASME Section XI Code.

**APPENDIX A**

**GERIS 2000 Indication  
Data Sheets**

**Rev 1  
September 2002  
(Includes 2 Appended Pages September 27, 2002)**

**GE NUCLEAR ENERGY  
UT EXAMINATION SUMMARY SHEET****Report No:008900**

**PROJECT** Peach Bottom Unit 2 - 2R14  
**WELD ID:** CH-MB Meridional Weld @ 60 Degrees  
**SYSTEM:** RPV - Closure Head

**INITIAL CALIBRATION:** VES.IN.1  
**FINAL CALIBRATION:** VES.OUT.1  
**GERIS DATA:** mbl.1, mbl.2, mbl.3, mbl.4, mbr.1, mbr.2  
**EXAMINERS:** CE Frakes Lv II, Shane Gauthier Lv II, Mark Hilborn Lv II  
**MANUAL DATA:** RPV-024, RPV-026  
**EXAMINERS:** C. Minor Lv. III.  
**MAGNETIC PARTICLE:** MT-016  
**EXAMINERS:** Steve Woodward Lv II

Ultrasonic examination results were unacceptable to the requirements of ASME B&PVC Section XI, 1989 Edition No Addenda, Category B-A Welds.

Automated 0°L, 45°S, 60°RL, and 70°RL scans and calibrations were performed in accordance with procedure GE-UT-704 Version 4.

Automated scanning was performed from the OD surface, examining the top and bottom sides of weld H9 for a

There were sixty five (65) recordable indications. The indications are located intermittently along the weld length and are aligned with the fusion line.

Eighteen (18) indications displayed tip signals and possessed a through wall dimension. Sixteen (16) of the recorded indications have been evaluated as being unacceptable to the requirements of Table IWB-3510-1. Two (2) of the recorded indications have been evaluated as being acceptable to the requirements of Table IWB-3510-1.

The remaining forty seven (47) indications without through wall dimension have been evaluated as being acceptable to the requirements of Table IWB-3510-1.

Baseline examination results were reviewed, the number and lengths of indications changed but the location did not.

Magnetic particle examinations were performed on the weld CH-MB inside surface in accordance with GE-MT-100 Revision V3. No recordable indications were found.

A visual VT-3 examination was performed on the weld CH-MB inside surface in accordance with MAG-CG-407 Rev. 7. No recordable indications were found.

Supplemental manual ultrasonic examination of selected areas of the internal surface of weld CH-MB was performed in accordance with PDI-UT-7 Rev. E Addenda-01. PDI-UT-7 used for information only, not qualified for ID detection or sizing. No near surface indications were found.

Due to scan limitations it not possible to examine 100% of the ASME code required area.

Auto UT composite coverage = 93.1%

*Mark Hilborn III*  
**PREPARED BY**  
**DATE** 9/26/02

*Steve Woodward II*  
**REVIEWED BY**  
**DATE** 9/27/02

**UTILITY REVIEW**  
**DATE**

**ANII REVIEW**  
**DATE**



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** Peach Bottom 2 - 2R14  
**Weld ID:** CH-MB

**Exam Data Sheet : mbl.3**  
**Patch ID : mbl.3**

**Channel : 2      Angle : 45**

**Direction : 270**

[illegible]

**Comments :**

Analyst: Philip Shandri  
Level: III Date: 9-22-02

Reviewed By: Hack-Tank  
Level: III Date: 9/25/02



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

Project : Peach Bottom 2 - 2R14  
Weld ID : CH-MB

Exam Data Sheet : mb1.1  
Patch ID : mb1.1

Channel : 2 Angle : 45

Direction : 270

Ind #	Amp.	Search Unit		ThruWall	Length	S	Comments
		X	Y				
			20.39				
6	84%	137.28	20.89	0.20	1.00	0.00	
			21.39				
			22.39				
7	13%	137.53	22.90	N/A	0.75	0.00	
			23.14				
			24.14				
8	26%	137.28	24.14	N/A	0.75	0.00	
			24.89				
			28.14				
9	18%	136.28	28.29	N/A	0.75	0.00	
			28.89				
			29.14				
10	12%	137.53	29.64	0.10	0.75	0.00	
			29.89				
			30.14				
11	12%	139.29	30.14	N/A	0.50	0.00	
			30.64				
			32.14				
12	11%	138.29	32.14	N/A	0.50	0.00	
			32.64				

Comments :

Analyst: Philip Shaver

Level: III

Date: 9-22-02

Reviewed By: Mark T. ...

Level: III

Date: 9/25/02



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

Project : Peach Bottom 2 - 2R14  
Weld ID : CH-MB

Exam Data Sheet : mb1.1  
Patch ID : mb1.1

Channel : 2      Angle : 45

Direction : 270

Ind #	Amp.	Search Unit		ThruWall	Length	S	Comments
		X	Y				
			34.89				
13	17%	136.03	35.14	N/A	0.75	0.00	
			35.64				
			36.64				
14	24%	136.53	37.64	0.16	1.75	0.00	
			38.39				
			40.14				
15	14%	137.78	40.64	N/A	0.75	0.00	
			40.89				
			41.64				
16	76%	137.28	44.14	0.25	3.75	0.00	
			45.39				
			45.14				
17	13%	133.03	45.39	N/A	0.75	0.00	
			45.89				
			48.14				
18	34%	137.53	48.39	N/A	0.75	0.00	
			48.89				
			50.64				
19	187%	137.78	52.14	N/A	2.50	0.00	
			53.14				

Comments :

Analyst: Chiep Shari

Level: III

Date: 9-22-02

Reviewed By: Hale Tural

Level: III

Date: 9/25/02



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** Peach Bottom 2 - 2R14  
**Weld ID:** CH-MB

**Exam Data Sheet : mbl 1**  
**Patch ID : mbl 1**

**Channel : 2                      Angle : 45**

**Direction : 270**

[illegible]**Comments :**

**Analyst:**

Level: III

Date: 9-22-02

Reviewed By:

Level: III

Date: 9/25/02



GE Nuclear Energy

**GERIS 2000 Indication  
Data Sheet**Project : Peach Bottom 2 - 2R14  
Weld ID : CH-MBExam Data Sheet : mb1 2  
Patch ID : mb1 2Channel : 2      Angle : 45Direction : 270

Ind #	Amp.	Search Unit		ThruWall	Length	S	Comments
		X	Y				
26	20%	137.78	63.64	N/A	0.25	0.00	
			63.89				
			63.89				
27	12%	139.04	67.89	N/A	0.75	0.00	
			68.39				
			68.64				
28	15%	138.04	73.14	N/A	0.75	0.00	
			73.39				
			73.89				
29	76%	138.04	74.89	N/A	0.75	0.00	
			75.14				
			75.64				
30	143%	138.04	76.89	N/A	1.25	0.00	
			77.39				
			78.14				
31	91%	138.54	82.64	N/A	2.25	0.00	
			83.14				
			84.89				
32	156%	138.79	87.14	N/A	1.00	0.00	
			87.89				
			88.14				

Comments :

Analyst:

Philip Shamber

Level:

III

Date:

9-22-02

Reviewed By:

Mark Turk

Level:

III

Date:

9/25/02





**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project : Peach Bottom 2 - 2R14**  
**Weld ID : CH-M B**

**Exam Data Sheet : mb1 2**  
**Patch ID : mb1 2**

**Channel : 2      Angle : 45**

**Direction : 270**

[illegible]

**Comments :**

**Analyst:**

**Level:**

Date: 9-22-52

Reviewed By:

**Level:**

Date. 9/25/02



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project: Peach Bottom 2 - 2R14**  
**Weld ID: CH-MB**

**Exam Data Sheet : mbl.4**  
**Patch ID : mbl.4**

**Channel : 2      Angle : 45**

**Direction : 270**

[illegible]

**Comments :**

Analyst: Philip Shambli  
Level III Date: 9-22-02

Reviewed By: Mark Tuma  
Level: III Date: 9/25/02



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

Project : Peach Bottom 2 - 2R14  
Weld ID : CH-MB

Exam Data Sheet : mbr.2  
Patch ID : mbr.2

Channel : 2 Angle : 45

Direction : 270

Ind #	Amp.	Search Unit		ThruWall	Length	S	Comments
		X	Y				
			11.11				
37	15%	125.96	11.36	N/A	0.50	0.00	
			11.61				
			18.36				
38	45%	127.96	18.61	0.19	0.75	0.00	
			19.11				
			21.86				
39	31%	127.46	22.11	0.16	0.40	0.00	
			22.26				
			25.36				
40	31%	125.71	25.61	N/A	0.50	0.00	
			25.86				
			31.61				
41	31%	126.21	32.61	N/A	1.50	0.00	
			33.11				
			34.61				
42	29%	125.96	35.11	0.19	1.75	0.00	
			36.36				
			39.11				
43	20%	127.21	39.11	N/A	0.25	0.00	
			39.36				

Comments :

Analyst CP 15

Level: IV

Date: 9/21/02

Reviewed By: Mark Troh

Level: III

Date: 9/25/02



## GERIS 2000 Indication Data Sheet

**Project:** Peach Bottom 2 - 2R14  
**Weld ID:** CH-MB

**Exam Data Sheet : mbr.2**  
**Patch ID : mbr.2**

Channel : 2      Angle : 45

**Direction : 270**

[illegible]

**Comments :**

Analyst:

Level: IV

Date: 9/21/02

Reviewed By:

Level: III

Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Data Sheet

Project : Peach Bottom 2 - 2R14

Weld ID :

Exam Data Sheet : mbr.1Patch ID : mbr.1Channel : 2Angle : 45Direction : 270

Ind #	Amp.	Search Unit		ThruWall	Length	S	Comments
		X	Y				
			48.11				
48	131%	128.97	48.61	N/A	0.75	0.00	
			48.86				
			49.36				
49	143%	128.72	49.61	N/A	1.00	0.00	
			50.36				
			49.86				
50	37%	126.96	50.61	0.12	1.00	0.00	
			50.86				
			53.61				
51	143%	128.47	53.86	N/A	0.75	0.00	
			54.36				
			56.11				
52	45%	127.21	56.61	N/A	0.75	0.00	
			56.86				
			56.36				
53	37%	128.97	56.61	0.14	0.75	0.00	
			57.11				
			60.11				
54	18%	127.46	60.86	N/A	1.00	0.00	
			61.11				

Comments :

Analyst: OP MSLevel IIIDate: 9/21/02Reviewed By: Nick TushLevel IIIDate: 9/25/02



GE Nuclear Energy

## GERIS 2000 Indication Data Sheet

Project : Peach Bottom 2 - 2R14  
Weld ID : CH-MB

Exam Data Sheet : mbr.1  
Patch ID : mbr.1

Channel : 2 Angle : 45

Direction : 270

Ind #	Amp.	Search Unit		ThruWall	Length	S	Comments
		X	Y				
			61.10				
55	22%	129.47	61.36	N/A	0.51	0.00	
			61.61				
			72.61				
56	100%	129.71	73.10	0.17	1.00	0.00	
			73.61				
			74.61				
57	109%	129.47	75.11	0.17	1.00	0.00	
			75.61				
			80.11				
58	70%	129.22	80.61	N/A	1.25	0.00	
			81.36				
			81.61				
59	45%	129.72	82.11	N/A	0.75	0.00	
			82.36				
			84.11				
60	45%	129.47	84.11	N/A	0.50	0.00	
			84.61				
			84.61				
61	171%	128.97	85.11	0.12	1.00	0.00	
			85.61				

Comments : None

Analyst: CP MT

Level: III

Date: 3/22/02

Reviewed By: Mark Tinel

Level: III

Date: 9/26/02



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** Peach Bottom 2 - 2R14  
**Weld ID:** CH-MB

**Exam Data Sheet : mbr.1**  
**Patch ID : mbr.1**

**Channel : 2      Angle : 45**

**Direction : 270**

[illegible]

**Comments :**

**Analyst**

**Level.**

Date: 9/2/02

Reviewed By:

**Level:**

Date:



**GE Nuclear Energy**

## GERIS 2000 Indication Data Sheet

**Project:** Peach Bottom 2 - 2R14  
**Weld ID:** CH-MB

**Exam Data Sheet : mbr.1**  
**Patch ID : mbr.1**

**Channel : 4      Angle : 45**

**Direction : 270**

[illegible]

**Comments :**

Analyst: CPM  
Level: III Date: 9/10/02

Reviewed By: Mark Tinsch  
Level: III Date: 9/25/02



**APPENDIX B**

**GERIS 2000 Indication  
Evaluation Data Sheets**

**Rev 1  
September 2002  
(Includes 2 New Pages September 27, 2002)**



GE Nuclear Energy

## GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.3  
Sizing Data Sheet : n/a  
Indication : 5

Flaw Throughwall Dimension = 0.170  
Flaw Length "l" = 0.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	3.07	3.57 Y
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed 3.07	Allowed 0.00

a = 0.170  
a/l value = 0.227  
Y = 0.000

Flaw is Surface

Allowed a/t = 3.07%  
a/t = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None

Data Review By: Philip Sharpe

Reviewed By: Mark Tuck

Level: III Date: 9-22-02

Level: III Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.1  
Sizing Data Sheet : n/a  
Indication : 6

Flaw Throughwall Dimension = 0.200  
Flaw Length "l" = 1.00  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	2.80	3.30 Y
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.80	0.00

a = 0.200  
a/l value = 0.200  
Y = 0.000

Flaw is Surface

Allowed a/l = 2.80%  
a/l = 4.65%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None

Data Review By: Philip Shaver  
Level: III Date: 9-22-02

Reviewed By: Mark Tuck  
Level: III Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.1  
Sizing Data Sheet : n/a  
Indication : 14

Flaw Throughwall Dimension = 0.160  
Flaw Length "l" = 1.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	2.17	2.45 Y
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed 2.17	Allowed 0.00

a = 0.160  
a/l value = 0.091  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.17%  
a/t = 3.72%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Philip Hamilton

Level: III Date: 9-22-02

Reviewed By: Mark T. Vosh

Level: III Date: 9/25/02



GE Nuclear Energy

**GERIS 2000 Indication  
Evaluation Data Sheet**

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.1  
Sizing Data Sheet : n/a  
Indication : 10

Flaw Throughwall Dimension = 0.100  
Flaw Length "l" = 0.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	2.40	2.77 Y
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed 2.40	Allowed 0.00

a = 0.100  
a/l value = 0.133  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.40%  
a/t = 2.33%

Flaw is acceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Philip Shamba  
Level: III Date: 9-22-02

Reviewed By: Mark Tord  
Level: III Date: 9/25/02



GE Nuclear Energy

## GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.1  
Sizing Data Sheet : n/a  
Indication : 16

Flaw Throughwall Dimension = 0.250  
Flaw Length "L" = 3.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	2.07	2.30 Y
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.07	0.00

a = 0.250  
a/l value = 0.067  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.07%  
a/t = 5.81%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Philip Shanley

Level: III

Date: 9-22-02

Reviewed By: Mark Tindle

Level: III

Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.1  
Sizing Data Sheet : n/a  
Indication : 20

Flaw Throughwall Dimension = 0.170  
Flaw Length "l" = 1.25  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	2.42	2.79 Y
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.42	0.00

a = 0.170  
a/l value = 0.136  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.42%  
a/t = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Philip Shaver  
Level: III Date: 9-22-02

Reviewed By: Mark Trach  
Level: III Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.1  
Sizing Data Sheet : n/a  
Indication : 24

Flaw Throughwall Dimension = 0.170  
Flaw Length "l" = 1.00  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	2.62	3.06 Y
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.62	0.00

a = 0.170  
a/l value = 0.170  
Y = 0.000

Flaw is Surface

Allowed a/l = 2.62%  
a/l = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Philip Shambles

Level: III

Date: 9-22-02

Reviewed By: Mark Trone

Level: III

Date: 9/25/02





GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbl.2  
Sizing Data Sheet : n/a  
Indication : 34

Flaw Throughwall Dimension = 0.160  
Flaw Length "L" = 0.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	2.93	3.43 Y
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.93	0.00

a = 0.160  
a/t value = 0.213  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.93%  
a/t = 3.72%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Philip Shellen

Level: III

Date: 9-22-02

Reviewed By: Mark Torale

Level: III

Date: 9/25/02



GE Nuclear Energy

**GERIS 2000 Indication  
Evaluation Data Sheet**

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.2  
Sizing Data Sheet : n/a  
Indication : 38

Flaw Throughwall Dimension = 0.190  
Flaw Length "l" = 0.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	3.33	3.84 Y
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			3.33	0.00

a = 0.190  
a/t value = 0.253  
Y = 0.000

Flaw is Surface

Allowed a/t = 3.33%  
a/t = 4.42%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: CA M

Level: III

Date: 9/21/02

Reviewed By: Mark Torsak

Level: III

Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MA

Exam Data Sheet : mbr.2  
Sizing Data Sheet : n/a  
Indication : 39

Flaw Throughwall Dimension = 0.160  
Flaw Length "l" = 0.40  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	-	-
0.05	2.0	2.2	-	-
0.10	2.2	2.5	-	-
0.15	2.5	2.9	-	-
0.20	2.8	3.3	-	-
0.25	3.3	3.8	-	-
0.30	3.8	4.4	-	-
0.35	4.4	5.1	-	-
0.40	5.0	5.8	5.00	5.80 Y
0.45	5.1	6.7	-	-
0.50	5.2	7.6	-	-
			Allowed 5.00	Allowed 0.00

a = 0.160  
a/l value = 0.400  
Y = 0.000

Flaw is Surface

Allowed a/t = 5.00%  
a/t = 3.72%

Flaw is acceptable by Table IWB-3510-1.

Comments : None.

Data Review By: CP 15

Level: III

Date: 9/25/02

Reviewed By: Mark Trank

Level: III

Date: 9/25/02



GE Nuclear Energy

**GERIS 2000 Indication  
Evaluation Data Sheet**

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.2  
Sizing Data Sheet : n/a  
Indication : 42

Flaw Throughwall Dimension = 0.190  
Flaw Length "L" = 1.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	2.25	2.57 Y
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.25	0.00

a = 0.190  
a/t value = 0.109  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.25%  
a/t = 4.42%

Flaw is unacceptable by Table IWB-3510-1

Comments : None.

Data Review By: CP MT

Level: III

Date: 9/25/02

Reviewed By: Mark Turzok

Level: III

Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.2  
Sizing Data Sheet : n/a  
Indication : 44

Flaw Throughwall Dimension = 0.170  
Flaw Length "l" = 0.75  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	~	~
0.20	2.8	3.3	3.07	3.57 Y
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			3.07	0.00

a = 0.170  
a/l value = 0.227  
Y = 0.000

Flaw is Surface

Allowed a/t = 3.07%  
a/t = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By

CP MT

Level. III

Date: 9/21/02

Reviewed By:

Mark Tuzok

Level: III

Date: 9/25/02



GE Nuclear Energy

**GERIS 2000 Indication  
Evaluation Data Sheet**

Project : Peach Bottom, Unit-2

Weld ID : CH-MB

Exam Data Sheet : mbr.1

Sizing Data Sheet : n/a

Indication : 50

Flaw Throughwall Dimension = 0.120

Flaw Length "l" = 1.00

Surface Separation "S" = 0.00

"T" nominal = 4.25

"T" measured = 4.30

Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda

TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	2.32	2.66 Y
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.32	0.00

a = 0.120

a/l value = 0.120

Y = 0.000

Flaw is Surface

Allowed a/t = 2.32%

a/t = 2.79%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: OPMLevel: IIIDate: 9/25/02Reviewed By: Blake TorokLevel: IIIDate: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2

Weld ID : CH-MB

Exam Data Sheet : mbr.1

Sizing Data Sheet : n/a

Indication : 53

Flaw Throughwall Dimension = 0.140

Flaw Length "l" = 0.75

Surface Separation "S" = 0.00

"T" nominal = 4.25

"T" measured = 4.30

Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda

TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	2.72	3.19 Y
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.72	0.00

a = 0.140

a/l value = 0.187

Y = 0.000

Flaw is Surface

Allowed a/l = 2.72%

a/t = 3.26%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: OP MT

Level: III

Date: 9/25/02

Reviewed By: Mark T. ...

Level: III

Date: 9/25/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.1  
Sizing Data Sheet : n/a  
Indication : 56

Flaw Throughwall Dimension = 0.170  
Flaw Length "L" = 1.00  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	2.62	3.06 Y
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.62	0.00

a = 0.170  
a/t value = 0.170  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.62%  
a/t = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: CP MS

Level: III

Date: 9/26/02

Reviewed By: Mark Tural

Level: III

Date: 9/26/02





GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.1  
Sizing Data Sheet : n/a  
Indication : 57

Flaw Throughwall Dimension = 0.170  
Flaw Length "L" = 1.00  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	~	~
0.15	2.5	2.9	2.62	3.06 Y
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.62	0.00

a = 0.170  
a/t value = 0.170  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.62%  
a/t = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None

Data Review By: CP 15

Level: III

Date: 9/26/02

Reviewed By: Mark Tiroh

Level: III

Date: 9/26/02



GE Nuclear Energy

# GERIS 2000 Indication Evaluation Data Sheet

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.1  
Sizing Data Sheet : n/a  
Indication : 61

Flaw Throughwall Dimension = 0.120  
Flaw Length "l" = 1.00  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/l	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	2.32	2.66 Y
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.32	0.00

a = 0.120  
a/l value = 0.120  
Y = 0.000

Flaw is Surface

Allowed a/l = 2.32%  
a/l = 2.79%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By

CP 15

Level. III

Date: 9/25/02

Reviewed By:

Mark T. ...

Level: III

Date: 9/25/02



GE Nuclear Energy

**GERIS 2000 Indication  
Evaluation Data Sheet**

Project : Peach Bottom, Unit-2  
Weld ID : CH-MB

Exam Data Sheet : mbr.1  
Sizing Data Sheet : n/a  
Indication : 63

Flaw Throughwall Dimension = 0.170  
Flaw Length "L" = 1.50  
Surface Separation "S" = 0.00

"T" nominal = 4.25  
"T" measured = 4.30  
Clad "T" nominal = N/A

ASME Section XI, 1989 Edition, No Addenda  
TABLE IWB-3510-1 for 4" to 12"

a/t	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	~	~
0.05	2.0	2.2	~	~
0.10	2.2	2.5	2.28	2.61 Y
0.15	2.5	2.9	~	~
0.20	2.8	3.3	~	~
0.25	3.3	3.8	~	~
0.30	3.8	4.4	~	~
0.35	4.4	5.1	~	~
0.40	5.0	5.8	~	~
0.45	5.1	6.7	~	~
0.50	5.2	7.6	~	~
			Allowed	Allowed
			2.28	0.00

a = 0.170  
a/t value = 0.113  
Y = 0.000

Flaw is Surface

Allowed a/t = 2.28%  
a/t = 3.95%

Flaw is unacceptable by Table IWB-3510-1.

Comments : None.

Data Review By: CP 15

Level: III

Date: 9/6/02

Reviewed By: Rose Turner

Level: III

Date: 9/25/02