

DEC 18 2002



LR-N02-0415
LCR H02-07

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Gentlemen:

**WITHDRAWAL OF REQUEST FOR LICENSE AMENDMENT
INCREASED SNUBBER SURVEILLANCE TEST INTERVAL
HOPE CREEK GENERATING STATION
FACILITY OPERATING LICENSE NO. NPF-57
DOCKET NO. 50-354**

By letter dated July 3, 2002, PSEG Nuclear LLC (PSEG) proposed to increase the interval for snubber functional testing in accordance with Surveillance Requirement (SR) 4.7.5.e from 18 months to 54 months for certain hydraulic snubbers. In connection with the proposed change to the Technical Specifications, PSEG also requested relief from certain snubber functional testing requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components." Based on discussion with the NRC staff, PSEG has concluded that the proposed change would be more appropriately reviewed and approved first as a Code Case by the ASME Boiler and Pressure Vessel Committee.

PSEG hereby withdraws its request for license amendment and the associated relief request HC-RR-F03.

If you have any questions or require additional information, please contact Mr. Paul Duke at (856) 339-1466.

Sincerely,

A handwritten signature in cursive script, appearing to read "G. Salamon".

G. Salamon
Manager - Nuclear Safety and Licensing

A047

DEC 18 2002

C: Mr. H. Miller, Administrator – Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

U. S. Nuclear Regulatory Commission
ATTN: Mr. G. Wunder, Licensing Project Manager - Hope Creek
Mail Stop 08B3
Washington, DC 20555-0001

USNRC Senior Resident Inspector - Hope Creek (X24)

Mr. K. Tosch, Manager IV
Bureau of Nuclear Engineering
PO Box 415
Trenton, New Jersey 08625