

January 2, 2003

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF MEETING HELD ON DECEMBER 12, 2002, REGARDING THE
ALTERNATE SOURCE TERM SUBMITTAL

On December 12, 2002, representatives of Energy Northwest met with the NRC staff to discuss problems that were experienced during the alternate source term (AST) submittal, causing its subsequent withdrawal.

Energy Northwest gave an overview of the submittal errors and discussed actions being taken to revise and later resubmit the amendment request. Errors discovered in the meteorological and main steam line break data were discussed at length. Energy Northwest discussed the revised meteorological conversion errors and revisions that have been verified. Analyses with ARCON96 were performed with the revised meteorological data.

Energy Northwest is still determining the root cause of the submittal errors. The staff asked for feedback on the root cause and Energy Northwest agreed to submit their findings to the NRC. Energy Northwest thanked the staff for their recommendations and the opportunity to discuss the issues surrounding the submittal. At the conclusion of the meeting, the staff expressed their appreciation to Energy Northwest. An attendance list is provided in the attachment. The slides used during the meeting are available in ADAMS under accession number ML023470090.

/RA/

Brian Benney, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Meeting Attendees

cc w/encl: See next page

January 2, 2003

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF MEETING HELD ON DECEMBER 12, 2002, REGARDING THE ALTERNATE SOURCE TERM SUBMITTAL

On December 12, 2002, representatives of Energy Northwest met with the NRC staff to discuss problems that were experienced during the alternate source term (AST) submittal, causing its subsequent withdrawal.

Energy Northwest gave an overview of the submittal errors and discussed actions being taken to revise and later resubmit the amendment request. Errors discovered in the meteorological and main steam line break data were discussed at length. Energy Northwest discussed the revised meteorological conversion errors and revisions that have been verified. Analyses with ARCON96 were performed with the revised meteorological data.

Energy Northwest is still determining the root cause of the submittal errors. The staff asked for feedback on the root cause and Energy Northwest agreed to submit their findings to the NRC. Energy Northwest thanked the staff for their recommendations and the opportunity to discuss the issues surrounding the submittal. At the conclusion of the meeting, the staff expressed their appreciation to Energy Northwest. An attendance list is provided in the attachment. The slides used during the meeting are available in ADAMS under accession number ML023470090.

/RA/

Brian Benney, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Meeting Attendees

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	JBongarra
PDIV-2 Reading	EForrest
RidsNrrDlpm (JZwolinski / TMarsh)	RLobel
RidsNrrDlpmLpdiv (WRuland)	PHearn
SDembek	LBrown
RidsNrrPMBBenney	MKotzalas
RidsNrrLAEPeyton	MBlumberg
RidsRgn4MailCenter	RidsOgcRp
RidsAcrcAcnwMailCenter	

Package No.: ML030020042

Meeting Notice: ML023290004

ADAMS Accession No: ML030020029

Meeting Handout: ML023470090

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	BBenney:rkb	EPeyton	SDembek
DATE	12/31/02	12/24/02	12/31/02

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML030020029.wpd

OFFICIAL RECORD COPY

MEETING ATTENDEES

MEETING WITH ENERGY NORTHWEST

REGARDING ALTERNATE SOURCE TERM SUBMITTAL

DECEMBER 12, 2002

ENERGY NORTHWEST

Mike Humphreys
Larry Linik
Bruce Boyum
Douglas Coleman
Marsha Eads
Linda Woosley
Abbas Mostala
Bob Vosburg
Jim Metcalf

NRC

Stephen Dembek
Brian Benney
Leta Brown
Mark Blumberg
Jim Bongarra
Peter Hearn
Ed Forrest
Richard Lobel

Columbia Generating Station

cc:

Mr. Rodney L. Webring (Mail Drop PE04)
Vice President, Nuclear Generation
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Mr. Dale Atkinson (Mail Drop PE08)
Vice President, Technical Services
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Mr. Albert E. Mouncer (Mail Drop PE01)
Vice President, Corporate Services/
General Counsel/CFO
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Thomas C. Poindexter, Esq.
Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Chairman
Energy Facility Site Evaluation Council
P.O. Box 43172
Olympia, WA 98504-3172

Mr. Bob Nichols
Executive Policy Division
Office of the Governor
P.O. Box 43113
Olympia, WA 98504-3113

Mr. D. W. Coleman (Mail Drop PE20)
Manager, Performance Assessment
and Regulatory Programs
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Ms. Lynn Albin
Washington State Department of Health
P.O. Box 7827
Olympia, WA 98504-7827

Ms. Christina Perrino (Mail Drop PE20)
Manager, Licensing
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Mr. J. V. Parrish
Chief Executive Officer
Energy Northwest
P.O. Box 968 (Mail Drop 1023)
Richland, WA 99352-0968

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Chairman
Benton County Board of Commissioners
P.O. Box 190
Prosser, WA 99350-0190

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 69
Richland, WA 99352-0069