

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
Unit 0 (Common) Components					
-	0AB03P(1)	Boric Acid Transfer Pump	0CC01E-C	1CC016	Control Cable For 0CC01E-C and 1CC01PB
	0AB03P(2)	Boric Acid Transfer Pump		1CC027	Power Cable For 0CC01E-C
0AB03P(1)	1AB001	Power Cable For 0AB03P(1) and 1AB03P		1CC029	Control Cable For 0CC01E-C
	1AB003	Power Cable For 0AB03P(1) and 0AB03P(2)		1CC030	Control Cable For 0CC01E-C
	1AB004	Control Cable For 0AB03P(1) and 1AB03P		1CC031	Control Cable For 0CC01E-C
	1AB005	Control Cable For 0AB03P(1) and 1AB03P		1CC175	Control Cable For 0CC01E-C
	1AB006	Control Cable For 0AB03P(1) and 1AB03P		1CC277	Control Cable For 0CC01E-C
	1AB049	Control Cable For 0AB03P(1) and 1AB03P		1EF043	Control Cable For 0CC01E-C
0AB03P(2)	1AB003	Power Cable For 0AB03P(1) and 0AB03P(2)	0CC01E-D	2CC016	Control Cable For 0CC01E-D and 2CC01PB
	2AB001	Power Cable For 0AB03P(2) and 2AB03P		2CC027	Power Cable For 0CC01E-D
	2AB004	Control Cable For 0AB03P(2) and 2AB03P		2CC029	Control Cable For 0CC01E-D
	2AB005	Control Cable For 0AB03P(2) and 2AB03P		2CC030	Control Cable For 0CC01E-D
	2AB006	Control Cable For 0AB03P(2) and 2AB03P		2CC031	Control Cable For 0CC01E-D
	2AB049	Control Cable For 0AB03P(2) and 2AB03P		2CC175	Control Cable For 0CC01E-D
0CC01E-A	1CC006	Control Cable For 0CC01E-A and 1CC01PA		2CC277	Control Cable For 0CC01E-D
	1CC019	Power Cable For 0CC01E-A		2EF043	Control Cable For 0CC01E-D
	1CC022	Control Cable For 0CC01E-A	0FI-SX044	1SX378	Instrument Cable For 0FI-SX044
	1CC023	Control Cable For 0CC01E-A		1SX379	Instrument Cable For 0FI-SX044
	1CC025	Control Cable For 0CC01E-A	0SX02PB	1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1CC174	Control Cable For 0CC01E-A			
0CC01E-B	1CC276	Control Cable For 0CC01E-A			
	1EF027	Control Cable For 0CC01E-A			
	2CC006	Control Cable For 0CC01E-B and 2CC01PA		1SX097	Control Cable For 0SX02PB
	2CC019	Power Cable For 0CC01E-B		1SX203	Control Cable For 0SX02PB
	2CC022	Control Cable For 0CC01E-B		1SX204	Control Cable For 0SX02PB
	2CC023	Control Cable For 0CC01E-B	0SX146	1SX089	Control Cable For 0SX146
	2CC025	Control Cable For 0CC01E-B		2SX089	Control Cable For 0SX147
	2CC106	Control Cable For 0CC01E-B	0SX162B	1SX170	Control Cable For 0SX162B
	2CC174	Control Cable For 0CC01E-B	0SX162D	2SX170	Control Cable For 0SX162D

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
0FI-SX044	2CC276	Control Cable For OCC01E-B	0VA475Y	1VA765	Control Cable For 0VA475Y
	2EF027	Control Cable For OCC01E-B		1VA766	Control Cable For 0VA475Y
	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031		1VA767	Control Cable For 0VA475Y
	0SX02PA	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1VA768	Control Cable For 0VA475Y
0SX162A	1SX172	Control Cable For 0SX02PA	0VA477Y	1VA769	Control Cable For 0VA475Y
	1SX205	Control Cable For 0SX02PA		1VA771	Control Cable For 0VA475Y
	1SX206	Control Cable For 0SX02PA		1VA796	Control Cable For 0VA475Y
	1SX158	Control Cable For 0SX162A		2VA765	Control Cable For 0VA477Y
0SX162C	2SX158	Control Cable For 0SX162C	0VC01CB	2VA766	Control Cable For 0VA477Y
0VA01CA	1VA001	Power Cable For 0VA01CA		2VA767	Control Cable For 0VA477Y
0VA01CC	2VA001	Power Cable For 0VA01CC		2VA768	Control Cable For 0VA477Y
0VA02CA	1VA016	Power Cable For 0VA02CA		2VA769	Control Cable For 0VA477Y
0VA02CC	2VA016	Power Cable For 0VA02CC	0VC01Y	2VA771	Control Cable For 0VA477Y
0VA474Y	1VA254	Control Cable For 0VA474Y		2VA796	Control Cable For 0VA477Y
	1VA485	Control Cable For 0VA474Y		1VC059	Power Cable For 0VC01CB
	1VA757	Control Cable For 0VA474Y		1VC064	Control Cable For 0VC01CB
	1VA758	Control Cable For 0VA474Y	0VC01Y	1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA759	Control Cable For 0VA474Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VA760	Control Cable For 0VA474Y		1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA761	Control Cable For 0VA474Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
0VA476Y	1VA763	Control Cable For 0VA474Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VA795	Control Cable For 0VA474Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	2VA254	Control Cable For 0VA476Y			
	2VA652	Control Cable For 0VA476Y			
	2VA757	Control Cable For 0VA476Y			
	2VA758	Control Cable For 0VA476Y			
	2VA759	Control Cable For 0VA476Y			
	2VA760	Control Cable For 0VA476Y			
	2VA761	Control Cable For 0VA476Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
0VC01CA	2VA763	Control Cable For 0VA476Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	2VA795	Control Cable For 0VA476Y			
	1VC018	Control Cable For 0VC01CA		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
0VC02CA	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC024	Control Cable For 0VC02CA		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
0VC033Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y	0VC02CB	1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC072	Control Cable For 0VC02CB
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y	0VC02Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC157	Control Cable For 0VC033Y and 0VC281Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC571	Control Cable For 0VC033Y and 0VC281Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
0VC043Y	1PR065	Power Cable For 0VC281Y and 0VC043Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1PR066	Power Cable For 0VC281Y and 0VC043Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y		1VC067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1PR314	Power Cable For 0VC281Y and 0VC043Y	0VC03Y	1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC159	Control Cable For 0VC043Y			
	1VC573	Control Cable For 0VC043Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
0VC094Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
0VC095Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
0VC133Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
0VC17Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y	0VC044Y	1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
0VC18Y	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y		1VC244	Control Cable For 0VC044Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC576	Control Cable For 0VC044Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y	0VC04Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
0VC19Y	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y	0VC16Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21

Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0		
0VC20Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y
0VC281Y	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y
	1PR065	Power Cable For 0VC281Y and 0VC043Y
	1PR066	Power Cable For 0VC281Y and 0VC043Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y
	1PR314	Power Cable For 0VC281Y and 0VC043Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y

Division 12/22

Affected Equipment	Equipment In Zone	Equipment Description
0VC172Y	1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y		1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	1VC157	Control Cable For 0VC033Y and 0VC281Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC571	Control Cable For 0VC033Y and 0VC281Y	0VC175Y	1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y	0VC182Y	1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
			0VC217Y	1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
			0VC282Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
				1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0				1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
Unit 1 Components					
-	1AB03P	Boric Acid Transfer Pump	1AF005E	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
	1AB03T	Boric Acid Tank		1AF082	Instrument Cable For 1AF005E
	1AB8465	BA Pump Suction Crosstie Isolation Valve (MV)			
	1AB8468	BA Pump Discharge Crosstie Isolation Valve (MV)			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1AB03P	1AP14E	Division 11 480V Non-ESF Aux Bldg Unit Substation 133X		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AP42E	Division 11 480V Non-ESF MCC 133X3			
	1AB001	Power Cable For 0AB03P(1) and 1AB03P			
	1AB002	Power Cable For 1AB03P	1AF005F	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
	1AB004	Control Cable For 0AB03P(1) and 1AB03P		1AF084	Instrument Cable For 1AF005F
	1AB005	Control Cable For 0AB03P(1) and 1AB03P		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
1AF005A	1AB006	Control Cable For 0AB03P(1) and 1AB03P			
	1AB049	Control Cable For 0AB03P(1) and 1AB03P			
	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF081	Instrument Cable For 1AF005A	1AF005G	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
1AF005B	1AF115	Control Cable For 1AF005A			
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1AF086	Instrument Cable For 1AF005G
				1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D	1AF005H	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
	1AF083	Instrument Cable For 1AF005B		1AF088	Instrument Cable For 1AF005H
	1AF116	Control Cable For 1AF005B		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D	1AF006B	1AF062	Control Cable For 1AF006B and 1AF017B
				1AF063	Control Cable For 1AF006B
1AF005C	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D		1AF296	Control Cable For 1AF006B and 1AF017B
	1AF085	Instrument Cable For 1AF005C		1AF326	Control Cable For 1AF006B
	1AF117	Control Cable For 1AF005C	1AF013E	1AF039	Control Cable For 1AF013E
				1AF041	Control Cable For 1AF013E
			1AF013F	1AF044	Control Cable For 1AF013F

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1AF005D	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1AF013G	1AF045 1AF048 1AF049	Control Cable For 1AF013F Control Cable For 1AF013G Control Cable For 1AF013G
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D	1AF013H	1AF052 1AF053	Control Cable For 1AF013H Control Cable For 1AF013H
	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D	1AF017B	1AF062 1AF100 1AF296	Control Cable For 1AF006B and 1AF017B Control Cable For 1AF017B Control Cable For 1AF006B and 1AF017B
	1AF087	Instrument Cable For 1AF005D	1AF01PB	1AF068 1AF070 1AF168 1AF289 1AF298 1AF338 1AF346 1DC184	Control Cable For 1AF01PB Control Cable For 1AF01PB Control Cable For 1AF01PB Control Cable For 1AF01PB-C and 1AF01PB Control Cable For 1AF01PB Instrument Cable For 1AF01PB Control Cable For 1AF01PB Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF118	Control Cable For 1AF005D		1AF159 1AF160 1AF162 1AF169 1DC184	Control Cable For 1AF01PB-A Control Cable For 1AF01PB-A Control Cable For 1AF01PB-A Control Cable For 1AF01PB-A Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			Control Cable For 1AF01PB-C and 1AF017A
1AF006A	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D	1AF01PB-A		Control Cable For 1AF01PB
	1AF056	Control Cable For 1AF006A and 1AF01PA			Control Cable For 1AF01PB
	1AF057	Control Cable For 1AF006A and 1AF017A			Control Cable For 1AF01PB
	1AF058	Control Cable For 1AF006A			Control Cable For 1AF01PB
	1AF295	Control Cable For 1AF006A and 1AF017A			Control Cable For 1AF01PB
1AF013A	1AF324	Control Cable For 1AF006A and 1AF01PA	1AF01PB-B		Control Cable For 1AF01PB
	1AF022	Control Cable For 1AF013A			Control Cable For 1AF01PB
	1AF024	Control Cable For 1AF013A			Control Cable For 1AF01PB
	1AF027	Control Cable For 1AF013B			Control Cable For 1AF01PB
	1AF028	Control Cable For 1AF013B			Control Cable For 1AF01PB
1AF013C	1AF031	Control Cable For 1AF013C	1AF01PB-C		Control Cable For 1AF01PB
	1AF032	Control Cable For 1AF013C			Control Cable For 1AF01PB
	1AF035	Control Cable For 1AF013D			Control Cable For 1AF01PB
	1AF036	Control Cable For 1AF013D			Control Cable For 1AF01PB
	1AF057	Control Cable For 1AF006A and 1AF017A			Control Cable For 1AF01PB
1AF017A	1AF097	Control Cable For 1AF017A			Control Cable For 1AF01PB
	1AF295	Control Cable For 1AF006A and 1AF017A			Control Cable For 1AF01PB
	1AF001	Power Cable For 1AF01PA			Control Cable For 1AF01PB
	1AF006	Control Cable For 1AF01PA			Control Cable For 1AF01PB
					Control Cable For 1AF01PB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1AF01PA-A	1AF007	Control Cable For 1AF01PA		1AF290	Control Cable For 1AF01PB-C
	1AF008	Control Cable For 1AF01PA		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11			
	1AF056	Control Cable For 1AF006A and 1AF01PA			
	1AF276	Control Cable For 1AF01PA			
	1AF324	Control Cable For 1AF006A and 1AF01PA	1AP06EF	1DG054	Control Cable For 1DG01KB and 1AP06EF
	1AF004	Control Cable For 1AF01PA-A		1DG229	Control Cable For 1AP06EF
	1AF014	Control Cable For 1AF01PA-A	1AP06EH	1CS018	Power Cable For 1AP06EH
	1AF019	Control Cable For 1AF01PA-A		1CS020	Control Cable For 1AP06EH
	1SI001	Power Cable For 1AP05EC		1CS034	Control Cable For 1AP06EH
1AP05EC	1CS001	Power Cable For 1AP05EJ		1CS043	Control Cable For 1AP06EH
1AP05EJ	1CS006	Control Cable For 1AP05EJ		1CS044	Control Cable For 1AP06EH
	1CS021	Control Cable For 1AP05EJ		1CS058	Control Cable For 1AP06EH and 1CS009B
	1CS041	Control Cable For 1AP05EJ		1CS123	Control Cable For 1AP06EH
	1CS042	Control Cable For 1AP05EJ	1AP06ES	1AP587	Control Cable For 1AP06ES and 2AP06EF
	1CS055	Control Cable For 1AP05EJ and 1CS009A	1AP23E	1AP149	Power Cable For 1AP23E
	1CS122	Control Cable For 1AP05EJ	1AP24E	1AP152	Power Cable For 1AP24E and 1AP32E
1AP07EL	1AP093	Power Cable For 1AP07EL		1AP154	Power Cable For 1AP24E and 1AP32E
	1AP142	Control Cable For 1AP07EL		1AP690	Power Cable For 1AP24E and 1AP32E
1AP14E	1AP376	Control Cable For 1AP14E	1AP32E	1AP152	Power Cable For 1AP24E and 1AP32E
	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E		1AP154	Power Cable For 1AP24E and 1AP32E
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E		1AP690	Power Cable For 1AP24E and 1AP32E
1AP21E	1AP143	Power Cable For 1AP21E	1CC01PB	1CC010	Power Cable For 1CC01PB
1AP21EA	1SI517	Control Cable For 1AP21EA		1CC012	Control Cable For 1CC01PB
1AP22E	1AP147	Power Cable For 1AP22E		1CC013	Control Cable For 1CC01PB
1AP25E	1AP144	Power Cable For 1AP25E		1CC014	Control Cable For 1CC01PB
1AP26E	1AP146	Power Cable For 1AP26E		1CC016	Control Cable For 0CC01E-C and 1CC01PB
1AP38E	1AP156	Power Cable For 1AP38E		1EF064	Control Cable For 1CC01PB
	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E	1CC685	1CC041	Control Cable For 1CC685
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E		1CC278	Control Cable For 1CC685
1AP42E	1AP258	Power Cable For 1AP42E	1CC9412B	1CC048	Control Cable For 1CC9412B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1CC01PA	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E	1CC9413B	1CC057	Control Cable For 1CC9413B
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E	1CC9414	1CC065	Control Cable For 1CC9414
	1CC002	Control Cable For 1CC01PA	1CC9473B	1CC130	Control Cable For 1CC9473B
	1CC003	Control Cable For 1CC01PA	1CS009B	1CS058	Control Cable For 1AP06EH and 1CS009B
	1CC004	Control Cable For 1CC01PA		1CS080	Control Cable For 1CS009B
	1CC006	Control Cable For 0CC01E-A and 1CC01PA		1CS113	Control Cable For 1CS009B
	1EF028	Control Cable For 1CC01PA	1CV01PB	1CV012	Control Cable For 1CV01PB
1CC9412A	1CC045	Control Cable For 1CC9412A		1CV016	Control Cable For 1CV01PB
1CC9413A	1CC051	Control Cable For 1CC9413A		1EF044	Control Cable For 1CV01PB and 1SX01PB
1CC9415	1CC067	Control Cable For 1CC9415	1CV112C	1CV075	Control Cable For 1CV112C
1CC9416	1CC059	Control Cable For 1CC9416	1CV112E	1CV083	Control Cable For 1CV112E
1CC9438	1CC036	Control Cable For 1CC9438		1CV085	Control Cable For 1CV112E
1CC9473A	1CC127	Control Cable For 1CC9473A	1CV121	1CV140	Instrument Cable For 1CV121
1CS009A	1CS055	Control Cable For 1AP05EJ and 1CS009A	1CV8104	1CV617	Control Cable For 1CV8104
	1CS079	Control Cable For 1CS009A		1CV618	Control Cable For 1CV8104
1CV01PA	1CV001	Power Cable For 1CV01PA	1CV8111	1CV063	Control Cable For 1CV8111
	1CV006	Control Cable For 1CV01PA	1CV8116	1CV649	Control Cable For 1CV8116
	1CV009	Control Cable For 1CV01PA	1CV8355B	1CV623	Control Cable For 1CV8355B
	1EF031	Control Cable For 1CV01PA and 1SX01PA	1CV8355C	1CV626	Control Cable For 1CV8355C
1CV112B	1CV069	Control Cable For 1CV112B	1DG01KB	1DG052	Control Cable For 1DG01KB
1CV112D	1CV079	Control Cable For 1CV112D		1DG053	Control Cable For 1DG01KB
	1CV080	Control Cable For 1CV112D		1DG054	Control Cable For 1DG01KB and 1AP06EF
1CV8110	1CV059	Control Cable For 1CV8110		1DG150	Control Cable For 1DG01KB
1CV8114	1CV645	Control Cable For 1CV8114		1DG178	Control Cable For 1DG01KB
1CV8355A	1CV611	Control Cable For 1CV8355A		1DG201	Control Cable For 1DG01KB
1CV8355D	1CV614	Control Cable For 1CV8355D	1DO01PD	1DO009	Power Cable For 1DO01PD
1CV8804A	1CV407	Control Cable For 1CV8804A		1DO010	Control Cable For 1DO01PD
	1CV468	Control Cable For 1CV8804A	1FI-0121A	1CV139	Instrument Cable For 1FI-0121A and 1FI-0121B
	1SI454	Control Cable For 1CV8804A	1FI-0121B	1CV139	Instrument Cable For 1FI-0121A and 1FI-0121B
1DO01PA	1DO001	Power Cable For 1DO01PA	1IP02E	1IP020	Power Cable For 1IP02E
	1DO002	Control Cable For 1DO01PA	1IP04E	1IP044	Power Cable For 1IP04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1FI-SX031	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031	1LI-0460B	1RC406	Instrument Cable For 1LI-0460B
	1SX376	Instrument Cable For 1FI-SX031	1LI-0502	1FW026	Instrument Cable For 1LI-0502
	1SX377	Instrument Cable For 1FI-SX031	1LI-0503	1FW027	Instrument Cable For 1LI-0503
1IP01E	1IP004	Power Cable For 1IP01E	1LL-SI075B	1SI257	Control Cable For 1LL-SI075B
1IP03E	1IP032	Power Cable For 1IP03E	1MS001A-DIV12	1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
1IP05E	1IP002	Power Cable For 1IP05E		1MS270	Control Cable For 1MS001A-DIV12
1IP07E	1IP030	Power Cable For 1IP07E		1MS273	Control Cable For 1MS001A-DIV12
1LI-0459A	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B		1MS276	Control Cable For 1MS001A-DIV12
1LI-0459B	1RC371	Instrument Cable For 1LI-0459B		1MS525	Control Cable For 1MS001A-DIV12 and 1MS001C-DIV12
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B		1MS530	Control Cable For 1MS001A-DIV12
1LI-0501	1FW025	Instrument Cable For 1LI-0501		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A		1MS282	Control Cable For 1MS001B-DIV12
1LI-0501A	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A		1MS283	Control Cable For 1MS001B-DIV12
1LI-0504	1FW028	Instrument Cable For 1LI-0504	1MS001B-DIV12	1MS286	Control Cable For 1MS001B-DIV12
1LI-0930	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7		1MS289	Control Cable For 1MS001B-DIV12
				1MS521	Control Cable For 1MS001B-DIV12 and 1MS001D-DIV12
1LI-0932	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
1LL-SI075A	1SI234	Control Cable For 1LL-SI075A		1MS295	Control Cable For 1MS001C-DIV12
1MS001A-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1MS296	Control Cable For 1MS001C-DIV12
	1MS272	Control Cable For 1MS001A-DIV11		1MS299	Control Cable For 1MS001C-DIV12
	1MS275	Control Cable For 1MS001A-DIV11	1MS001C-DIV12	1MS523	Control Cable For 1MS001C-DIV12
	1MS518	Control Cable For 1MS001A-DIV11			
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11			
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11			
1MS001B-DIV11	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1MS525	Control Cable For 1MS001A-DIV12 and 1MS001C-DIV12
	1MS285	Control Cable For 1MS001B-DIV11	1MS001D-DIV12	1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1MS288	Control Cable For 1MS001B-DIV11		1MS309	Control Cable For 1MS001D-DIV12
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11		1MS312	Control Cable For 1MS001D-DIV12
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11		1MS521	Control Cable For 1MS001B-DIV12 and 1MS001D-DIV12
1MS001C-DIV11	1AF121	Control Cable For 1MS001C-DIV11		1MS528	Control Cable For 1MS001D-DIV12
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1MS018B	1MS533	Control Cable For 1MS001D-DIV12
	1MS298	Control Cable For 1MS001C-DIV11		1MS610	Control Cable For 1MS018B and 1MS018C
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11		1MS612	Control Cable For 1MS018B and 1MS018C
	1MS524	Control Cable For 1MS001C-DIV11		1MS614	Control Cable For 1MS018B
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11		1MS616	Power Cable For 1MS018B
1MS001D-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1MS617	Instrument Cable For 1MS018B
	1MS311	Control Cable For 1MS001D-DIV11		1MS618	Instrument Cable For 1MS018B
	1MS527	Control Cable For 1MS001D-DIV11	1MS018C	1MS619	Instrument Cable For 1MS018B
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11		1MS620	Instrument Cable For 1MS018B
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11		1MS621	Instrument Cable For 1MS018B
1MS018A	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D		1MS622	Instrument Cable For 1MS018B
	1MS581	Control Cable For 1MS018A and 1MS018D		1MS643	Instrument Cable For 1MS018B
	1MS583	Control Cable For 1MS018A and 1MS018D		1MS610	Control Cable For 1MS018B and 1MS018C
				1MS612	Control Cable For 1MS018B and 1MS018C
				1MS626	Control Cable For 1MS018C
				1MS628	Power Cable For 1MS018C
				1MS629	Instrument Cable For 1MS018C
				1MS630	Instrument Cable For 1MS018C
				1MS631	Instrument Cable For 1MS018C
				1MS632	Instrument Cable For 1MS018C
				1MS633	Instrument Cable For 1MS018C

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1MS018D	1MS585	Control Cable For 1MS018A		1MS634	Instrument Cable For 1MS018C
	1MS587	Power Cable For 1MS018A		1MS646	Instrument Cable For 1MS018C
	1MS588	Instrument Cable For 1MS018A	1MS101A	1MS320	Control Cable For 1MS101A
	1MS589	Instrument Cable For 1MS018A	1MS101B	1MS325	Control Cable For 1MS101B
	1MS590	Instrument Cable For 1MS018A	1MS101C	1MS330	Control Cable For 1MS101C
	1MS591	Instrument Cable For 1MS018A	1MS101D	1MS335	Control Cable For 1MS101D
	1MS592	Instrument Cable For 1MS018A	1PI-0403A	1CV673	Instrument Cable For 1PI-0403A
	1MS593	Instrument Cable For 1MS018A	1PI-0525A	1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
	1MS594	Power Cable For 1MS018A	1PI-MS194	1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
	1MS640	Instrument Cable For 1MS018A	1RH01PB	1RH008	Power Cable For 1RH01PB
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D	1RH611	1RH021	Control Cable For 1RH611
			1RH8701B	1RH038	Control Cable For 1RH8701B
	1MS581	Control Cable For 1MS018A and 1MS018D		1RH042	Control Cable For 1RH8701B
	1MS583	Control Cable For 1MS018A and 1MS018D		1RH043	Control Cable For 1RH8701B
	1MS597	Control Cable For 1MS018D	1RH8702B	1RH064	Control Cable For 1RH8702B
	1MS599	Power Cable For 1MS018D		1RH065	Control Cable For 1RH8702B
	1MS600	Instrument Cable For 1MS018D	1RH8716B	1RH073	Control Cable For 1RH8716B
	1MS601	Instrument Cable For 1MS018D	1SI8801B	1SI037	Power Cable For 1SI8801B
	1MS602	Instrument Cable For 1MS018D		1SI038	Control Cable For 1SI8801B
	1MS603	Instrument Cable For 1MS018D		1SI039	Control Cable For 1SI8801B
	1MS604	Instrument Cable For 1MS018D	1SI8804B	1SI063	Control Cable For 1SI8804B
	1MS605	Instrument Cable For 1MS018D		1SI066	Control Cable For 1SI8804B
	1MS606	Power Cable For 1MS018D		1SI067	Control Cable For 1SI8804B
	1MS649	Instrument Cable For 1MS018D	1SI8807B	1SI085	Control Cable For 1SI8807B
1MS101A	1MS321	Control Cable For 1MS101A	1SI8809B	1SI139	Control Cable For 1SI8809B
1MS101B	1MS326	Control Cable For 1MS101B	1SI8811B	1SI164	Control Cable For 1SI8811B
1MS101C	1MS331	Control Cable For 1MS101C	1SI8812B	1SI175	Control Cable For 1SI8812B
1MS101D	1MS336	Control Cable For 1MS101D	1SI8924	1SI472	Control Cable For 1SI8924
1NI-NR005D	1NR297	Instrument Cable For 1NI-NR005D	1SX001B	1SX037	Control Cable For 1SX001B
1PI-0405	1CV663	Instrument Cable For 1PI-0405	1SX005	1SX044	Control Cable For 1SX005
1PI-0455A	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B	1SX010	1SX092	Control Cable For 1SX010

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1PI-0455B	1RC370	Instrument Cable For 1PI-0455B	1SX011	1SX095	Control Cable For 1SX011
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B	1SX016B	1SX056	Control Cable For 1SX016B
1PI-0514A	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193	1SX01PB	1EF044	Control Cable For 1CV01PB and 1SX01PB
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B		1SX012	Power Cable For 1SX01PB
1PI-0514B	1MS099	Instrument Cable For 1PI-0514B		1SX016	Control Cable For 1SX01PB
	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193		1SX017	Control Cable For 1SX01PB-C and 1SX01PB
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B		1SX019	Control Cable For 1SX01PB
1PI-0524A	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B		1SX038	Control Cable For 1SX01PB
1PI-0524B	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B		1SX144	Control Cable For 1SX01PB
	1MS103	Instrument Cable For 1PI-0524B		1SX209	Control Cable For 1SX01PB
1PI-0534A	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B	1SX01PB-C	1SX286	Control Cable For 1SX01PB
1PI-0534B	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B		1SX017	Control Cable For 1SX01PB-C and 1SX01PB
	1MS107	Instrument Cable For 1PI-0534B		1SX305	Control Cable For 1SX01PB-C
1PI-0544A	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B	1SX027B	1SX314	Control Cable For 1SX01PB-C
1PI-0544B	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B	1SX034	1SX062	Control Cable For 1SX027B
	1MS111	Instrument Cable For 1PI-0544B	1SX136	1SX068	Control Cable For 1SX034
1PI-CC107	1CC314	Control Cable For 1PI-CC107	1SX147B	1SX083	Control Cable For 1SX136
	1CC315	Instrument Cable For 1PI-CC107		1LV034	Control Cable For 1SX147B
	1LV002	Control Cable For 1PI-CC107	1SX169B	1SX191	Control Cable For 1SX147B
1PI-MS193	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193	1SX173	1SX301	Control Cable For 1SX169B
1RC014A	1RC622	Control Cable For 1RC014A		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
1RC014C	1RC628	Control Cable For 1RC014C	1TI-IT002	1RC669	Control Cable For 1TI-IT002
1RH01PA	1RH001	Power Cable For 1RH01PA	1TI-RC005B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1RH610	1RH017	Control Cable For 1RH610	1TI-RC006B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1RH8701A	1RH029	Control Cable For 1RH8701A and 1SI8811A	1TI-RC007B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
	1RH030	Control Cable For 1RH8701A			
	1RH031	Control Cable For 1RH8701A			
	1SI168	Control Cable For 1RH8701A			
1RH8702A	1RH050	Control Cable For 1RH8702A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1RH051	Control Cable For 1RH8702A	1TI-RC008B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
	1RH052	Control Cable For 1RH8702A	1VA01CE	1VA115	Control Cable For 1VA01CE
	1RH054	Control Cable For 1RH8702A	1VA01CH	1VA170	Control Cable For 1VA01CH
	1RH055	Control Cable For 1RH8702A	1VA02CC	1VA105	Control Cable For 1VA02CC
1RH8716A	1RH069	Control Cable For 1RH8716A	1VA06CC	1VA057	Control Cable For 1VA06CC
1RY8000A	1RY394	Control Cable For 1RY8000A	1VA06CD	1VA141	Control Cable For 1VA06CD
1SI8801A	1SI035	Control Cable For 1SI8801A	1VD01YA	1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8806	1SI072	Power Cable For 1SI8806		1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SI073	Control Cable For 1SI8806		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SI074	Control Cable For 1SI8806		1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SI077	Control Cable For 1SI8806		1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8807A	1SI081	Control Cable For 1SI8807A		1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8809A	1SI134	Control Cable For 1SI8809A		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8811A	1RH029	Control Cable For 1RH8701A and 1SI8811A	1VD01YB	1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SI152	Control Cable For 1SI8811A		1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8812A	1SI170	Control Cable For 1SI8812A		1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8840	1SI211	Control Cable For 1SI8840		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8923A	1SI199	Control Cable For 1SI8923A		1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SX001A	1SX033	Control Cable For 1SX001A		1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SX004	1SX041	Control Cable For 1SX004	1VD02YA	1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SX01PA	1EF031	Control Cable For 1CV01PA and 1SX01PA		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX005	Control Cable For 1SX01PA		1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX006	Control Cable For 1SX01PA-C and 1SX01PA		1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX008	Control Cable For 1SX01PA		1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX034	Control Cable For 1SX01PA		1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX052	Control Cable For 1SX01PA		1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX058	Control Cable For 1SX01PA	1VD02YB		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX143	Control Cable For 1SX01PA			Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX208	Control Cable For 1SX01PA			Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX280	Control Cable For 1SX01PA			Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SX01PA-C	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1SX311	Control Cable For 1SX01PA-C		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX312	Control Cable For 1SX01PA-C		1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SX313	Control Cable For 1SX01PA-C			
1SX033	1SX065	Control Cable For 1SX033	1VE01Y	1VE022	Control Cable For 1VE01Y and 1VE02Y
1SX101A	1AF002	Control Cable For 1SX101A		1VE042	Control Cable For 1VE01Y and 1VE02Y
	1AF003	Control Cable For 1SX101A	1VE02Y	1VE022	Control Cable For 1VE01Y and 1VE02Y
	1SX471	Control Cable For 1SX101A		1VE042	Control Cable For 1VE01Y and 1VE02Y
1SX147A	1LV033	Control Cable For 1SX147A	1VP01CB	1VP038	Control Cable For 1VP01CB
	1SX178	Control Cable For 1SX147A		1VP042	Control Cable For 1VP01CB
1TI-0413A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A	1VP01CD	1VP082	Control Cable For 1VP01CD
1TI-0423A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A		1VP086	Control Cable For 1VP01CD
1TI-0433A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A	1VX01Y	1VX067	Control Cable For 1VX01Y and 1VX02Y
1TI-0443A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A		1VX099	Control Cable For 1VX01Y and 1VX02Y
1TI-IT001	1IT275	Instrument Cable For 1TI-IT001	1VX02Y	1VX067	Control Cable For 1VX01Y and 1VX02Y
	1IT276	Instrument Cable For 1TI-IT001		1VX099	Control Cable For 1VX01Y and 1VX02Y
	1IT277	Instrument Cable For 1TI-IT001			
	1IT278	Instrument Cable For 1TI-IT001			
	1IT279	Instrument Cable For 1TI-IT001			
	1IT280	Instrument Cable For 1TI-IT001			
	1IT281	Instrument Cable For 1TI-IT001			
	1IT282	Instrument Cable For 1TI-IT001			
	1IT283	Instrument Cable For 1TI-IT001			
	1IT284	Instrument Cable For 1TI-IT001			
	1IT285	Instrument Cable For 1TI-IT001			
	1IT286	Instrument Cable For 1TI-IT001			
	1IT287	Instrument Cable For 1TI-IT001			
	1IT288	Instrument Cable For 1TI-IT001			
	1IT289	Instrument Cable For 1TI-IT001			
	1IT290	Instrument Cable For 1TI-IT001			
	1IT291	Instrument Cable For 1TI-IT001			
	1IT292	Instrument Cable For 1TI-IT001			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	1IT293	Instrument Cable For 1TI-IT001			
	1IT294	Instrument Cable For 1TI-IT001			
	1IT295	Instrument Cable For 1TI-IT001			
	1IT296	Instrument Cable For 1TI-IT001			
	1IT297	Instrument Cable For 1TI-IT001			
	1IT298	Instrument Cable For 1TI-IT001			
	1IT299	Instrument Cable For 1TI-IT001			
	1IT300	Instrument Cable For 1TI-IT001			
	1IT301	Instrument Cable For 1TI-IT001			
	1IT302	Instrument Cable For 1TI-IT001			
	1IT303	Instrument Cable For 1TI-IT001			
	1IT304	Instrument Cable For 1TI-IT001			
	1IT305	Instrument Cable For 1TI-IT001			
	1IT306	Instrument Cable For 1TI-IT001			
	1IT307	Instrument Cable For 1TI-IT001			
	1IT345	Instrument Cable For 1TI-IT001			
	1IT346	Instrument Cable For 1TI-IT001			
	1IT424	Instrument Cable For 1TI-IT001			
	1RC648	Control Cable For 1TI-IT001			
1TI-RC005A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC006A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC007A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC008A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1UL-AN012-A7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1UL-AN012-B7	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
	1AN166	Control Cable For 1UL-AN012-B7			
	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-C7	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1VA01CA	1VA111	Control Cable For 1VA01CA			
1VA01CD	1VA165	Control Cable For 1VA01CD			
1VA02CA	1VA104	Control Cable For 1VA02CA			
1VA02CB	1VA148	Power Cable For 1VA02CB			
	1VA150	Control Cable For 1VA02CB			
1VA06CA	1VA053	Control Cable For 1VA06CA			
1VA06CB	1VA821	Power Cable For 1VA06CB			
	1VA822	Control Cable For 1VA06CB			
	1VA823	Control Cable For 1VA06CB			
1VD09YA	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1VD10YA	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YB	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VP003	Power Cable For 1VP01CA			
1VP01CC	1VP016	Control Cable For 1VP01CA			
	1VP020	Control Cable For 1VP01CA			
	1VP047	Power Cable For 1VP01CC			
1VX04Y	1VP060	Control Cable For 1VP01CC			
	1VP064	Control Cable For 1VP01CC			
	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VX064	Control Cable For 1VX04Y and 1VX05Y			
	1VX102	Control Cable For 1VX04Y and 1VX05Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
1VX05Y	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VX064	Control Cable For 1VX04Y and 1VX05Y			
	1VX102	Control Cable For 1VX04Y and 1VX05Y			
Unit 2 Components					
-	2AB03P	Boric Acid Transfer Pump	2AF005E	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
	2AB03T	Boric Acid Tank		2AF082	Instrument Cable For 2AF005E
	2AB8465	BA Pump Suction Crosstie Isolation Valve (MV)		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2AB8468	BA Pump Discharge Crosstie Isolation Valve (MV)			
	2AP14E	Division 21 480V Non-ESF Aux Bldg Unit Substation 233X			
	2AP22E	Division 21 480V ESF MCC 231X3	2AF005F	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
	2AP42E	Division 21 480V Non-ESF MCC 233X3		2AF084	Instrument Cable For 2AF005F
	2AB03P	Power Cable For 0AB03P(2) and 2AB03P		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2AB002	Power Cable For 2AB03P			
	2AB004	Control Cable For 0AB03P(2) and 2AB03P			
2AB03P	2AB005	Control Cable For 0AB03P(2) and 2AB03P			
	2AB006	Control Cable For 0AB03P(2) and 2AB03P			
	2AB049	Control Cable For 0AB03P(2) and 2AB03P	2AF005G	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D		2AF086	Instrument Cable For 2AF005G
	2AF081	Instrument Cable For 2AF005A		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
2AF005A	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2AF005H	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D		2AF088	Instrument Cable For 2AF005H
2AF005B	2AF083	Instrument Cable For 2AF005B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2AF005C	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2AF006B	2AF062	Control Cable For 2AF006B and 2AF017B
	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D		2AF063	Control Cable For 2AF006B
	2AF085	Instrument Cable For 2AF005C		2AF296	Control Cable For 2AF006B and 2AF017B
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2AF334	Control Cable For 2AF006B
2AF005D	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2AF013E	2AF039	Control Cable For 2AF013E
	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D		2AF041	Control Cable For 2AF013E
	2AF087	Instrument Cable For 2AF005D	2AF013F	2AF044	Control Cable For 2AF013F
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2AF045	Control Cable For 2AF013F
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2AF013G	2AF048	Control Cable For 2AF013G
2AF006A	2AF054	Power Cable For 2AF006A		2AF049	Control Cable For 2AF013G
	2AF055	Control Cable For 2AF006A and 2AF022A	2AF013H	2AF052	Control Cable For 2AF013H
	2AF056	Control Cable For 2AF006A and 2AF01PA		2AF053	Control Cable For 2AF013H
	2AF057	Control Cable For 2AF006A and 2AF017A	2AF017B	2AF062	Control Cable For 2AF006B and 2AF017B
	2AF058	Control Cable For 2AF006A		2AF100	Control Cable For 2AF017B
	2AF295	Control Cable For 2AF006A and 2AF017A	2AF01PB	2AF296	Control Cable For 2AF006B and 2AF017B
	2AF332	Control Cable For 2AF006A and 2AF01PA		2AF068	Control Cable For 2AF01PB
	2AF024	Control Cable For 2AF013A		2AF070	Control Cable For 2AF01PB
	2AF028	Control Cable For 2AF013B		2AF168	Control Cable For 2AF01PB
	2AF032	Control Cable For 2AF013C		2AF289	Control Cable For 2AF01PB-C and 2AF01PB
2AF013A	2AF024	Control Cable For 2AF013A		2AF298	Control Cable For 2AF01PB
2AF013B	2AF028	Control Cable For 2AF013B		2AF338	Instrument Cable For 2AF01PB
2AF013C	2AF032	Control Cable For 2AF013C		2AF346	Control Cable For 2AF01PB
2AF013D	2AF036	Control Cable For 2AF013D	2AF01PB-A	2AF159	Control Cable For 2AF01PB-A

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2AF017A	2AF057	Control Cable For 2AF006A and 2AF017A		2AF160	Control Cable For 2AF01PB-A
	2AF097	Control Cable For 2AF017A		2AF162	Control Cable For 2AF01PB-A
	2AF098	Power Cable For 2AF017A		2AF169	Control Cable For 2AF01PB-A
	2AF099	Control Cable For 2AF017A and 2AF022A		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2AF295	Control Cable For 2AF006A and 2AF017A			
2AF01PA	2AF001	Power Cable For 2AF01PA			
	2AF006	Control Cable For 2AF01PA	2AF01PB-C	2AF282	Power Cable For 2AF01PB-C
	2AF007	Control Cable For 2AF01PA		2AF283	Control Cable For 2AF01PB-C
	2AF008	Control Cable For 2AF01PA		2AF284	Control Cable For 2AF01PB-C
	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21		2AF289	Control Cable For 2AF01PB-C and 2AF01PB
	2AF056	Control Cable For 2AF006A and 2AF01PA		2AF290	Control Cable For 2AF01PB-C
2AF01PA-A	2AF276	Control Cable For 2AF01PA		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2AF332	Control Cable For 2AF006A and 2AF01PA			
	2AF004	Control Cable For 2AF01PA-A	2AP06EF 2AP06EP	1AP587	Control Cable For 1AP06ES and 2AP06EF
	2AF012	Power Cable For 2AF01PA-A		2CS044	Control Cable For 2AP06EP
	2AF014	Control Cable For 2AF01PA-A		2CS058	Control Cable For 2AP06EP and 2CS009B
2AF022A	2AF015	Control Cable For 2AF01PA-A		2CS123	Control Cable For 2AP06EP
	2AF019	Control Cable For 2AF01PA-A		2DG054	Control Cable For 2DG01KB and 2AP06ER
	2AF176	Control Cable For 2AF01PA-A	2AP06ER 2AP23E 2AP24E 2AP32E 2CC01PB	2AP149	Power Cable For 2AP23E
	2AF055	Control Cable For 2AF006A and 2AF022A		2AP152	Power Cable For 2AP24E
	2AF099	Control Cable For 2AF017A and 2AF022A		2AP154	Power Cable For 2AP32E
2AP05EP	2AF257	Control Cable For 2AF022A		2CC012	Control Cable For 2CC01PB
	2AF258	Control Cable For 2AF022A		2CC013	Control Cable For 2CC01PB
	2CS001	Power Cable For 2AP05EP		2CC014	Control Cable For 2CC01PB
	2CS006	Control Cable For 2AP05EP		2CC016	Control Cable For 0CC01E-D and 2CC01PB
	2CS021	Control Cable For 2AP05EP		2EF064	Control Cable For 2CC01PB
2AP05EV	2CS041	Control Cable For 2AP05EP	2CC685 2CC9412B	2CC278	Control Cable For 2CC685
	2CS042	Control Cable For 2AP05EP		2CC048	Control Cable For 2CC9412B
	2CS045	Control Cable For 2AP05EP and 2CS009A			
	2CS055	Control Cable For 2AP05EP			
	2CS122	Control Cable For 2AP05EP			
2AP05EV	2SI001	Power Cable For 2AP05EV			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2AP07EE	2AP093	Power Cable For 2AP07EE	2CC9413B	2CC057	Control Cable For 2CC9413B
	2AP142	Control Cable For 2AP07EE	2CC9414	2CC065	Control Cable For 2CC9414
2AP14E	2AP376	Control Cable For 2AP14E	2CC9473B	2CC130	Control Cable For 2CC9473B
	2DC041	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2CS009B	2CS058	Control Cable For 2AP06EP and 2CS009B
	2DC042	Power Cable For 2AP14E, 2AP38E, and 2AP42E		2CS080	Control Cable For 2CS009B
2AP21E	2AP143	Power Cable For 2AP21E		2CS113	Control Cable For 2CS009B
2AP21EA	2SI517	Control Cable For 2AP21EA	2CV01PB	2CV012	Control Cable For 2CV01PB
2AP22E	2AP147	Power Cable For 2AP22E		2CV016	Control Cable For 2CV01PB
2AP25E	2AP144	Power Cable For 2AP25E		2EF044	Control Cable For 2CV01PB and 2SX01PB
2AP26E	2AP146	Power Cable For 2AP26E	2CV112C	2CV075	Control Cable For 2CV112C
2AP38E	2AP156	Power Cable For 2AP38E	2CV121	2CV140	Instrument Cable For 2CV121
	2DC041	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2CV8104	2CV617	Control Cable For 2CV8104
	2DC042	Power Cable For 2AP14E, 2AP38E, and 2AP42E		2CV618	Control Cable For 2CV8104
2AP42E	2AP258	Power Cable For 2AP42E	2CV8116	2CV649	Control Cable For 2CV8116
	2DC041	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2CV8355B	2CV623	Control Cable For 2CV8355B
	2DC042	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2CV8355C	2CV626	Control Cable For 2CV8355C
2CC01PA	2CC001	Power Cable For 2CC01PA	2DG01KB	2DG052	Control Cable For 2DG01KB
	2CC002	Control Cable For 2CC01PA		2DG053	Control Cable For 2DG01KB
	2CC003	Control Cable For 2CC01PA		2DG054	Control Cable For 2DG01KB and 2AP06ER
	2CC004	Control Cable For 2CC01PA		2DG150	Control Cable For 2DG01KB
	2CC006	Control Cable For 0CC01E-B and 2CC01PA		2DG201	Control Cable For 2DG01KB
	2EF028	Control Cable For 2CC01PA	2DO01PD	2DO009	Power Cable For 2DO01PD
2CC9412A	2CC045	Control Cable For 2CC9412A		2DO010	Control Cable For 2DO01PD
2CC9413A	2CC051	Control Cable For 2CC9413A	2FI-0121A	2CV139	Instrument Cable For 2FI-0121A and 2FI-0121B
2CC9415	2CC067	Control Cable For 2CC9415	2FI-0121B	2CV139	Instrument Cable For 2FI-0121A and 2FI-0121B
2CC9416	2CC059	Control Cable For 2CC9416	2IP02E	2IP020	Power Cable For 2IP02E
2CC9438	2CC036	Control Cable For 2CC9438	2IP04E	2IP044	Power Cable For 2IP04E
2CC9473A	2CC126	Power Cable For 2CC9473A	2LI-0460B	2RC406	Instrument Cable For 2LI-0460B
	2CC127	Control Cable For 2CC9473A	2LI-0502	2FW026	Instrument Cable For 2LI-0502
	2CC128	Control Cable For 2CC9473A	2LI-0503	2FW027	Instrument Cable For 2LI-0503
2CS009A	2CS055	Control Cable For 2AP05EP and 2CS009A	2LL-SI075B	2SI257	Control Cable For 2LL-SI075B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2CV01PA	2CS079	Control Cable For 2CS009A	2MS001A-DIV22	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2CV001	Power Cable For 2CV01PA			
	2CV006	Control Cable For 2CV01PA			
	2CV009	Control Cable For 2CV01PA			
2CV112B	2EF031	Control Cable For 2CV01PA and 2SX01PA		2MS270	Control Cable For 2MS001A-DIV22
	2CV069	Control Cable For 2CV112B			
	2CV079	Control Cable For 2CV112D			
	2CV080	Control Cable For 2CV112D			
2CV8110	2CV059	Control Cable For 2CV8110	2MS001B-DIV22	2MS530	Control Cable For 2MS001A-DIV22
	2CV8114	Control Cable For 2CV8114			
	2CV8355A	Control Cable For 2CV8355A			
	2CV8355D	Control Cable For 2CV8355D			
2CV8804A	2CV614	Control Cable For 2CV8355D		2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2CV407	Control Cable For 2CV8804A			
	2CV413	Control Cable For 2CV8804A and 2RH8701A			
	2CV468	Control Cable For 2CV8804A			
2DO01PA	2SI454	Control Cable For 2CV8804A		2MS282	Control Cable For 2MS001B-DIV22
	2DO002	Control Cable For 2DO01PA			
	2LV057	Control Cable For 2FI-SX031			
	2SX376	Instrument Cable For 2FI-SX031			
2FI-SX031	2SX377	Instrument Cable For 2FI-SX031	2MS001C-DIV22	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2IP004	Power Cable For 2IP01E			
	2IP03E	Power Cable For 2IP03E			
	2IP002	Power Cable For 2IP05E			
2IP07E	2IP030	Power Cable For 2IP07E		2MS295	Control Cable For 2MS001C-DIV22
	2LI-0459A	Instrument Cable For 2LI-0459A and 2LI-0459B			
	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
	2RC371	Instrument Cable For 2LI-0459A and 2LI-0459B			
2LI-0501	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B		2MS299	Control Cable For 2MS001C-DIV22
	2FW025	Instrument Cable For 2LI-0501			
	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0501A	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A		2MS523	Control Cable For 2MS001C-DIV22
	2FW028	Instrument Cable For 2LI-0504			
2LI-0504	2FW028	Instrument Cable For 2LI-0504		2MS525	Control Cable For 2MS001A-DIV22 and 2MS001C-DIV22

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2LI-0930	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7	2MS001D-DIV22	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
2LL-SI075A	2SI234	Control Cable For 2LL-SI075A		2MS309	Control Cable For 2MS001D-DIV22
2MS001A-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2MS312	Control Cable For 2MS001D-DIV22
	2MS272	Control Cable For 2MS001A-DIV21		2MS521	Control Cable For 2MS001B-DIV22 and 2MS001D-DIV22
	2MS275	Control Cable For 2MS001A-DIV21		2MS528	Control Cable For 2MS001D-DIV22
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21		2MS533	Control Cable For 2MS001D-DIV22
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21	2MS018B	2MS610	Control Cable For 2MS018B and 2MS018C
2MS001B-DIV21	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21		2MS612	Control Cable For 2MS018B and 2MS018C
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2MS614	Control Cable For 2MS018B
	2MS285	Control Cable For 2MS001B-DIV21		2MS616	Power Cable For 2MS018B
	2MS288	Control Cable For 2MS001B-DIV21	2MS018C	2MS623	Power Cable For 2MS018B
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21		2MS643	Instrument Cable For 2MS018B
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21		2MS610	Control Cable For 2MS018B and 2MS018C
2MS001C-DIV21	2AF121	Control Cable For 2MS001C-DIV21		2MS612	Control Cable For 2MS018B and 2MS018C
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21	2MS101A	2MS626	Control Cable For 2MS018C
	2MS298	Control Cable For 2MS001C-DIV21	2MS101B	2MS628	Power Cable For 2MS018C
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21	2MS101C	2MS635	Power Cable For 2MS018C
	2MS524	Control Cable For 2MS001C-DIV21	2MS101D	2MS646	Instrument Cable For 2MS018C
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21	2RH611	2MS320	Control Cable For 2MS101A
			2SI8801B	2MS325	Control Cable For 2MS101B
				2MS330	Control Cable For 2MS101C
				2MS335	Control Cable For 2MS101D
				2RH021	Control Cable For 2RH611
				2SI037	Power Cable For 2SI8801B
				2SI038	Control Cable For 2SI8801B
				2SI039	Control Cable For 2SI8801B
			2SI8807B	2SI085	Control Cable For 2SI8807B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2MS001D-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21	2SI8809B	2SI139	Control Cable For 2SI8809B
			2SI8811B	2SI164	Control Cable For 2SI8811B
			2SI8812B	2SI175	Control Cable For 2SI8812B
	2MS311	Control Cable For 2MS001D-DIV21	2SI8924	2SI472	Control Cable For 2SI8924
	2MS527	Control Cable For 2MS001D-DIV21	2SX001B	2SX037	Control Cable For 2SX001B
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21	2SX005	2SX044	Control Cable For 2SX005
			2SX010	2SX092	Control Cable For 2SX010
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21	2SX011	2SX095	Control Cable For 2SX011
			2SX01PB	2EF044	Control Cable For 2CV01PB and 2SX01PB
				2SX016	Control Cable For 2SX01PB
2MS018A	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2SX017	Control Cable For 2SX01PB-C and 2SX01PB
	2MS581	Control Cable For 2MS018A and 2MS018D		2SX019	Control Cable For 2SX01PB
	2MS583	Control Cable For 2MS018A and 2MS018D		2SX038	Control Cable For 2SX01PB
	2MS585	Control Cable For 2MS018A		2SX144	Control Cable For 2SX01PB
	2MS587	Power Cable For 2MS018A		2SX209	Control Cable For 2SX01PB
	2MS588	Instrument Cable For 2MS018A		2SX286	Control Cable For 2SX01PB
	2MS589	Instrument Cable For 2MS018A	2SX01PB-C	2SX017	Control Cable For 2SX01PB-C and 2SX01PB
	2MS590	Instrument Cable For 2MS018A		2SX304	Control Cable For 2SX01PB-C
	2MS591	Instrument Cable For 2MS018A		2SX305	Control Cable For 2SX01PB-C
	2MS592	Instrument Cable For 2MS018A		2SX314	Control Cable For 2SX01PB-C
	2MS593	Instrument Cable For 2MS018A		2SX034	Control Cable For 2SX034
	2MS594	Power Cable For 2MS018A	2SX034	2SX068	Control Cable For 2SX034
	2MS594	Power Cable For 2MS018A	2SX136	2SX083	Control Cable For 2SX136
	2MS640	Instrument Cable For 2MS018A	2SX147B	2LV034	Control Cable For 2SX147B
	2MS018D	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2SX169B	2SX301	Control Cable For 2SX169B
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2SX173	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
	2MS581	Control Cable For 2MS018A and 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS597	Control Cable For 2MS018D			
	2MS599	Power Cable For 2MS018D			
	2MS600	Instrument Cable For 2MS018D	2TI-IT002	2RC669	Control Cable For 2TI-IT002
	2MS601	Instrument Cable For 2MS018D	2TI-RC005B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
	2MS602	Instrument Cable For 2MS018D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	2MS603	Instrument Cable For 2MS018D	2TI-RC006B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
	2MS604	Instrument Cable For 2MS018D	2TI-RC007B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
	2MS605	Instrument Cable For 2MS018D	2TI-RC008B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
	2MS606	Power Cable For 2MS018D			
	2MS649	Instrument Cable For 2MS018D	2VA01CE	2VA115	Control Cable For 2VA01CE
2MS101A	2MS321	Control Cable For 2MS101A	2VA01CH	2VA170	Control Cable For 2VA01CH
2MS101B	2MS326	Control Cable For 2MS101B	2VA02CC	2VA105	Control Cable For 2VA02CC
2MS101C	2MS331	Control Cable For 2MS101C	2VA06CC	2VA057	Control Cable For 2VA06CC
2MS101D	2MS336	Control Cable For 2MS101D	2VA06CD	2VA141	Control Cable For 2VA06CD
2NI-NR005B	2NR246	Instrument Cable For 2NI-NR005B	2VD01CB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2NI-NR005D	2NR297	Instrument Cable For 2NI-NR005D	2VD01YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0405	2CV663	Instrument Cable For 2PI-0405		2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0455A	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B		2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0455B	2RC370	Instrument Cable For 2PI-0455B		2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B		2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0514A	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193	2VD01YB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B		2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0514B	2MS099	Instrument Cable For 2PI-0514B		2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193		2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B		2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0524A	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B		2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0524B	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B		2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2MS103	Instrument Cable For 2PI-0524B		2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0534A	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B		2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0534B	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B		2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2MS107	Instrument Cable For 2PI-0534B		2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2PI-0544A	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B	2VD02YA		
2PI-0544B	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
	2MS111	Instrument Cable For 2PI-0544B			
2PI-CC107	2CC314	Control Cable For 2PI-CC107			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2PI-MS193	2CC315	Instrument Cable For 2PI-CC107		2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2LV002	Control Cable For 2PI-CC107		2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193		2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2RC014A	2RC622	Control Cable For 2RC014A		2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2RC014C	2RC628	Control Cable For 2RC014C		2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2RH01PA	2RH001	Power Cable For 2RH01PA	2VD02YB	2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2RH610	2RH017	Control Cable For 2RH610		2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2RH8701A	2CV413	Control Cable For 2CV8804A and 2RH8701A		2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2RH029	Control Cable For 2RH8701A and 2SI8811A		2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2RH030	Control Cable For 2RH8701A		2VE01Y	Control Cable For 2VE01Y and 2VE02Y
	2RH031	Control Cable For 2RH8701A		2VE042	Control Cable For 2VE01Y and 2VE02Y
2RH8702A	2SI168	Control Cable For 2RH8701A		2VE022	Control Cable For 2VE01Y and 2VE02Y
	2RH050	Control Cable For 2RH8702A	2VE02Y	2VE042	Control Cable For 2VE01Y and 2VE02Y
	2RH051	Control Cable For 2RH8702A		2VP038	Control Cable For 2VP01CB
	2RH052	Control Cable For 2RH8702A		2VP042	Control Cable For 2VP01CB
	2RH054	Control Cable For 2RH8702A		2VP082	Control Cable For 2VP01CD
	2RH055	Control Cable For 2RH8702A		2VP086	Control Cable For 2VP01CD
2RH8716A	2RH069	Control Cable For 2RH8716A		2VX067	Control Cable For 2VX01Y and 2VX02Y
2RY8000A	2RY394	Control Cable For 2RY8000A		2VX099	Control Cable For 2VX01Y and 2VX02Y
2SI8801A	2SI035	Control Cable For 2SI8801A	2VP01CB	2VX067	Control Cable For 2VX01Y and 2VX02Y
2SI8806	2SI072	Power Cable For 2SI8806		2VX099	Control Cable For 2VX01Y and 2VX02Y
	2SI073	Control Cable For 2SI8806	2VP01CD		
	2SI074	Control Cable For 2SI8806			
	2SI077	Control Cable For 2SI8806	2VX01Y		
2SI8807A	2SI081	Control Cable For 2SI8807A			
2SI8809A	2SI134	Control Cable For 2SI8809A	2VX02Y		
2SI8811A	2RH029	Control Cable For 2RH8701A and 2SI8811A			
	2SI152	Control Cable For 2SI8811A			
2SI8812A	2SI170	Control Cable For 2SI8812A			
2SI8840	2SI211	Control Cable For 2SI8840			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2SI8923A	2SI199	Control Cable For 2SI8923A			
2SX001A	2SX033	Control Cable For 2SX001A			
2SX004	2SX041	Control Cable For 2SX004			
2SX01PA	2EF031	Control Cable For 2CV01PA and 2SX01PA			
	2SX001	Power Cable For 2SX01PA			
	2SX005	Control Cable For 2SX01PA			
	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX008	Control Cable For 2SX01PA			
	2SX032	Control Cable For 2SX01PA			
	2SX034	Control Cable For 2SX01PA			
	2SX052	Control Cable For 2SX01PA			
	2SX058	Control Cable For 2SX01PA			
	2SX143	Control Cable For 2SX01PA			
	2SX208	Control Cable For 2SX01PA			
	2SX279	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX280	Control Cable For 2SX01PA			
2SX01PA-C	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX278	Power Cable For 2SX01PA-C			
	2SX279	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX312	Control Cable For 2SX01PA-C			
	2SX313	Control Cable For 2SX01PA-C			
2SX033	2SX065	Control Cable For 2SX033			
2SX101A	2AF002	Control Cable For 2SX101A			
	2AF003	Control Cable For 2SX101A			
	2SX471	Control Cable For 2SX101A			
2SX147A	2LV033	Control Cable For 2SX147A			
	2SX178	Control Cable For 2SX147A			
2TI-0413A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
2TI-0423A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
2TI-0433A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
2TI-0443A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2TI-IT001	2IT275	Instrument Cable For 2TI-IT001			
	2IT276	Instrument Cable For 2TI-IT001			
	2IT277	Instrument Cable For 2TI-IT001			
	2IT278	Instrument Cable For 2TI-IT001			
	2IT279	Instrument Cable For 2TI-IT001			
	2IT280	Instrument Cable For 2TI-IT001			
	2IT281	Instrument Cable For 2TI-IT001			
	2IT282	Instrument Cable For 2TI-IT001			
	2IT283	Instrument Cable For 2TI-IT001			
	2IT284	Instrument Cable For 2TI-IT001			
	2IT285	Instrument Cable For 2TI-IT001			
	2IT286	Instrument Cable For 2TI-IT001			
	2IT287	Instrument Cable For 2TI-IT001			
	2IT288	Instrument Cable For 2TI-IT001			
	2IT289	Instrument Cable For 2TI-IT001			
	2IT290	Instrument Cable For 2TI-IT001			
	2IT291	Instrument Cable For 2TI-IT001			
	2IT292	Instrument Cable For 2TI-IT001			
	2IT293	Instrument Cable For 2TI-IT001			
	2IT294	Instrument Cable For 2TI-IT001			
	2IT295	Instrument Cable For 2TI-IT001			
	2IT296	Instrument Cable For 2TI-IT001			
	2IT297	Instrument Cable For 2TI-IT001			
	2IT298	Instrument Cable For 2TI-IT001			
	2IT299	Instrument Cable For 2TI-IT001			
	2IT300	Instrument Cable For 2TI-IT001			
	2IT301	Instrument Cable For 2TI-IT001			
	2IT302	Instrument Cable For 2TI-IT001			
	2IT303	Instrument Cable For 2TI-IT001			
	2IT304	Instrument Cable For 2TI-IT001			
	2IT305	Instrument Cable For 2TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	2IT306	Instrument Cable For 2TI-IT001			
	2IT307	Instrument Cable For 2TI-IT001			
	2IT345	Instrument Cable For 2TI-IT001			
	2IT346	Instrument Cable For 2TI-IT001			
	2IT424	Instrument Cable For 2TI-IT001			
	2RC648	Control Cable For 2TI-IT001			
2TI-RC005A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC006A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC007A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC008A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2UL-AN012-A7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-B7	2AN166	Control Cable For 2UL-AN012-B7			
	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-C7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2VA01CA	2VA108	Power Cable For 2VA01CA			
	2VA109	Control Cable For 2VA01CA			
	2VA111	Control Cable For 2VA01CA			
	2VA166	Control Cable For 2VA01CA and 2VA01CD			
2VA01CB	2VA191	Power Cable For 2VA01CB			
	2VA233	Control Cable For 2VA01CB			
2VA01CC	2VA192	Power Cable For 2VA01CC			
	2VA228	Control Cable For 2VA01CC			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
2VA01CD	2VA164	Power Cable For 2VA01CD			
	2VA165	Control Cable For 2VA01CD			
	2VA166	Control Cable For 2VA01CA and 2VA01CD			
2VA02CA	2VA104	Control Cable For 2VA02CA			
2VA02CB	2VA148	Power Cable For 2VA02CB			
	2VA150	Control Cable For 2VA02CB			
2VA06CA	2VA053	Control Cable For 2VA06CA			
2VD09YA	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-0					
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YB	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP003	Power Cable For 2VP01CA			
	2VP016	Control Cable For 2VP01CA			
	2VP019	Control Cable For 2VP01CA			
	2VP020	Control Cable For 2VP01CA			
2VP01CC	2VP060	Control Cable For 2VP01CC			
	2VP064	Control Cable For 2VP01CC			
2VX04Y	2VE031	Control Cable For 2VX04Y and 2VX05Y			
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			
2VX05Y	2VE031	Control Cable For 2VX04Y and 2VX05Y			
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
-	1SX147A	Containment Chiller Condenser Bypass Valve (AO)	-	1SX147B	Containment Chiller Condenser Bypass Valve (AO)
1SX147A	1SX178	Control Cable For 1SX147A	1SX147B	1SX191	Control Cable For 1SX147B
	1SX187	Control Cable For 1SX147A		1SX200	Control Cable For 1SX147B
	1SX188	Control Cable For 1SX147A		1SX201	Control Cable For 1SX147B
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2SX147A	Containment Chiller Condenser Bypass Valve (AO)	-	2SX147B	Containment Chiller Condenser Bypass Valve (AO)
2PI-0526A	2MS125	Instrument Cable For 2PI-0526A	2MS018B	2MS617	Instrument Cable For 2MS018B
2PI-0536A	2MS126	Instrument Cable For 2PI-0536A		2MS618	Instrument Cable For 2MS018B
2SX147A	2SX178	Control Cable For 2SX147A		2MS619	Instrument Cable For 2MS018B
	2SX187	Control Cable For 2SX147A		2MS620	Instrument Cable For 2MS018B
	2SX188	Control Cable For 2SX147A		2MS621	Instrument Cable For 2MS018B
2VA06CB	2VA821	Power Cable For 2VA06CB		2MS622	Instrument Cable For 2MS018B
	2VA823	Control Cable For 2VA06CB	2MS018C	2MS629	Instrument Cable For 2MS018C
				2MS630	Instrument Cable For 2MS018C
				2MS631	Instrument Cable For 2MS018C
				2MS632	Instrument Cable For 2MS018C
				2MS633	Instrument Cable For 2MS018C
				2MS634	Instrument Cable For 2MS018C
			2SX147B	2SX191	Control Cable For 2SX147B
				2SX200	Control Cable For 2SX147B
				2SX201	Control Cable For 2SX147B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
1MS018A	1MS588	Instrument Cable For 1MS018A	1MS018B	1MS617	Instrument Cable For 1MS018B
	1MS589	Instrument Cable For 1MS018A		1MS618	Instrument Cable For 1MS018B
	1MS590	Instrument Cable For 1MS018A		1MS619	Instrument Cable For 1MS018B
	1MS591	Instrument Cable For 1MS018A		1MS620	Instrument Cable For 1MS018B
	1MS592	Instrument Cable For 1MS018A		1MS621	Instrument Cable For 1MS018B
	1MS593	Instrument Cable For 1MS018A		1MS622	Instrument Cable For 1MS018B
	1MS600	Instrument Cable For 1MS018D	1MS018C	1MS629	Instrument Cable For 1MS018C
1MS018D	1MS601	Instrument Cable For 1MS018D		1MS630	Instrument Cable For 1MS018C
	1MS602	Instrument Cable For 1MS018D		1MS631	Instrument Cable For 1MS018C
	1MS603	Instrument Cable For 1MS018D		1MS632	Instrument Cable For 1MS018C
	1MS604	Instrument Cable For 1MS018D		1MS633	Instrument Cable For 1MS018C
	1MS605	Instrument Cable For 1MS018D		1MS634	Instrument Cable For 1MS018C
1PI-0526A	1MS125	Instrument Cable For 1PI-0526A			
1PI-0536A	1MS126	Instrument Cable For 1PI-0536A			
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
Unit 0 (Common) Components					
0AB03P(1)	1AB049	Control Cable For 0AB03P(1) and 1AB03P	NONE		
0VA01CA	1VA001	Power Cable For 0VA01CA			
0VA02CA	1VA016	Power Cable For 0VA02CA			
0VA474Y	1VA254	Control Cable For 0VA474Y			
	1VA485	Control Cable For 0VA474Y			
Unit 1 Components					
-	1AP25E	Division 11 480V ESF MCC 131X2	1PI-0403A	1CV673	Instrument Cable For 1PI-0403A
	1AP26E	Division 11 480V ESF MCC 131X4	1TI-0605	1RH147	Instrument Cable For 1TI-0605
1AB03P	1AB049	Control Cable For 0AB03P(1) and 1AB03P			
1AF005A	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005B	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005C	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005D	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AP05EJ	1CS021	Control Cable For 1AP05EJ			
	1CS041	Control Cable For 1AP05EJ			
1AP14E	1AP376	Control Cable For 1AP14E			
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1AP25E	1AP144	Power Cable For 1AP25E			
	1AP658	Power Cable For 1AP25E			
1AP26E	1AP146	Power Cable For 1AP26E			
1AP38E	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1AP42E	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1CC01PA	1CC001	Power Cable For 1CC01PA			
1CC9416	1CC059	Control Cable For 1CC9416			
	1CC060	Control Cable For 1CC9416			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
1CC9438	1CC036	Control Cable For 1CC9438			
	1CC038	Control Cable For 1CC9438			
1CS009A	1CS079	Control Cable For 1CS009A			
	1RH026	Control Cable For 1CS009A and 1SI8811A			
1CV8804A	1CV413	Control Cable For 1CV8804A and 1RH8701A			
	1CV468	Control Cable For 1CV8804A			
	1RH025	Control Cable For 1CV8804A and 1RH8701A			
	1SI454	Control Cable For 1CV8804A			
1IP05E	1IP002	Power Cable For 1IP05E			
1IP07E	1IP030	Power Cable For 1IP07E			
1LI-0459A	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034			
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B			
1LI-0459B	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034			
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B			
1LI-0461	1RY208	Instrument Cable For 1LI-0461			
1LI-0501	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309			
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			
1LI-0501A	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309			
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			
1LI-0504	1FW023	Instrument Cable For 1LI-0504 and 1LI-0504A			
1LI-0504A	1FW023	Instrument Cable For 1LI-0504 and 1LI-0504A			
1LI-0930	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1LI-0932	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1LI-FW309	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1LI-FW310	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1LI-RY034	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034			
1LL-SI075A	1SI234	Control Cable For 1LL-SI075A			
1MS018A	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
	1MS587	Power Cable For 1MS018A			
1MS018D	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
	1MS599	Power Cable For 1MS018D			
1NI-0031B	1NR239	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR240	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR241	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR242	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR243	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR245	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
	1NR250	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR403	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR408	Instrument Cable For 1NI-0031B			
	1NR409	Instrument Cable For 1NI-0031B			
	1NR410	Instrument Cable For 1NI-0031B			
	1NR411	Instrument Cable For 1NI-0031B			
	1NR412	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
1NI-NR005B	1NR239	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR240	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR241	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR242	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR243	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR245	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR246	Instrument Cable For 1NI-NR005B			
	1NR250	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR403	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR404	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR405	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR406	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR407	Instrument Cable For 1NI-NR005B and 1NI-NR005D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
1NI-NR005D	1NR412	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR239	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR240	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR241	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR242	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR243	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR245	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR250	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR297	Instrument Cable For 1NI-NR005D			
	1NR402	Instrument Cable For 1NI-NR005D			
	1NR403	Control Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
	1NR404	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR405	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR406	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR407	Instrument Cable For 1NI-NR005B and 1NI-NR005D			
	1NR412	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D			
1PI-0405	1CV663	Instrument Cable For 1PI-0405			
1PI-0455A	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033			
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B			
1PI-0455B	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B			
1PI-0457	1RY206	Instrument Cable For 1PI-0457			
1PI-0514A	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193			
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B			
1PI-0514B	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193			
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B			
1PI-0526A	1MS125	Instrument Cable For 1PI-0526A			
1PI-0536A	1MS126	Instrument Cable For 1PI-0536A			
1PI-MS193	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193			
1PI-MS194	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1PI-RY033	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033			
1RC014A	1RC622	Control Cable For 1RC014A			
1RC014C	1RC628	Control Cable For 1RC014C			
1RH8701A	1CV413	Control Cable For 1CV8804A and 1RH8701A			
	1RH023	Power Cable For 1RH8701A			
	1RH025	Control Cable For 1CV8804A and 1RH8701A			
	1RH029	Control Cable For 1RH8701A and 1SI8811A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
1RH8702A	1RH030	Control Cable For 1RH8701A			
	1RH031	Control Cable For 1RH8701A			
	1SI168	Control Cable For 1RH8701A			
	1RH044	Power Cable For 1RH8702A			
	1RH046	Control Cable For 1RH8702A			
	1RH050	Control Cable For 1RH8702A			
	1RH051	Control Cable For 1RH8702A			
	1RH052	Control Cable For 1RH8702A			
1RY455A	1RH054	Control Cable For 1RH8702A			
	1RH055	Control Cable For 1RH8702A			
	1RY486	Control Cable For 1RY455A			
	1RY8000A	Control Cable For 1RY8000A			
1RY8000A	1RY392	Control Cable For 1RY8000A			
	1RY393	Power Cable For 1RY8000A			
	1RY394	Control Cable For 1RY8000A			
	1RY428	Control Cable For 1RY8000A			
1SI8806	1SI072	Power Cable For 1SI8806			
	1SI073	Control Cable For 1SI8806			
	1SI074	Control Cable For 1SI8806			
1SI8811A	1RH026	Control Cable For 1CS009A and 1SI8811A			
	1RH029	Control Cable For 1RH8701A and 1SI8811A			
1SX01PA	1SX001	Power Cable For 1SX01PA			
	1SX052	Control Cable For 1SX01PA			
	1SX058	Control Cable For 1SX01PA			
1SX147A	1SX178	Control Cable For 1SX147A			
1TI-0413A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
1TI-0423A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
1TI-0433A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
1TI-0443A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
1TI-0604	1RH146	Instrument Cable For 1TI-0604			
	1RH166	Instrument Cable For 1TI-0604			
1TI-IT001	1IT275	Instrument Cable For 1TI-IT001			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
	11T276	Instrument Cable For 1TI-IT001			
	11T277	Instrument Cable For 1TI-IT001			
	11T278	Instrument Cable For 1TI-IT001			
	11T279	Instrument Cable For 1TI-IT001			
	11T280	Instrument Cable For 1TI-IT001			
	11T281	Instrument Cable For 1TI-IT001			
	11T282	Instrument Cable For 1TI-IT001			
	11T283	Instrument Cable For 1TI-IT001			
	11T284	Instrument Cable For 1TI-IT001			
	11T285	Instrument Cable For 1TI-IT001			
	11T286	Instrument Cable For 1TI-IT001			
	11T287	Instrument Cable For 1TI-IT001			
	11T288	Instrument Cable For 1TI-IT001			
	11T289	Instrument Cable For 1TI-IT001			
	11T290	Instrument Cable For 1TI-IT001			
	11T291	Instrument Cable For 1TI-IT001			
	11T292	Instrument Cable For 1TI-IT001			
	11T293	Instrument Cable For 1TI-IT001			
	11T294	Instrument Cable For 1TI-IT001			
	11T295	Instrument Cable For 1TI-IT001			
	11T296	Instrument Cable For 1TI-IT001			
	11T297	Instrument Cable For 1TI-IT001			
	11T298	Instrument Cable For 1TI-IT001			
	11T299	Instrument Cable For 1TI-IT001			
	11T300	Instrument Cable For 1TI-IT001			
	11T301	Instrument Cable For 1TI-IT001			
	11T302	Instrument Cable For 1TI-IT001			
	11T303	Instrument Cable For 1TI-IT001			
	11T304	Instrument Cable For 1TI-IT001			
	11T305	Instrument Cable For 1TI-IT001			
	11T306	Instrument Cable For 1TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
	1IT307	Instrument Cable For 1TI-IT001			
	1IT345	Instrument Cable For 1TI-IT001			
	1IT346	Instrument Cable For 1TI-IT001			
	1IT424	Instrument Cable For 1TI-IT001			
1TI-RC005A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
1TI-RC006A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
1TI-RC007A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
1TI-RC008A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
1TI-RC022A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC022B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC023A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC023B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC024A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
1TI-RC024B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC025A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC025B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1UL-AN012-A7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-B7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-C7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
	1SI469	Instrument Cable For 1LI-0932, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1VA06CB	1VA821	Power Cable For 1VA06CB			
	1VA822	Control Cable For 1VA06CB			
	1VA823	Control Cable For 1VA06CB			
1VD09YA	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YA	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-1					
1VD10YB	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VP003	Power Cable For 1VP01CA			
1VP01CC	1VP047	Power Cable For 1VP01CC			
1VX04Y	1VE031	Control Cable For 1VX04Y and 1VX05Y			
1VX05Y	1VE031	Control Cable For 1VX04Y and 1VX05Y			
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
Unit 0 (Common) Components					
0VA01CC	2VA001	Power Cable For 0VA01CC	NONE		
0VA02CC	2VA016	Power Cable For 0VA02CC			
0VA476Y	2VA254	Control Cable For 0VA476Y			
	2VA652	Control Cable For 0VA476Y			
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2AP25E	Division 21 480V ESF MCC 231X2	2CC01PB	2CC010	Power Cable For 2CC01PB
	2AP26E	Division 21 480V ESF MCC 231X4	2MS018B	2MS617	Instrument Cable For 2MS018B
2AF005A	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2MS618	Instrument Cable For 2MS018B
2AF005B	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2MS619	Instrument Cable For 2MS018B
2AF005C	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2MS620	Instrument Cable For 2MS018B
2AF005D	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2MS621	Instrument Cable For 2MS018B
2AP05EP	2CS021	Control Cable For 2AP05EP	2MS018C	2MS622	Instrument Cable For 2MS018B
2AP25E	2AP144	Power Cable For 2AP25E		2MS629	Instrument Cable For 2MS018C
	2AP658	Power Cable For 2AP25E		2MS630	Instrument Cable For 2MS018C
2AP26E	2AP146	Power Cable For 2AP26E		2MS631	Instrument Cable For 2MS018C
2CC9416	2CC059	Control Cable For 2CC9416	2PI-0403A	2MS632	Instrument Cable For 2MS018C
	2CC060	Control Cable For 2CC9416	2SX01PB	2MS633	Instrument Cable For 2MS018C
2CC9438	2CC036	Control Cable For 2CC9438	2TI-0605	2MS634	Instrument Cable For 2MS018C
	2CC038	Control Cable For 2CC9438		2CV673	Instrument Cable For 2PI-0403A
2CS009A	2CS079	Control Cable For 2CS009A		2SX012	Power Cable For 2SX01PB
	2RH026	Control Cable For 2CS009A and 2SI8811A		2RH147	Instrument Cable For 2TI-0605
2CV01PA	2CV001	Power Cable For 2CV01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
2CV8804A	2CV413	Control Cable For 2CV8804A and 2RH8701A			
	2CV468	Control Cable For 2CV8804A			
	2RH025	Control Cable For 2CV8804A and 2RH8701A			
2IP05E	2IP002	Power Cable For 2IP05E			
2IP07E	2IP030	Power Cable For 2IP07E			
2LI-0459A	2RY430	Instrument Cable For 2LI-0459A, 2LI-0459B, and 2LI-RY034			
	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
2LI-0459B	2RY430	Instrument Cable For 2LI-0459A, 2LI-0459B, and 2LI-RY034			
	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
2LI-0461	2RY208	Instrument Cable For 2LI-0461			
2LI-0501	2FW918	Instrument Cable For 2LI-0501, 2LI-0501A, and 2LI-FW309			
	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0501A	2FW918	Instrument Cable For 2LI-0501, 2LI-0501A, and 2LI-FW309			
	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0504	2FW023	Instrument Cable For 2LI-0504 and 2LI-0504A			
2LI-0504A	2FW023	Instrument Cable For 2LI-0504 and 2LI-0504A			
2LI-0930	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2LI-0932	2SI469	Instrument Cable For 2LI-0932, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2LI-FW309	2FW918	Instrument Cable For 2LI-0501, 2LI-0501A, and 2LI-FW309			
	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
2LI-FW310	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2LI-RY034	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
	2RY430	Instrument Cable For 2LI-0459A, 2LI-0459B, and 2LI-RY034			
2LL-SI075A	2SI234	Control Cable For 2LL-SI075A			
2MS018A	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS587	Power Cable For 2MS018A			
2MS018D	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS599	Power Cable For 2MS018D			
2NI-0031B	2NR239	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR240	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR241	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR242	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR243	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR245	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR250	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR403	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR408	Instrument Cable For 2NI-0031B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
2NI-NR005B	2NR409	Instrument Cable For 2NI-0031B			
	2NR410	Instrument Cable For 2NI-0031B			
	2NR411	Instrument Cable For 2NI-0031B			
	2NR412	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR239	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR240	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR241	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR242	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR243	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR245	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR246	Instrument Cable For 2NI-NR005B			
	2NR250	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR403	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR404	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR405	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR406	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR407	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
2NI-NR005D	2NR412	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR239	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR240	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
	2NR241	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR242	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR243	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR245	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR250	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR297	Instrument Cable For 2NI-NR005D			
	2NR402	Instrument Cable For 2NI-NR005D			
	2NR403	Control Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
	2NR404	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR405	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR406	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR407	Instrument Cable For 2NI-NR005B and 2NI-NR005D			
	2NR412	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D			
2PI-0405	2CV663	Instrument Cable For 2PI-0405			
2PI-0455A	2RY431	Instrument Cable For 2PI-0455A, 2PI-0455B, and 2PI-RY033			
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0455B	2RY431	Instrument Cable For 2PI-0455A, 2PI-0455B, and 2PI-RY033			
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0457	2RY206	Instrument Cable For 2PI-0457			
2PI-0514A	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193			
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
2PI-0514B	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193			
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
2PI-0526A	2MS125	Instrument Cable For 2PI-0526A			
2PI-0536A	2MS126	Instrument Cable For 2PI-0536A			
2PI-MS193	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193			
2PI-MS194	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2PI-RY033	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
	2RY431	Instrument Cable For 2PI-0455A, 2PI-0455B, and 2PI-RY033			
2RC014A	2RC622	Control Cable For 2RC014A			
2RC014C	2RC628	Control Cable For 2RC014C			
2RH8701A	2CV413	Control Cable For 2CV8804A and 2RH8701A			
	2RH023	Power Cable For 2RH8701A			
	2RH025	Control Cable For 2CV8804A and 2RH8701A			
	2RH029	Control Cable For 2RH8701A and 2SI8811A			
	2RH030	Control Cable For 2RH8701A			
	2RH031	Control Cable For 2RH8701A			
	2SI168	Control Cable For 2RH8701A			
2RH8702A	2RH044	Power Cable For 2RH8702A			
	2RH046	Control Cable For 2RH8702A			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
	2RH050	Control Cable For 2RH8702A			
	2RH051	Control Cable For 2RH8702A			
	2RH052	Control Cable For 2RH8702A			
	2RH054	Control Cable For 2RH8702A			
	2RH055	Control Cable For 2RH8702A			
2RY455A	2RY486	Control Cable For 2RY455A			
2RY8000A	2RY392	Control Cable For 2RY8000A			
	2RY393	Power Cable For 2RY8000A			
	2RY394	Control Cable For 2RY8000A			
2SI8806	2SI072	Power Cable For 2SI8806			
2SI8811A	2RH026	Control Cable For 2CS009A and 2SI8811A			
	2RH029	Control Cable For 2RH8701A and 2SI8811A			
2SX147A	2SX178	Control Cable For 2SX147A			
2TI-0413A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
2TI-0423A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
2TI-0433A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
2TI-0443A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
2TI-0604	2RH146	Instrument Cable For 2TI-0604			
2TI-IT001	2IT275	Instrument Cable For 2TI-IT001			
	2IT276	Instrument Cable For 2TI-IT001			
	2IT277	Instrument Cable For 2TI-IT001			
	2IT278	Instrument Cable For 2TI-IT001			
	2IT279	Instrument Cable For 2TI-IT001			
	2IT280	Instrument Cable For 2TI-IT001			
	2IT281	Instrument Cable For 2TI-IT001			
	2IT282	Instrument Cable For 2TI-IT001			
	2IT283	Instrument Cable For 2TI-IT001			
	2IT284	Instrument Cable For 2TI-IT001			
	2IT285	Instrument Cable For 2TI-IT001			
	2IT286	Instrument Cable For 2TI-IT001			
	2IT287	Instrument Cable For 2TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
	2IT288	Instrument Cable For 2TI-IT001			
	2IT289	Instrument Cable For 2TI-IT001			
	2IT290	Instrument Cable For 2TI-IT001			
	2IT291	Instrument Cable For 2TI-IT001			
	2IT292	Instrument Cable For 2TI-IT001			
	2IT293	Instrument Cable For 2TI-IT001			
	2IT294	Instrument Cable For 2TI-IT001			
	2IT295	Instrument Cable For 2TI-IT001			
	2IT296	Instrument Cable For 2TI-IT001			
	2IT297	Instrument Cable For 2TI-IT001			
	2IT298	Instrument Cable For 2TI-IT001			
	2IT299	Instrument Cable For 2TI-IT001			
	2IT300	Instrument Cable For 2TI-IT001			
	2IT301	Instrument Cable For 2TI-IT001			
	2IT302	Instrument Cable For 2TI-IT001			
	2IT303	Instrument Cable For 2TI-IT001			
	2IT304	Instrument Cable For 2TI-IT001			
	2IT305	Instrument Cable For 2TI-IT001			
	2IT306	Instrument Cable For 2TI-IT001			
	2IT307	Instrument Cable For 2TI-IT001			
	2IT345	Instrument Cable For 2TI-IT001			
	2IT346	Instrument Cable For 2TI-IT001			
	2IT424	Instrument Cable For 2TI-IT001			
2TI-RC005A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
2TI-RC006A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
2TI-RC007A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
2TI-RC008A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
2TI-RC022A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
2TI-RC022B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC023A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC023B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC024A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC024B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC025A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC025B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2UL-AN012-A7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2SI469	Instrument Cable For 2LI-0932, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5A-2					
2UL-AN012-B7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2SI469	Instrument Cable For 2LI-0932, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-C7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2SI469	Instrument Cable For 2LI-0932, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2VA06CB	2VA821	Power Cable For 2VA06CB			
	2VA822	Control Cable For 2VA06CB			
	2VA823	Control Cable For 2VA06CB			
2VD09YA	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YB	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP003	Power Cable For 2VP01CA			
2VP01CC	2VP047	Power Cable For 2VP01CC			
2VX04Y	2VE031	Control Cable For 2VX04Y and 2VX05Y			
2VX05Y	2VE031	Control Cable For 2VX04Y and 2VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5B-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
1LI-0459A	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034	1AP06EC	1SI008	Power Cable For 1AP06EC
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B	1AP06EH	1CS031	Control Cable For 1AP06EH
1LI-0459B	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034		1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B	1CC685	1CC043	Control Cable For 1CC685
1LI-0501	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309	1CS009B	1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A	1CV01PB	1CV011	Power Cable For 1CV01PB
1LI-0501A	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309	1CV112C	1CV084	Control Cable For 1CV112C and 1CV112E
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A	1CV112E	1CV082	Power Cable For 1CV112E
1LI-FW309	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309		1CV084	Control Cable For 1CV112C and 1CV112E
	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1CV8111	1CV062	Control Cable For 1CV8111
			1RH8701B	1RH039	Control Cable For 1RH8701B
1LI-FW310	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1RH8702B	1RH040	Control Cable For 1RH8701B
				1SI062	Control Cable For 1RH8702B and 1SI8812B
1LI-RY034	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B		1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034		1SI173	Control Cable For 1RH8702B, 1SI8811B, and 1SI8812B
			1RH8716B	1RH070	Power Cable For 1RH8716B
				1RH071	Control Cable For 1RH8716B
			1SI8804B	1RH072	Control Cable For 1RH8716B
				1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
			1SI8811B	1SI177	Control Cable For 1SI8804B
				1CS050	Control Cable For 1SI8811B
				1SI156	Control Cable For 1SI8811B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5B-1					
1NI-NR005D	1NR402	Instrument Cable For 1NI-NR005D		1SI173	Control Cable For 1RH8702B, 1SI8811B, and 1SI8812B
1PI-0455A	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033	1SI8812B	1SI062	Control Cable For 1RH8702B and 1SI8812B
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B		1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
1PI-0455B	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033		1SI171	Power Cable For 1SI8812B
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B		1SI172	Control Cable For 1SI8812B
1PI-0514A	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193		1SI173	Control Cable For 1RH8702B, 1SI8811B, and 1SI8812B
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B	1SX01PB	1SX055	Control Cable For 1SX01PB
1PI-0514B	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193		1SX061	Control Cable For 1SX01PB
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B	1SX147B	1SX191	Control Cable For 1SX147B
1PI-MS193	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1VA02CD	1VA152	Power Cable For 1VA02CD
	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193		1VA153	Control Cable For 1VA02CD
1PI-MS194	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1PI-RY033	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033			
1TI-RC022A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5B-1					
1TI-RC022B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC023A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC023B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC024A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC024B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC025A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
1TI-RC025B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B			
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5B-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			2AP06EP	2CS018 2CS020 2CS031 2CS043 2SI155	Power Cable For 2AP06EP Control Cable For 2AP06EP Control Cable For 2AP06EP Control Cable For 2AP06EP Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
			2AP06EU	2SI008	Power Cable For 2AP06EU
			2CC685	2CC043	Control Cable For 2CC685
			2CS009B	2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
			2CV01PB	2CV011	Power Cable For 2CV01PB
			2CV112C	2CV084	Control Cable For 2CV112C and 2CV112E
			2CV112E	2CV082 2CV084	Power Cable For 2CV112E Control Cable For 2CV112C and 2CV112E
			2CV8111	2CV062	Control Cable For 2CV8111
			2LI-0931	2SI468	Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
			2LI-0933	2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
			2RH01PB	2RH008	Power Cable For 2RH01PB
			2RH8701B	2RH038 2RH039 2RH040	Control Cable For 2RH8701B Control Cable For 2RH8701B Control Cable For 2RH8701B
			2RH8702B	2SI062	Control Cable For 2RH8702B and 2SI8812B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5B-2					
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI173	Control Cable For 2RH8702B, 2SI8811B, and 2SI8812B
	2RH8716B			2RH070	Power Cable For 2RH8716B
				2RH071	Control Cable For 2RH8716B
				2RH072	Control Cable For 2RH8716B
	2SI8804B			2SI066	Control Cable For 2SI8804B
				2SI067	Control Cable For 2SI8804B
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI177	Control Cable For 2SI8804B
	2SI8811B			2CS050	Control Cable For 2SI8811B
				2SI156	Control Cable For 2SI8811B
				2SI173	Control Cable For 2RH8702B, 2SI8811B, and 2SI8812B
	2SI8812B			2SI062	Control Cable For 2RH8702B and 2SI8812B
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI171	Power Cable For 2SI8812B
				2SI172	Control Cable For 2SI8812B
				2SI173	Control Cable For 2RH8702B, 2SI8811B, and 2SI8812B
	2SX01PB			2SX055	Control Cable For 2SX01PB
				2SX061	Control Cable For 2SX01PB
	2SX147B			2SX191	Control Cable For 2SX147B
	2UL-AN012-A7			2SI468	Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
				2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
	2UL-AN012-B7			2SI468	Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
				2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.5B-2			2UL-AN012-C7	2SI468	Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
				2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
			2VA02CD	2VA152	Power Cable For 2VA02CD
				2VA153	Control Cable For 2VA02CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
Unit 0 (Common) Components					
	0VA430Y	Aux Bldg HVAC Fan 0C & 0D Supply Air Control Damper (AO)	0CC01E-C	1CC016	Control Cable For 0CC01E-C and 1CC01PB
	0VA490Y	Unit 2 Division 22 Electrical Penetration Area Fire Damper		1CC030	Control Cable For 0CC01E-C
	0VA492Y	Unit 2 Division 22 Electrical Penetration Area Fire Damper		1CC175	Control Cable For 0CC01E-C
	0VA495Y	Unit 1 Division 12 Electrical Penetration Area Fire Damper	0CC01E-D	1EF043	Control Cable For 0CC01E-C
	0VA496Y	Unit 1 Division 12 Electrical Penetration Area Fire Damper		2CC016	Control Cable For 0CC01E-D and 2CC01PB
	0VA497Y	Unit 1 Division 12 Electrical Penetration Area Fire Damper		2CC030	Control Cable For 0CC01E-D
	0VA514Y	Unit 1 Division 12 Elect. Penet. Area Flow Control Damper (AO)		2CC175	Control Cable For 0CC01E-D
0AB03P(1)	1AB005	Control Cable For 0AB03P(1) and 1AB03P	0FI-SX044	2EF043	Control Cable For 0CC01E-D
	1AB006	Control Cable For 0AB03P(1) and 1AB03P		1SX378	Instrument Cable For 0FI-SX044
0AB03P(2)	2AB005	Control Cable For 0AB03P(2) and 2AB03P		1SX379	Instrument Cable For 0FI-SX044
	2AB006	Control Cable For 0AB03P(2) and 2AB03P	0SX02PB	1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
0CC01E-A	1CC006	Control Cable For 0CC01E-A and 1CC01PA		1SX097	Control Cable For 0SX02PB
	1CC022	Control Cable For 0CC01E-A		1SX203	Control Cable For 0SX02PB
	1CC023	Control Cable For 0CC01E-A	0SX146	1SX204	Control Cable For 0SX02PB
	1CC025	Control Cable For 0CC01E-A	0SX147	1SX089	Control Cable For 0SX146
	1CC174	Control Cable For 0CC01E-A	0SX162B	1SX170	Control Cable For 0SX147
	1CC276	Control Cable For 0CC01E-A	0SX162D	2SX170	Control Cable For 0SX162B
	1EF027	Control Cable For 0CC01E-A	0VA475Y	1VA129	Control Cable For 0VA475Y
0CC01E-B	2CC006	Control Cable For 0CC01E-B and 2CC01PA		1VA524	Control Cable For 0VA475Y
	2CC019	Power Cable For 0CC01E-B		1VA525	Control Cable For 0VA475Y
	2CC022	Control Cable For 0CC01E-B		1VA526	Control Cable For 0VA475Y
	2CC023	Control Cable For 0CC01E-B		1VA527	Control Cable For 0VA475Y
	2CC025	Control Cable For 0CC01E-B		1VA528	Control Cable For 0VA475Y
	2CC106	Control Cable For 0CC01E-B		1VA529	Control Cable For 0VA475Y
				1VA540	Control Cable For 0VA475Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
0FI-SX044 0SX02PA	2CC174	Control Cable For 0CC01E-B		1VA542	Control Cable For 0VA475Y
	2CC276	Control Cable For 0CC01E-B		1VA543	Control Cable For 0VA475Y
	2EF027	Control Cable For 0CC01E-B		1VA582	Control Cable For 0VA475Y
	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031		1VA756	Control Cable For 0VA475Y
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	0VA477Y	1VA851	Control Cable For 0VA475Y
				2VA381	Control Cable For 0VA477Y
				2VA382	Control Cable For 0VA477Y
	1SX172	Control Cable For 0SX02PA		2VA383	Control Cable For 0VA477Y
	1SX205	Control Cable For 0SX02PA		2VA384	Control Cable For 0VA477Y
	1SX206	Control Cable For 0SX02PA		2VA385	Control Cable For 0VA477Y
	1SX258	Control Cable For 0SX02PA		2VA386	Control Cable For 0VA477Y
	0SX158A	Control Cable For 0SX158A		2VA765	Control Cable For 0VA477Y
	0SX162A	Control Cable For 0SX162A		2VA766	Control Cable For 0VA477Y
	0SX162C	Control Cable For 0SX162C		2VA767	Control Cable For 0VA477Y
0VA01CA	2SX345	Control Cable For 0SX162C	0VC01CB	2VA768	Control Cable For 0VA477Y
	1VA001	Power Cable For 0VA01CA		2VA769	Control Cable For 0VA477Y
0VA01CC	1VA002	Control Cable For 0VA01CA		2VA771	Control Cable For 0VA477Y
	2VA001	Power Cable For 0VA01CC		2VA796	Control Cable For 0VA477Y
0VA02CA	2VA002	Control Cable For 0VA01CC		1VC059	Power Cable For 0VC01CB
	1VA016	Power Cable For 0VA02CA		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
0VA02CC	1VA017	Control Cable For 0VA02CA			
	2VA016	Power Cable For 0VA02CC		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
0VA474Y	2VA017	Control Cable For 0VA02CC			
	1VA027	Control Cable For 0VA474Y	0VC01Y	1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA083	Control Cable For 0VA474Y			
	1VA254	Control Cable For 0VA474Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VA472	Control Cable For 0VA474Y			
	1VA473	Control Cable For 0VA474Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA474	Control Cable For 0VA474Y			
	1VA475	Control Cable For 0VA474Y			
	1VA476	Control Cable For 0VA474Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
OVA476Y	1VA477	Control Cable For OVA474Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VA478	Control Cable For OVA474Y			
	1VA479	Control Cable For OVA474Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA481	Control Cable For OVA474Y			
	1VA482	Control Cable For OVA474Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA755	Control Cable For OVA474Y			
	1VA757	Control Cable For OVA474Y		1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA758	Control Cable For OVA474Y			
	1VA759	Control Cable For OVA474Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VA760	Control Cable For OVA474Y			
	1VA761	Control Cable For OVA474Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VA763	Control Cable For OVA474Y			
	1VA793	Control Cable For OVA474Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VA795	Control Cable For OVA474Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	2VA025	Control Cable For OVA476Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	2VA027	Control Cable For OVA476Y			
	2VA254	Control Cable For OVA476Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	2VA361	Control Cable For OVA476Y	0VC02CB		
	2VA362	Control Cable For OVA476Y		1VC067	Power Cable For 0VC02CB
	2VA363	Control Cable For OVA476Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	2VA364	Control Cable For OVA476Y			
	2VA365	Control Cable For OVA476Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	2VA366	Control Cable For OVA476Y			
	2VA367	Control Cable For OVA476Y			
	2VA369	Control Cable For OVA476Y			
	2VA640	Control Cable For OVA476Y			
	2VA652	Control Cable For OVA476Y			
	2VA757	Control Cable For OVA476Y			
	2VA758	Control Cable For OVA476Y			
	2VA759	Control Cable For OVA476Y			
	2VA760	Control Cable For OVA476Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	2VA761	Control Cable For 0VA476Y		1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	2VA763	Control Cable For 0VA476Y			
	2VA793	Control Cable For 0VA476Y		1VC072	Control Cable For 0VC02CB
	2VA795	Control Cable For 0VA476Y		1VC077	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
0VC01CA	1VC018	Control Cable For 0VC01CA		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
0VC02CA	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y	0VC02Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC021	Power Cable For 0VC02CA		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC024	Control Cable For 0VC02CA		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC032	Control Cable For 0VC281Y and 0VC02CA		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
0VC033Y	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y	0VC03Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
0VC043Y	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1PR065	Power Cable For 0VC281Y and 0VC043Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1PR066	Power Cable For 0VC281Y and 0VC043Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1PR314	Power Cable For 0VC281Y and 0VC043Y		1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC17Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y	0VC044Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
				1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
OVC18Y	1VC022	Control Cable For OVC02CA, OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y		1VC060	Control Cable For OVC282Y, OVC01Y, OVC02Y, OVC03Y, OVC044Y, OVC04Y, OVC16Y, and OVC172Y
	1VC023	Control Cable For OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y		1VC065	Control Cable For OVC282Y, OVC01Y, OVC02CB, OVC03Y, OVC044Y, OVC16Y, and OVC172Y
	1VC025	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y		1VC066	Control Cable For OVC282Y, OVC01Y, OVC02Y, OVC03Y, OVC044Y, OVC04Y, OVC16Y, and OVC172Y
	1VC026	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y		1VC068	Control Cable For OVC02CB, OVC282Y, OVC01Y, OVC03Y, OVC044Y, OVC16Y, and OVC172Y
	1VC034	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y		1VC069	Control Cable For OVC282Y, OVC01Y, OVC02CB, OVC03Y, OVC044Y, OVC16Y, and OVC172Y
	1VC623	Control Cable For OVC02CA, OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y		1VC070	Control Cable For OVC282Y, OVC01Y, OVC02CB, OVC03Y, OVC044Y, OVC16Y, and OVC172Y
	1PR313	Power Cable For OVC20Y, OVC281Y, OVC043Y, OVC18Y, and OVC19Y		1VC071	Control Cable For OVC01CB, OVC282Y, OVC01Y, OVC03Y, OVC044Y, OVC16Y, and OVC172Y
	1VC015	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y		1VC119	Control Cable For OVC01CB, OVC01Y, OVC02CB, OVC02Y, OVC03Y, OVC044Y, OVC04Y, OVC16Y, OVC172Y, OVC175Y, OVC182Y, OVC217Y, and OVC282Y
	1VC034	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y		1VC244	Control Cable For OVC044Y
	1VC623	Control Cable For OVC02CA, OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y		1VC576	Control Cable For OVC044Y
OVC19Y	1PR313	Power Cable For OVC20Y, OVC281Y, OVC043Y, OVC18Y, and OVC19Y		1VC614	Control Cable For OVC02CB, OVC282Y, OVC01Y, OVC02Y, OVC03Y, OVC044Y, OVC04Y, OVC16Y, and OVC172Y
	1VC015	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y		1PR067	Power Cable For OVC282Y, OVC02Y, OVC03Y, OVC044Y, OVC04Y, and OVC16Y
	1VC016	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y	OVC04Y	1VC060	Control Cable For OVC282Y, OVC01Y, OVC02Y, OVC03Y, OVC044Y, OVC04Y, OVC16Y, and OVC172Y
	1VC020	Control Cable For OVC01CA, OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC022	Control Cable For OVC02CA, OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC023	Control Cable For OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC025	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
0VC20Y	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y		1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC281Y	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y	0VC16Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
	1PR065	Power Cable For 0VC281Y and 0VC043Y		1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
	1PR066	Power Cable For 0VC281Y and 0VC043Y		1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y		1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1PR314	Power Cable For 0VC281Y and 0VC043Y		1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y		1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC032	Control Cable For 0VC281Y and 0VC02CA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y		1VC077	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			0VC172Y	1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0				1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
	0VC175Y			1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	0VC182Y			1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	0VC217Y			1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
	0VC282Y			1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
				1VC036	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC060	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC068	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC071	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC077	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
Unit 1 Components					
-	1AP30E	Division 11 480V ESF MCC 131X5	-	1AP32E	Division 12 480V ESF MCC 132X5
	1CC01T	Component Cooling Surge Tank	1AF005E	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
1AB03P	1AB005	Control Cable For 0AB03P(1) and 1AB03P		1AF082	Instrument Cable For 1AF005E
	1AB006	Control Cable For 0AB03P(1) and 1AB03P			
1AF005A	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	1AF081	Instrument Cable For 1AF005A		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF115	Control Cable For 1AF005A			
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1AF005F	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D		1AF084	Instrument Cable For 1AF005F
1AF005B	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF083	Instrument Cable For 1AF005B			
	1AF116	Control Cable For 1AF005B			
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1AF005G	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D		1AF086	Instrument Cable For 1AF005G
1AF005C	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF085	Instrument Cable For 1AF005C	1AF005H	1AF079	Instrument Cable For 1AF005E, 1AF005F, 1AF005G, and 1AF005H
	1AF117	Control Cable For 1AF005C		1AF088	Instrument Cable For 1AF005H
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005D	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D	1AF006B	1AF062	Control Cable For 1AF006B and 1AF017B
	1AF087	Instrument Cable For 1AF005D		1AF063	Control Cable For 1AF006B
	1AF118	Control Cable For 1AF005D		1AF296	Control Cable For 1AF006B and 1AF017B
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1AF013E	1AF041	Control Cable For 1AF006B
			1AF013F	1AF044	Control Cable For 1AF013E
				1AF045	Control Cable For 1AF013F
					Control Cable For 1AF013F

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D	1AF013G	1AF048	Control Cable For 1AF013G
1AF006A	1AF057	Control Cable For 1AF006A and 1AF017A		1AF049	Control Cable For 1AF013G
	1AF295	Control Cable For 1AF006A and 1AF017A	1AF013H	1AF052	Control Cable For 1AF013H
	1AF324	Control Cable For 1AF006A and 1AF01PA		1AF053	Control Cable For 1AF013H
1AF013A	1AF022	Control Cable For 1AF013A	1AF017B	1AF062	Control Cable For 1AF006B and 1AF017B
	1AF024	Control Cable For 1AF013A		1AF100	Control Cable For 1AF017B
1AF013B	1AF027	Control Cable For 1AF013B		1AF296	Control Cable For 1AF006B and 1AF017B
	1AF028	Control Cable For 1AF013B	1AF01PB	1AF068	Control Cable For 1AF01PB
1AF013C	1AF031	Control Cable For 1AF013C		1AF070	Control Cable For 1AF01PB
	1AF032	Control Cable For 1AF013C		1AF168	Control Cable For 1AF01PB
1AF013D	1AF035	Control Cable For 1AF013D		1AF289	Control Cable For 1AF01PB-C and 1AF01PB
	1AF036	Control Cable For 1AF013D		1AF298	Control Cable For 1AF01PB
1AF017A	1AF057	Control Cable For 1AF006A and 1AF017A		1AF338	Instrument Cable For 1AF01PB
	1AF295	Control Cable For 1AF006A and 1AF017A		1AF346	Control Cable For 1AF01PB
1AF01PA	1AF006	Control Cable For 1AF01PA		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF007	Control Cable For 1AF01PA			
	1AF008	Control Cable For 1AF01PA	1AF01PB-A	1AF159	Control Cable For 1AF01PB-A
	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11		1AF160	Control Cable For 1AF01PB-A
	1AF276	Control Cable For 1AF01PA		1AF162	Control Cable For 1AF01PB-A
	1AF324	Control Cable For 1AF006A and 1AF01PA		1AF169	Control Cable For 1AF01PB-A
1AF01PA-A	1AF004	Control Cable For 1AF01PA-A		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1AF014	Control Cable For 1AF01PA-A			
	1AF019	Control Cable For 1AF01PA-A			
1AP05EA	1AP401	Control Cable For 1AP05EA	1AF01PB-C	1AF289	Control Cable For 1AF01PB-C and 1AF01PB
1AP05EC	1SI001	Power Cable For 1AP05EC		1AF290	Control Cable For 1AF01PB-C
1AP05EF	1DG019	Control Cable For 1DG01KA and 1AP05EF			
1AP05EJ	1CS001	Power Cable For 1AP05EJ			
	1CS006	Control Cable For 1AP05EJ			
	1CS021	Control Cable For 1AP05EJ			
	1CS025	Control Cable For 1AP05EJ			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	1CS041	Control Cable For 1AP05EJ		1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
	1CS042	Control Cable For 1AP05EJ			
	1CS055	Control Cable For 1AP05EJ and 1CS009A			
	1CS122	Control Cable For 1AP05EJ			
1AP05EP	1AP075	Control Cable For 1AP05EP	1AP06EF	1DG054	Control Cable For 1DG01KB and 1AP06EF
1AP05ER	1AP050	Control Cable For 1AP05ER		1DG229	Control Cable For 1AP06EF
	1AP312	Control Cable For 1AP05ER	1AP06EH	1CS020	Control Cable For 1AP06EH
	1AP585	Control Cable For 1AP05ER and 2AP05EG		1CS034	Control Cable For 1AP06EH
1AP05EU	1AP082	Control Cable For 1AP05EU		1CS043	Control Cable For 1AP06EH
	1AP395	Control Cable For 1AP05EU		1CS044	Control Cable For 1AP06EH
1AP07EL	1AP093	Power Cable For 1AP07EL		1CS058	Control Cable For 1AP06EH and 1CS009B
	1AP142	Control Cable For 1AP07EL	1AP06ES	1AP587	Control Cable For 1AP06ES and 2AP06EF
1AP14E	1AP376	Control Cable For 1AP14E	1AP24E	1AP154	Power Cable For 1AP24E and 1AP32E
	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E		1AP690	Power Cable For 1AP24E and 1AP32E
1AP21E	1AP143	Power Cable For 1AP21E	1AP32E	1AP154	Power Cable For 1AP24E and 1AP32E
1AP21EA	1SI517	Control Cable For 1AP21EA		1AP690	Power Cable For 1AP24E and 1AP32E
1AP25E	1AP144	Power Cable For 1AP25E	1CC01PB	1CC013	Control Cable For 1CC01PB
1AP26E	1AP146	Power Cable For 1AP26E		1CC014	Control Cable For 1CC01PB
1AP30E	1AP148	Power Cable For 1AP30E		1CC016	Control Cable For 0CC01E-C and 1CC01PB
1AP38E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E		1CC284	Control Cable For 1CC01PB
1AP42E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E		1EF064	Control Cable For 1CC01PB
1CC01PA	1CC002	Control Cable For 1CC01PA	1CC685	1CC041	Control Cable For 1CC685
	1CC003	Control Cable For 1CC01PA		1CC278	Control Cable For 1CC685
	1CC004	Control Cable For 1CC01PA	1CC9412B	1CC048	Control Cable For 1CC9412B
	1CC006	Control Cable For 0CC01E-A and 1CC01PA	1CC9413B	1CC055	Control Cable For 1CC9413B
	1CC283	Control Cable For 1CC01PA		1CC057	Control Cable For 1CC9413B
	1EF028	Control Cable For 1CC01PA	1CC9414	1CC063	Control Cable For 1CC9414
1CC9412A	1CC045	Control Cable For 1CC9412A		1CC065	Control Cable For 1CC9414
1CC9413A	1CC051	Control Cable For 1CC9413A	1CC9473B	1CC130	Control Cable For 1CC9473B
1CC9416	1CC059	Control Cable For 1CC9416	1CS009B	1CS058	Control Cable For 1AP06EH and 1CS009B
1CC9438	1CC036	Control Cable For 1CC9438	1CV01PB	1CV016	Control Cable For 1CV01PB

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1CS009A	1CS055	Control Cable For 1AP05EJ and 1CS009A		1EF044	Control Cable For 1CV01PB and 1SX01PB
	1CS079	Control Cable For 1CS009A	1CV112C	1CV071	Power Cable For 1CV112C
1CV01PA	1CV001	Power Cable For 1CV01PA		1CV072	Control Cable For 1CV112C
	1CV006	Control Cable For 1CV01PA		1CV073	Control Cable For 1CV112C
	1CV009	Control Cable For 1CV01PA		1CV074	Control Cable For 1CV112C
	1EF031	Control Cable For 1CV01PA and 1SX01PA		1CV075	Control Cable For 1CV112C
1CV112B	1CV065	Power Cable For 1CV112B	1CV112E	1CV083	Control Cable For 1CV112E
	1CV066	Control Cable For 1CV112B		1CV085	Control Cable For 1CV112E
	1CV067	Control Cable For 1CV112B	1CV121	1CV140	Instrument Cable For 1CV121
	1CV068	Control Cable For 1CV112B	1CV8104	1CV615	Control Cable For 1CV8104
	1CV069	Control Cable For 1CV112B		1CV616	Power Cable For 1CV8104
1CV112D	1CV079	Control Cable For 1CV112D		1CV617	Control Cable For 1CV8104
	1CV080	Control Cable For 1CV112D		1CV618	Control Cable For 1CV8104
1CV8110	1CV059	Control Cable For 1CV8110	1CV8111	1CV063	Control Cable For 1CV8111
1CV8114	1CV645	Control Cable For 1CV8114	1CV8116	1CV649	Control Cable For 1CV8116
1CV8355A	1CV611	Control Cable For 1CV8355A	1CV8355B	1CV623	Control Cable For 1CV8355B
1CV8355D	1CV614	Control Cable For 1CV8355D	1CV8355C	1CV626	Control Cable For 1CV8355C
1CV8804A	1CV407	Control Cable For 1CV8804A	1DG01KB	1DG052	Control Cable For 1DG01KB
	1CV413	Control Cable For 1CV8804A and 1RH8701A		1DG053	Control Cable For 1DG01KB
	1CV468	Control Cable For 1CV8804A		1DG054	Control Cable For 1DG01KB and 1AP06EF
1DG01KA	1DG017	Control Cable For 1DG01KA		1DG150	Control Cable For 1DG01KB
	1DG018	Control Cable For 1DG01KA		1DG178	Control Cable For 1DG01KB
	1DG019	Control Cable For 1DG01KA and 1AP05EF		1DG201	Control Cable For 1DG01KB
	1DG153	Control Cable For 1DG01KA	1DO01PD	1DO009	Power Cable For 1DO01PD
	1DG154	Control Cable For 1DG01KA		1DO010	Control Cable For 1DO01PD
	1DG174	Control Cable For 1DG01KA	1FI-0121A	1CV139	Instrument Cable For 1FI-0121A and 1FI-0121B
	1DG200	Control Cable For 1DG01KA	1FI-0121B	1CV139	Instrument Cable For 1FI-0121A and 1FI-0121B
1DO01PA	1DO001	Power Cable For 1DO01PA	1LI-0460B	1RC406	Instrument Cable For 1LI-0460B
	1DO002	Control Cable For 1DO01PA	1LI-0502	1FW026	Instrument Cable For 1LI-0502
1DO01PC	1DO004	Power Cable For 1DO01PC	1LI-0503	1FW027	Instrument Cable For 1LI-0503
	1DO005	Control Cable For 1DO01PC	1LL-SI075B	1SI257	Control Cable For 1LL-SI075B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6.0					
1F-SX031	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031	1MS001A-DIV12	1DC184	Control Cable For 0SX02PB, 1AF005L, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-B, and 1SX176
	1SX376	Instrument Cable For 1FI-SX031			Control Cable For 1MS001A-DIV12
	1SX377	Instrument Cable For 1FI-SX031			Control Cable For 1MS001A-DIV12
1IP01E	1IP004	Power Cable For 1IP01E			Control Cable For 1MS001A-DIV12 and 1MS001C-DIV12
1IP05E	1IP002	Power Cable For 1IP05E		1MS276	Control Cable For 1MS001A-DIV12
1IP07E	1IP030	Power Cable For 1IP07E		1MS276	Control Cable For 1MS001A-DIV12 and 1MS001C-DIV12
1LI-0459A	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B		1MS525	Control Cable For 1MS001A-DIV12
1LI-0459B	1RC371	Instrument Cable For 1LI-0459B			Control Cable For 1MS001A-DIV12
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B		1MS530	Control Cable For 0SX02PB, 1AF005L, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-B, and 1SX176
1LI-0501	1FW025	Instrument Cable For 1LI-0501	1MS001B-DIV12	1DC184	Control Cable For 1MS001B-DIV12
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			Control Cable For 1MS001B-DIV12
1LI-0501A	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			Control Cable For 1MS001B-DIV12 and 1MS001D-DIV12
1LI-0504	1FW028	Instrument Cable For 1LI-0504			Control Cable For 1MS001B-DIV12
1LI-0930	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7		1MS286	Control Cable For 1MS001B-DIV12
				1MS289	Control Cable For 1MS001B-DIV12
1LL-SI075A	1SI234	Control Cable For 1LL-SI075A		1MS521	Control Cable For 1MS001B-DIV12 and 1MS001D-DIV12
1MS001A-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1MS001C-DIV12	1DC184	Control Cable For 0SX02PB, 1AF005L, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-B, and 1SX176
	1MS272	Control Cable For 1MS001A-DIV11			Control Cable For 1MS001C-DIV12
	1MS275	Control Cable For 1MS001A-DIV11			Control Cable For 1MS001C-DIV12
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11		1MS299	Control Cable For 1MS001C-DIV12
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11		1MS523	Control Cable For 1MS001C-DIV12
1MS001B-DIV11	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11	1MS001D-DIV12	1DC184	Control Cable For 0SX02PB, 1AF005L, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-B, and 1SX176
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			Control Cable For 1MS001D-DIV12
	1MS285	Control Cable For 1MS001B-DIV11		1MS312	Control Cable For 1MS001B-DIV12 and 1MS001D-DIV12
	1MS288	Control Cable For 1MS001B-DIV11		1MS523	Control Cable For 1MS001C-DIV12

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11		1MS528	Control Cable For 1MS001D-DIV12
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11	1MS018B	1MS533	Control Cable For 1MS001D-DIV12
1MS001C-DIV11	1AF121	Control Cable For 1MS001C-DIV11		1MS610	Control Cable For 1MS018B and 1MS018C
	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11		1MS612	Control Cable For 1MS018B and 1MS018C
	1MS298	Control Cable For 1MS001C-DIV11		1MS614	Control Cable For 1MS018B
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11		1MS617	Instrument Cable For 1MS018B
	1MS524	Control Cable For 1MS001C-DIV11		1MS618	Instrument Cable For 1MS018B
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11		1MS619	Instrument Cable For 1MS018B
1MS001D-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1MS018C	1MS620	Instrument Cable For 1MS018B
	1MS311	Control Cable For 1MS001D-DIV11		1MS621	Instrument Cable For 1MS018B
	1MS527	Control Cable For 1MS001D-DIV11		1MS622	Instrument Cable For 1MS018B
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11		1MS643	Instrument Cable For 1MS018B
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11		1MS610	Control Cable For 1MS018B and 1MS018C
1MS018A	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D		1MS612	Control Cable For 1MS018B and 1MS018C
	1MS581	Control Cable For 1MS018A and 1MS018D	1MS101A	1MS626	Control Cable For 1MS018C
	1MS583	Control Cable For 1MS018A and 1MS018D	1MS101B	1MS628	Power Cable For 1MS018C
	1MS585	Control Cable For 1MS018A	1MS101C	1MS629	Instrument Cable For 1MS018C
	1MS587	Power Cable For 1MS018A	1MS101D	1MS630	Instrument Cable For 1MS018C
	1MS588	Instrument Cable For 1MS018A	1PI-0525A	1MS631	Instrument Cable For 1MS018C
	1MS589	Instrument Cable For 1MS018A	1PI-MS194	1MS632	Instrument Cable For 1MS018C
	1MS590	Instrument Cable For 1MS018A	1RC014B	1MS633	Instrument Cable For 1MS018C
	1MS591	Instrument Cable For 1MS018A	1RC014D	1MS634	Instrument Cable For 1MS018C
				1MS646	Instrument Cable For 1MS018C
				1MS320	Control Cable For 1MS101A
				1MS325	Control Cable For 1MS101B
				1MS330	Control Cable For 1MS101C
				1MS335	Control Cable For 1MS101D
				1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
				1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
				1RC625	Control Cable For 1RC014B
				1RC631	Control Cable For 1RC014D

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1MS018D	1MS592	Instrument Cable For 1MS018A	1RH611	1RH021	Control Cable For 1RH611
	1MS593	Instrument Cable For 1MS018A	1RH8701B	1RH042	Control Cable For 1RH8701B
	1MS640	Instrument Cable For 1MS018A		1RH043	Control Cable For 1RH8701B
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D	1RH8702B	1RH064	Control Cable For 1RH8702B
				1RH065	Control Cable For 1RH8702B
	1MS581	Control Cable For 1MS018A and 1MS018D	1RH8716B	1RH073	Control Cable For 1RH8716B
	1MS583	Control Cable For 1MS018A and 1MS018D	1SI8801B	1SI037	Power Cable For 1SI8801B
	1MS597	Control Cable For 1MS018D		1SI038	Control Cable For 1SI8801B
	1MS599	Power Cable For 1MS018D		1SI039	Control Cable For 1SI8801B
	1MS600	Instrument Cable For 1MS018D		1SI040	Control Cable For 1SI8801B
	1MS601	Instrument Cable For 1MS018D	1SI8804B	1SI063	Control Cable For 1SI8804B
	1MS602	Instrument Cable For 1MS018D	1SI8807B	1SI085	Control Cable For 1SI8807B
	1MS603	Instrument Cable For 1MS018D	1SI8809B	1SI139	Control Cable For 1SI8809B
	1MS604	Instrument Cable For 1MS018D	1SI8811B	1SI164	Control Cable For 1SI8811B
	1MS605	Instrument Cable For 1MS018D	1SI8812B	1SI175	Control Cable For 1SI8812B
	1MS649	Instrument Cable For 1MS018D	1SI8924	1SI472	Control Cable For 1SI8924
1MS101A	1MS321	Control Cable For 1MS101A	1SX001B	1SX037	Control Cable For 1SX001B
1MS101B	1MS326	Control Cable For 1MS101B	1SX005	1SX044	Control Cable For 1SX005
1MS101C	1MS331	Control Cable For 1MS101C	1SX010	1SX092	Control Cable For 1SX010
1MS101D	1MS336	Control Cable For 1MS101D	1SX011	1SX095	Control Cable For 1SX011
1NI-NR005D	1NR297	Instrument Cable For 1NI-NR005D	1SX016B	1SX056	Control Cable For 1SX016B
1PI-0455A	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B	1SX01PB	1EF044	Control Cable For 1CV01PB and 1SX01PB
1PI-0455B	1RC370	Instrument Cable For 1PI-0455B		1SX019	Control Cable For 1SX01PB
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B		1SX144	Control Cable For 1SX01PB
1PI-0514A	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B	1SX01PB-C	1SX305	Control Cable For 1SX01PB-C
1PI-0514B	1MS099	Instrument Cable For 1PI-0514B		1SX314	Control Cable For 1SX01PB-C
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B	1SX027B	1SX062	Control Cable For 1SX027B
1PI-0524A	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B	1SX034	1SX068	Control Cable For 1SX034
1PI-0524B	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B	1SX136	1SX083	Control Cable For 1SX136
	1MS103	Instrument Cable For 1PI-0524B	1SX147B	1LV034	Control Cable For 1SX147B
1PI-0534A	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B		1SX191	Control Cable For 1SX147B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1PI-0534B	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B	1SX169B	1SX301	Control Cable For 1SX169B
	1MS107	Instrument Cable For 1PI-0534B	1SX173	1DC184	Control Cable For 0SX02PB, 1AF005E, 1AF005F, 1AF005G, 1AF005H, 1AF01PB, 1MS001A-DIV12, 1MS001B-DIV12, 1MS001C-DIV12, 1MS001D-DIV12, 1AF01PB-A, 1AF01PB-C, and 1SX173
1PI-0544A	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
1PI-0544B	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
	1MS111	Instrument Cable For 1PI-0544B			
1PI-CC107	1CC314	Control Cable For 1PI-CC107	1TI-IT002	1RC669	Control Cable For 1TI-IT002
	1CC315	Instrument Cable For 1PI-CC107	1TI-RC005B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
	1LV002	Control Cable For 1PI-CC107	1TI-RC006B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1RC014A	1RC622	Control Cable For 1RC014A	1TI-RC007B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1RC014C	1RC628	Control Cable For 1RC014C	1TI-RC008B	1RC613	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1RH01PA	1RH001	Power Cable For 1RH01PA			
1RH610	1RH017	Control Cable For 1RH610			
1RH8701A	1CV413	Control Cable For 1CV8804A and 1RH8701A	1VD01YA	1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1RH029	Control Cable For 1RH8701A and 1SI8811A		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1RH030	Control Cable For 1RH8701A			
	1RH031	Control Cable For 1RH8701A	1VD01YB	1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SI168	Control Cable For 1RH8701A		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1RH8702A	1RH050	Control Cable For 1RH8702A			
	1RH051	Control Cable For 1RH8702A			
	1RH054	Control Cable For 1RH8702A	1VD02YA	1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1RH055	Control Cable For 1RH8702A		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1RH8716A	1RH069	Control Cable For 1RH8716A			
1RY8000A	1RY394	Control Cable For 1RY8000A			
1SI8801A	1SI035	Control Cable For 1SI8801A	1VD02YB	1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
1SI8806	1SI073	Control Cable For 1SI8806		1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1SI074	Control Cable For 1SI8806			
	1SI077	Control Cable For 1SI8806	1VE01Y	1VE022	Control Cable For 1VE01Y and 1VE02Y
1SI8807A	1SI081	Control Cable For 1SI8807A		1VE033	Control Cable For 1VE01Y and 1VE02Y
1SI8809A	1SI134	Control Cable For 1SI8809A		1VE042	Control Cable For 1VE01Y and 1VE02Y
1SI8811A	1RH029	Control Cable For 1RH8701A and 1SI8811A	1VE02Y	1VE022	Control Cable For 1VE01Y and 1VE02Y
	1SI152	Control Cable For 1SI8811A		1VE033	Control Cable For 1VE01Y and 1VE02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1SI8812A	1SI170	Control Cable For 1SI8812A		1VE042	Control Cable For 1VE01Y and 1VE02Y
1SI8840	1SI211	Control Cable For 1SI8840	1VP01CB	1VP038	Control Cable For 1VP01CB
1SI8923A	1SI199	Control Cable For 1SI8923A	1VP01CD	1VP082	Control Cable For 1VP01CD
1SX001A	1SX033	Control Cable For 1SX001A			
1SX004	1SX041	Control Cable For 1SX004			
1SX016A	1SX053	Control Cable For 1SX016A			
	1SX472	Control Cable For 1SX016A and 1SX027A			
1SX01PA	1EF031	Control Cable For 1CV01PA and 1SX01PA			
	1SX005	Control Cable For 1SX01PA			
	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			
	1SX008	Control Cable For 1SX01PA			
	1SX052	Control Cable For 1SX01PA			
	1SX058	Control Cable For 1SX01PA			
	1SX143	Control Cable For 1SX01PA			
	1SX208	Control Cable For 1SX01PA			
	1SX280	Control Cable For 1SX01PA			
1SX01PA-C	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			
	1SX311	Control Cable For 1SX01PA-C			
	1SX312	Control Cable For 1SX01PA-C			
	1SX313	Control Cable For 1SX01PA-C			
1SX027A	1SX059	Control Cable For 1SX027A			
	1SX472	Control Cable For 1SX016A and 1SX027A			
1SX033	1SX065	Control Cable For 1SX033			
1SX101A	1AF003	Control Cable For 1SX101A			
	1SX471	Control Cable For 1SX101A			
1SX147A	1LV033	Control Cable For 1SX147A			
	1SX178	Control Cable For 1SX147A			
1SX169A	1SX295	Control Cable For 1SX169A			
1TI-0413A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
1TI-0423A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
1TI-0433A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1TI-0443A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
1TI-IT001	1IT275	Instrument Cable For 1TI-IT001			
	1IT276	Instrument Cable For 1TI-IT001			
	1IT277	Instrument Cable For 1TI-IT001			
	1IT278	Instrument Cable For 1TI-IT001			
	1IT279	Instrument Cable For 1TI-IT001			
	1IT280	Instrument Cable For 1TI-IT001			
	1IT281	Instrument Cable For 1TI-IT001			
	1IT282	Instrument Cable For 1TI-IT001			
	1IT283	Instrument Cable For 1TI-IT001			
	1IT284	Instrument Cable For 1TI-IT001			
	1IT285	Instrument Cable For 1TI-IT001			
	1IT286	Instrument Cable For 1TI-IT001			
	1IT287	Instrument Cable For 1TI-IT001			
	1IT288	Instrument Cable For 1TI-IT001			
	1IT289	Instrument Cable For 1TI-IT001			
	1IT290	Instrument Cable For 1TI-IT001			
	1IT291	Instrument Cable For 1TI-IT001			
	1IT292	Instrument Cable For 1TI-IT001			
	1IT293	Instrument Cable For 1TI-IT001			
	1IT294	Instrument Cable For 1TI-IT001			
	1IT295	Instrument Cable For 1TI-IT001			
	1IT296	Instrument Cable For 1TI-IT001			
	1IT297	Instrument Cable For 1TI-IT001			
	1IT298	Instrument Cable For 1TI-IT001			
	1IT299	Instrument Cable For 1TI-IT001			
	1IT300	Instrument Cable For 1TI-IT001			
	1IT301	Instrument Cable For 1TI-IT001			
	1IT302	Instrument Cable For 1TI-IT001			
	1IT303	Instrument Cable For 1TI-IT001			
	1IT304	Instrument Cable For 1TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	1IT305	Instrument Cable For 1TI-IT001			
	1IT306	Instrument Cable For 1TI-IT001			
	1IT307	Instrument Cable For 1TI-IT001			
	1IT345	Instrument Cable For 1TI-IT001			
	1IT346	Instrument Cable For 1TI-IT001			
	1IT424	Instrument Cable For 1TI-IT001			
	1RC648	Control Cable For 1TI-IT001			
1TI-RC005A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC006A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC007A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC008A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1UL-AN012-A7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-B7	1AN166	Control Cable For 1UL-AN012-B7			
	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-C7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1VA01CD	1VA165	Control Cable For 1VA01CD			
1VA02CA	1VA104	Control Cable For 1VA02CA			
1VA02CB	1VA148	Power Cable For 1VA02CB			
	1VA149	Control Cable For 1VA02CB			
	1VA150	Control Cable For 1VA02CB			
1VA06CA	1VA053	Control Cable For 1VA06CA			
1VA06CB	1VA822	Control Cable For 1VA06CB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1VD01CA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1VD10YB	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VP003	Power Cable For 1VP01CA			
	1VP016	Control Cable For 1VP01CA			
	1VP019	Control Cable For 1VP01CA			
	1VP020	Control Cable For 1VP01CA			
	1VP021	Control Cable For 1VP01CA			
1VP01CC	1VP047	Power Cable For 1VP01CC			
	1VP060	Control Cable For 1VP01CC			
	1VP063	Control Cable For 1VP01CC			
	1VP064	Control Cable For 1VP01CC			
	1VP065	Control Cable For 1VP01CC			
1VX04C	1VX001	Power Cable For 1VX04C			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
1VX04Y	1VX004	Control Cable For 1VX04C			
	1VE018	Control Cable For 1VX04Y and 1VX05Y			
	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VE039	Control Cable For 1VX04Y and 1VX05Y			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX064	Control Cable For 1VX04Y and 1VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
1VX05Y	1VX102	Control Cable For 1VX04Y and 1VX05Y			
	1VE018	Control Cable For 1VX04Y and 1VX05Y			
	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VE039	Control Cable For 1VX04Y and 1VX05Y			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX064	Control Cable For 1VX04Y and 1VX05Y			
	1VX102	Control Cable For 1VX04Y and 1VX05Y			
Unit 2 Components					
-	2AP30E	Division 21 480V ESF MCC 231X5	-	2AP32E	Division 22 480V ESF MCC 232X5
	2CC01T	Component Cooling Surge Tank	2AF005E	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
2AB03P	2AB005	Control Cable For 0AB03P(2) and 2AB03P		2AF082	Instrument Cable For 2AF005E
	2AB006	Control Cable For 0AB03P(2) and 2AB03P	2AF005F	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
2AF005A	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D		2AF084	Instrument Cable For 2AF005F
	2AF081	Instrument Cable For 2AF005A	2AF005G	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2AF086	Instrument Cable For 2AF005G
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D	2AF005H	2AF079	Instrument Cable For 2AF005E, 2AF005F, 2AF005G, and 2AF005H
2AF005B	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D	2AF006B	2AF088	Instrument Cable For 2AF005H
	2AF083	Instrument Cable For 2AF005B		2AF062	Control Cable For 2AF006B and 2AF017B
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21		2AF063	Control Cable For 2AF006B
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2AF296	Control Cable For 2AF006B and 2AF017B
2AF005C	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D	2AF013E	2AF041	Control Cable For 2AF013E
			2AF013F	2AF045	Control Cable For 2AF013F
			2AF013G	2AF049	Control Cable For 2AF013G
			2AF013H	2AF053	Control Cable For 2AF013H
			2AF017B	2AF062	Control Cable For 2AF006B and 2AF017B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2AF005D	2AF085	Instrument Cable For 2AF005C		2AF100	Control Cable For 2AF017B
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21	2AF01PB	2AF296	Control Cable For 2AF006B and 2AF017B
				2AF068	Control Cable For 2AF01PB
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2AF070	Control Cable For 2AF01PB
	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D		2AF168	Control Cable For 2AF01PB
	2AF087	Instrument Cable For 2AF005D		2AF298	Control Cable For 2AF01PB
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21	2AF01PB-A	2AF338	Instrument Cable For 2AF01PB
				2AF346	Control Cable For 2AF01PB
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D		2AF159	Control Cable For 2AF01PB-A
	2AF056	Control Cable For 2AF006A and 2AF01PA		2AF160	Control Cable For 2AF01PB-A
2AF006A	2AF057	Control Cable For 2AF006A and 2AF017A	2AF01PB-C	2AF162	Control Cable For 2AF01PB-A
	2AF058	Control Cable For 2AF006A		2AF169	Control Cable For 2AF01PB-A
	2AF295	Control Cable For 2AF006A and 2AF017A	2AP06EF	2AF290	Control Cable For 2AF01PB-C
	2AF332	Control Cable For 2AF006A and 2AF01PA	2AP06EP	1AP587	Control Cable For 1AP06ES and 2AP06EF
	2AF024	Control Cable For 2AF013A		2CS044	Control Cable For 2AP06EP
2AF013A	2AF028	Control Cable For 2AF013B	2AP06ER	2CS058	Control Cable For 2AP06EP and 2CS009B
2AF013B	2AF032	Control Cable For 2AF013C		2DG054	Control Cable For 2DG01KB and 2AP06ER
2AF013C	2AF036	Control Cable For 2AF013D	2AP32E	2AP154	Power Cable For 2AP32E
2AF013D	2AF057	Control Cable For 2AF006A and 2AF017A	2CC01PB	2CC013	Control Cable For 2CC01PB
2AF017A	2AF097	Control Cable For 2AF017A		2CC014	Control Cable For 2CC01PB
	2AF295	Control Cable For 2AF006A and 2AF017A		2CC016	Control Cable For 0CC01E-D and 2CC01PB
2AF01PA	2AF001	Power Cable For 2AF01PA		2CC334	Control Cable For 2CC01PB
	2AF006	Control Cable For 2AF01PA	2CC685	2EF064	Control Cable For 2CC01PB
	2AF007	Control Cable For 2AF01PA	2CC9412B	2CC278	Control Cable For 2CC685
	2AF008	Control Cable For 2AF01PA	2CC9413B	2CC048	Control Cable For 2CC9412B
	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21		2CC055	Control Cable For 2CC9413B
	2AF056	Control Cable For 2AF006A and 2AF01PA	2CC9414	2CC057	Control Cable For 2CC9413B
				2CC063	Control Cable For 2CC9414
				2CC065	Control Cable For 2CC9414
			2CC9473B	2CC130	Control Cable For 2CC9473B
			2CS009B	2CS058	Control Cable For 2AP06EP and 2CS009B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2AF01PA-A	2AF276	Control Cable For 2AF01PA		2CS113	Control Cable For 2CS009B
	2AF293	Control Cable For 2AF01PA	2CV01PB	2EF044	Control Cable For 2CV01PB and 2SX01PB
	2AF332	Control Cable For 2AF006A and 2AF01PA	2CV112C	2CV071	Power Cable For 2CV112C
	2AF004	Control Cable For 2AF01PA-A		2CV072	Control Cable For 2CV112C
2AF022A	2AF014	Control Cable For 2AF01PA-A		2CV073	Control Cable For 2CV112C
	2AF019	Control Cable For 2AF01PA-A		2CV074	Control Cable For 2CV112C
	2AF257	Control Cable For 2AF022A		2CV075	Control Cable For 2CV112C
2AP05ED	2AF258	Control Cable For 2AF022A	2CV121	2CV140	Instrument Cable For 2CV121
	2AP395	Control Cable For 2AP05ED	2CV8104	2CV615	Control Cable For 2CV8104
2AP05EE	2AP180	Control Cable For 2AP05EE		2CV616	Power Cable For 2CV8104
2AP05EG	1AP585	Control Cable For 1AP05ER and 2AP05EG		2CV617	Control Cable For 2CV8104
2AP05EP	2CS001	Power Cable For 2AP05EP		2CV618	Control Cable For 2CV8104
	2CS004	Control Cable For 2AP05EP	2CV8116	2CV649	Control Cable For 2CV8116
	2CS006	Control Cable For 2AP05EP	2CV8355B	2CV623	Control Cable For 2CV8355B
	2CS021	Control Cable For 2AP05EP	2CV8355C	2CV626	Control Cable For 2CV8355C
	2CS025	Control Cable For 2AP05EP	2DG01KB	2DG052	Control Cable For 2DG01KB
	2CS041	Control Cable For 2AP05EP		2DG053	Control Cable For 2DG01KB
	2CS042	Control Cable For 2AP05EP		2DG054	Control Cable For 2DG01KB and 2AP06ER
	2CS055	Control Cable For 2AP05EP and 2CS009A		2DG150	Control Cable For 2DG01KB
	2CS122	Control Cable For 2AP05EP		2DG201	Control Cable For 2DG01KB
2AP05ER	2AP056	Control Cable For 2AP05ER	2DO01PD	2DO009	Power Cable For 2DO01PD
2AP05ET	2AP311	Control Cable For 2AP05ET		2DO010	Control Cable For 2DO01PD
	2AP661	Control Cable For 2AP05ET	2FI-0121A	2CV139	Instrument Cable For 2FI-0121A and 2FI-0121B
2AP05EV	2SI001	Power Cable For 2AP05EV	2FI-0121B	2CV139	Instrument Cable For 2FI-0121A and 2FI-0121B
	2SI005	Control Cable For 2AP05EV	2LI-0460B	2RC406	Instrument Cable For 2LI-0460B
2AP07EE	2AP093	Power Cable For 2AP07EE	2LI-0502	2FW026	Instrument Cable For 2LI-0502
	2AP142	Control Cable For 2AP07EE	2LI-0503	2FW027	Instrument Cable For 2LI-0503
2AP14E	2AP376	Control Cable For 2AP14E	2LL-SI075B	2SI257	Control Cable For 2LL-SI075B
	2DC041	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2MS001A-DIV22	2MS273	Control Cable For 2MS001A-DIV22
	2DC042	Power Cable For 2AP14E, 2AP38E, and 2AP42E		2MS276	Control Cable For 2MS001A-DIV22
2AP21E	2AP143	Power Cable For 2AP21E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2AP21EA	2SI517	Control Cable For 2AP21EA		2MS525	Control Cable For 2MS001A-DIV22 and 2MS001C-DIV22
2AP22E	2AP147	Power Cable For 2AP22E		2MS530	Control Cable For 2MS001A-DIV22
2AP25E	2AP144	Power Cable For 2AP25E	2MS001B-DIV22	2MS289	Control Cable For 2MS001B-DIV22
2AP26E	2AP146	Power Cable For 2AP26E		2MS521	Control Cable For 2MS001B-DIV22 and 2MS001D-DIV22
2AP30E	2AP148	Power Cable For 2AP30E			
2AP38E	2DC041	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2MS001C-DIV22	2MS299	Control Cable For 2MS001C-DIV22
	2DC042	Power Cable For 2AP14E, 2AP38E, and 2AP42E		2MS523	Control Cable For 2MS001C-DIV22
2AP42E	2DC041	Power Cable For 2AP14E, 2AP38E, and 2AP42E		2MS525	Control Cable For 2MS001A-DIV22 and 2MS001C-DIV22
	2DC042	Power Cable For 2AP14E, 2AP38E, and 2AP42E	2MS001D-DIV22	2MS521	Control Cable For 2MS001B-DIV22 and 2MS001D-DIV22
2AP93E	2DC244	Control Cable For 2AP99E and 2AP93E		2MS528	Control Cable For 2MS001D-DIV22
2AP99E	2DC244	Control Cable For 2AP99E and 2AP93E		2MS533	Control Cable For 2MS001D-DIV22
2CC01PA	2CC001	Power Cable For 2CC01PA		2MS610	Control Cable For 2MS018B and 2MS018C
	2CC002	Control Cable For 2CC01PA	2MS018B	2MS612	Control Cable For 2MS018B and 2MS018C
	2CC003	Control Cable For 2CC01PA		2MS610	Control Cable For 2MS018B and 2MS018C
	2CC004	Control Cable For 2CC01PA	2MS018C	2MS612	Control Cable For 2MS018B and 2MS018C
	2CC006	Control Cable For 0CC01E-B and 2CC01PA		2MS628	Power Cable For 2MS018C
	2CC283	Control Cable For 2CC01PA		2MS320	Control Cable For 2MS101A
	2CC333	Control Cable For 2CC01PA	2MS101A	2MS325	Control Cable For 2MS101B
	2EF028	Control Cable For 2CC01PA	2MS101B	2MS330	Control Cable For 2MS101C
2CC9412A	2CC045	Control Cable For 2CC9412A	2MS101C	2MS335	Control Cable For 2MS101D
2CC9413A	2CC051	Control Cable For 2CC9413A	2MS101D	2RH611	Control Cable For 2RH611
2CC9415	2CC067	Control Cable For 2CC9415	2SI8801B	2SI037	Power Cable For 2SI8801B
2CC9416	2CC059	Control Cable For 2CC9416		2SI038	Control Cable For 2SI8801B
2CC9438	2CC036	Control Cable For 2CC9438		2SI039	Control Cable For 2SI8801B
2CC9473A	2CC127	Control Cable For 2CC9473A		2SI040	Control Cable For 2SI8801B
2CS009A	2CS055	Control Cable For 2AP05EP and 2CS009A		2SI085	Control Cable For 2SI8807B
	2CS079	Control Cable For 2CS009A	2SI8807B	2SI139	Control Cable For 2SI8809B
2CV01PA	2CV001	Power Cable For 2CV01PA	2SI8809B	2SI164	Control Cable For 2SI8811B
	2CV006	Control Cable For 2CV01PA	2SI8811B	2SI175	Control Cable For 2SI8812B
	2CV009	Control Cable For 2CV01PA	2SI8812B		
	2EF031	Control Cable For 2CV01PA and 2SX01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2CV112B	2CV065	Power Cable For 2CV112B	2SI8924	2SI472	Control Cable For 2SI8924
	2CV066	Control Cable For 2CV112B	2SX001B	2SX037	Control Cable For 2SX001B
	2CV067	Control Cable For 2CV112B	2SX005	2SX044	Control Cable For 2SX005
	2CV068	Control Cable For 2CV112B	2SX010	2SX092	Control Cable For 2SX010
	2CV069	Control Cable For 2CV112B	2SX011	2SX095	Control Cable For 2SX011
2CV112D	2CV079	Control Cable For 2CV112D	2SX01PB	2EF044	Control Cable For 2CV01PB and 2SX01PB
	2CV080	Control Cable For 2CV112D		2SX019	Control Cable For 2SX01PB
2CV8110	2CV059	Control Cable For 2CV8110	2SX01PB-C	2SX305	Control Cable For 2SX01PB-C
2CV8114	2CV645	Control Cable For 2CV8114		2SX314	Control Cable For 2SX01PB-C
2CV8355A	2CV611	Control Cable For 2CV8355A	2SX034	2SX068	Control Cable For 2SX034
2CV8355D	2CV614	Control Cable For 2CV8355D	2SX136	2SX083	Control Cable For 2SX136
2CV8804A	2CV407	Control Cable For 2CV8804A	2SX147B	2LV034	Control Cable For 2SX147B
	2CV413	Control Cable For 2CV8804A and 2RH8701A	2SX169B	2SX301	Control Cable For 2SX169B
	2CV468	Control Cable For 2CV8804A	2TI-IT002	2RC669	Control Cable For 2TI-IT002
	2SI454	Control Cable For 2CV8804A	2TI-RC005B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
2DC03E	2DC021	Power Cable For 2DC03E	2TI-RC006B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
2DG01KA	2DG153	Control Cable For 2DG01KA	2TI-RC007B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
	2DG154	Control Cable For 2DG01KA	2TI-RC008B	2RC613	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
	2DG157	Control Cable For 2DG01KA			
	2DG175	Control Cable For 2DG01KA			
2DO01PA	2DO002	Control Cable For 2DO01PA	2VD01CB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2DO01PC	2DO004	Power Cable For 2DO01PC	2VD01YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2DO005	Control Cable For 2DO01PC	2VD01YB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
2FI-SX031	2LV057	Control Cable For 2FI-SX031	2VD02YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2SX376	Instrument Cable For 2FI-SX031			
	2SX377	Instrument Cable For 2FI-SX031			
2IP01E	2IP004	Power Cable For 2IP01E			
2IP03E	2IP032	Power Cable For 2IP03E			
2IP05E	2IP002	Power Cable For 2IP05E			
2IP07E	2IP030	Power Cable For 2IP07E	2VE01Y	2VE033	Control Cable For 2VE01Y and 2VE02Y
2LI-0459A	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B	2VE02Y	2VE033	Control Cable For 2VE01Y and 2VE02Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2LI-0459B	2RC371	Instrument Cable For 2LI-0459B	2VP01CB	2VP038	Control Cable For 2VP01CB
	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B	2VP01CD	2VP082	Control Cable For 2VP01CD
2LI-0501	2FW025	Instrument Cable For 2LI-0501			
	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0501A	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0504	2FW028	Instrument Cable For 2LI-0504			
2LI-0930	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2LI-FW309	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2LI-FW310	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2LI-RY034	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2LL-SI075A	2SI234	Control Cable For 2LL-SI075A			
2MS001A-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
	2MS272	Control Cable For 2MS001A-DIV21			
	2MS275	Control Cable For 2MS001A-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001B-DIV21	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
	2MS285	Control Cable For 2MS001B-DIV21			
	2MS288	Control Cable For 2MS001B-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001C-DIV21	2AF121	Control Cable For 2MS001C-DIV21			
	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
	2MS298	Control Cable For 2MS001C-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS524	Control Cable For 2MS001C-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS001D-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
	2MS311	Control Cable For 2MS001D-DIV21			
	2MS527	Control Cable For 2MS001D-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS018A	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS581	Control Cable For 2MS018A and 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	2MS585	Control Cable For 2MS018A			
	2MS587	Power Cable For 2MS018A			
	2MS588	Instrument Cable For 2MS018A			
	2MS589	Instrument Cable For 2MS018A			
	2MS590	Instrument Cable For 2MS018A			
	2MS591	Instrument Cable For 2MS018A			
	2MS592	Instrument Cable For 2MS018A			
	2MS593	Instrument Cable For 2MS018A			
	2MS594	Power Cable For 2MS018A			
	2MS640	Instrument Cable For 2MS018A			
2MS018D	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS581	Control Cable For 2MS018A and 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS597	Control Cable For 2MS018D			
	2MS599	Power Cable For 2MS018D			
	2MS600	Instrument Cable For 2MS018D			
	2MS601	Instrument Cable For 2MS018D			
	2MS602	Instrument Cable For 2MS018D			
	2MS603	Instrument Cable For 2MS018D			
	2MS604	Instrument Cable For 2MS018D			
	2MS605	Instrument Cable For 2MS018D			
	2MS606	Power Cable For 2MS018D			
	2MS649	Instrument Cable For 2MS018D			
2MS101A	2MS321	Control Cable For 2MS101A			
2MS101B	2MS326	Control Cable For 2MS101B			
2MS101C	2MS331	Control Cable For 2MS101C			
2MS101D	2MS336	Control Cable For 2MS101D			
2NI-NR005B	2NR246	Instrument Cable For 2NI-NR005B			
2NI-NR005D	2NR297	Instrument Cable For 2NI-NR005D			
2PI-0405	2CV663	Instrument Cable For 2PI-0405			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2PI-0455A	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0455B	2RC370	Instrument Cable For 2PI-0455B			
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0514A	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
2PI-0514B	2MS099	Instrument Cable For 2PI-0514B			
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
2PI-0524A	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
2PI-0524B	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
	2MS103	Instrument Cable For 2PI-0524B			
2PI-0534A	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
2PI-0534B	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
	2MS107	Instrument Cable For 2PI-0534B			
2PI-0544A	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
2PI-0544B	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
	2MS111	Instrument Cable For 2PI-0544B			
2PI-CC107	2CC314	Control Cable For 2PI-CC107			
	2CC315	Instrument Cable For 2PI-CC107			
	2LV002	Control Cable For 2PI-CC107			
2PI-MS193	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2PI-MS194	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2PI-RY033	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2RC014A	2RC622	Control Cable For 2RC014A			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2RC014C	2RC628	Control Cable For 2RC014C			
2RH01PA	2RH001	Power Cable For 2RH01PA			
	2RH003	Control Cable For 2RH01PA			
	2RH091	Control Cable For 2RH01PA			
2RH610	2RH017	Control Cable For 2RH610			
2RH8701A	2CV413	Control Cable For 2CV8804A and 2RH8701A			
	2RH029	Control Cable For 2RH8701A and 2SI8811A			
	2RH030	Control Cable For 2RH8701A			
	2RH031	Control Cable For 2RH8701A			
	2SI168	Control Cable For 2RH8701A			
2RH8702A	2RH054	Control Cable For 2RH8702A			
	2RH055	Control Cable For 2RH8702A			
2RH8716A	2RH069	Control Cable For 2RH8716A			
2RY8000A	2RY394	Control Cable For 2RY8000A			
2SI8801A	2SI035	Control Cable For 2SI8801A			
2SI8806	2SI073	Control Cable For 2SI8806			
	2SI074	Control Cable For 2SI8806			
	2SI077	Control Cable For 2SI8806			
2SI8807A	2SI081	Control Cable For 2SI8807A			
2SI8809A	2SI134	Control Cable For 2SI8809A			
2SI8811A	2RH029	Control Cable For 2RH8701A and 2SI8811A			
	2SI152	Control Cable For 2SI8811A			
2SI8812A	2SI170	Control Cable For 2SI8812A			
2SI8840	2SI211	Control Cable For 2SI8840			
2SI8923A	2SI199	Control Cable For 2SI8923A			
2SX001A	2SX033	Control Cable For 2SX001A			
2SX004	2SX041	Control Cable For 2SX004			
2SX016A	2SX053	Control Cable For 2SX016A			
	2SX472	Control Cable For 2SX016A and 2SX027A			
2SX01PA	2EF031	Control Cable For 2CV01PA and 2SX01PA			
	2SX001	Power Cable For 2SX01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2SX01PA-C	2SX005	Control Cable For 2SX01PA			
	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX008	Control Cable For 2SX01PA			
	2SX034	Control Cable For 2SX01PA			
	2SX052	Control Cable For 2SX01PA			
	2SX058	Control Cable For 2SX01PA			
	2SX143	Control Cable For 2SX01PA			
	2SX208	Control Cable For 2SX01PA			
	2SX279	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX280	Control Cable For 2SX01PA			
2SX027A	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX278	Power Cable For 2SX01PA-C			
	2SX279	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX312	Control Cable For 2SX01PA-C			
2SX033	2SX313	Control Cable For 2SX01PA-C			
	2SX059	Control Cable For 2SX027A			
	2SX472	Control Cable For 2SX016A and 2SX027A			
2SX101A	2SX065	Control Cable For 2SX033			
	2AF002	Control Cable For 2SX101A			
2SX147A	2AF003	Control Cable For 2SX101A			
	2SX471	Control Cable For 2SX101A			
	2LV033	Control Cable For 2SX147A			
	2SX178	Control Cable For 2SX147A			
2TI-0413A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
2TI-0423A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
2TI-0433A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
2TI-0443A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
2TI-IT001	2IT275	Instrument Cable For 2TI-IT001			
	2IT276	Instrument Cable For 2TI-IT001			
	2IT277	Instrument Cable For 2TI-IT001			
	2IT278	Instrument Cable For 2TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	2IT279	Instrument Cable For 2TI-IT001			
	2IT280	Instrument Cable For 2TI-IT001			
	2IT281	Instrument Cable For 2TI-IT001			
	2IT282	Instrument Cable For 2TI-IT001			
	2IT283	Instrument Cable For 2TI-IT001			
	2IT284	Instrument Cable For 2TI-IT001			
	2IT285	Instrument Cable For 2TI-IT001			
	2IT286	Instrument Cable For 2TI-IT001			
	2IT287	Instrument Cable For 2TI-IT001			
	2IT288	Instrument Cable For 2TI-IT001			
	2IT289	Instrument Cable For 2TI-IT001			
	2IT290	Instrument Cable For 2TI-IT001			
	2IT291	Instrument Cable For 2TI-IT001			
	2IT292	Instrument Cable For 2TI-IT001			
	2IT293	Instrument Cable For 2TI-IT001			
	2IT294	Instrument Cable For 2TI-IT001			
	2IT295	Instrument Cable For 2TI-IT001			
	2IT296	Instrument Cable For 2TI-IT001			
	2IT297	Instrument Cable For 2TI-IT001			
	2IT298	Instrument Cable For 2TI-IT001			
	2IT299	Instrument Cable For 2TI-IT001			
	2IT300	Instrument Cable For 2TI-IT001			
	2IT301	Instrument Cable For 2TI-IT001			
	2IT302	Instrument Cable For 2TI-IT001			
	2IT303	Instrument Cable For 2TI-IT001			
	2IT304	Instrument Cable For 2TI-IT001			
	2IT305	Instrument Cable For 2TI-IT001			
	2IT306	Instrument Cable For 2TI-IT001			
	2IT307	Instrument Cable For 2TI-IT001			
	2IT345	Instrument Cable For 2TI-IT001			
	2IT346	Instrument Cable For 2TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	2IT424	Instrument Cable For 2TI-IT001			
	2RC648	Control Cable For 2TI-IT001			
2TI-RC005A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC006A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC007A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC008A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC022A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC022B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC023A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC023B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2TI-RC024A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC024B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC025A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2TI-RC025B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B			
2UL-AN012-A7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-B7	2AN166 2SI467	Control Cable For 2UL-AN012-B7 Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-C7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2VA01CA	2VA111 2VA166	Control Cable For 2VA01CA Control Cable For 2VA01CA and 2VA01CD			
2VA01CC	2VA192 2VA228	Power Cable For 2VA01CC Control Cable For 2VA01CC			
2VA01CD	2VA164 2VA165 2VA166	Power Cable For 2VA01CD Control Cable For 2VA01CD Control Cable For 2VA01CA and 2VA01CD			
2VA02CA	2VA104	Control Cable For 2VA02CA			
2VA02CB	2VA148	Power Cable For 2VA02CB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
	2VA149	Control Cable For 2VA02CB			
	2VA150	Control Cable For 2VA02CB			
2VA06CA	2VA053	Control Cable For 2VA06CA			
2VA06CB	2VA822	Control Cable For 2VA06CB			
2VD01CA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2VD10YB	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP003	Power Cable For 2VP01CA			
	2VP016	Control Cable For 2VP01CA			
	2VP019	Control Cable For 2VP01CA			
	2VP020	Control Cable For 2VP01CA			
	2VP021	Control Cable For 2VP01CA			
2VP01CC	2VP047	Power Cable For 2VP01CC			
	2VP060	Control Cable For 2VP01CC			
	2VP064	Control Cable For 2VP01CC			
	2VP065	Control Cable For 2VP01CC			
2VX04C	2VX001	Power Cable For 2VX04C			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
2VX04Y	2VE018	Control Cable For 2VX04Y and 2VX05Y			
	2VE031	Control Cable For 2VX04Y and 2VX05Y			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-0					
2VX05Y	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			
	2VE018	Control Cable For 2VX04Y and 2VX05Y			
	2VE031	Control Cable For 2VX04Y and 2VX05Y			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
Unit 0 (Common) Components					
-	0VA495Y	Unit 1 Division 12 Electrical Penetration Area Fire Damper	0VA01CB	1VA009	Power Cable For 0VA01CB
	0VA496Y	Unit 1 Division 12 Electrical Penetration Area Fire Damper	0VA02CB	1VA019	Power Cable For 0VA02CB
	0VA497Y	Unit 1 Division 12 Electrical Penetration Area Fire Damper	0VA475Y	1VA256	Control Cable For 0VA475Y
0VA01CA	1VA001	Power Cable For 0VA01CA		1VA546	Control Cable For 0VA475Y
0VA02CA	1VA016	Power Cable For 0VA02CA		1VA765	Control Cable For 0VA475Y
0VA474Y	1VA485	Control Cable For 0VA474Y		1VA766	Control Cable For 0VA475Y
				1VA767	Control Cable For 0VA475Y
				1VA768	Control Cable For 0VA475Y
				1VA769	Control Cable For 0VA475Y
				1VA771	Control Cable For 0VA475Y
				1VA796	Control Cable For 0VA475Y
Unit 1 Components					
-	1NI-NR005D	Ch A Post Accident Neutron Flux Indicator @ 1PL10J (1NR11E)	-	1AP27E	Division 12 480V ESF MCC 132X2
1LI-0459A	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034		1AP28E	Division 12 480V ESF MCC 132X4
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B		1LI-FW309	Loop 1A SG Wide Range Level Indicator @ 1PL10J (1LT-501)
1LI-0459B	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034		1LI-FW310	Loop 1B SG Wide Range Level Indicator @ 1PL10J (1LT-502)
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B		1LI-RY034	Pressurizer Level Indicator @ 1PL10J (1LT-459)
1LI-0501	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309		1NI-NR006D	Ch B Post Accident Neutron Flux Indicator @ 1PL10J (1NR13E)
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A		1PI-MS193	Loop 1A SG Pressure Indicator @ 1PL10J (1PT-0514)
1LI-0501A	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309		1PI-MS194	Loop 1B SG Pressure Indicator @ 1PL10J (1PT-0525)
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A		1PI-RY033	Pressurizer Pressure Indicator @ 1PL10J (1PT-455)
1LI-FW309	1FW918	Instrument Cable For 1LI-0501, 1LI-0501A, and 1LI-FW309		1TI-RC022A	Loop 1A Wide Range Hot Leg Temperature Indicator @ 1PL10J (1TE-RC022A)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B		1TI-RC022B	Loop 1A Wide Range Cold Leg Temperature Indicator @ 1PL10J (1TE-RC022B)
				1TI-RC023A	Loop 1B Wide Range Hot Leg Temperature Indicator @ 1PL10J (1TE-RC023A)
1LI-FW310	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B		1TI-RC023B	Loop 1B Wide Range Cold Leg Temperature Indicator @ 1PL10J (1TE-RC023B)
				1TI-RC024A	Loop 1C Wide Range Hot Leg Temperature Indicator @ 1PL10J (1TE-RC024A)
1LI-RY034	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B		1TI-RC024B	Loop 1C Wide Range Cold Leg Temperature Indicator @ 1PL10J (1TE-RC024B)
	1RY430	Instrument Cable For 1LI-0459A, 1LI-0459B, and 1LI-RY034		1TI-RC025A	Loop 1D Wide Range Hot Leg Temperature Indicator @ 1PL10J (1TE-RC025A)
1NI-0031B	1NR408	Instrument Cable For 1NI-0031B	1AF013E	1AF039	Control Cable For 1AF013E
	1NR409	Instrument Cable For 1NI-0031B	1AF013F	1AF044	Control Cable For 1AF013F
	1NR410	Instrument Cable For 1NI-0031B	1AF013G	1AF048	Control Cable For 1AF013G
	1NR411	Instrument Cable For 1NI-0031B	1AF013H	1AF052	Control Cable For 1AF013H
	1NR412	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D	1AF01PB	1AF289	Control Cable For 1AF01PB-C and 1AF01PB
1NI-NR005B	1NR412	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D	1AF01PB-C	1AF282	Power Cable For 1AF01PB-C
1NI-NR005D	1NR402	Instrument Cable For 1NI-NR005D		1AF283	Control Cable For 1AF01PB-C
	1NR412	Instrument Cable For 1NI-0031B, 1NI-NR005B, and 1NI-NR005D		1AF284	Control Cable For 1AF01PB-C
1PI-0455A	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033	1AP06EC	1SI008	Power Cable For 1AP06EC
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B	1AP06EH	1CS031	Control Cable For 1AP06EH
1PI-0455B	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033		1CS034	Control Cable For 1AP06EH
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B		1CS044	Control Cable For 1AP06EH
1PI-0514A	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193	1AP27E	1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
			1AP28E	1AP150	Power Cable For 1AP27E
			1CC685	1AP153	Power Cable For 1AP28E
				1CC041	Control Cable For 1CC685

TABLE 2.4-4 (Cont'd)

Division 11/21

Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1		
1PI-0514B	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B
	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193
1PI-MS193	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B
	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1PI-MS194	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193
	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1PI-RY033	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1RY455A	1RY431	Instrument Cable For 1PI-0455A, 1PI-0455B, and 1PI-RY033
	1RY486	Control Cable For 1RY455A
1TI-RC022A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1TI-RC022B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B

Division 12/22

Affected Equipment	Equipment In Zone	Equipment Description
1CS009B	1CC043	Control Cable For 1CC685
	1CS080	Control Cable For 1CS009B
1CV01PB	1CS113	Control Cable For 1CS009B
	1RH059	Control Cable For 1CS009B
1CV112C	1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
	1CV011	Power Cable For 1CV01PB
1CV112E	1CV075	Control Cable For 1CV112C
	1CV084	Control Cable For 1CV112C and 1CV112E
1CV8111	1CV082	Power Cable For 1CV112E
	1CV083	Control Cable For 1CV112E
1DO01PB	1CV084	Control Cable For 1CV112C and 1CV112E
	1CV085	Control Cable For 1CV112E
1IP06E	1CV062	Control Cable For 1CV8111
	1CV063	Control Cable For 1CV8111
1LI-0460A	1DO007	Control Cable For 1DO01PB
	1DO103	Power Cable For 1DO01PB
1LI-0460B	1IP018	Power Cable For 1IP06E
	1IP042	Power Cable For 1IP08E
1LI-0502	1RY204	Instrument Cable For 1LI-0460A and 1LI-0460B
	1FW920	Instrument Cable For 1LI-0460A and 1LI-0460B
1LI-0502A	1FW921	Instrument Cable For 1LI-0502, 1LI-0502A, and 1LI-FW310
	1FW920	Instrument Cable For 1LI-0502 and 1LI-0502A
1LI-0503	1FW921	Instrument Cable For 1LI-0502, 1LI-0502A, and 1LI-FW310
	1FW021	Instrument Cable For 1LI-0502 and 1LI-0502A
1LI-0503A	1FW021	Instrument Cable For 1LI-0503 and 1LI-0503A
	1FW021	Instrument Cable For 1LI-0503 and 1LI-0503A
1LI-0931	1SI468	Instrument Cable For 1LI-0931, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
	1SI470	Instrument Cable For 1LI-0933, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
1TI-RC023A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1LI-FW309	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1TI-RC023B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1LI-FW310	1FW920	Instrument Cable For 1LI-0502, 1LI-0502A, and 1LI-FW310
1TI-RC024A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B		1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1TI-RC024B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1LI-RY034	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
1TI-RC025A	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1LL-SI075B	1SI257	Control Cable For 1LL-SI075B
1TI-RC025B	1LV200	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B	1NI-0032B	1NR257	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR263	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR266	Instrument Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
			1NI-NR006B	1NR257	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR263	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR266	Instrument Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
			1NI-NR006D	1NR249	Instrument Cable For 1NI-NR006D
				1NR257	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR263	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR266	Instrument Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
				1NR298	Instrument Cable For 1NI-NR006D
	1PI-0403A			1CV673	Instrument Cable For 1PI-0403A
	1PI-0456			1RY202	Instrument Cable For 1PI-0456
	1PI-0458			1RY210	Instrument Cable For 1PI-0458
	1PI-0525A			1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
				1MS668	Instrument Cable For 1PI-0525A
	1PI-MS193			1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
	1PI-MS194			1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
	1PI-RY033			1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
	1RC014B			1RC625	Control Cable For 1RC014B
	1RC014D			1RC631	Control Cable For 1RC014D
	1RH8701B			1RH032	Power Cable For 1RH8701B
				1RH034	Control Cable For 1RH8701B
				1RH038	Control Cable For 1RH8701B
				1RH039	Control Cable For 1RH8701B
				1RH040	Control Cable For 1RH8701B
				1RH042	Control Cable For 1RH8701B
				1RH043	Control Cable For 1RH8701B
	1RH8702B			1RH056	Power Cable For 1RH8702B
				1RH058	Control Cable For 1RH8702B and 1SI8804B
				1RH062	Control Cable For 1RH8702B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
				1RH063	Control Cable For 1RH8702B and 1SI8804B
				1RH064	Control Cable For 1RH8702B
				1RH065	Control Cable For 1RH8702B
				1SI062	Control Cable For 1RH8702B and 1SI8812B
				1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
				1SI173	Control Cable For 1RH8702B, 1SI8811B, and 1SI8812B
				1SI174	Control Cable For 1RH8702B
	1RH8716B			1RH070	Power Cable For 1RH8716B
				1RH071	Control Cable For 1RH8716B
				1RH072	Control Cable For 1RH8716B
				1RH073	Control Cable For 1RH8716B
	1RY456			1RY487	Control Cable For 1RY456
	1RY8000B			1RY395	Control Cable For 1RY8000B
				1RY396	Power Cable For 1RY8000B
				1RY397	Control Cable For 1RY8000B
	1SI8804B			1RH058	Control Cable For 1RH8702B and 1SI8804B
				1RH063	Control Cable For 1RH8702B and 1SI8804B
				1SI063	Control Cable For 1SI8804B
				1SI066	Control Cable For 1SI8804B
				1SI067	Control Cable For 1SI8804B
				1SI068	Control Cable For 1SI8804B
				1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
				1SI177	Control Cable For 1SI8804B
	1SI8809B			1SI139	Control Cable For 1SI8809B
	1SI8811B			1CS050	Control Cable For 1SI8811B
				1SI156	Control Cable For 1SI8811B
				1SI162	Control Cable For 1SI8811B
				1SI164	Control Cable For 1SI8811B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
				1SI173	Control Cable For 1RH8702B, 1SI8811B, and 1SI8812B
	1SI8812B			1SI062	Control Cable For 1RH8702B and 1SI8812B
				1SI155	Control Cable For 1AP06EH, 1CS009B, 1RH8702B, 1SI8804B, and 1SI8812B
				1SI171	Power Cable For 1SI8812B
				1SI172	Control Cable For 1SI8812B
				1SI173	Control Cable For 1RH8702B, 1SI8811B, and 1SI8812B
				1SI175	Control Cable For 1SI8812B
	1SX016B			1SX056	Control Cable For 1SX016B
				1SX474	Control Cable For 1SX016B and 1SX027B
	1SX01PB			1SX055	Control Cable For 1SX01PB
				1SX061	Control Cable For 1SX01PB
				1SX209	Control Cable For 1SX01PB
	1SX027B			1SX062	Control Cable For 1SX027B
				1SX474	Control Cable For 1SX016B and 1SX027B
	1SX147B			1SX191	Control Cable For 1SX147B
	1TI-0413B			1RC372	Instrument Cable For 1TI-0413B and 1TI-RC005B
	1TI-0423B			1RC391	Instrument Cable For 1TI-0423B and 1TI-RC006B
	1TI-0433B			1RC396	Instrument Cable For 1TI-0433B and 1TI-RC007B
	1TI-0443B			1RC401	Instrument Cable For 1TI-0443B and 1TI-RC008B
	1TI-0605			1RH147	Instrument Cable For 1TI-0605
	1TI-IT002			1IT349	Instrument Cable For 1TI-IT002
				1IT350	Instrument Cable For 1TI-IT002
				1IT383	Instrument Cable For 1TI-IT002
				1IT384	Instrument Cable For 1TI-IT002
				1IT385	Instrument Cable For 1TI-IT002
				1IT386	Instrument Cable For 1TI-IT002
				1IT387	Instrument Cable For 1TI-IT002
				1IT388	Instrument Cable For 1TI-IT002
				1IT389	Instrument Cable For 1TI-IT002

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
				1IT390	Instrument Cable For 1TI-IT002
				1IT391	Instrument Cable For 1TI-IT002
				1IT392	Instrument Cable For 1TI-IT002
				1IT393	Instrument Cable For 1TI-IT002
				1IT394	Instrument Cable For 1TI-IT002
				1IT395	Instrument Cable For 1TI-IT002
				1IT396	Instrument Cable For 1TI-IT002
				1IT397	Instrument Cable For 1TI-IT002
				1IT398	Instrument Cable For 1TI-IT002
				1IT399	Instrument Cable For 1TI-IT002
				1IT400	Instrument Cable For 1TI-IT002
				1IT401	Instrument Cable For 1TI-IT002
				1IT402	Instrument Cable For 1TI-IT002
				1IT403	Instrument Cable For 1TI-IT002
				1IT404	Instrument Cable For 1TI-IT002
				1IT405	Instrument Cable For 1TI-IT002
				1IT406	Instrument Cable For 1TI-IT002
				1IT407	Instrument Cable For 1TI-IT002
				1IT408	Instrument Cable For 1TI-IT002
				1IT409	Instrument Cable For 1TI-IT002
				1IT410	Instrument Cable For 1TI-IT002
				1IT411	Instrument Cable For 1TI-IT002
				1IT412	Instrument Cable For 1TI-IT002
				1IT413	Instrument Cable For 1TI-IT002
				1IT414	Instrument Cable For 1TI-IT002
				1IT426	Instrument Cable For 1TI-IT002
			1TI-RC005B	1RC372	Instrument Cable For 1TI-0413B and 1TI-RC005B
			1TI-RC006B	1RC391	Instrument Cable For 1TI-0423B and 1TI-RC006B
			1TI-RC007B	1RC396	Instrument Cable For 1TI-0433B and 1TI-RC007B
			1TI-RC008B	1RC401	Instrument Cable For 1TI-0443B and 1TI-RC008B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1			1TI-RC022A	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC776	Instrument Cable For 1TI-RC022A
			1TI-RC022B	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC752	Instrument Cable For 1TI-RC022B
			1TI-RC023A	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC777	Instrument Cable For 1TI-RC023A
			1TI-RC023B	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC754	Instrument Cable For 1TI-RC023B
			1TI-RC024A	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC778	Instrument Cable For 1TI-RC024A
			1TI-RC024B	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC756	Instrument Cable For 1TI-RC024B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1			1TI-RC025A	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC779	Instrument Cable For 1TI-RC025A
			1TI-RC025B	1LV085	Control Cable For 1LI-FW309, 1LI-FW310, 1LI-RY034, 1PI-MS193, 1PI-MS194, 1PI-RY033, 1TI-RC022A, 1TI-RC022B, 1TI-RC023A, 1TI-RC023B, 1TI-RC024A, 1TI-RC024B, 1TI-RC025A, and 1TI-RC025B
				1RC758	Instrument Cable For 1TI-RC025B
			1UL-AN012-A7	1SI468	Instrument Cable For 1LI-0931, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
				1SI470	Instrument Cable For 1LI-0933, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
			1UL-AN012-B7	1SI468	Instrument Cable For 1LI-0931, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
				1SI470	Instrument Cable For 1LI-0933, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
			1UL-AN012-C7	1SI468	Instrument Cable For 1LI-0931, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
				1SI470	Instrument Cable For 1LI-0933, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7
			1VA02CD	1VA152	Power Cable For 1VA02CD
				1VA153	Control Cable For 1VA02CD
				1VA154	Control Cable For 1VA02CD
			1VD01YA	1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD01YB	1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD02YA	1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD02YB	1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VE01C	1VE006	Power Cable For 1VE01C

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-1					
				1VE008	Control Cable For 1VE01C, 1VE01Y, and 1VE02Y
			1VE01Y	1VE008	Control Cable For 1VE01C, 1VE01Y, and 1VE02Y
				1VE014	Control Cable For 1VE01Y and 1VE02Y
			1VE02Y	1VE008	Control Cable For 1VE01C, 1VE01Y, and 1VE02Y
				1VE014	Control Cable For 1VE01Y and 1VE02Y
			1VP01CB	1VP025	Power Cable For 1VP01CB
			1VP01CD	1VP069	Power Cable For 1VP01CD
			1VX01C	1VX105	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX113	Power Cable For 1VX01C
			1VX01Y	1VX038	Control Cable For 1VX01Y and 1VX02Y
				1VX105	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
			1VX02Y	1VX038	Control Cable For 1VX01Y and 1VX02Y
				1VX105	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
Unit 2 Components					
NONE				NONE	

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
2LI-FW309	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A		2TI-RC022B	Loop 2A Wide Range Cold Leg Temperature Indicator @ 2PL10J (2TE-RC022B)
	2FW918	Instrument Cable For 2LI-0501, 2LI-0501A, and 2LI-FW309		2TI-RC023A	Loop 2B Wide Range Hot Leg Temperature Indicator @ 2PL10J (2TE-RC023A)
	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B		2TI-RC023B	Loop 2B Wide Range Cold Leg Temperature Indicator @ 2PL10J (2TE-RC023B)
2LI-FW310	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B		2TI-RC024A	Loop 2C Wide Range Hot Leg Temperature Indicator @ 2PL10J (2TE-RC024A)
				2TI-RC024B	Loop 2C Wide Range Cold Leg Temperature Indicator @ 2PL10J (2TE-RC024B)
2LI-RY034	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B		2TI-RC025A	Loop 2D Wide Range Hot Leg Temperature Indicator @ 2PL10J (2TE-RC025A)
	2RY430	Instrument Cable For 2LI-0459A, 2LI-0459B, and 2LI-RY034		2TI-RC025B	Loop 2D Wide Range Cold Leg Temperature Indicator @ 2PL10J (2TE-RC025B)
2NI-0031B	2NR408	Instrument Cable For 2NI-0031B	2AF013E	2AF039	Control Cable For 2AF013E
	2NR409	Instrument Cable For 2NI-0031B	2AF013F	2AF044	Control Cable For 2AF013F
	2NR410	Instrument Cable For 2NI-0031B	2AF013G	2AF048	Control Cable For 2AF013G
	2NR411	Instrument Cable For 2NI-0031B	2AF013H	2AF052	Control Cable For 2AF013H
	2NR412	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D	2AF01PB	2AF289	Control Cable For 2AF01PB-C and 2AF01PB
2NI-NR005B	2NR412	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D	2AF01PB-C	2AF282	Power Cable For 2AF01PB-C
				2AF283	Control Cable For 2AF01PB-C
2NI-NR005D	2NR402	Instrument Cable For 2NI-NR005D		2AF284	Control Cable For 2AF01PB-C
	2NR412	Instrument Cable For 2NI-0031B, 2NI-NR005B, and 2NI-NR005D	2AP06EP	2AF289	Control Cable For 2AF01PB-C and 2AF01PB
2PI-0455A	2RY431	Instrument Cable For 2PI-0455A, 2PI-0455B, and 2PI-RY033		2AF291	Control Cable For 2AF01PB-C
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B		2AF292	Control Cable For 2AF01PB-C
2PI-0455B	2RY431	Instrument Cable For 2PI-0455A, 2PI-0455B, and 2PI-RY033		2CS018	Power Cable For 2AP06EP
			2AP06EU	2CS020	Control Cable For 2AP06EP
				2CS031	Control Cable For 2AP06EP
				2CS034	Control Cable For 2AP06EP
				2CS043	Control Cable For 2AP06EP
				2CS044	Control Cable For 2AP06EP
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI008	Power Cable For 2AP06EU

TABLE 2.4-4 (Cont 'd)

Division 11/21

Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2		
2PI-0514A	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B
	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193
2PI-0514B	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B
	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193
2PI-MS193	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B
	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
2PI-MS194	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193
	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
2PI-RY033	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
	2RY431	Instrument Cable For 2PI-0455A, 2PI-0455B, and 2PI-RY033
2RY455A	2RY486	Control Cable For 2RY455A
2TI-RC022A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
2TI-RC022B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B

Division 12/22

Affected Equipment	Equipment In Zone	Equipment Description
2AP27E	2AP150	Power Cable For 2AP27E
2AP28E	2AP153	Power Cable For 2AP28E
2CC01PB	2CC010	Power Cable For 2CC01PB
2CC685	2CC041	Control Cable For 2CC685
2CS009B	2CC043	Control Cable For 2CC685
	2CS080	Control Cable For 2CS009B
	2CS113	Control Cable For 2CS009B
2CV01PB	2RH059	Control Cable For 2CS009B
	2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
	2CV011	Power Cable For 2CV01PB
2CV112C	2CV075	Control Cable For 2CV112C
2CV112E	2CV084	Control Cable For 2CV112C and 2CV112E
	2CV082	Power Cable For 2CV112E
	2CV083	Control Cable For 2CV112E
2CV8111	2CV084	Control Cable For 2CV112C and 2CV112E
	2CV085	Control Cable For 2CV112E
	2CV062	Control Cable For 2CV8111
2DO01PB	2CV063	Control Cable For 2CV8111
	2DO006	Power Cable For 2DO01PB
	2DO007	Control Cable For 2DO01PB
2IP06E	2DO203	Power Cable For 2DO01PB
	2IP018	Power Cable For 2IP06E
	2IP042	Power Cable For 2IP08E
2LI-0460A	2RY204	Instrument Cable For 2LI-0460A and 2LI-0460B
2LI-0460B	2RY204	Instrument Cable For 2LI-0460A and 2LI-0460B
2LI-0502	2FW920	Instrument Cable For 2LI-0502, 2LI-0502A, and 2LI-FW310
2LI-0502A	2FW921	Instrument Cable For 2LI-0502 and 2LI-0502A
	2FW920	Instrument Cable For 2LI-0502, 2LI-0502A, and 2LI-FW310
	2FW921	Instrument Cable For 2LI-0502 and 2LI-0502A

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
2TI-RC023A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B	2LI-0503	2FW021	Instrument Cable For 2LI-0503 and 2LI-0503A
			2LI-0503A	2FW021	Instrument Cable For 2LI-0503 and 2LI-0503A
			2LI-0931	2SI468	Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
2TI-RC023B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B	2LI-0933	2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
			2LI-FW309	2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
2TI-RC024A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B	2LI-FW310	2FW920	Instrument Cable For 2LI-0502, 2LI-0502A, and 2LI-FW310
				2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
2TI-RC024B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B	2LI-RY034	2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
2TI-RC025A	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B	2LL-SI075B	2SI257	Control Cable For 2LL-SI075B
			2MS018B	2MS616	Power Cable For 2MS018B
2TI-RC025B	2LV200	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B		2MS617	Instrument Cable For 2MS018B
				2MS618	Instrument Cable For 2MS018B
2VA06CB	2VA822	Control Cable For 2VA06CB		2MS619	Instrument Cable For 2MS018B
				2MS620	Instrument Cable For 2MS018B
				2MS621	Instrument Cable For 2MS018B
				2MS622	Instrument Cable For 2MS018B
				2MS623	Power Cable For 2MS018B
			2MS018C	2MS628	Power Cable For 2MS018C
				2MS629	Instrument Cable For 2MS018C
				2MS630	Instrument Cable For 2MS018C

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
				2MS631	Instrument Cable For 2MS018C
				2MS632	Instrument Cable For 2MS018C
				2MS633	Instrument Cable For 2MS018C
				2MS634	Instrument Cable For 2MS018C
				2MS635	Power Cable For 2MS018C
			2NI-0032B	2NR257	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR258	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR259	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR260	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR261	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR263	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR266	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR413	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR418	Instrument Cable For 2NI-0032B
				2NR419	Instrument Cable For 2NI-0032B
				2NR420	Instrument Cable For 2NI-0032B
				2NR421	Instrument Cable For 2NI-0032B
				2NR422	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
			2NI-NR006B	2NR257	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR258	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR259	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR260	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
				2NR261	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR263	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR264	Instrument Cable For 2NI-NR006B
				2NR266	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR413	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR414	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR415	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR416	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR417	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR422	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
			2NI-NR006D	2NR249	Instrument Cable For 2NI-NR006D
				2NR257	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR258	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR259	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR260	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR261	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR263	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR266	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR298	Instrument Cable For 2NI-NR006D

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2				2NR413	Control Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
				2NR414	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR415	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR416	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR417	Instrument Cable For 2NI-NR006B and 2NI-NR006D
				2NR422	Instrument Cable For 2NI-0032B, 2NI-NR006B, and 2NI-NR006D
	2PI-0403A			2CV673	Instrument Cable For 2PI-0403A
	2PI-0456			2RY202	Instrument Cable For 2PI-0456
	2PI-0458			2RY210	Instrument Cable For 2PI-0458
	2PI-0525A			2MS667	Instrument Cable For 2PI-0525A and 2PI-MS194
				2MS668	Instrument Cable For 2PI-0525A
	2PI-MS193			2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2MS667	Instrument Cable For 2PI-0525A and 2PI-MS194
	2PI-RY033			2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC625	Control Cable For 2RC014B
	2RC014B			2RC631	Control Cable For 2RC014D
	2RC014D			2RH008	Power Cable For 2RH01PB
	2RH01PB				

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2			2RH8701B	2RH032	Power Cable For 2RH8701B
				2RH034	Control Cable For 2RH8701B
				2RH038	Control Cable For 2RH8701B
				2RH039	Control Cable For 2RH8701B
				2RH040	Control Cable For 2RH8701B
				2RH042	Control Cable For 2RH8701B
				2RH043	Control Cable For 2RH8701B
			2RH8702B	2RH056	Power Cable For 2RH8702B
				2RH058	Control Cable For 2RH8702B and 2SI8804B
				2RH062	Control Cable For 2RH8702B
				2RH063	Control Cable For 2RH8702B and 2SI8804B
				2RH064	Control Cable For 2RH8702B
				2RH065	Control Cable For 2RH8702B
				2SI062	Control Cable For 2RH8702B and 2SI8812B
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI173	Control Cable For 2RH8702B, 2SI8811B, and 2SI8812B
				2SI174	Control Cable For 2RH8702B
			2RH8716B	2RH070	Power Cable For 2RH8716B
				2RH071	Control Cable For 2RH8716B
				2RH072	Control Cable For 2RH8716B
				2RH073	Control Cable For 2RH8716B
			2RY456	2RY487	Control Cable For 2RY456
			2RY8000B	2RY395	Control Cable For 2RY8000B
				2RY396	Power Cable For 2RY8000B
				2RY397	Control Cable For 2RY8000B
			2SI8804B	2RH058	Control Cable For 2RH8702B and 2SI8804B
				2RH063	Control Cable For 2RH8702B and 2SI8804B
				2SI063	Control Cable For 2SI8804B
				2SI066	Control Cable For 2SI8804B
				2SI067	Control Cable For 2SI8804B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
				2SI068	Control Cable For 2SI8804B
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI177	Control Cable For 2SI8804B
	2SI8809B			2SI139	Control Cable For 2SI8809B
	2SI8811B			2CS050	Control Cable For 2SI8811B
				2SI156	Control Cable For 2SI8811B
				2SI162	Control Cable For 2SI8811B
				2SI164	Control Cable For 2SI8811B
				2SI173	Control Cable For 2RH8702B, 2SI8811B, and 2SI8812B
	2SI8812B			2SI062	Control Cable For 2RH8702B and 2SI8812B
				2SI155	Control Cable For 2AP06EP, 2CS009B, 2RH8702B, 2SI8804B, and 2SI8812B
				2SI171	Power Cable For 2SI8812B
				2SI172	Control Cable For 2SI8812B
				2SI173	Control Cable For 2RH8702B, 2SI8811B, and 2SI8812B
				2SI175	Control Cable For 2SI8812B
	2SX016B			2SX056	Control Cable For 2SX016B
				2SX474	Control Cable For 2SX016B and 2SX027B
	2SX01PB			2SX012	Power Cable For 2SX01PB
				2SX055	Control Cable For 2SX01PB
				2SX061	Control Cable For 2SX01PB
				2SX209	Control Cable For 2SX01PB
	2SX027B			2SX062	Control Cable For 2SX027B
				2SX474	Control Cable For 2SX016B and 2SX027B
	2SX147B			2SX191	Control Cable For 2SX147B
	2TI-0413B			2RC372	Instrument Cable For 2TI-0413B and 2TI-RC005B
	2TI-0423B			2RC391	Instrument Cable For 2TI-0423B and 2TI-RC006B
	2TI-0433B			2RC396	Instrument Cable For 2TI-0433B and 2TI-RC007B
	2TI-0443B			2RC401	Instrument Cable For 2TI-0443B and 2TI-RC008B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2			2TI-0605	2RH147	Instrument Cable For 2TI-0605
			2TI-IT002	2IT349	Instrument Cable For 2TI-IT002
				2IT350	Instrument Cable For 2TI-IT002
				2IT383	Instrument Cable For 2TI-IT002
				2IT384	Instrument Cable For 2TI-IT002
				2IT385	Instrument Cable For 2TI-IT002
				2IT386	Instrument Cable For 2TI-IT002
				2IT387	Instrument Cable For 2TI-IT002
				2IT388	Instrument Cable For 2TI-IT002
				2IT389	Instrument Cable For 2TI-IT002
				2IT390	Instrument Cable For 2TI-IT002
				2IT391	Instrument Cable For 2TI-IT002
				2IT392	Instrument Cable For 2TI-IT002
				2IT393	Instrument Cable For 2TI-IT002
				2IT394	Instrument Cable For 2TI-IT002
				2IT395	Instrument Cable For 2TI-IT002
				2IT396	Instrument Cable For 2TI-IT002
				2IT397	Instrument Cable For 2TI-IT002
				2IT398	Instrument Cable For 2TI-IT002
				2IT399	Instrument Cable For 2TI-IT002
				2IT400	Instrument Cable For 2TI-IT002
				2IT401	Instrument Cable For 2TI-IT002
				2IT402	Instrument Cable For 2TI-IT002
				2IT403	Instrument Cable For 2TI-IT002
				2IT404	Instrument Cable For 2TI-IT002
				2IT405	Instrument Cable For 2TI-IT002
				2IT406	Instrument Cable For 2TI-IT002
				2IT407	Instrument Cable For 2TI-IT002
				2IT408	Instrument Cable For 2TI-IT002
				2IT409	Instrument Cable For 2TI-IT002
				2IT410	Instrument Cable For 2TI-IT002

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
				2IT411	Instrument Cable For 2TI-IT002
				2IT412	Instrument Cable For 2TI-IT002
				2IT413	Instrument Cable For 2TI-IT002
				2IT414	Instrument Cable For 2TI-IT002
				2IT426	Instrument Cable For 2TI-IT002
	2TI-RC005B			2RC372	Instrument Cable For 2TI-0413B and 2TI-RC005B
	2TI-RC006B			2RC391	Instrument Cable For 2TI-0423B and 2TI-RC006B
	2TI-RC007B			2RC396	Instrument Cable For 2TI-0433B and 2TI-RC007B
	2TI-RC008B			2RC401	Instrument Cable For 2TI-0443B and 2TI-RC008B
	2TI-RC022A			2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC744	Instrument Cable For 2TI-RC022A
	2TI-RC022B			2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC752	Instrument Cable For 2TI-RC022B
	2TI-RC023A			2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC746	Instrument Cable For 2TI-RC023A
	2TI-RC023B			2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC754	Instrument Cable For 2TI-RC023B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2			2TI-RC024A	2LV085	Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC748	Instrument Cable For 2TI-RC024A
	2TI-RC024B		2LV085		Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC756	Instrument Cable For 2TI-RC024B
	2TI-RC025A		2LV085		Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC750	Instrument Cable For 2TI-RC025A
	2TI-RC025B		2LV085		Control Cable For 2LI-FW309, 2LI-FW310, 2LI-RY034, 2PI-MS193, 2PI-MS194, 2PI-RY033, 2TI-RC022A, 2TI-RC022B, 2TI-RC023A, 2TI-RC023B, 2TI-RC024A, 2TI-RC024B, 2TI-RC025A, and 2TI-RC025B
				2RC758	Instrument Cable For 2TI-RC025B
	2UL-AN012-A7		2SI468		Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
				2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
	2UL-AN012-B7		2SI468		Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
				2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
	2UL-AN012-C7		2SI468		Instrument Cable For 2LI-0931, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
				2SI470	Instrument Cable For 2LI-0933, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7
	2VA02CD		2VA152		Power Cable For 2VA02CD

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6-2					
				2VA153	Control Cable For 2VA02CD
				2VA154	Control Cable For 2VA02CD
	2VD01YA			2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VD01YB			2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VD02YA			2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VD02YB			2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VE01C			2VE006	Power Cable For 2VE01C
				2VE008	Control Cable For 2VE01C, 2VE01Y, and 2VE02Y
	2VE01Y			2VE008	Control Cable For 2VE01C, 2VE01Y, and 2VE02Y
				2VE014	Control Cable For 2VE01Y and 2VE02Y
				2VE022	Control Cable For 2VE01Y and 2VE02Y
	2VE02Y			2VE008	Control Cable For 2VE01C, 2VE01Y, and 2VE02Y
				2VE014	Control Cable For 2VE01Y and 2VE02Y
				2VE022	Control Cable For 2VE01Y and 2VE02Y
	2VP01CB			2VP025	Power Cable For 2VP01CB
	2VP01CD			2VP069	Power Cable For 2VP01CD
	2VX01C			2VX113	Power Cable For 2VX01C
				2VX114	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
	2VX01Y			2VX038	Control Cable For 2VX01Y and 2VX02Y
				2VX114	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
	2VX02Y			2VX038	Control Cable For 2VX01Y and 2VX02Y
				2VX114	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6A-0					
Unit 0 (Common) Components			NONE		
0CC01E-A	1CC019	Power Cable For 0CC01E-A			
0VC01CA	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC02CA	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC033Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC157	Control Cable For 0VC033Y and 0VC281Y			
	1VC571	Control Cable For 0VC033Y and 0VC281Y			
0VC043Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC159	Control Cable For 0VC043Y			
	1VC573	Control Cable For 0VC043Y			
0VC094Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC095Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC133Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6A-0					
0VC17Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC18Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC19Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC20Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC281Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC157	Control Cable For 0VC033Y and 0VC281Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6A-1					
Unit 0 (Common) Components					
NONE			0VA01CB	1VA010	Control Cable For 0VA01CB
				1VA011	Control Cable For 0VA01CB
				1VA023	Control Cable For 0VA01CB and 0VA02CB
				1VA037	Control Cable For 0VA01CB and 0VA475Y
			0VA02CB	1VA020	Control Cable For 0VA02CB
				1VA023	Control Cable For 0VA01CB and 0VA02CB
				1VA033	Control Cable For 0VA02CB and 0VA475Y
				1VA799	Control Cable For 0VA02CB
			0VA475Y	1VA024	Control Cable For 0VA475Y
				1VA025	Control Cable For 0VA475Y
				1VA031	Control Cable For 0VA475Y
				1VA033	Control Cable For 0VA02CB and 0VA475Y
				1VA035	Control Cable For 0VA475Y
				1VA037	Control Cable For 0VA01CB and 0VA475Y
				1VA129	Control Cable For 0VA475Y
				1VA794	Control Cable For 0VA475Y
Unit 1 Components					
-	1CV112B	VCT Outlet Isolation Valve (MO)	-	1CV112C	VCT Outlet Isolation Valve (MO)
1CV112B	1CV065	Power Cable For 1CV112B		1CV8104	Emergency Boration Valve (MO)
	1CV066	Control Cable For 1CV112B	1CV112C	1CV071	Power Cable For 1CV112C
				1CV072	Control Cable For 1CV112C
			1CV8104	1CV615	Control Cable For 1CV8104
				1CV616	Power Cable For 1CV8104
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6A-2					
Unit 0 (Common) Components					
NONE			0VA477Y	2VA032	Control Cable For 0VA477Y
				2VA765	Control Cable For 0VA477Y
				2VA766	Control Cable For 0VA477Y
				2VA767	Control Cable For 0VA477Y
				2VA768	Control Cable For 0VA477Y
				2VA769	Control Cable For 0VA477Y
				2VA771	Control Cable For 0VA477Y
				2VA796	Control Cable For 0VA477Y
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2CV112B	VCT Outlet Isolation Valve (MO)	-	2CV112C	VCT Outlet Isolation Valve (MO)
2CV112B	2CV065	Power Cable For 2CV112B		2CV8104	Emergency Boration Valve (MO)
	2CV066	Control Cable For 2CV112B	2CV112C	2CV071	Power Cable For 2CV112C
				2CV072	Control Cable For 2CV112C
			2CV8104	2CV615	Control Cable For 2CV8104
				2CV616	Power Cable For 2CV8104

TABLE 2.4-4 (Cont'd)

Division 11/21

Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6B-0		
Unit 0 (Common) Components		
0CC01E-B	2CC019	Power Cable For 0CC01E-B
	2CC022	Control Cable For 0CC01E-B
	2CC025	Control Cable For 0CC01E-B
	2CC106	Control Cable For 0CC01E-B
	2CC174	Control Cable For 0CC01E-B
	2CC276	Control Cable For 0CC01E-B
0SX162C	2SX158	Control Cable For 0SX162C
0VA01CC	2VA002	Control Cable For 0VA01CC
0VA02CC	2VA017	Control Cable For 0VA02CC
Unit 1 Components		
NONE		
Unit 2 Components		
2AF005A	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21
2AF005B	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21
2AF005C	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21
2AF005D	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21
2AF006A	2AF057	Control Cable For 2AF006A and 2AF017A
	2AF058	Control Cable For 2AF006A

Division 12/22

Affected Equipment	Equipment In Zone	Equipment Description
NONE		
NONE		
2MS001D-DIV22	2MS312	Control Cable For 2MS001D-DIV22

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6B-0					
2AF017A	2AF295	Control Cable For 2AF006A and 2AF017A			
	2AF057	Control Cable For 2AF006A and 2AF017A			
	2AF097	Control Cable For 2AF017A			
2AF01PA	2AF295	Control Cable For 2AF006A and 2AF017A			
	2AF001	Power Cable For 2AF01PA			
	2AF006	Control Cable For 2AF01PA			
2AF01PA-A	2AF007	Control Cable For 2AF01PA			
	2AF004	Control Cable For 2AF01PA-A			
	2AF014	Control Cable For 2AF01PA-A			
2AF022A	2AF257	Control Cable For 2AF022A			
	2AF258	Control Cable For 2AF022A			
2AP05EP	2CS004	Control Cable For 2AP05EP			
2AP05ET	2AP661	Control Cable For 2AP05ET			
2AP22E	2AP147	Power Cable For 2AP22E			
2AP30E	2AP148	Power Cable For 2AP30E			
2CC01PA	2CC001	Power Cable For 2CC01PA			
	2CC003	Control Cable For 2CC01PA			
2CC9415	2CC067	Control Cable For 2CC9415			
2CC9473A	2CC127	Control Cable For 2CC9473A			
2CV01PA	2CV006	Control Cable For 2CV01PA			
2DO01PA	2DO002	Control Cable For 2DO01PA			
2DO01PC	2DO004	Power Cable For 2DO01PC			
	2DO005	Control Cable For 2DO01PC			
2IP03E	2IP032	Power Cable For 2IP03E			
2MS001A-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2MS001B-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6B-0					
2MS001C-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2MS001D-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2RH01PA	2RH003	Control Cable For 2RH01PA			
	2RH091	Control Cable For 2RH01PA			
2RH8701A	2RH029	Control Cable For 2RH8701A and 2SI8811A			
2SI8811A	2RH029	Control Cable For 2RH8701A and 2SI8811A			
2SX001A	2SX033	Control Cable For 2SX001A			
2SX016A	2SX472	Control Cable For 2SX016A and 2SX027A			
2SX01PA	2SX001	Power Cable For 2SX01PA			
	2SX005	Control Cable For 2SX01PA			
	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX034	Control Cable For 2SX01PA			
	2SX143	Control Cable For 2SX01PA			
	2SX279	Control Cable For 2SX01PA-C and 2SX01PA			
2SX01PA-C	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX278	Power Cable For 2SX01PA-C			
	2SX279	Control Cable For 2SX01PA-C and 2SX01PA			
2SX027A	2SX472	Control Cable For 2SX016A and 2SX027A			
2SX101A	2AF002	Control Cable For 2SX101A			
	2AF003	Control Cable For 2SX101A			
	2SX471	Control Cable For 2SX101A			
2VA01CA	2VA111	Control Cable For 2VA01CA			
	2VA166	Control Cable For 2VA01CA and 2VA01CD			
2VA01CC	2VA192	Power Cable For 2VA01CC			
	2VA228	Control Cable For 2VA01CC			
2VA01CD	2VA164	Power Cable For 2VA01CD			
	2VA166	Control Cable For 2VA01CA and 2VA01CD			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6B-0					
2VA02CB	2VA148	Power Cable For 2VA02CB			
	2VA149	Control Cable For 2VA02CB			
	2VA150	Control Cable For 2VA02CB			
2VA06CB	2VA822	Control Cable For 2VA06CB			
2VD01CA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6B-0					
2VD10YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP020	Control Cable For 2VP01CA			
2VP01CC	2VP064	Control Cable For 2VP01CC			
2VX04C	2VX001	Power Cable For 2VX04C			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
2VX04Y	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			
2VX05Y	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
Unit 0 (Common) Components			NONE		
0CC01E-A	1CC022	Control Cable For 0CC01E-A			
	1CC025	Control Cable For 0CC01E-A			
	1CC276	Control Cable For 0CC01E-A			
0SX02PA	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
	1SX258	Control Cable For 0SX02PA			
0SX158A	1SX079	Control Cable For 0SX158A			
0VA01CA	1VA001	Power Cable For 0VA01CA			
	1VA002	Control Cable For 0VA01CA			
0VA02CA	1VA016	Power Cable For 0VA02CA			
	1VA017	Control Cable For 0VA02CA			
0VA474Y	1VA027	Control Cable For 0VA474Y			
	1VA793	Control Cable For 0VA474Y			
0VC01CA	1VC013	Power Cable For 0VC01CA			
	1VC018	Control Cable For 0VC01CA			
0VC02CA	1VC021	Power Cable For 0VC02CA			
0VC043Y	1PR065	Power Cable For 0VC281Y and 0VC043Y			
	1PR066	Power Cable For 0VC281Y and 0VC043Y			
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1PR314	Power Cable For 0VC281Y and 0VC043Y			
0VC18Y	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
0VC19Y	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
0VC20Y	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
0VC281Y	1PR065	Power Cable For 0VC281Y and 0VC043Y			
	1PR066	Power Cable For 0VC281Y and 0VC043Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1PR314	Power Cable For 0VC281Y and 0VC043Y			
Unit 1 Components					
1AF005A	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11	1PI-0516A	1MS127	Instrument Cable For 1PI-0516A
			1PI-0546A	1MS128	Instrument Cable For 1PI-0546A
1AF005B	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1AF005C	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1AF005D	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1AF01PA	1AF006	Control Cable For 1AF01PA			
	1AF007	Control Cable For 1AF01PA			
	1AF276	Control Cable For 1AF01PA			
1AF01PA-A	1AF004	Control Cable For 1AF01PA-A			
1AP05EA	1AP401	Control Cable For 1AP05EA			
1AP05EC	1SI001	Power Cable For 1AP05EC			
1AP05EF	1DG019	Control Cable For 1DG01KA and 1AP05EF			
1AP05EJ	1CS001	Power Cable For 1AP05EJ			
	1CS122	Control Cable For 1AP05EJ			
1AP05EP	1AP075	Control Cable For 1AP05EP			
1AP05ER	1AP050	Control Cable For 1AP05ER			
	1AP312	Control Cable For 1AP05ER			
	1AP585	Control Cable For 1AP05ER and 2AP05EG			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
1AP05EU	1AP082	Control Cable For 1AP05EU			
	1AP395	Control Cable For 1AP05EU			
1AP07EL	1AP093	Power Cable For 1AP07EL			
1AP14E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1AP21E	1AP143	Power Cable For 1AP21E			
1AP25E	1AP144	Power Cable For 1AP25E			
1AP26E	1AP146	Power Cable For 1AP26E			
1AP30E	1AP148	Power Cable For 1AP30E			
1AP38E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1AP42E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
	1DC042	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1CC01PA	1CC003	Control Cable For 1CC01PA			
	1CC283	Control Cable For 1CC01PA			
1CC9416	1CC059	Control Cable For 1CC9416			
1CC9438	1CC036	Control Cable For 1CC9438			
1CS009A	1CS079	Control Cable For 1CS009A			
1CV01PA	1CV001	Power Cable For 1CV01PA			
	1CV006	Control Cable For 1CV01PA			
1CV8804A	1CV413	Control Cable For 1CV8804A and 1RH8701A			
	1CV468	Control Cable For 1CV8804A			
1DG01KA	1DG017	Control Cable For 1DG01KA			
	1DG018	Control Cable For 1DG01KA			
	1DG019	Control Cable For 1DG01KA and 1AP05EF			
	1DG153	Control Cable For 1DG01KA			
	1DG154	Control Cable For 1DG01KA			
	1DG174	Control Cable For 1DG01KA			
	1DG200	Control Cable For 1DG01KA			
1DO01PA	1DO001	Power Cable For 1DO01PA			
	1DO002	Control Cable For 1DO01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
1DO01PC	1DO004	Power Cable For 1DO01PC			
	1DO005	Control Cable For 1DO01PC			
1IP01E	1IP004	Power Cable For 1IP01E			
1IP05E	1IP002	Power Cable For 1IP05E			
1IP07E	1IP030	Power Cable For 1IP07E			
1MS001A-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS001B-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS001C-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS001D-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS018A	1MS587	Power Cable For 1MS018A			
	1MS594	Power Cable For 1MS018A			
1MS018D	1MS599	Power Cable For 1MS018D			
	1MS606	Power Cable For 1MS018D			
1RH01PA	1RH001	Power Cable For 1RH01PA			
1RH8701A	1CV413	Control Cable For 1CV8804A and 1RH8701A			
	1RH029	Control Cable For 1RH8701A and 1SI8811A			
	1RH031	Control Cable For 1RH8701A			
	1SI168	Control Cable For 1RH8701A			
1RH8702A	1RH050	Control Cable For 1RH8702A			
	1RH051	Control Cable For 1RH8702A			
	1RH054	Control Cable For 1RH8702A			
	1RH055	Control Cable For 1RH8702A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
1RY8000A	1RY394	Control Cable For 1RY8000A			
1SI8811A	1RH029	Control Cable For 1RH8701A and 1SI8811A			
1SX016A	1SX472	Control Cable For 1SX016A and 1SX027A			
1SX01PA	1SX005	Control Cable For 1SX01PA			
	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			
	1SX280	Control Cable For 1SX01PA			
1SX01PA-C	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			
1SX027A	1SX472	Control Cable For 1SX016A and 1SX027A			
1SX101A	1AF003	Control Cable For 1SX101A			
	1SX471	Control Cable For 1SX101A			
1SX169A	1SX295	Control Cable For 1SX169A			
1VA01CD	1VA165	Control Cable For 1VA01CD			
1VA02CA	1VA104	Control Cable For 1VA02CA			
1VA02CB	1VA149	Control Cable For 1VA02CB			
1VA06CA	1VA053	Control Cable For 1VA06CA			
1VA06CB	1VA822	Control Cable For 1VA06CB			
1VD01CA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
1VD10YA	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VP003	Power Cable For 1VP01CA			
	1VP019	Control Cable For 1VP01CA			
	1VP020	Control Cable For 1VP01CA			
	1VP021	Control Cable For 1VP01CA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6C-0					
1VP01CC	1VP047	Power Cable For 1VP01CC			
	1VP063	Control Cable For 1VP01CC			
	1VP064	Control Cable For 1VP01CC			
	1VP065	Control Cable For 1VP01CC			
1VX04C	1VX001	Power Cable For 1VX04C			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX004	Control Cable For 1VX04C			
1VX04Y	1VE018	Control Cable For 1VX04Y and 1VX05Y			
	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VE039	Control Cable For 1VX04Y and 1VX05Y			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX064	Control Cable For 1VX04Y and 1VX05Y			
1VX05Y	1VX102	Control Cable For 1VX04Y and 1VX05Y			
	1VE018	Control Cable For 1VX04Y and 1VX05Y			
	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VE039	Control Cable For 1VX04Y and 1VX05Y			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX064	Control Cable For 1VX04Y and 1VX05Y			
	1VX102	Control Cable For 1VX04Y and 1VX05Y			
Unit 2 Components					
2AP05EG	1AP585	Control Cable For 1AP05ER and 2AP05EG	NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6D-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.6E-0					
Unit 0 (Common) Components					
-	OVA489Y	Unit 2 Division 22 Electrical Penetration Area Fire Damper	NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
2AP05EP	2CS041	Control Cable For 2AP05EP	NONE		
2RY8000A	2RY394	Control Cable For 2RY8000A			
2SI8806	2SI073	Control Cable For 2SI8806			
	2SI074	Control Cable For 2SI8806			
2SX01PA	2SX052	Control Cable For 2SX01PA			
	2SX058	Control Cable For 2SX01PA			
2VA06CB	2VA822	Control Cable For 2VA06CB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-0					
Unit 0 (Common) Components					
-	0VA01CA	Auxiliary Building HVAC Supply Fan 0A	-	0VA01CB	Auxiliary Building HVAC Supply Fan 0B
	0VA01CC	Auxiliary Building HVAC Supply Fan 0C		0VA01CD	Auxiliary Building HVAC Supply Fan 0D
	0VA02CA	Auxiliary Building HVAC Exhaust Fan 0A		0VA02CB	Auxiliary Building HVAC Exhaust Fan 0B
	0VA02CC	Auxiliary Building HVAC Exhaust Fan 0C		0VA02CD	Auxiliary Building HVAC Exhaust Fan 0D
0VA01CA	1VA001	Power Cable For 0VA01CA	0VA01CB	1VA009	Power Cable For 0VA01CB
	1VA002	Control Cable For 0VA01CA		1VA010	Control Cable For 0VA01CB
	1VA003	Control Cable For 0VA01CA		1VA011	Control Cable For 0VA01CB
	1VA034	Control Cable For 0VA01CA and 0VA474Y		1VA023	Control Cable For 0VA01CB and 0VA02CB
0VA01CC	2VA001	Power Cable For 0VA01CC		1VA037	Control Cable For 0VA01CB and 0VA475Y
	2VA002	Control Cable For 0VA01CC		1VA805	Control Cable For 0VA01CB
	2VA003	Control Cable For 0VA01CC		1VA807	Control Cable For 0VA01CB and 0VA02CB
	2VA013	Control Cable For 0VA01CC and 0VA02CC	0VA01CD	2VA009	Power Cable For 0VA01CD
	2VA028	Control Cable For 0VA01CC and 0VA476Y		2VA010	Control Cable For 0VA01CD
0VA02CA	1VA013	Control Cable For 0VA02CA		2VA011	Control Cable For 0VA01CD
	1VA016	Power Cable For 0VA02CA		2VA023	Control Cable For 0VA01CD and 0VA02CD
	1VA017	Control Cable For 0VA02CA	0VA02CB	1VA019	Power Cable For 0VA02CB
0VA02CC	2VA013	Control Cable For 0VA01CC and 0VA02CC		1VA020	Control Cable For 0VA02CB
	2VA016	Power Cable For 0VA02CC		1VA023	Control Cable For 0VA01CB and 0VA02CB
	2VA017	Control Cable For 0VA02CC		1VA033	Control Cable For 0VA02CB and 0VA475Y
	2VA024	Control Cable For 0VA02CC and 0VA476Y		1VA799	Control Cable For 0VA02CB
0VA474Y	1VA027	Control Cable For 0VA474Y		1VA807	Control Cable For 0VA01CB and 0VA02CB
	1VA028	Control Cable For 0VA474Y	0VA02CD	2VA019	Power Cable For 0VA02CD
	1VA034	Control Cable For 0VA01CA and 0VA474Y		2VA020	Control Cable For 0VA02CD
	1VA036	Control Cable For 0VA474Y		2VA023	Control Cable For 0VA01CD and 0VA02CD
	1VA083	Control Cable For 0VA474Y		2VA034	Control Cable For 0VA02CD
	1VA254	Control Cable For 0VA474Y		2VA799	Control Cable For 0VA02CD
	1VA454	Control Cable For 0VA474Y	0VA475Y	1VA024	Control Cable For 0VA475Y
	1VA455	Control Cable For 0VA474Y		1VA025	Control Cable For 0VA475Y
	1VA457	Control Cable For 0VA474Y		1VA031	Control Cable For 0VA475Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-0					
	1VA458	Control Cable For 0VA474Y		1VA033	Control Cable For 0VA02CB and 0VA475Y
	1VA460	Control Cable For 0VA474Y		1VA035	Control Cable For 0VA475Y
	1VA461	Control Cable For 0VA474Y		1VA037	Control Cable For 0VA01CB and 0VA475Y
	1VA463	Control Cable For 0VA474Y		1VA129	Control Cable For 0VA475Y
	1VA464	Control Cable For 0VA474Y		1VA256	Control Cable For 0VA475Y
	1VA466	Control Cable For 0VA474Y		1VA515	Control Cable For 0VA475Y
	1VA467	Control Cable For 0VA474Y		1VA516	Control Cable For 0VA475Y
	1VA469	Control Cable For 0VA474Y		1VA518	Control Cable For 0VA475Y
	1VA470	Control Cable For 0VA474Y		1VA519	Control Cable For 0VA475Y
	1VA471	Control Cable For 0VA474Y		1VA521	Control Cable For 0VA475Y
	1VA472	Control Cable For 0VA474Y		1VA522	Control Cable For 0VA475Y
	1VA473	Control Cable For 0VA474Y		1VA524	Control Cable For 0VA475Y
	1VA474	Control Cable For 0VA474Y		1VA525	Control Cable For 0VA475Y
	1VA475	Control Cable For 0VA474Y		1VA526	Control Cable For 0VA475Y
	1VA476	Control Cable For 0VA474Y		1VA527	Control Cable For 0VA475Y
	1VA477	Control Cable For 0VA474Y		1VA528	Control Cable For 0VA475Y
	1VA478	Control Cable For 0VA474Y		1VA529	Control Cable For 0VA475Y
	1VA479	Control Cable For 0VA474Y		1VA531	Control Cable For 0VA475Y
	1VA481	Control Cable For 0VA474Y		1VA532	Control Cable For 0VA475Y
	1VA482	Control Cable For 0VA474Y		1VA533	Control Cable For 0VA475Y
	1VA485	Control Cable For 0VA474Y		1VA534	Control Cable For 0VA475Y
	1VA487	Control Cable For 0VA474Y		1VA535	Control Cable For 0VA475Y
	1VA488	Control Cable For 0VA474Y		1VA537	Control Cable For 0VA475Y
	1VA493	Control Cable For 0VA474Y		1VA538	Control Cable For 0VA475Y
	1VA494	Control Cable For 0VA474Y		1VA540	Control Cable For 0VA475Y
	1VA495	Control Cable For 0VA474Y		1VA542	Control Cable For 0VA475Y
	1VA496	Control Cable For 0VA474Y		1VA543	Control Cable For 0VA475Y
	1VA497	Control Cable For 0VA474Y		1VA546	Control Cable For 0VA475Y
	1VA498	Control Cable For 0VA474Y		1VA552	Control Cable For 0VA475Y
	1VA499	Control Cable For 0VA474Y		1VA553	Control Cable For 0VA475Y
	1VA500	Control Cable For 0VA474Y		1VA555	Control Cable For 0VA475Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-0					
OVA476Y	1VA502	Control Cable For OVA474Y		1VA556	Control Cable For OVA475Y
	1VA503	Control Cable For OVA474Y		1VA557	Control Cable For OVA475Y
	1VA755	Control Cable For OVA474Y		1VA558	Control Cable For OVA475Y
	1VA757	Control Cable For OVA474Y		1VA559	Control Cable For OVA475Y
	1VA758	Control Cable For OVA474Y		1VA560	Control Cable For OVA475Y
	1VA759	Control Cable For OVA474Y		1VA563	Control Cable For OVA475Y
	1VA760	Control Cable For OVA474Y		1VA566	Control Cable For OVA475Y
	1VA761	Control Cable For OVA474Y		1VA567	Control Cable For OVA475Y
	1VA763	Control Cable For OVA474Y		1VA568	Control Cable For OVA475Y
	1VA773	Control Cable For OVA474Y		1VA570	Control Cable For OVA475Y
	1VA793	Control Cable For OVA474Y		1VA571	Control Cable For OVA475Y
	1VA795	Control Cable For OVA474Y		1VA582	Control Cable For OVA475Y
	2VA024	Control Cable For OVA02CC and OVA476Y		1VA756	Control Cable For OVA475Y
	2VA025	Control Cable For OVA476Y		1VA765	Control Cable For OVA475Y
	2VA027	Control Cable For OVA476Y		1VA766	Control Cable For OVA475Y
	2VA028	Control Cable For OVA01CC and OVA476Y		1VA767	Control Cable For OVA475Y
	2VA033	Control Cable For OVA476Y		1VA768	Control Cable For OVA475Y
	2VA254	Control Cable For OVA476Y		1VA769	Control Cable For OVA475Y
	2VA361	Control Cable For OVA476Y		1VA771	Control Cable For OVA475Y
	2VA362	Control Cable For OVA476Y		1VA774	Control Cable For OVA475Y
	2VA363	Control Cable For OVA476Y		1VA794	Control Cable For OVA475Y
	2VA364	Control Cable For OVA476Y		1VA796	Control Cable For OVA475Y
	2VA365	Control Cable For OVA476Y	OVA477Y	2VA031	Control Cable For OVA477Y
	2VA370	Control Cable For OVA476Y		2VA032	Control Cable For OVA477Y
	2VA371	Control Cable For OVA476Y		2VA256	Control Cable For OVA477Y
	2VA372	Control Cable For OVA476Y		2VA381	Control Cable For OVA477Y
	2VA375	Control Cable For OVA476Y		2VA382	Control Cable For OVA477Y
	2VA376	Control Cable For OVA476Y		2VA383	Control Cable For OVA477Y
	2VA635	Control Cable For OVA476Y		2VA384	Control Cable For OVA477Y
	2VA636	Control Cable For OVA476Y		2VA385	Control Cable For OVA477Y
	2VA637	Control Cable For OVA476Y		2VA386	Control Cable For OVA477Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-0					
	2VA639	Control Cable For 0VA476Y		2VA387	Control Cable For 0VA477Y
	2VA640	Control Cable For 0VA476Y		2VA388	Control Cable For 0VA477Y
	2VA645	Control Cable For 0VA476Y		2VA389	Control Cable For 0VA477Y
	2VA646	Control Cable For 0VA476Y		2VA390	Control Cable For 0VA477Y
	2VA647	Control Cable For 0VA476Y		2VA391	Control Cable For 0VA477Y
	2VA648	Control Cable For 0VA476Y		2VA392	Control Cable For 0VA477Y
	2VA649	Control Cable For 0VA476Y		2VA398	Control Cable For 0VA477Y
	2VA652	Control Cable For 0VA476Y		2VA399	Control Cable For 0VA477Y
	2VA653	Control Cable For 0VA476Y		2VA400	Control Cable For 0VA477Y
	2VA654	Control Cable For 0VA476Y		2VA401	Control Cable For 0VA477Y
	2VA656	Control Cable For 0VA476Y		2VA402	Control Cable For 0VA477Y
	2VA657	Control Cable For 0VA476Y		2VA403	Control Cable For 0VA477Y
	2VA658	Control Cable For 0VA476Y		2VA404	Control Cable For 0VA477Y
	2VA659	Control Cable For 0VA476Y		2VA405	Control Cable For 0VA477Y
	2VA660	Control Cable For 0VA476Y		2VA406	Control Cable For 0VA477Y
	2VA757	Control Cable For 0VA476Y		2VA765	Control Cable For 0VA477Y
	2VA758	Control Cable For 0VA476Y		2VA766	Control Cable For 0VA477Y
	2VA759	Control Cable For 0VA476Y		2VA767	Control Cable For 0VA477Y
	2VA760	Control Cable For 0VA476Y		2VA768	Control Cable For 0VA477Y
	2VA761	Control Cable For 0VA476Y		2VA769	Control Cable For 0VA477Y
	2VA763	Control Cable For 0VA476Y		2VA771	Control Cable For 0VA477Y
	2VA773	Control Cable For 0VA476Y		2VA774	Control Cable For 0VA477Y
	2VA793	Control Cable For 0VA476Y		2VA794	Control Cable For 0VA477Y
	2VA795	Control Cable For 0VA476Y		2VA796	Control Cable For 0VA477Y
			0VC01Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC02Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-0			0VC03Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC044Y	1VC244	Control Cable For 0VC044Y
				1VC576	Control Cable For 0VC044Y
			0VC04Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC16Y	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
			0VC172Y	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
			0VC282Y	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
Unit 1 Components			NONE		
NONE					
Unit 2 Components			NONE		
NONE					

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-1					
Unit 0 (Common) Components					
0VA01CA	1VA001	Power Cable For 0VA01CA	0VA01CB	1VA009	Power Cable For 0VA01CB
0VA02CA	1VA016	Power Cable For 0VA02CA	0VA02CB	1VA019	Power Cable For 0VA02CB
0VA474Y	1VA485	Control Cable For 0VA474Y	0VA475Y	1VA256	Control Cable For 0VA475Y
				1VA546	Control Cable For 0VA475Y
				1VA765	Control Cable For 0VA475Y
				1VA766	Control Cable For 0VA475Y
				1VA767	Control Cable For 0VA475Y
				1VA768	Control Cable For 0VA475Y
				1VA769	Control Cable For 0VA475Y
				1VA771	Control Cable For 0VA475Y
				1VA796	Control Cable For 0VA475Y
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 11.7-2					
Unit 0 (Common) Components					
0VA01CC	2VA001	Power Cable For 0VA01CC	0VA01CD	2VA009	Power Cable For 0VA01CD
0VA02CC	2VA016	Power Cable For 0VA02CC		2VA010	Control Cable For 0VA01CD
			0VA02CD	2VA019	Power Cable For 0VA02CD
				2VA020	Control Cable For 0VA02CD
				2VA799	Control Cable For 0VA02CD
			0VA477Y	2VA031	Control Cable For 0VA477Y
				2VA256	Control Cable For 0VA477Y
				2VA403	Control Cable For 0VA477Y
				2VA794	Control Cable For 0VA477Y
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 12.1-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
2AP05EP	2CS041	Control Cable For 2AP05EP	NONE		
2CV8804A	2SI454	Control Cable For 2CV8804A			
2RY8000A	2RY394	Control Cable For 2RY8000A			
2SI8806	2SI073	Control Cable For 2SI8806			
	2SI074	Control Cable For 2SI8806			
2SX01PA	2SX052	Control Cable For 2SX01PA			
	2SX058	Control Cable For 2SX01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 13					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 14.1-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
2LI-0501	2FW025	Instrument Cable For 2LI-0501	2CV121	2CV140	Instrument Cable For 2CV121
2LI-0504	2FW028	Instrument Cable For 2LI-0504			
2PI-0514B	2MS099	Instrument Cable For 2PI-0514B			
2PI-0524B	2MS103	Instrument Cable For 2PI-0524B			
2PI-0534B	2MS107	Instrument Cable For 2PI-0534B			
2PI-0544B	2MS111	Instrument Cable For 2PI-0544B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 14.2-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 14.3-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 14.4-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 14.5-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 14.6-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 16.1-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
-	1SI01T	Refueling Water Storage Tank	NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 16.1-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2SI01T	Refueling Water Storage Tank	NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 17.1-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 17.1-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 17.2-1					
Unit 0 (Common) Components					
-	0SX02AB	Essential Service Water Cooling Tower 0B	-	0SX157B	ESW Cooling Tower 0B Makeup Inlet Valve (MO)
	0SX158B	ESW Cooling Tower 0B Makeup Inlet Valve (MO)		0SX162B	ESW Cooling Tower 0B Hot Water Bypass to Basin Valve (MO)
				0SX162D	ESW Cooling Tower 0B Hot Water Bypass to Basin Valve (MO)
				0SX163E	ESW Cooling Tower 0B Riser Valve (MO)
				0SX163F	ESW Cooling Tower 0B Riser Valve (MO)
				0SX163G	ESW Cooling Tower 0B Riser Valve (MO)
				0SX163H	ESW Cooling Tower 0B Riser Valve (MO)
			0SX02PB	1SX168	Control Cable For 0SX02PB and 0SX162B
				1SX562	Control Cable For 0SX02PB
				1SX564	Control Cable For 0SX02PB
			0SX157B	2SX080	Power Cable For 0SX157B
				2SX084	Control Cable For 0SX157B
			0SX162B	1SX167	Power Cable For 0SX162B
				1SX168	Control Cable For 0SX02PB and 0SX162B
				1SX561	Control Cable For 0SX162B
			0SX162D	2SX167	Power Cable For 0SX162D
				2SX168	Control Cable For 0SX162D
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

