

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
-	1VE04Y	Division 12 MEER Fire Damper	-	1VD01CB	Diesel Generator Room 1B Supply Fan
	1VX16Y	Division 12 ESF Swgr Room Fire Damper		1VD01YA	Diesel Generator Room 1B Outside Air Intake Damper
				1VD01YB	Diesel Generator Room 1B Outside Air Intake Damper
				1VD16YA	Diesel Generator Room 1B Fire Damper
				1VD16YB	Diesel Generator Room 1B Fire Damper
				1VE01Y	Division 12 MEER Outside Air Intake Damper
				1VX01C	Division 12 ESF Switchgear Room Supply Fan
				1VX01Y	Division 12 ESF Swgr Room Outside Air Intake Damper
			1VD01CB	1VD007	Power Cable For 1VD01CB
				1VD008	Control Cable For 1VD01CB
				1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD079	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD01YA	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD024	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD025	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD026	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD063	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD065	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-1					
					1VD066 Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
					1VD076 Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
					1VD079 Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
					1VD081 Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
					1VD086 Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
					1VD090 Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
					1VD095 Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD01YB	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD024	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD025	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD026	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD063	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD065	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD076	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD079	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-1					
				1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD02YA	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD024	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD025	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD026	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD063	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD065	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD076	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD079	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD02YB	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD024	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD025	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-1					
				1VD026	Instrument Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD063	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD065	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD076	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD079	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1VD16YA			1CO273	Control Cable For 1VD16YA and 1VD16YB
	1VD16YB			1CO273	Control Cable For 1VD16YA and 1VD16YB
	1VE01Y			1VE002	Instrument Cable For 1VE01Y and 1VE02Y
				1VE026	Control Cable For 1VE01Y and 1VE02Y
	1VE02Y			1VE002	Instrument Cable For 1VE01Y and 1VE02Y
				1VE026	Control Cable For 1VE01Y and 1VE02Y
	1VX01C			1VX113	Power Cable For 1VX01C
	1VX01Y			1VX025	Instrument Cable For 1VX01Y and 1VX02Y
				1VX069	Control Cable For 1VX01Y and 1VX02Y
				1VX074	Control Cable For 1VX01Y and 1VX02Y
	1VX02Y			1VX025	Instrument Cable For 1VX01Y and 1VX02Y
				1VX069	Control Cable For 1VX01Y and 1VX02Y
				1VX074	Control Cable For 1VX01Y and 1VX02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-1					
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2VE04Y	Division 22 MEER Fire Damper	-	2VD01CB	Diesel Generator Room 2B Supply Fan
	2VX16Y	Division 22 ESF Swgr Room Fire Damper		2VD01YA	Diesel Generator Room 2B Outside Air Intake Damper
2VD23YA	2CO262	Control Cable For 2VD23YA and 2VD23YB		2VD01YB	Diesel Generator Room 2B Outside Air Intake Damper
2VD23YB	2CO262	Control Cable For 2VD23YA and 2VD23YB		2VD16YA	Diesel Generator Room 2B Fire Damper
				2VD16YB	Diesel Generator Room 2B Fire Damper
				2VE01Y	Division 22 MEER Outside Air Intake Damper
				2VX01C	Division 22 ESF Switchgear Room Supply Fan
				2VX01Y	Division 22 ESF Swgr Room Outside Air Intake Damper
			2VD01CB	2VD007	Power Cable For 2VD01CB
				2VD008	Control Cable For 2VD01CB
				2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD079	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD01YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD024	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD025	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD026	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-2					
				2VD063	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD065	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD079	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD01YB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD024	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD025	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD026	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD063	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD065	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD079	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-2					
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD02YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD024	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD025	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD026	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD063	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD065	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD079	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD02YB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-2					
				2VD024	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD025	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD026	Instrument Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD063	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD065	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD079	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VD16YA			2CO273	Control Cable For 2VD16YA
	2VE01Y			2VE002	Instrument Cable For 2VE01Y and 2VE02Y
				2VE025	Control Cable For 2VE01Y and 2VE02Y
	2VE02Y			2VE002	Instrument Cable For 2VE01Y and 2VE02Y
				2VE025	Control Cable For 2VE01Y and 2VE02Y
	2VX01C			2VX113	Power Cable For 2VX01C
	2VX01Y			2VX025	Instrument Cable For 2VX01Y and 2VX02Y
				2VX069	Control Cable For 2VX01Y and 2VX02Y
				2VX074	Control Cable For 2VX01Y and 2VX02Y
	2VX02Y			2VX025	Instrument Cable For 2VX01Y and 2VX02Y
				2VX069	Control Cable For 2VX01Y and 2VX02Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.1-2			2VX074		Control Cable For 2VX01Y and 2VX02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
-	1VD01CA	Diesel Generator Room 1A Supply Fan	NONE		
	1VD09YA	Diesel Generator Room 1A Outside Air Intake Damper			
	1VD09YB	Diesel Generator Room 1A Outside Air Intake Damper			
	1VD23YA	Diesel Generator Room 1A Fire Damper			
	1VD23YB	Diesel Generator Room 1A Fire Damper			
	1VE06Y	Division 11 MEER Fire Damper			
	1VX04C	Division 11 ESF Switchgear Room/MEER Supply Fan			
	1VX04Y	Division 11 ESF Swgr Room Outside Air Intake Damper			
	1VX22Y	Division 11 ESF Swgr Room Fire Damper			
1VD01CA	1VD001	Power Cable For 1VD01CA			
	1VD002	Control Cable For 1VD01CA			
	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD074	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD019	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD022	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-1					
	1VD023	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD056	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD057	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD074	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD019	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD022	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD023	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD056	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD057	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-1					
	1VD074	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD019	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD022	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD023	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD056	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD057	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD074	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

(Sheet 987)

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-1					
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD019	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD022	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD023	Instrument Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD056	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD057	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD074	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VX04C	1VX001	Power Cable For 1VX04C			
	1VX063	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
1VX04Y	1VX020	Instrument Cable For 1VX04Y and 1VX05Y			
	1VX061	Control Cable For 1VX04Y and 1VX05Y			
	1VX063	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
1VX05Y	1VX020	Instrument Cable For 1VX04Y and 1VX05Y			
	1VX061	Control Cable For 1VX04Y and 1VX05Y			
	1VX063	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			

Unit 2 Components

TABLE 2.4-4 (Cont 'd)

Division 11/21		
Affected Equipment	Equipment In Zone	Equipment Description

Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description

Fire Zone Number: 18.2-1

NONE

NONE

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2VD01CA	Diesel Generator Room 2A Supply Fan	NONE		
	2VD09YA	Diesel Generator Room 2A Outside Air Intake Damper			
	2VD09YB	Diesel Generator Room 2A Outside Air Intake Damper			
	2VD23YA	Diesel Generator Room 2A Fire Damper			
	2VD23YB	Diesel Generator Room 2A Fire Damper			
	2VE06Y	Division 21 MEER Fire Damper			
	2VX04C	Division 21 ESF Switchgear Room/MEER Supply Fan			
	2VX04Y	Division 21 ESF Swgr Room Outside Air Intake Damper			
	2VX22Y	Division 21 ESF Swgr Room Fire Damper			
2VD01CA	2VD001	Power Cable For 2VD01CA			
	2VD002	Control Cable For 2VD01CA			
	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD074	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-2					
	2VD019	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD022	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD023	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD056	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD057	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD074	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD019	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD022	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD023	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD056	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD057	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-2					
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD074	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD019	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD022	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD023	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD056	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD057	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD074	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-2					
2VD10YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD019	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD022	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD023	Instrument Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD056	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD057	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD074	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VX04C	2VX001	Power Cable For 2VX04C		
2VX063		Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
2VX04Y	2VX020	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX061	Control Cable For 2VX04Y and 2VX05Y			
	2VX063	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
2VX05Y	2VX020	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX061	Control Cable For 2VX04Y and 2VX05Y			

(Sheet 993)

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.2-2					
	2VX063	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
-	1AF013A	AFW Pump 1A to SG 1A Stop Valve (MO)	-	1AF013E	AFW Pump 1B to SG 1A Stop Valve (MO)
	1AF013B	AFW Pump 1A to SG 1B Stop Valve (MO)		1AF013F	AFW Pump 1B to SG 1B Stop Valve (MO)
	1AF013C	AFW Pump 1A to SG 1C Stop Valve (MO)		1AF013G	AFW Pump 1B to SG 1C Stop Valve (MO)
	1AF013D	AFW Pump 1A to SG 1D Stop Valve (MO)		1AF013H	AFW Pump 1B to SG 1D Stop Valve (MO)
	1MS001A	Loop 1A Main Steam Isolation Valve (HO)		1MS001A-DIV12	Loop 1A Main Steam Isolation Valve (HO); Division 12 Actuation Circuit
	1MS001A-DIV11	Loop 1A Main Steam Isolation Valve (HO); Division 11 Actuation Circuit		1MS001B-DIV12	Loop 1B Main Steam Isolation Valve (HO); Division 12 Actuation Circuit
	1MS001B	Loop 1B Main Steam Isolation Valve (HO)		1MS001C-DIV12	Loop 1C Main Steam Isolation Valve (HO); Division 12 Actuation Circuit
	1MS001B-DIV11	Loop 1B Main Steam Isolation Valve (HO); Division 11 Actuation Circuit		1MS001D-DIV12	Loop 1D Main Steam Isolation Valve (HO); Division 12 Actuation Circuit
	1MS001C	Loop 1C Main Steam Isolation Valve (HO)		1MS018B	Steam Generator 1B Power Operated Relief Valve (HO)
	1MS001C-DIV11	Loop 1C Main Steam Isolation Valve (HO); Division 11 Actuation Circuit		1MS018C	Steam Generator 1C Power Operated Relief Valve (HO)
	1MS001D	Loop 1D Main Steam Isolation Valve (HO)		1MS101A	Loop 1A MSIV Bypass Valve (AO)
	1MS001D-DIV11	Loop 1D Main Steam Isolation Valve (HO); Division 11 Actuation Circuit		1MS101B	Loop 1B MSIV Bypass Valve (AO)
	1MS013A	Main Steam Relief Valve		1MS101C	Loop 1C MSIV Bypass Valve (AO)
	1MS013B	Main Steam Relief Valve		1MS101D	Loop 1D MSIV Bypass Valve (AO)
	1MS013C	Main Steam Relief Valve	1AP06EL	1WO027	Power Cable For 1AP06EL
	1MS013D	Main Steam Relief Valve		1WO029	Control Cable For 1AP06EL
	1MS014A	Main Steam Relief Valve		1WO140	Control Cable For 1AP06EL
	1MS014B	Main Steam Relief Valve	1MS001A-DIV12	1MS270	Control Cable For 1MS001A-DIV12
	1MS014C	Main Steam Relief Valve		1MS271	Control Cable For 1MS001A-DIV12
	1MS014D	Main Steam Relief Valve		1MS564	Control Cable For 1MS001A-DIV12
	1MS015A	Main Steam Relief Valve		1MS565	Control Cable For 1MS001A-DIV12
	1MS015B	Main Steam Relief Valve	1MS001B-DIV12	1MS279	Control Cable For 1MS001B-DIV12
	1MS015C	Main Steam Relief Valve			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-1					
	1MS015D	Main Steam Relief Valve		1MS280	Control Cable For 1MS001B-DIV12
	1MS016A	Main Steam Relief Valve		1MS281	Control Cable For 1MS001B-DIV12
	1MS016B	Main Steam Relief Valve		1MS282	Control Cable For 1MS001B-DIV12
	1MS016C	Main Steam Relief Valve		1MS283	Control Cable For 1MS001B-DIV12
	1MS016D	Main Steam Relief Valve		1MS520	Control Cable For 1MS001B-DIV12
	1MS017A	Main Steam Relief Valve	1MS001C-DIV12	1MS292	Control Cable For 1MS001C-DIV12
	1MS017B	Main Steam Relief Valve		1MS293	Control Cable For 1MS001C-DIV12
	1MS017C	Main Steam Relief Valve		1MS294	Control Cable For 1MS001C-DIV12
	1MS017D	Main Steam Relief Valve		1MS295	Control Cable For 1MS001C-DIV12
	1MS018A	Steam Generator 1A Power Operated Relief Valve (HO)		1MS296	Control Cable For 1MS001C-DIV12
	1MS018D	Steam Generator 1D Power Operated Relief Valve (HO)	1MS001D-DIV12	1MS522	Control Cable For 1MS001C-DIV12
	1MS019A	Steam Generator 1A Atmospheric Relief Isolation Valve (MV)		1MS309	Control Cable For 1MS001D-DIV12
	1MS019B	Steam Generator 1B Atmospheric Relief Isolation Valve (MV)		1MS310	Control Cable For 1MS001D-DIV12
	1MS019C	Steam Generator 1C Atmospheric Relief Isolation Valve (MV)	1MS018B	1MS571	Control Cable For 1MS001D-DIV12
	1MS019D	Steam Generator 1D Atmospheric Relief Isolation Valve (MV)		1MS572	Control Cable For 1MS001D-DIV12
	1MS185A	SG 1A PORV Hand Pump Isolation Valve (MV)		1MS617	Instrument Cable For 1MS018B
	1MS185B	SG 1B PORV Hand Pump Isolation Valve (MV)		1MS618	Instrument Cable For 1MS018B
	1MS185C	SG 1C PORV Hand Pump Isolation Valve (MV)		1MS619	Instrument Cable For 1MS018B
	1MS185D	SG 1D PORV Hand Pump Isolation Valve (MV)	1MS018C	1MS620	Instrument Cable For 1MS018B
	1MS186A	SG 1A PORV Hand Pump Isolation Valve (MV)		1MS621	Instrument Cable For 1MS018B
	1MS186B	SG 1B PORV Hand Pump Isolation Valve (MV)		1MS622	Instrument Cable For 1MS018B
	1MS186C	SG 1C PORV Hand Pump Isolation Valve (MV)		1MS623	Power Cable For 1MS018B
	1MS186D	SG 1D PORV Hand Pump Isolation Valve (MV)		1MS629	Instrument Cable For 1MS018C
	1MS187A	SG 1A PORV Hand Pump Isolation Valve (MV)		1MS630	Instrument Cable For 1MS018C
	1MS187B	SG 1B PORV Hand Pump Isolation Valve (MV)		1MS631	Instrument Cable For 1MS018C
	1MS187C	SG 1C PORV Hand Pump Isolation Valve (MV)	1MS101A	1MS632	Instrument Cable For 1MS018C
	1MS187D	SG 1D PORV Hand Pump Isolation Valve (MV)	1MS101B	1MS633	Instrument Cable For 1MS018C
				1MS634	Instrument Cable For 1MS018C
				1MS635	Power Cable For 1MS018C
				1MS320	Control Cable For 1MS101A
				1MS325	Control Cable For 1MS101B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-1					
1MS001A-DIV11	1MS265	Control Cable For 1MS001A-DIV11		1MS670	Control Cable For 1MS101B
	1MS266	Control Cable For 1MS001A-DIV11	1MS101C	1MS330	Control Cable For 1MS101C
	1MS267	Control Cable For 1MS001A-DIV11	1MS101D	1MS335	Control Cable For 1MS101D
	1MS268	Control Cable For 1MS001A-DIV11		1MS671	Control Cable For 1MS101D
	1MS269	Control Cable For 1MS001A-DIV11	1PI-0515A	1MS115	Instrument Cable For 1PI-0515A
	1MS518	Control Cable For 1MS001A-DIV11	1PI-0516A	1MS127	Instrument Cable For 1PI-0516A
1MS001B-DIV11	1MS278	Control Cable For 1MS001B-DIV11	1PI-0525A	1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
	1MS284	Control Cable For 1MS001B-DIV11	1PI-0535A	1MS121	Instrument Cable For 1PI-0535A
	1MS566	Control Cable For 1MS001B-DIV11	1PI-0545A	1MS124	Instrument Cable For 1PI-0545A
1MS001C-DIV11	1MS567	Control Cable For 1MS001B-DIV11	1PI-0546A	1MS128	Instrument Cable For 1PI-0546A
	1MS291	Control Cable For 1MS001C-DIV11	1PI-MS194	1MS667	Instrument Cable For 1PI-0525A and 1PI-MS194
	1MS297	Control Cable For 1MS001C-DIV11			
	1MS569	Control Cable For 1MS001C-DIV11			
1MS001D-DIV11	1MS570	Control Cable For 1MS001C-DIV11			
	1MS304	Control Cable For 1MS001D-DIV11			
	1MS305	Control Cable For 1MS001D-DIV11			
	1MS306	Control Cable For 1MS001D-DIV11			
	1MS307	Control Cable For 1MS001D-DIV11			
	1MS308	Control Cable For 1MS001D-DIV11			
1MS018A	1MS526	Control Cable For 1MS001D-DIV11			
	1MS588	Instrument Cable For 1MS018A			
	1MS589	Instrument Cable For 1MS018A			
	1MS590	Instrument Cable For 1MS018A			
	1MS591	Instrument Cable For 1MS018A			
	1MS592	Instrument Cable For 1MS018A			
1MS018D	1MS593	Instrument Cable For 1MS018A			
	1MS594	Power Cable For 1MS018A			
	1MS600	Instrument Cable For 1MS018D			
	1MS601	Instrument Cable For 1MS018D			
	1MS602	Instrument Cable For 1MS018D			
	1MS603	Instrument Cable For 1MS018D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-1					
	1MS604	Instrument Cable For 1MS018D			
	1MS605	Instrument Cable For 1MS018D			
	1MS606	Power Cable For 1MS018D			
1MS101A	1MS321	Control Cable For 1MS101A			
	1MS322	Control Cable For 1MS101A			
	1MS324	Control Cable For 1MS101A			
1MS101B	1MS326	Control Cable For 1MS101B			
	1MS327	Control Cable For 1MS101B			
	1MS329	Control Cable For 1MS101B			
1MS101C	1MS331	Control Cable For 1MS101C			
	1MS332	Control Cable For 1MS101C			
	1MS334	Control Cable For 1MS101C			
1MS101D	1MS336	Control Cable For 1MS101D			
	1MS337	Control Cable For 1MS101D			
	1MS338	Control Cable For 1MS101D			
	1MS339	Control Cable For 1MS101D			
1PI-0514A	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193			
1PI-0514B	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193			
1PI-0524A	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B			
1PI-0524B	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B			
1PI-0526A	1MS125	Instrument Cable For 1PI-0526A			
1PI-0534A	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B			
1PI-0534B	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B			
1PI-0536A	1MS126	Instrument Cable For 1PI-0536A			
1PI-0544A	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
1PI-0544B	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
1PI-MS193	1MS665	Instrument Cable For 1PI-0514A, 1PI-0514B, and 1PI-MS193			

Unit 2 Components

TABLE 2.4-4 (Cont 'd)

Division 11/21		
Affected Equipment	Equipment In Zone	Equipment Description

Fire Zone Number: 18.3-1

NONE

Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description

NONE

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
-	2AF013A	AFW Pump 2A to SG 2A Stop Valve (MO)	-	2AF013E	AFW Pump 2B to SG 2A Stop Valve (MO)
	2AF013B	AFW Pump 2A to SG 2B Stop Valve (MO)		2AF013F	AFW Pump 2B to SG 2B Stop Valve (MO)
	2AF013C	AFW Pump 2A to SG 2C Stop Valve (MO)		2AF013G	AFW Pump 2B to SG 2C Stop Valve (MO)
	2AF013D	AFW Pump 2A to SG 2D Stop Valve (MO)		2AF013H	AFW Pump 2B to SG 2D Stop Valve (MO)
	2MS001A	Loop 2A Main Steam Isolation Valve (HO)		2MS001A-DIV22	Loop 2A Main Steam Isolation Valve (HO); Division 22 Actuation Circuit
	2MS001A-DIV21	Loop 2A Main Steam Isolation Valve (HO); Division 21 Actuation Circuit		2MS001B-DIV22	Loop 2B Main Steam Isolation Valve (HO); Division 22 Actuation Circuit
	2MS001B	Loop 2B Main Steam Isolation Valve (HO)		2MS001C-DIV22	Loop 2C Main Steam Isolation Valve (HO); Division 22 Actuation Circuit
	2MS001B-DIV21	Loop 2B Main Steam Isolation Valve (HO); Division 21 Actuation Circuit		2MS001D-DIV22	Loop 2D Main Steam Isolation Valve (HO); Division 22 Actuation Circuit
	2MS001C	Loop 2C Main Steam Isolation Valve (HO)		2MS018B	Steam Generator 2B Power Operated Relief Valve (HO)
	2MS001C-DIV21	Loop 2C Main Steam Isolation Valve (HO); Division 21 Actuation Circuit		2MS018C	Steam Generator 2C Power Operated Relief Valve (HO)
	2MS001D	Loop 2D Main Steam Isolation Valve (HO)		2MS101A	Loop 2A MSIV Bypass Valve (AO)
	2MS001D-DIV21	Loop 2D Main Steam Isolation Valve (HO); Division 21 Actuation Circuit		2MS101B	Loop 2B MSIV Bypass Valve (AO)
	2MS013A	Main Steam Relief Valve		2MS101C	Loop 2C MSIV Bypass Valve (AO)
	2MS013B	Main Steam Relief Valve		2MS101D	Loop 2D MSIV Bypass Valve (AO)
	2MS013C	Main Steam Relief Valve	2MS001A-DIV22	2MS270	Control Cable For 2MS001A-DIV22
	2MS013D	Main Steam Relief Valve		2MS271	Control Cable For 2MS001A-DIV22
	2MS014A	Main Steam Relief Valve		2MS564	Control Cable For 2MS001A-DIV22
	2MS014B	Main Steam Relief Valve		2MS565	Control Cable For 2MS001A-DIV22
	2MS014C	Main Steam Relief Valve	2MS001B-DIV22	2MS279	Control Cable For 2MS001B-DIV22
	2MS014D	Main Steam Relief Valve			

(Sheet 1000)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-2					
	2MS015A	Main Steam Relief Valve		2MS280	Control Cable For 2MS001B-DIV22
	2MS015B	Main Steam Relief Valve		2MS281	Control Cable For 2MS001B-DIV22
	2MS015C	Main Steam Relief Valve		2MS282	Control Cable For 2MS001B-DIV22
	2MS015D	Main Steam Relief Valve		2MS283	Control Cable For 2MS001B-DIV22
	2MS016A	Main Steam Relief Valve		2MS520	Control Cable For 2MS001B-DIV22
	2MS016B	Main Steam Relief Valve	2MS001C-DIV22	2MS292	Control Cable For 2MS001C-DIV22
	2MS016C	Main Steam Relief Valve		2MS293	Control Cable For 2MS001C-DIV22
	2MS016D	Main Steam Relief Valve		2MS294	Control Cable For 2MS001C-DIV22
	2MS017A	Main Steam Relief Valve		2MS295	Control Cable For 2MS001C-DIV22
	2MS017B	Main Steam Relief Valve		2MS296	Control Cable For 2MS001C-DIV22
	2MS017C	Main Steam Relief Valve		2MS522	Control Cable For 2MS001C-DIV22
	2MS017D	Main Steam Relief Valve	2MS001D-DIV22	2MS309	Control Cable For 2MS001D-DIV22
	2MS018A	Steam Generator 2A Power Operated Relief Valve (HO)		2MS310	Control Cable For 2MS001D-DIV22
	2MS018D	Steam Generator 2D Power Operated Relief Valve (HO)		2MS571	Control Cable For 2MS001D-DIV22
	2MS019A	Steam Generator 2A Atmospheric Relief Isolation Valve (MV)	2MS018B	2MS572	Control Cable For 2MS001D-DIV22
	2MS019B	Steam Generator 2B Atmospheric Relief Isolation Valve (MV)		2MS617	Instrument Cable For 2MS018B
	2MS019C	Steam Generator 2C Atmospheric Relief Isolation Valve (MV)		2MS618	Instrument Cable For 2MS018B
	2MS019D	Steam Generator 2D Atmospheric Relief Isolation Valve (MV)		2MS619	Instrument Cable For 2MS018B
	2MS185A	SG 2A PORV Hand Pump Isolation Valve (MV)	2MS018C	2MS620	Instrument Cable For 2MS018B
	2MS185B	SG 2B PORV Hand Pump Isolation Valve (MV)		2MS621	Instrument Cable For 2MS018B
	2MS185C	SG 2C PORV Hand Pump Isolation Valve (MV)		2MS622	Instrument Cable For 2MS018B
	2MS185D	SG 2D PORV Hand Pump Isolation Valve (MV)		2MS623	Power Cable For 2MS018B
	2MS186A	SG 2A PORV Hand Pump Isolation Valve (MV)		2MS629	Instrument Cable For 2MS018C
	2MS186B	SG 2B PORV Hand Pump Isolation Valve (MV)		2MS630	Instrument Cable For 2MS018C
	2MS186C	SG 2C PORV Hand Pump Isolation Valve (MV)		2MS631	Instrument Cable For 2MS018C
	2MS186D	SG 2D PORV Hand Pump Isolation Valve (MV)	2MS101A	2MS632	Instrument Cable For 2MS018C
	2MS187A	SG 2A PORV Hand Pump Isolation Valve (MV)	2MS101B	2MS633	Instrument Cable For 2MS018C
				2MS634	Instrument Cable For 2MS018C
				2MS635	Power Cable For 2MS018C
				2MS320	Control Cable For 2MS101A
				2MS325	Control Cable For 2MS101B

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-2					
	2MS187B	SG 2B PORV Hand Pump Isolation Valve (MV)	2MS101C	2MS330	Control Cable For 2MS101C
	2MS187C	SG 2C PORV Hand Pump Isolation Valve (MV)	2MS101D	2MS335	Control Cable For 2MS101D
	2MS187D	SG 2D PORV Hand Pump Isolation Valve (MV)		2MS674	Control Cable For 2MS101D
2LI-0459B	2RC371	Instrument Cable For 2LI-0459B	2PI-0515A	2MS115	Instrument Cable For 2PI-0515A
2LI-0501	2FW025	Instrument Cable For 2LI-0501	2PI-0516A	2MS127	Instrument Cable For 2PI-0516A
2LI-0504	2FW028	Instrument Cable For 2LI-0504	2PI-0525A	2MS667	Instrument Cable For 2PI-0525A and 2PI-MS194
2MS001A-DIV21	2MS265	Control Cable For 2MS001A-DIV21	2PI-0535A	2MS121	Instrument Cable For 2PI-0535A
	2MS266	Control Cable For 2MS001A-DIV21	2PI-0545A	2MS124	Instrument Cable For 2PI-0545A
	2MS267	Control Cable For 2MS001A-DIV21	2PI-0546A	2MS128	Instrument Cable For 2PI-0546A
	2MS268	Control Cable For 2MS001A-DIV21	2PI-MS194	2MS667	Instrument Cable For 2PI-0525A and 2PI-MS194
	2MS269	Control Cable For 2MS001A-DIV21			
	2MS518	Control Cable For 2MS001A-DIV21			
2MS001B-DIV21	2MS278	Control Cable For 2MS001B-DIV21			
	2MS284	Control Cable For 2MS001B-DIV21			
	2MS566	Control Cable For 2MS001B-DIV21			
	2MS567	Control Cable For 2MS001B-DIV21			
2MS001C-DIV21	2MS291	Control Cable For 2MS001C-DIV21			
	2MS297	Control Cable For 2MS001C-DIV21			
	2MS569	Control Cable For 2MS001C-DIV21			
	2MS570	Control Cable For 2MS001C-DIV21			
2MS001D-DIV21	2MS304	Control Cable For 2MS001D-DIV21			
	2MS305	Control Cable For 2MS001D-DIV21			
	2MS306	Control Cable For 2MS001D-DIV21			
	2MS307	Control Cable For 2MS001D-DIV21			
	2MS308	Control Cable For 2MS001D-DIV21			
	2MS526	Control Cable For 2MS001D-DIV21			
2MS018A	2MS588	Instrument Cable For 2MS018A			
	2MS589	Instrument Cable For 2MS018A			
	2MS590	Instrument Cable For 2MS018A			
	2MS591	Instrument Cable For 2MS018A			
	2MS592	Instrument Cable For 2MS018A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-2					
	2MS593	Instrument Cable For 2MS018A			
	2MS594	Power Cable For 2MS018A			
2MS018D	2MS600	Instrument Cable For 2MS018D			
	2MS601	Instrument Cable For 2MS018D			
	2MS602	Instrument Cable For 2MS018D			
	2MS603	Instrument Cable For 2MS018D			
	2MS604	Instrument Cable For 2MS018D			
	2MS605	Instrument Cable For 2MS018D			
	2MS606	Power Cable For 2MS018D			
2MS101A	2MS321	Control Cable For 2MS101A			
	2MS322	Control Cable For 2MS101A			
	2MS324	Control Cable For 2MS101A			
2MS101B	2MS326	Control Cable For 2MS101B			
	2MS327	Control Cable For 2MS101B			
	2MS329	Control Cable For 2MS101B			
2MS101C	2MS331	Control Cable For 2MS101C			
	2MS332	Control Cable For 2MS101C			
	2MS334	Control Cable For 2MS101C			
2MS101D	2MS336	Control Cable For 2MS101D			
	2MS337	Control Cable For 2MS101D			
	2MS339	Control Cable For 2MS101D			
2PI-0455B	2RC370	Instrument Cable For 2PI-0455B			
2PI-0514A	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193			
2PI-0514B	2MS099	Instrument Cable For 2PI-0514B			
	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193			
2PI-0524A	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
2PI-0524B	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
	2MS103	Instrument Cable For 2PI-0524B			
2PI-0526A	2MS125	Instrument Cable For 2PI-0526A			
2PI-0534A	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.3-2					
2PI-0534B	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
	2MS107	Instrument Cable For 2PI-0534B			
2PI-0536A	2MS126	Instrument Cable For 2PI-0536A			
2PI-0544A	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
2PI-0544B	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
	2MS111	Instrument Cable For 2PI-0544B			
2PI-MS193	2MS665	Instrument Cable For 2PI-0514A, 2PI-0514B, and 2PI-MS193			
2TI-RC005A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC006A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC007A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC008A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
Unit 0 (Common) Components					
-	0VC01CA	Control Room HVAC Supply Fan 0A	NONE		
	0VC02CA	Control Room HVAC Return Fan 0A			
	0VC032Y	Train A Outside Air Damper			
	0VC033Y	Train A Supply Fan 0A Outlet Damper			
	0VC034Y	MCR HVAC Main Supply Duct Fire Damper			
	0VC043Y	Train A Recirculation Charcoal Absorber Bypass Damper			
	0VC102Y	MCR HVAC Main Return Duct Fire Damper			
	0VC17Y	Train A Return Air Fan 0A Inlet Damper			
	0VC18Y	Train A Purge Exhaust Damper to Turbine Bldg			
	0VC19Y	Train A Return Air Fan 0A Outlet Damper			
	0VC20Y	Train A Maximum Outside Air (Purge Line) Inlet Damper			
	0VC281Y	Train A Outside Air Damper			
0SX158B	2SX079	Control Cable For 0SX158B			
0SX162A	1SX345	Control Cable For 0SX162A			
0SX162C	2SX157	Control Cable For 0SX162C			
0SX163A	1SX149	Control Cable For 0SX163A			
0SX163B	1SX153	Control Cable For 0SX163B			
0SX163C	2SX149	Control Cable For 0SX163C			
0SX163D	2SX153	Control Cable For 0SX163D			
0VC01CA	1FP112	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC013	Power Cable For 0VC01CA			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
0VC02CA	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC021	Power Cable For 0VC02CA			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC029	Control Cable For 0VC281Y and 0VC02CA			
	1VC032	Control Cable For 0VC281Y and 0VC02CA			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC146	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC160	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC161	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC163	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC164	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC190	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC191	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC582	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC583	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			

(Sheet 1006)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
0VC033Y	1FP112	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC122	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC123	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC125	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC126	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC128	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC129	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC131	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC132	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

(Sheet 1007)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC134	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC135	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC137	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC138	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC140	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC141	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC143	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC148	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC149	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC151	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC152	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC157	Control Cable For 0VC033Y and 0VC281Y			
	1VC160	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC161	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC162	Control Cable For 0VC033Y and 0VC281Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC163	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC164	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC165	Control Cable For 0VC033Y and 0VC281Y			
	1VC166	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC167	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC168	Control Cable For 0VC033Y and 0VC281Y			
	1VC172	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC173	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC175	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC176	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC178	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC179	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC491	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC571	Control Cable For 0VC033Y and 0VC281Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC043Y	1FP112	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1PR065	Power Cable For 0VC281Y and 0VC043Y			
	1PR066	Power Cable For 0VC281Y and 0VC043Y			
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1PR314	Power Cable For 0VC281Y and 0VC043Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC035	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC122	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC123	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC124	Control Cable For 0VC043Y			
	1VC125	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC126	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC127	Control Cable For 0VC043Y			
	1VC128	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC129	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

(Sheet 1010)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC130	Control Cable For 0VC043Y			
	1VC131	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC132	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC133	Control Cable For 0VC043Y			
	1VC134	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC135	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC136	Control Cable For 0VC043Y			
	1VC137	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC138	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC139	Control Cable For 0VC043Y			
	1VC140	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC141	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC142	Control Cable For 0VC043Y			
	1VC143	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC148	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC149	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC150	Control Cable For 0VC043Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC151	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC152	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC153	Control Cable For 0VC043Y			
	1VC159	Control Cable For 0VC043Y			
	1VC160	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC161	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC163	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC164	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC166	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC167	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC172	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC173	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC175	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC176	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC178	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC179	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC358	Control Cable For 0VC043Y			
	1VC396	Control Cable For 0VC043Y			
	1VC454	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC455	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC491	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC573	Control Cable For 0VC043Y			
	1VC577	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC094Y	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC195	Control Cable For 0VC094Y, 0VC095Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC198	Control Cable For 0VC094Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC095Y	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC195	Control Cable For 0VC094Y, 0VC095Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
0VC133Y	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC201	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC207	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC17Y	1FP112	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC122	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC123	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC125	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC126	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC128	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC129	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC131	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC132	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC134	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC135	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC137	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC138	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC140	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC141	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC143	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC148	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

(Sheet 1015)

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC149	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC151	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC152	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC160	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC161	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC163	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC164	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC166	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC167	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC172	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC173	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC174	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC175	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC176	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC177	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC178	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC179	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC180	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC189	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC192	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC195	Control Cable For 0VC094Y, 0VC095Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC198	Control Cable For 0VC094Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC201	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC207	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC491	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC581	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC643	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC644	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC645	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC646	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC647	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC656	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

(Sheet 1017)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC657	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC658	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC659	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC660	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC18Y	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC035	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC108	Control Cable For 0VC20Y and 0VC18Y			
	1VC111	Control Cable For 0VC20Y and 0VC18Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC146	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC174	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

(Sheet 1018)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC177	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC180	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC181	Control Cable For 0VC20Y and 0VC18Y			
	1VC182	Control Cable For 0VC20Y and 0VC18Y			
	1VC184	Control Cable For 0VC20Y and 0VC18Y			
	1VC185	Control Cable For 0VC20Y and 0VC18Y			
	1VC189	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC190	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC191	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC192	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC195	Control Cable For 0VC094Y, 0VC095Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC198	Control Cable For 0VC094Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC201	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC207	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC454	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC455	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC577	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC581	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC582	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC583	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC635	Control Cable For 0VC20Y and 0VC18Y			
	1VC636	Control Cable For 0VC20Y and 0VC18Y			
	1VC637	Control Cable For 0VC20Y and 0VC18Y			
	1VC638	Control Cable For 0VC20Y and 0VC18Y			
	1VC639	Control Cable For 0VC20Y and 0VC18Y			
	1VC640	Control Cable For 0VC20Y and 0VC18Y			
	1VC641	Control Cable For 0VC20Y and 0VC18Y			
	1VC642	Control Cable For 0VC20Y and 0VC18Y			
	1VC643	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC644	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC645	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC646	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC647	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC648	Control Cable For 0VC20Y and 0VC18Y			
	1VC649	Control Cable For 0VC20Y and 0VC18Y			
	1VC650	Control Cable For 0VC20Y and 0VC18Y			
	1VC651	Control Cable For 0VC20Y and 0VC18Y			
	1VC652	Control Cable For 0VC20Y and 0VC18Y			
	1VC653	Control Cable For 0VC20Y and 0VC18Y			
	1VC654	Control Cable For 0VC20Y and 0VC18Y			
	1VC655	Control Cable For 0VC20Y and 0VC18Y			
	1VC656	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC657	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC658	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC659	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC660	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC19Y	1FP112	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC035	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC122	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC123	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

(Sheet 1021)

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC125	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC126	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC128	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC129	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC131	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC132	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC134	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC135	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC137	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC138	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC140	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC141	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC143	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC148	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC149	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC151	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC152	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC160	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC161	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC163	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC164	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC166	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC167	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC172	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC173	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC174	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC175	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC176	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC177	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC178	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC179	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC180	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC189	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC192	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC195	Control Cable For 0VC094Y, 0VC095Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC198	Control Cable For 0VC094Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC201	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC207	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC454	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC455	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC491	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC577	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC581	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC643	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC644	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC645	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC646	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

(Sheet 1024)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC647	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC656	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC657	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC658	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC659	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC660	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC20Y	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC035	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC108	Control Cable For 0VC20Y and 0VC18Y			
	1VC111	Control Cable For 0VC20Y and 0VC18Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC146	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			

(Sheet 1025)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC174	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC177	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC180	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC181	Control Cable For 0VC20Y and 0VC18Y			
	1VC182	Control Cable For 0VC20Y and 0VC18Y			
	1VC184	Control Cable For 0VC20Y and 0VC18Y			
	1VC185	Control Cable For 0VC20Y and 0VC18Y			
	1VC189	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC190	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC191	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC192	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC195	Control Cable For 0VC094Y, 0VC095Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC198	Control Cable For 0VC094Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC201	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC207	Control Cable For 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC454	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC455	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC577	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC581	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC582	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC583	Control Cable For 0VC20Y, 0VC02CA, and 0VC18Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC635	Control Cable For 0VC20Y and 0VC18Y			
	1VC636	Control Cable For 0VC20Y and 0VC18Y			
	1VC637	Control Cable For 0VC20Y and 0VC18Y			
	1VC638	Control Cable For 0VC20Y and 0VC18Y			
	1VC639	Control Cable For 0VC20Y and 0VC18Y			
	1VC640	Control Cable For 0VC20Y and 0VC18Y			
	1VC641	Control Cable For 0VC20Y and 0VC18Y			
	1VC642	Control Cable For 0VC20Y and 0VC18Y			
	1VC643	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC644	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC645	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC646	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC647	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC648	Control Cable For 0VC20Y and 0VC18Y			
	1VC649	Control Cable For 0VC20Y and 0VC18Y			
	1VC650	Control Cable For 0VC20Y and 0VC18Y			
	1VC651	Control Cable For 0VC20Y and 0VC18Y			
	1VC652	Control Cable For 0VC20Y and 0VC18Y			
	1VC653	Control Cable For 0VC20Y and 0VC18Y			
	1VC654	Control Cable For 0VC20Y and 0VC18Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC655	Control Cable For 0VC20Y and 0VC18Y			
	1VC656	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC657	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC658	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC659	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC660	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC281Y	1FP112	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1FP143	Control Cable For 0VC281Y			
	1FP150	Control Cable For 0VC281Y			
	1PR065	Power Cable For 0VC281Y and 0VC043Y			
	1PR066	Power Cable For 0VC281Y and 0VC043Y			
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1PR314	Power Cable For 0VC281Y and 0VC043Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC017	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC029	Control Cable For 0VC281Y and 0VC02CA			
	1VC030	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			

(Sheet 1028)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC032	Control Cable For 0VC281Y and 0VC02CA			
	1VC035	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC122	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC123	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC125	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC126	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC128	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC129	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC131	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC132	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC134	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC135	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC137	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC138	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC140	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC141	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC143	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC144	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC145	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC147	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC148	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC149	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC151	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC152	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC157	Control Cable For 0VC033Y and 0VC281Y			
	1VC160	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC161	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC162	Control Cable For 0VC033Y and 0VC281Y			
	1VC163	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC164	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC165	Control Cable For 0VC033Y and 0VC281Y			
	1VC166	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC167	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC168	Control Cable For 0VC033Y and 0VC281Y			
	1VC172	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC173	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1VC175	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC176	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC178	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC179	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC454	Control Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC455	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC491	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC571	Control Cable For 0VC033Y and 0VC281Y			
	1VC577	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
Unit 1 Components					
1AF006A	1AF058	Control Cable For 1AF006A			NONE
1AF017A	1AF097	Control Cable For 1AF017A			
1AF01PA	1AF013	Control Cable For 1AF01PA-A and 1AF01PA			
	1AF064	Control Cable For 1AF01PA-A and 1AF01PA			
	1AF293	Control Cable For 1AF01PA			
	1EF026	Control Cable For 1AF01PA			
	1AF01PA-A	1AF013	Control Cable For 1AF01PA-A and 1AF01PA		
	1AF064	Control Cable For 1AF01PA-A and 1AF01PA			
1AP05EA	1AP180	Control Cable For 1AP05EA			
1AP05EC	1SI004	Control Cable For 1AP05EC			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1SI005	Control Cable For 1AP05EC			
1AP05EE	1AP311	Control Cable For 1AP05EE			
	1AP661	Control Cable For 1AP05EE			
1AP05EF	1DG005	Control Cable For 1AP05EF			
	1DG152	Control Cable For 1AP05EF			
	1DG228	Control Cable For 1AP05EF			
1AP05EG	1AP056	Control Cable For 1AP05EG			
	1AP634	Control Cable For 1AP05EG			
1AP05EJ	1CS002	Control Cable For 1AP05EJ			
	1CS004	Control Cable For 1AP05EJ			
	1EF086	Control Cable For 1AP05EJ			
1AP05EK	1WO024	Control Cable For 1AP05EK			
1AP05EP	1AP072	Power Cable For 1AP05EP and 2AP05EJ			
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
1AP05ER	1AP049	Control Cable For 1AP05ER			
	1DG211	Control Cable For 1AP05ER			
1AP07EL	1AP098	Control Cable For 1AP07EL			
1CC9415	1CC067	Control Cable For 1CC9415			
1CC9473A	1CC127	Control Cable For 1CC9473A			
1DG01KA	1DG174	Control Cable For 1DG01KA			
1IP01J	1EF037	Control Cable For 1IP01J			
	1IP005	Power Cable For 1IP01J			
	1IP006	Power Cable For 1IP01J			
1IP03J	1IP033	Power Cable For 1IP03J			
	1IP034	Power Cable For 1IP03J			
1RH01PA	1RH003	Control Cable For 1RH01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-1					
	1RH091	Control Cable For 1RH01PA			
1RH8701A	1RH031	Control Cable For 1RH8701A			
1RH8702A	1RH054	Control Cable For 1RH8702A			
	1RH055	Control Cable For 1RH8702A			
1RY455A	1DC100	Control Cable For 1RY455A			
1RY8000A	1RY394	Control Cable For 1RY8000A			
1UL-AN012-A7	1AN084	Control Cable For 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-B7	1AN084	Control Cable For 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-C7	1AN084	Control Cable For 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1VX04Y	1VE039	Control Cable For 1VX04Y and 1VX05Y			
1VX05C	1VX044	Control Cable For 1VX05C			
1VX05Y	1VE039	Control Cable For 1VX04Y and 1VX05Y			
Unit 2 Components					
2AP05EE	2AP178	Power Cable For 2AP05EE			NONE
	2AP401	Control Cable For 2AP05EE			
2AP05EJ	1AP072	Power Cable For 1AP05EP and 2AP05EJ			
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
2AP93E	2DC242	Control Cable For 2AP99E and 2AP93E			
	2DC244	Control Cable For 2AP99E and 2AP93E			
2AP99E	2DC242	Control Cable For 2AP99E and 2AP93E			
	2DC244	Control Cable For 2AP99E and 2AP93E			
2VX05C	2VX044	Control Cable For 2VX05C			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
Unit 0 (Common) Components					
-	0VC173Y	MCR HVAC Main Supply Duct Fire Damper	-	0VC01CB	Control Room HVAC Supply Fan 0B
-	0VC174Y	MCR HVAC Main Return Duct Fire Damper	-	0VC01Y	Train B Return Air Fan 0B Inlet Damper
0SX02PA	1SX172	Control Cable For 0SX02PA	-	0VC02CB	Control Room HVAC Return Fan 0B
				0VC02Y	Train B Purge Exhaust Damper to Turbine Bldg
				0VC03Y	Train B Return Air Fan 0B Outlet Damper
				0VC044Y	Train B Recirculation Charcoal Absorber Bypass Damper
				0VC04Y	Train B Maximum Outside Air (Purge Line) Inlet Damper
				0VC16Y	Train B Outside Air Damper
				0VC172Y	Train B Supply Fan 0B Outlet Damper
				0VC282Y	Train B Outside Air Damper
			0VC01CB	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC059	Power Cable For 0VC01CB
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
			0VC01Y	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC208	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC209	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC211	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC212	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC213	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC214	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC216	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC217	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC219	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC220	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC222	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC223	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC225	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC226	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC228	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC230	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC231	Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC232	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC233	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC234	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC236	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC237	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC250	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC251	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC253	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC254	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC256	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC257	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC262	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC263	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC264	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC265	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC266	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC267	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC268	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC269	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC270	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC279	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC282	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC285	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC175Y
				1VC288	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC291	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
				1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
				1VC431	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC584	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC669	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC670	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC671	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC672	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC673	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC682	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC683	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC684	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC685	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC686	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC02CB	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC067	Power Cable For 0VC02CB
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC077	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC096	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC229	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC250	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC251	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC253	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC254	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC280	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC281	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC585	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC586	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			0VC02Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC081	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC228	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC229	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC232	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC264	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC267	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC270	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC271	Control Cable For 0VC02Y and 0VC04Y
				1VC272	Control Cable For 0VC02Y and 0VC04Y
				1VC274	Control Cable For 0VC02Y and 0VC04Y
				1VC275	Control Cable For 0VC02Y and 0VC04Y
				1VC277	Control Cable For 0VC02Y and 0VC04Y
				1VC278	Control Cable For 0VC02Y and 0VC04Y
				1VC279	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC280	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC281	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC282	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC285	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC175Y
				1VC288	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
				1VC291	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
				1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
				1VC459	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC460	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC579	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC584	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y

(Sheet 1041)

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC585	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC586	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC661	Control Cable For 0VC02Y and 0VC04Y
				1VC662	Control Cable For 0VC02Y and 0VC04Y
				1VC663	Control Cable For 0VC02Y and 0VC04Y
				1VC664	Control Cable For 0VC02Y and 0VC04Y
				1VC665	Control Cable For 0VC02Y and 0VC04Y
				1VC666	Control Cable For 0VC02Y and 0VC04Y
				1VC667	Control Cable For 0VC02Y and 0VC04Y
				1VC668	Control Cable For 0VC02Y and 0VC04Y
				1VC669	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC670	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC671	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC672	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC673	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC674	Control Cable For 0VC02Y and 0VC04Y
				1VC675	Control Cable For 0VC02Y and 0VC04Y
				1VC676	Control Cable For 0VC02Y and 0VC04Y
				1VC677	Control Cable For 0VC02Y and 0VC04Y
				1VC678	Control Cable For 0VC02Y and 0VC04Y
				1VC679	Control Cable For 0VC02Y and 0VC04Y
				1VC680	Control Cable For 0VC02Y and 0VC04Y
				1VC681	Control Cable For 0VC02Y and 0VC04Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC682	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC683	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC684	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC685	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC686	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC03Y	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			1VC081		Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
			1VC119		Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
			1VC208		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC209		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC211		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC212		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC213		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC214		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC216		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC217		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC219		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC220		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC222		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC223		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC225		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC226		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC228		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC230	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC231	Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC232	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC233	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC234	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC236	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC237	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC250	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC251	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC253	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC254	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC256	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC257	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC262	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC263	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC264	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC265	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC266	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC267	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC268	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC269	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC270	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC279	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC282	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC285	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC175Y
				1VC288	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
				1VC291	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
				1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
				1VC431	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC459	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC460	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC579	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC584	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC669	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC670	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC671	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC672	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC673	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC682	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC683	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC684	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC685	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC686	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC044Y	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC081	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC208	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC209	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC210	Control Cable For 0VC044Y
				1VC211	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC212	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC213	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			1VC214		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC215		Control Cable For 0VC044Y
			1VC216		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC217		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC218		Control Cable For 0VC044Y
			1VC219		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC220		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC221		Control Cable For 0VC044Y
			1VC222		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC223		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC224		Control Cable For 0VC044Y
			1VC225		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC226		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC227		Control Cable For 0VC044Y
			1VC228		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC230		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC231		Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			1VC232		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC233		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			1VC234		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC235		Control Cable For 0VC044Y
			1VC236		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC237		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC238		Control Cable For 0VC044Y
			1VC244		Control Cable For 0VC044Y
			1VC245		Control Cable For 0VC044Y
			1VC250		Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC251		Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC253		Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC254		Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC256		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC257		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC262		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC263		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC265		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC266		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC268		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

(Sheet 1050)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC269	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC431	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC436	Control Cable For 0VC044Y
				1VC459	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC460	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC479	Control Cable For 0VC044Y
				1VC576	Control Cable For 0VC044Y
				1VC579	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			0VC04Y	1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC081	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC228	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			1VC229		Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
			1VC232		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC242		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			1VC264		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			1VC267		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			1VC270		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			1VC271		Control Cable For 0VC02Y and 0VC04Y
			1VC272		Control Cable For 0VC02Y and 0VC04Y
			1VC274		Control Cable For 0VC02Y and 0VC04Y
			1VC275		Control Cable For 0VC02Y and 0VC04Y
			1VC277		Control Cable For 0VC02Y and 0VC04Y
			1VC278		Control Cable For 0VC02Y and 0VC04Y
			1VC279		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			1VC280		Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
			1VC281		Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
			1VC282		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			1VC285		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC175Y
			1VC288		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
			1VC291		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
			1VC297		Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC459	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC460	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC574	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC579	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC584	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC585	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC586	Control Cable For 0VC02CB, 0VC02Y, and 0VC04Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC661	Control Cable For 0VC02Y and 0VC04Y
				1VC662	Control Cable For 0VC02Y and 0VC04Y
				1VC663	Control Cable For 0VC02Y and 0VC04Y
				1VC664	Control Cable For 0VC02Y and 0VC04Y
				1VC665	Control Cable For 0VC02Y and 0VC04Y
				1VC666	Control Cable For 0VC02Y and 0VC04Y
				1VC667	Control Cable For 0VC02Y and 0VC04Y
				1VC668	Control Cable For 0VC02Y and 0VC04Y
				1VC669	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC670	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC671	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC672	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC673	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC674	Control Cable For 0VC02Y and 0VC04Y
				1VC675	Control Cable For 0VC02Y and 0VC04Y
				1VC676	Control Cable For 0VC02Y and 0VC04Y
				1VC677	Control Cable For 0VC02Y and 0VC04Y
				1VC678	Control Cable For 0VC02Y and 0VC04Y
				1VC679	Control Cable For 0VC02Y and 0VC04Y
				1VC680	Control Cable For 0VC02Y and 0VC04Y
				1VC681	Control Cable For 0VC02Y and 0VC04Y
				1VC682	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC683	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC684	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC685	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
				1VC686	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
			0VC16Y	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1FP127	Control Cable For 0VC282Y and 0VC16Y
				1FP158	Control Cable For 0VC282Y and 0VC16Y
				1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC077	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC081	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC096	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC208	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC209	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC211	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC212	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC213	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC214	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			1VC216		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC217		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC219		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC220		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC222		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC223		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC225		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC226		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC228		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC230		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC231		Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			1VC232		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC233		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC234		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC236		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC237		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC243		Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC250	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC251	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC252	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC253	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC254	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC255	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC256	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC257	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC258	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC262	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC263	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC265	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC266	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC268	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC269	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC431	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC459	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC460	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC579	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			0VC172Y	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC208	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC209	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC211	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC212	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC213	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC214	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC216	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC217	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC219	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC220	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC222	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC223	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC225	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC226	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC228	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC230	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC231	Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC232	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC233	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC234	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC236	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC237	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC250	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC251	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC252	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC253	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC254	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC255	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC256	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC257	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC258	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC262	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC263	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC265	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC266	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC268	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC269	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC431	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
		0VC175Y		1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC231	Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC285	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC175Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			0VC182Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC231	Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC288	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
				1VC291	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC182Y
			0VC217Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC231	Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
			0VC282Y	1FP115	Control Cable For 0VC01CB, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1FP127	Control Cable For 0VC282Y and 0VC16Y
				1FP158	Control Cable For 0VC282Y and 0VC16Y
				1PR067	Power Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1PR068	Power Cable For 0VC282Y, 0VC044Y, and 0VC16Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC039	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC065	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC066	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC069	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC070	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC076	Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
				1VC077	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC081	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC096	Control Cable For 0VC282Y, 0VC02CB, and 0VC16Y
				1VC119	Control Cable For 0VC01CB, 0VC01Y, 0VC02CB, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, and 0VC282Y
				1VC208	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC209	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC211	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
			1VC212		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC213		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC214		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC216		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC217		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC219		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC220		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC222		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC223		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC225		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC226		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC228		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC230		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC231		Control Cable For 0VC217Y, 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			1VC232		Control Cable For 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
			1VC233		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
			1VC234		Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC236	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC237	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC250	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC251	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC252	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC253	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC254	Control Cable For 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC255	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC256	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC257	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC258	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC262	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC263	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC265	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC266	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
				1VC268	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC269	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC431	Control Cable For 0VC282Y, 0VC01Y, 0VC03Y, 0VC044Y, 0VC16Y, and 0VC172Y
				1VC459	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC460	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC575	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
				1VC579	Control Cable For 0VC282Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, and 0VC16Y
				1VC614	Control Cable For 0VC02CB, 0VC282Y, 0VC01Y, 0VC02Y, 0VC03Y, 0VC044Y, 0VC04Y, 0VC16Y, and 0VC172Y
Unit 1 Components					
1AP05EP	1AP072	Power Cable For 1AP05EP and 2AP05EJ	NONE		
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
Unit 2 Components					
2AF01PA	2AF013	Control Cable For 2AF01PA-A and 2AF01PA	NONE		
	2AF064	Control Cable For 2AF01PA-A and 2AF01PA			
	2EF026	Control Cable For 2AF01PA			
2AF01PA-A	2AF013	Control Cable For 2AF01PA-A and 2AF01PA			
	2AF064	Control Cable For 2AF01PA-A and 2AF01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
2AP05ED	2AP082	Control Cable For 2AP05ED			
2AP05EE	2AP178	Power Cable For 2AP05EE			
2AP05EG	2AP049	Control Cable For 2AP05EG			
	2AP050	Control Cable For 2AP05EG			
	2AP312	Control Cable For 2AP05EG			
	2DG211	Control Cable For 2AP05EG and 2AP05ES			
2AP05EJ	1AP072	Power Cable For 1AP05EP and 2AP05EJ			
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP075	Control Cable For 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
2AP05EP	2CS002	Control Cable For 2AP05EP			
	2EF086	Control Cable For 2AP05EP			
2AP05ER	2AP634	Control Cable For 2AP05ER			
2AP05ES	2DG005	Control Cable For 2AP05ES			
	2DG019	Control Cable For 2DG01KA and 2AP05ES			
	2DG152	Control Cable For 2AP05ES			
	2DG211	Control Cable For 2AP05EG and 2AP05ES			
	2DG228	Control Cable For 2AP05ES			
2AP05EV	2SI004	Control Cable For 2AP05EV			
2AP07EE	2AP098	Control Cable For 2AP07EE			
	2AP141	Control Cable For 2AP07EE			
2AP93E	2DC242	Control Cable For 2AP99E and 2AP93E			
2AP99E	2DC242	Control Cable For 2AP99E and 2AP93E			
2DG01KA	2DG017	Control Cable For 2DG01KA			
	2DG018	Control Cable For 2DG01KA			
	2DG019	Control Cable For 2DG01KA and 2AP05ES			
	2DG157	Control Cable For 2DG01KA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.4-2					
	2DG175	Control Cable For 2DG01KA			
	2DG200	Control Cable For 2DG01KA			
2IP01J	2EF037	Control Cable For 2IP01J			
	2IP005	Power Cable For 2IP01J			
	2IP006	Power Cable For 2IP01J			
2IP03J	2IP033	Power Cable For 2IP03J			
	2IP034	Power Cable For 2IP03J			
2RY455A	2DC100	Control Cable For 2RY455A			
2SX169A	2SX295	Control Cable For 2SX169A			
2UL-AN012-A7	2AN084	Control Cable For 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-B7	2AN084	Control Cable For 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-C7	2AN084	Control Cable For 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2VP01CC	2VP063	Control Cable For 2VP01CC			
2VX04C	2VX004	Control Cable For 2VX04C			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.5-1					
Unit 0 (Common) Components					
NONE				NONE	
Unit 1 Components					
NONE				NONE	
Unit 2 Components					
NONE				NONE	

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.5-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10A-1					
Unit 0 (Common) Components					
		NONE			NONE
Unit 1 Components					
		NONE			NONE
Unit 2 Components					
		NONE			NONE

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10A-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10B-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10B-2					
Unit 0 (Common) Components			NONE		
NONE					
Unit 1 Components			NONE		
NONE					
Unit 2 Components			NONE		
NONE					

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10C-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10C-2					
Unit 0 (Common) Components					
NONE				NONE	
Unit 1 Components					
NONE				NONE	
Unit 2 Components					
NONE				NONE	

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10D-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10D-2					
Unit 0 (Common) Components			NONE		
NONE					
Unit 1 Components			NONE		
NONE					
Unit 2 Components			NONE		
NONE					

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10E-1					
Unit 0 (Common) Components			NONE		
NONE					
Unit 1 Components					
1AP05ER	1APBU1	Power Cable For 1AP05ER	1AP06ES	1APBU3	Power Cable For 1AP06ES
Unit 2 Components			NONE		
NONE					

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.10E-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
2AP05EG	2APBU1	Power Cable For 2AP05EG	2AP06EF	2APBU3	Power Cable For 2AP06EF

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.11-0					
Unit 0 (Common) Components					
-	0SX02PA	Essential Service Water Makeup Pump 0A	-	0SX02PB	Essential Service Water Makeup Pump 0B
	0SX02PA-K	Diesel Engine for Essential Service Water Makeup Pump 0A	0SX02PB	1SX097	Control Cable For 0SX02PB
	0SX02PB-K	Diesel Engine for Essential Service Water Makeup Pump 0B		1SX334	Control Cable For 0SX02PB
	0SX03AA	ESW Makeup Pump 0A Diesel Jacket Water Heat Exchanger		1SX352	Control Cable For 0SX02PB
	0SX03AB	ESW Makeup Pump 0B Diesel Jacket Water Heat Exchanger		1SX354	Instrument Cable For 0SX02PB
	0SX04AA	ESW Makeup Pump 0A Diesel Gear Oil Cooler		1SX451	Power Cable For 0SX02PB
	0SX04AB	ESW Makeup Pump 0B Diesel Gear Oil Cooler		1SX452	Power Cable For 0SX02PB
0SX02PA	1SX172	Control Cable For 0SX02PA		1SX459	Power Cable For 0SX02PB
	1SX338	Control Cable For 0SX02PA		1SX460	Power Cable For 0SX02PB
	1SX363	Control Cable For 0SX02PA		1SX537	Power Cable For 0SX02PB
	1SX364	Instrument Cable For 0SX02PA		1SX538	Power Cable For 0SX02PB
	1SX453	Power Cable For 0SX02PA		1SX539	Power Cable For 0SX02PB
	1SX454	Power Cable For 0SX02PA		1SX540	Power Cable For 0SX02PB
	1SX461	Power Cable For 0SX02PA		1SX571	Control Cable For 0SX02PB
	1SX462	Power Cable For 0SX02PA			
	1SX541	Power Cable For 0SX02PA			
	1SX542	Power Cable For 0SX02PA			
	1SX543	Power Cable For 0SX02PA			
	1SX544	Power Cable For 0SX02PA			
	1SX572	Control Cable For 0SX02PA			
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.11-1					
Unit 0 (Common) Components					
-	ODO08TB	SX Makeup Pump Diesel Oil Storage Tank 0A			NONE
Unit 1 Components					
					NONE
Unit 2 Components					
					NONE

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.11-2					
Unit 0 (Common) Components					
-	ODO08TA	SX Makeup Pump Diesel Oil Storage Tank 0A	NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14A-1					
Unit 0 (Common) Components					
NONE			0SX02PB	1SX168 1SX250 1SX268	Control Cable For 0SX02PB and 0SX162B Control Cable For 0SX02PB Control Cable For 0SX02PB
			0SX157A	1SX080 1SX084 1SX085	Power Cable For 0SX157A Control Cable For 0SX157A Control Cable For 0SX157A
			0SX162B	1SX167 1SX168 1SX169	Power Cable For 0SX162B Control Cable For 0SX02PB and 0SX162B Control Cable For 0SX162B
			0SX163E	1SX161	Control Cable For 0SX163E
			0SX163F	1SX165	Control Cable For 0SX163F
Unit 1 Components					
NONE				1AP92E	Division 12 480V ESW Cooling Tower MCC 132Z1
				1AP98E	Division 12 480V ESF Unit Substation 132Z
				1VX06C	ESW Cooling Tower 0B Division 12 Electric Substation Bus 132Z Supply Fan
				1VX33Y	ESW Cooling Tower 0B Division 12 Electric Substation Bus 132Z Outside Air Intake
				1VX35Y	ESW Cooling Tower 0B Division 12 Electric Substation Bus 132Z Return Air Damper
			1AP06EN	1AP183	Power Cable For 1AP06EN
				1AP406	Control Cable For 1AP06EN
			1AP92E	1AP290	Power Cable For 1AP92E
				1DC243	Control Cable For 1AP98E and 1AP92E
				1DC245	Control Cable For 1AP98E and 1AP92E
			1AP98E	1APBU5	Power Cable For 1AP98E
				1DC243	Control Cable For 1AP98E and 1AP92E
				1DC245	Control Cable For 1AP98E and 1AP92E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14A-1					
			1VX06C	1VX045 1VX046	Power Cable For 1VX06C Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX049 1VX050	Control Cable For 1VX06C Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX054	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
			1VX33Y	1VX046	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX050	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX052	Control Cable For 1VX33Y and 1VX35Y
				1VX054	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX055	Control Cable For 1VX33Y and 1VX35Y
				1VX056	Control Cable For 1VX33Y and 1VX35Y
				1VX085	Instrument Cable For 1VX33Y and 1VX35Y
				1VX087	Instrument Cable For 1VX33Y and 1VX35Y
				1VX088	Instrument Cable For 1VX33Y and 1VX35Y
				1VX094	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
			1VX35Y	1VX046	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX050	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX052	Control Cable For 1VX33Y and 1VX35Y
				1VX054	Control Cable For 1VX06C, 1VX33Y, and 1VX35Y
				1VX055	Control Cable For 1VX33Y and 1VX35Y
				1VX056	Control Cable For 1VX33Y and 1VX35Y
				1VX085	Instrument Cable For 1VX33Y and 1VX35Y
				1VX087	Instrument Cable For 1VX33Y and 1VX35Y
				1VX088	Instrument Cable For 1VX33Y and 1VX35Y
				1VX094	Control Cable For 1VX33Y and 1VX35Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14A-1					
Unit 2 Components			NONE		
NONE					

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14A-2					
Unit 0 (Common) Components					
NONE			0SX157B	2SX080 2SX084 2SX085	Power Cable For 0SX157B Control Cable For 0SX157B Control Cable For 0SX157B
			0SX162D	2SX167 2SX168 2SX169	Power Cable For 0SX162D Control Cable For 0SX162D Control Cable For 0SX162D
			0SX163G	2SX161	Control Cable For 0SX163G
			0SX163H	2SX165	Control Cable For 0SX163H
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			-	2AP92E	Division 22 480V ESW Cooling Tower MCC 232Z1
				2AP98E	Division 22 480V ESF Unit Substation 232Z
				2VX06C	ESW Cooling Tower 0B Division 22 Electric Substation Bus 232Z Supply Fan
				2VX33Y	ESW Cooling Tower 0B Division 22 Electric Substation Bus 232Z Outside Air Intake
				2VX35Y	ESW Cooling Tower 0B Division 22 Electric Substation Bus 232Z Return Air Damper
			2AP06EV	2AP183	Power Cable For 2AP06EV
				2AP406	Control Cable For 2AP06EV
			2AP92E	2AP290	Power Cable For 2AP92E
				2DC243	Control Cable For 2AP98E and 2AP92E
				2DC245	Control Cable For 2AP98E and 2AP92E
			2AP98E	2APBU5	Power Cable For 2AP98E
				2DC243	Control Cable For 2AP98E and 2AP92E
				2DC245	Control Cable For 2AP98E and 2AP92E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14A-2					
			2VX06C	2VX045 2VX046 2VX049 2VX050 2VX054	Power Cable For 2VX06C Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX06C Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX06C, 2VX33Y, and 2VX35Y
			2VX33Y	2VX046 2VX050 2VX052 2VX054 2VX055 2VX056 2VX085 2VX087 2VX088 2VX094	Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX33Y and 2VX35Y Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX33Y and 2VX35Y Control Cable For 2VX33Y and 2VX35Y Instrument Cable For 2VX33Y and 2VX35Y Instrument Cable For 2VX33Y and 2VX35Y Instrument Cable For 2VX33Y and 2VX35Y Control Cable For 2VX33Y and 2VX35Y
			2VX35Y	2VX046 2VX050 2VX052 2VX054 2VX055 2VX056 2VX085 2VX087 2VX088 2VX094	Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX33Y and 2VX35Y Control Cable For 2VX06C, 2VX33Y, and 2VX35Y Control Cable For 2VX33Y and 2VX35Y Control Cable For 2VX33Y and 2VX35Y Instrument Cable For 2VX33Y and 2VX35Y Instrument Cable For 2VX33Y and 2VX35Y Instrument Cable For 2VX33Y and 2VX35Y Control Cable For 2VX33Y and 2VX35Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description

Fire Zone Number: 18.14A-2

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14B-1					
Unit 0 (Common) Components					
0SX02PA	1SX156	Control Cable For 0SX02PA and 0SX162A	NONE		
	1SX251	Control Cable For 0SX02PA			
	1SX258	Control Cable For 0SX02PA			
0SX158A	1SX077	Power Cable For 0SX158A			
	1SX078	Control Cable For 0SX158A			
	1SX079	Control Cable For 0SX158A			
0SX162A	1SX155	Power Cable For 0SX162A			
	1SX156	Control Cable For 0SX02PA and 0SX162A			
	1SX157	Control Cable For 0SX162A			
0SX163A	1SX149	Control Cable For 0SX163A			
0SX163B	1SX153	Control Cable For 0SX163B			
Unit 1 Components					
-	1AP93E	Division 11 480V ESW Cooling Tower MCC 131Z1	NONE		
	1AP99E	Division 11 480V ESF Unit Substation 131Z			
	1VX05C	ESW Cooling Tower 0A Division 11 Electric Substation Bus 131Z Supply Fan			
	1VX30Y	ESW Cooling Tower 0A Division 11 Electric Substation Bus 131Z Outside Air Intake			
	1VX32Y	ESW Cooling Tower 0A Division 11 Electric Substation Bus 131Z Return Air Damper			
1AP05EA	1AP178	Power Cable For 1AP05EA			
	1AP401	Control Cable For 1AP05EA			
1AP93E	1AP288	Power Cable For 1AP93E			
	1DC242	Control Cable For 1AP99E and 1AP93E			
	1DC244	Control Cable For 1AP99E and 1AP93E			
1AP99E	1APBU6	Power Cable For 1AP99E			
	1DC242	Control Cable For 1AP99E and 1AP93E			
	1DC244	Control Cable For 1AP99E and 1AP93E			

(Sheet 1090)

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14B-1					
1VX05C	1VX011	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX016	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX040 1VX041	Power Cable For 1VX05C Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
1VX30Y	1VX044	Control Cable For 1VX05C			
	1VX011	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX013	Control Cable For 1VX30Y and 1VX32Y			
	1VX014	Control Cable For 1VX30Y and 1VX32Y			
	1VX016	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX017	Control Cable For 1VX30Y and 1VX32Y			
	1VX041	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
1VX32Y	1VX081	Instrument Cable For 1VX30Y and 1VX32Y			
	1VX083	Instrument Cable For 1VX30Y and 1VX32Y			
	1VX084	Instrument Cable For 1VX30Y and 1VX32Y			
	1VX090	Control Cable For 1VX30Y and 1VX32Y			
	1VX011	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX013	Control Cable For 1VX30Y and 1VX32Y			
	1VX014	Control Cable For 1VX30Y and 1VX32Y			
	1VX016	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX017	Control Cable For 1VX30Y and 1VX32Y			
	1VX041	Control Cable For 1VX05C, 1VX30Y, and 1VX32Y			
	1VX081	Instrument Cable For 1VX30Y and 1VX32Y			
	1VX083	Instrument Cable For 1VX30Y and 1VX32Y			
	1VX084	Instrument Cable For 1VX30Y and 1VX32Y			
	1VX090	Control Cable For 1VX30Y and 1VX32Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14B-1					
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14B-2					
Unit 0 (Common) Components					
0SX158B	2SX077	Power Cable For 0SX158B			NONE
	2SX078	Control Cable For 0SX158B			
	2SX079	Control Cable For 0SX158B			
0SX162C	2SX155	Power Cable For 0SX162C			
	2SX156	Control Cable For 0SX162C			
	2SX157	Control Cable For 0SX162C			
0SX163C	2SX149	Control Cable For 0SX163C			
0SX163D	2SX153	Control Cable For 0SX163D			
Unit 1 Components					
					NONE
Unit 2 Components					
	2AP93E	Division 11 480V ESW Cooling Tower MCC 231Z1			NONE
	2AP99E	Division 21 480V ESF Unit Substation 231Z			
	2VX05C	ESW Cooling Tower 0A Division 21 Electric Substation Bus 231Z Supply Fan			
	2VX30Y	ESW Cooling Tower 0A Division 21 Electric Substation Bus 231Z Outside Air Intake			
	2VX32Y	ESW Cooling Tower 0A Division 21 Electric Substation Bus 231Z Return Air Damper			
2AP05EE	2AP178	Power Cable For 2AP05EE			
	2AP401	Control Cable For 2AP05EE			
2AP93E	2AP288	Power Cable For 2AP93E			
	2DC242	Control Cable For 2AP99E and 2AP93E			
	2DC244	Control Cable For 2AP99E and 2AP93E			
2AP99E	2APBU6	Power Cable For 2AP99E			
	2DC242	Control Cable For 2AP99E and 2AP93E			
	2DC244	Control Cable For 2AP99E and 2AP93E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.14B-2					
2VX05C	2VX011	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX016	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX040	Power Cable For 2VX05C			
	2VX041	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
2VX30Y	2VX044	Control Cable For 2VX05C			
	2VX011	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX013	Control Cable For 2VX30Y and 2VX32Y			
	2VX014	Control Cable For 2VX30Y and 2VX32Y			
	2VX016	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX017	Control Cable For 2VX30Y and 2VX32Y			
	2VX041	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX081	Instrument Cable For 2VX30Y and 2VX32Y			
2VX32Y	2VX083	Instrument Cable For 2VX30Y and 2VX32Y			
	2VX084	Instrument Cable For 2VX30Y and 2VX32Y			
	2VX090	Control Cable For 2VX30Y and 2VX32Y			
	2VX011	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX013	Control Cable For 2VX30Y and 2VX32Y			
	2VX014	Control Cable For 2VX30Y and 2VX32Y			
	2VX016	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX017	Control Cable For 2VX30Y and 2VX32Y			
	2VX041	Control Cable For 2VX05C, 2VX30Y, and 2VX32Y			
	2VX081	Instrument Cable For 2VX30Y and 2VX32Y			
2VX083	Instrument Cable For 2VX30Y and 2VX32Y				
2VX084	Instrument Cable For 2VX30Y and 2VX32Y				
2VX090	Control Cable For 2VX30Y and 2VX32Y				

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description

Fire Zone Number: 18.14B-2

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.23-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
-	1CD01T	Unit 1 Condensate Storage Tank	NONE		
Unit 2 Components					
-	2CD01T	Unit 2 Condensate Storage Tank	NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 18.39-0					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
NONE			NONE		