

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
Unit 0 (Common) Components					
-	0VC140Y	Unit 2 Main Control Room Supply Flow Control Damper	-	0VC217Y	Unit 2 Main Control Room Return Flow Control Damper
	0VC141Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC01Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	0VC142Y	Unit 2 Main Control Room Supply Duct Fire Damper		1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
	0VC143Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC02Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	0VC144Y	Unit 2 Main Control Room Supply Duct Fire Damper		1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
	0VC145Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC03Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	0VC146Y	Unit 2 Main Control Room Supply Duct Fire Damper		1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
	0VC147Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC044Y	1VC244	Control Cable For 0VC044Y
	0VC148Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC04Y	1VC242	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, and 0VC04Y
	0VC149Y	Unit 2 Main Control Room Supply Duct Fire Damper		1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
	0VC150Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC16Y	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	0VC151Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC172Y	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	0VC152Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC217Y	1VC297	Control Cable For 0VC01Y, 0VC02Y, 0VC03Y, 0VC04Y, and 0VC217Y
	0VC153Y	Unit 2 Main Control Room Supply Duct Fire Damper	0VC282Y	1VC243	Control Cable For 0VC16Y, 0VC172Y, and 0VC282Y
	0VC154Y	Unit 2 Main Control Room Supply Duct Fire Damper			
	0VC155Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC161Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
	0VC162Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC163Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC164Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC165Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC166Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC167Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC168Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC169Y	Unit 2 Main Control Room Exhaust Duct Fire Damper			
	0VC170Y	MCR HVAC Main Supply Duct Fire Damper			
	0VC171Y	MCR HVAC Main Return Duct Fire Damper			
	0VC240Y	MCR HVAC Main Supply Duct Fire Damper			
	0VC242Y	MCR HVAC Main Return Duct Fire Damper			
0AB03P(2)	2AB006	Control Cable For 0AB03P(2) and 2AB03P			
0CC01E-B	2CC023	Control Cable For 0CC01E-B			
	2CC174	Control Cable For 0CC01E-B			
0SX02PA	1SX172	Control Cable For 0SX02PA			
0SX158B	2SX079	Control Cable For 0SX158B			
0SX162C	2SX157	Control Cable For 0SX162C			
	2SX158	Control Cable For 0SX162C			
	2SX345	Control Cable For 0SX162C			
0SX163C	2SX149	Control Cable For 0SX163C			
0SX163D	2SX153	Control Cable For 0SX163D			
0VA01CC	2VA003	Control Cable For 0VA01CC			
	2VA013	Control Cable For 0VA01CC and 0VA02CC			
	2VA028	Control Cable For 0VA01CC and 0VA476Y			
	2VA738	Control Cable For 0VA01CC and 0VA02CC			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
0VA02CC	2VA013	Control Cable For 0VA01CC and 0VA02CC			
	2VA024	Control Cable For 0VA02CC and 0VA476Y			
	2VA738	Control Cable For 0VA01CC and 0VA02CC			
0VA476Y	2VA024	Control Cable For 0VA02CC and 0VA476Y			
	2VA028	Control Cable For 0VA01CC and 0VA476Y			
	2VA033	Control Cable For 0VA476Y			
0VC043Y	1VC722	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	2VC700	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
0VC18Y	1VC722	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	2VC700	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
0VC19Y	1VC722	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	2VC700	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
0VC20Y	1VC722	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	2VC700	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
0VC281Y	1VC722	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
	2VC700	Control Cable For 0VC19Y, 0VC20Y, 0VC281Y, 0VC043Y, and 0VC18Y			
Unit 1 Components					
1AP05EP	1AP072	Power Cable For 1AP05EP and 2AP05EJ	NONE		
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
Unit 2 Components					
2AB03P	2AB006	Control Cable For 0AB03P(2) and 2AB03P	NONE		
2AF005A	2AF170	Instrument Cable For 2AF005A			
	2IP016	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, and 2IP01J			
2AF005B	2AF179	Instrument Cable For 2AF005B			
	2IP016	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, and 2IP01J			
2AF005C	2AF180	Instrument Cable For 2AF005C			
	2IP016	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, and 2IP01J			
2AF005D	2AF181	Instrument Cable For 2AF005D			
	2IP016	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, and 2IP01J			
2AF006A	2AF058	Control Cable For 2AF006A			
2AF013A	2AF024	Control Cable For 2AF013A			
2AF013B	2AF028	Control Cable For 2AF013B			
2AF013C	2AF032	Control Cable For 2AF013C			
2AF013D	2AF036	Control Cable For 2AF013D			
2AF017A	2AF097	Control Cable For 2AF017A			
2AF01PA	2AF008	Control Cable For 2AF01PA			
	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			
2AF01PA-A	2AF019	Control Cable For 2AF01PA-A			
	2EF011	Control Cable For 2AF01PA-A			
2AP05ED	2AP082	Control Cable For 2AP05ED			
	2AP395	Control Cable For 2AP05ED			
2AP05EE	2AP178	Power Cable For 2AP05EE			
	2AP180	Control Cable For 2AP05EE			
	2AP401	Control Cable For 2AP05EE			
2AP05EG	2AP050	Control Cable For 2AP05EG			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
2AP05EJ	2AP312	Control Cable For 2AP05EG			
	2DG211	Control Cable For 2AP05EG and 2AP05ES			
	1AP072	Power Cable For 1AP05EP and 2AP05EJ			
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
2AP05EP	2AP075	Control Cable For 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
	2CS004	Control Cable For 2AP05EP			
	2CS006	Control Cable For 2AP05EP			
	2CS025	Control Cable For 2AP05EP			
	2CS041	Control Cable For 2AP05EP			
	2CS042	Control Cable For 2AP05EP			
	2CS055	Control Cable For 2AP05EP and 2CS009A			
2AP05ER	2AP056	Control Cable For 2AP05ER			
2AP05ES	2DG005	Control Cable For 2AP05ES			
	2DG019	Control Cable For 2DG01KA and 2AP05ES			
	2DG211	Control Cable For 2AP05EG and 2AP05ES			
2AP05ET	2AP311	Control Cable For 2AP05ET			
2AP05EV	2EF029	Control Cable For 2AP05EV and 2RH01PA			
	2SI004	Control Cable For 2AP05EV			
	2SI005	Control Cable For 2AP05EV			
2AP07EE	2AP098	Control Cable For 2AP07EE			
	2AP141	Control Cable For 2AP07EE			
	2AP142	Control Cable For 2AP07EE			
	2AP376	Control Cable For 2AP14E			
2AP14E	2AP376	Control Cable For 2AP14E			
2AP21EA	2SI517	Control Cable For 2AP21EA			
2AP93E	2DC242	Control Cable For 2AP99E and 2AP93E			
	2DC244	Control Cable For 2AP99E and 2AP93E			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
2AP99E	2DC242	Control Cable For 2AP99E and 2AP93E			
	2DC244	Control Cable For 2AP99E and 2AP93E			
2CC01PA	2CC002	Control Cable For 2CC01PA			
	2CC004	Control Cable For 2CC01PA			
2CC9412A	2CC045	Control Cable For 2CC9412A			
2CC9413A	2CC051	Control Cable For 2CC9413A			
	2CC053	Control Cable For 2CC9413A			
2CC9415	2CC067	Control Cable For 2CC9415			
2CC9416	2CC059	Control Cable For 2CC9416			
	2CC061	Control Cable For 2CC9416			
2CC9438	2CC036	Control Cable For 2CC9438			
	2CC037	Control Cable For 2CC9438			
2CC9473A	2CC127	Control Cable For 2CC9473A			
2CS009A	2CS055	Control Cable For 2AP05EP and 2CS009A			
2CV01PA	2CV009	Control Cable For 2CV01PA			
2CV112B	2CV060	Control Cable For 2CV112B and 2CV8110			
	2CV067	Control Cable For 2CV112B			
2CV112D	2CV080	Control Cable For 2CV112D			
	2CV081	Control Cable For 2CV112D			
2CV8110	2CV059	Control Cable For 2CV8110			
	2CV060	Control Cable For 2CV112B and 2CV8110			
2CV8114	2CV641	Control Cable For 2CV8114			
	2CV645	Control Cable For 2CV8114			
2CV8355A	2CV611	Control Cable For 2CV8355A			
2CV8355D	2CV614	Control Cable For 2CV8355D			
2CV8804A	2CV407	Control Cable For 2CV8804A			
2DG01KA	2DG017	Control Cable For 2DG01KA			
	2DG018	Control Cable For 2DG01KA			
	2DG019	Control Cable For 2DG01KA and 2AP05ES			
	2DG153	Control Cable For 2DG01KA			
	2DG200	Control Cable For 2DG01KA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
2ESFComp21	2EF012	Control Cable For 2ESFComp21			
	2EF016	Control Cable For 2ESFComp21			
2IP01J	2IP016	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, and 2IP01J			
	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR198	Control Cable For 2IP01J and 2NI-0031B			
2IP03J	2IP067	Control Cable For 2IP03J			
	2NR201	Control Cable For 2IP03J			
	2NR202	Control Cable For 2IP03J			
2LI-0459A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2LI-0461	2RY324	Instrument Cable For 2LI-0461, 2LI-0504A, 2LI-0932, 2PI-0526A, 2PI-0536A, and 2TI-0604			
2LI-0501A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2LI-0504A	2RY324	Instrument Cable For 2LI-0461, 2LI-0504A, 2LI-0932, 2PI-0526A, 2PI-0536A, and 2TI-0604			
2LI-0930	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2LI-0932	2RY324	Instrument Cable For 2LI-0461, 2LI-0504A, 2LI-0932, 2PI-0526A, 2PI-0536A, and 2TI-0604			
2LL-SI075A	2SI234	Control Cable For 2LL-SI075A			
2MS001A-DIV21	2MS275	Control Cable For 2MS001A-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001B-DIV21	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
	2MS288	Control Cable For 2MS001B-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001C-DIV21	2AF121	Control Cable For 2MS001C-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS524	Control Cable For 2MS001C-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS001D-DIV21	2MS527	Control Cable For 2MS001D-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS018A	2MS574	Instrument Cable For 2MS018A			
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS639	Instrument Cable For 2MS018A			
2MS018D	2MS575	Instrument Cable For 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			
2MS101A	2MS318	Control Cable For 2MS101A, 2MS101B, 2MS101C, and 2MS101D			
	2MS321	Control Cable For 2MS101A			
2MS101B	2MS318	Control Cable For 2MS101A, 2MS101B, 2MS101C, and 2MS101D			
	2MS326	Control Cable For 2MS101B			
2MS101C	2MS318	Control Cable For 2MS101A, 2MS101B, 2MS101C, and 2MS101D			
	2MS331	Control Cable For 2MS101C			
2MS101D	2MS318	Control Cable For 2MS101A, 2MS101B, 2MS101C, and 2MS101D			
	2MS336	Control Cable For 2MS101D			
2NI-0031B	2NR133	Instrument Cable For 2NI-0031B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
	2NR135	Instrument Cable For 2NI-0031B			
	2NR136	Instrument Cable For 2NI-0031B			
	2NR146	Control Cable For 2NI-0031B			
	2NR147	Control Cable For 2NI-0031B			
	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR198	Control Cable For 2IP01J and 2NI-0031B			
	2NR234	Instrument Cable For 2NI-0031B			
2NI-NR005B	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR246	Instrument Cable For 2NI-NR005B			
2NI-NR005D	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
2PI-0405	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0455A	2RC491	Instrument Cable For 2PI-0455A, 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2PI-0457	2RC503	Instrument Cable For 2PI-0457			
2PI-0514A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0524A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0526A	2RY324	Instrument Cable For 2LI-0461, 2LI-0504A, 2LI-0932, 2PI-0526A, 2PI-0536A, and 2TI-0604			
2PI-0534A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0536A	2RY324	Instrument Cable For 2LI-0461, 2LI-0504A, 2LI-0932, 2PI-0526A, 2PI-0536A, and 2TI-0604			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
2PI-0544A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-CC107	2CC314	Control Cable For 2PI-CC107			
	2CC315	Instrument Cable For 2PI-CC107			
	2CC330	Instrument Cable For 2PI-CC107			
	2LV002	Control Cable For 2PI-CC107			
2RC014A	2RC622	Control Cable For 2RC014A			
2RC014C	2RC628	Control Cable For 2RC014C			
2RH01PA	2EF029	Control Cable For 2AP05EV and 2RH01PA			
	2RH003	Control Cable For 2RH01PA			
	2RH091	Control Cable For 2RH01PA			
2RH610	2RH017	Control Cable For 2RH610			
2RH8701A	2RH031	Control Cable For 2RH8701A			
2RH8702A	2RH055	Control Cable For 2RH8702A			
2RH8716A	2RH069	Control Cable For 2RH8716A			
2RY455A	2DC100	Control Cable For 2RY455A			
	2RY418	Control Cable For 2RY455A			
	2RY486	Control Cable For 2RY455A			
2RY8000A	2RY394	Control Cable For 2RY8000A			
2SI8801A	2SI017	Control Cable For 2SI8801A			
	2SI035	Control Cable For 2SI8801A			
2SI8806	2SI077	Control Cable For 2SI8806			
2SI8807A	2SI081	Control Cable For 2SI8807A			
2SI8809A	2SI134	Control Cable For 2SI8809A			
2SI8811A	2SI152	Control Cable For 2SI8811A			
	2SI513	Control Cable For 2SI8811A			
	2SI521	Control Cable For 2SI8811A			
2SI8812A	2SI170	Control Cable For 2SI8812A			
2SI8840	2SI211	Control Cable For 2SI8840			
2SI8923A	2SI199	Control Cable For 2SI8923A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
2SX001A	2SX033	Control Cable For 2SX001A			
2SX004	2SX041	Control Cable For 2SX004			
2SX016A	2SX053	Control Cable For 2SX016A			
2SX01PA	2SX008	Control Cable For 2SX01PA			
2SX01PA-C	2SX312	Control Cable For 2SX01PA-C			
2SX027A	2SX059	Control Cable For 2SX027A			
2SX033	2SX065	Control Cable For 2SX033			
2SX147A	2LV033	Control Cable For 2SX147A			
	2SX177	Control Cable For 2SX147A			
	2SX178	Control Cable For 2SX147A			
2SX169A	2SX295	Control Cable For 2SX169A			
2TJ-0413A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0423A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0433A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0443A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0604	2RY324	Instrument Cable For 2LI-0461, 2LI-0504A, 2LI-0932, 2PI-0526A, 2PI-0536A, and 2TI-0604			
2TI-IT001	2IT421	Instrument Cable For 2TI-IT001			
	2RC648	Control Cable For 2TI-IT001			
2TI-RC005A	2RC491	Instrument Cable For 2PI-0455A, 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3C-2					
2TI-RC006A	2RC491	Instrument Cable For 2PI-0455A, 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC007A	2RC491	Instrument Cable For 2PI-0455A, 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC008A	2RC491	Instrument Cable For 2PI-0455A, 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2VD01CA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP016	Control Cable For 2VP01CA			
	2VP019	Control Cable For 2VP01CA			
2VP01CC	2VP060	Control Cable For 2VP01CC			
	2VP063	Control Cable For 2VP01CC			
2VX04C	2VX004	Control Cable For 2VX04C			
2VX05C	2VX044	Control Cable For 2VX05C			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
Unit 0 (Common) Components					
0AB03P(1)	1AB005	Control Cable For 0AB03P(1) and 1AB03P			NONE
	1AB006	Control Cable For 0AB03P(1) and 1AB03P			
0CC01E-A	1CC006	Control Cable For 0CC01E-A and 1CC01PA			
	1CC023	Control Cable For 0CC01E-A			
	1CC174	Control Cable For 0CC01E-A			
	1EF027	Control Cable For 0CC01E-A			
	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031			
0FI-SX044					
0SX02PA	1SX172	Control Cable For 0SX02PA			
	1SX205	Control Cable For 0SX02PA			
	1SX206	Control Cable For 0SX02PA			
	1SX258	Control Cable For 0SX02PA			
0SX158A	1SX079	Control Cable For 0SX158A			
0SX162A	1SX158	Control Cable For 0SX162A			
0VA01CA	1VA002	Control Cable For 0VA01CA			
	1VA003	Control Cable For 0VA01CA			
	1VA034	Control Cable For 0VA01CA and 0VA474Y			
0VA02CA	1VA013	Control Cable For 0VA02CA			
	1VA017	Control Cable For 0VA02CA			
0VA474Y	1VA027	Control Cable For 0VA474Y			
	1VA028	Control Cable For 0VA474Y			
	1VA034	Control Cable For 0VA01CA and 0VA474Y			
	1VA036	Control Cable For 0VA474Y			
	1VA083	Control Cable For 0VA474Y			
	1VA254	Control Cable For 0VA474Y			
	1VA757	Control Cable For 0VA474Y			
	1VA758	Control Cable For 0VA474Y			
	1VA759	Control Cable For 0VA474Y			
	1VA760	Control Cable For 0VA474Y			
	1VA761	Control Cable For 0VA474Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
0VC01CA	1VA763	Control Cable For 0VA474Y			
	1VA793	Control Cable For 0VA474Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
0VC02CA	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC032	Control Cable For 0VC281Y and 0VC02CA			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC033Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
0VC043Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC17Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
OVC18Y	1VC623	Control Cable For OVC02CA, OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC015	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC034	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
OVC19Y	1VC623	Control Cable For OVC02CA, OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC015	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC016	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC020	Control Cable For OVC01CA, OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC022	Control Cable For OVC02CA, OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC023	Control Cable For OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC025	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC026	Control Cable For OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC034	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC623	Control Cable For OVC02CA, OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
OVC20Y	1VC015	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC034	Control Cable For OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			
	1VC623	Control Cable For OVC02CA, OVC20Y, OVC281Y, OVC033Y, OVC043Y, OVC17Y, OVC18Y, and OVC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
0VC281Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC032	Control Cable For 0VC281Y and 0VC02CA			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
Unit 1 Components					
1AB03P	1AB005	Control Cable For 0AB03P(1) and 1AB03P	1VE01Y	1VE022	Control Cable For 1VE01Y and 1VE02Y
	1AB006	Control Cable For 0AB03P(1) and 1AB03P	1VE02Y	1VE022	Control Cable For 1VE01Y and 1VE02Y
1AF005A	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF081	Instrument Cable For 1AF005A			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005B	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF083	Instrument Cable For 1AF005B			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
1AF005C	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF085	Instrument Cable For 1AF005C			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005D	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF087	Instrument Cable For 1AF005D			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF006A	1AF057	Control Cable For 1AF006A and 1AF017A			
	1AF058	Control Cable For 1AF006A			
	1AF295	Control Cable For 1AF006A and 1AF017A			
	1AF324	Control Cable For 1AF006A and 1AF01PA			
1AF013A	1AF024	Control Cable For 1AF013A			
1AF013B	1AF028	Control Cable For 1AF013B			
1AF013C	1AF032	Control Cable For 1AF013C			
1AF013D	1AF036	Control Cable For 1AF013D			
1AF017A	1AF057	Control Cable For 1AF006A and 1AF017A			
	1AF097	Control Cable For 1AF017A			
	1AF295	Control Cable For 1AF006A and 1AF017A			
1AF01PA	1AF008	Control Cable For 1AF01PA			
	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11			
	1AF324	Control Cable For 1AF006A and 1AF01PA			
1AF01PA-A	1AF019	Control Cable For 1AF01PA-A			
1AP05EA	1AP401	Control Cable For 1AP05EA			
1AP05EF	1DG019	Control Cable For 1DG01KA and 1AP05EF			
1AP05EJ	1CS006	Control Cable For 1AP05EJ			
	1CS025	Control Cable For 1AP05EJ			
	1CS041	Control Cable For 1AP05EJ			
	1CS042	Control Cable For 1AP05EJ			
	1CS055	Control Cable For 1AP05EJ and 1CS009A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
1AP05EP	1AP075	Control Cable For 1AP05EP			
1AP05ER	1AP050	Control Cable For 1AP05ER			
	1AP312	Control Cable For 1AP05ER			
1AP05EU	1AP082	Control Cable For 1AP05EU			
	1AP395	Control Cable For 1AP05EU			
1AP07EL	1AP142	Control Cable For 1AP07EL			
1AP14E	1AP376	Control Cable For 1AP14E			
1AP21EA	1SI517	Control Cable For 1AP21EA			
1CC01PA	1CC002	Control Cable For 1CC01PA			
	1CC004	Control Cable For 1CC01PA			
	1CC006	Control Cable For 0CC01E-A and 1CC01PA			
	1EF028	Control Cable For 1CC01PA			
1CC9412A	1CC045	Control Cable For 1CC9412A			
1CC9413A	1CC051	Control Cable For 1CC9413A			
1CC9415	1CC067	Control Cable For 1CC9415			
1CC9416	1CC059	Control Cable For 1CC9416			
1CC9438	1CC036	Control Cable For 1CC9438			
1CC9473A	1CC127	Control Cable For 1CC9473A			
1CS009A	1CS055	Control Cable For 1AP05EJ and 1CS009A			
1CV01PA	1CV009	Control Cable For 1CV01PA			
	1EF031	Control Cable For 1CV01PA and 1SX01PA			
1CV112B	1CV067	Control Cable For 1CV112B			
	1CV068	Control Cable For 1CV112B			
1CV112D	1CV079	Control Cable For 1CV112D			
	1CV080	Control Cable For 1CV112D			
1CV8110	1CV059	Control Cable For 1CV8110			
1CV8114	1CV645	Control Cable For 1CV8114			
1CV8355A	1CV611	Control Cable For 1CV8355A			
1CV8355D	1CV614	Control Cable For 1CV8355D			
1CV8804A	1CV407	Control Cable For 1CV8804A			
1DG01KA	1DG017	Control Cable For 1DG01KA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
	1DG018	Control Cable For 1DG01KA			
	1DG019	Control Cable For 1DG01KA and 1AP05EF			
	1DG153	Control Cable For 1DG01KA			
	1DG154	Control Cable For 1DG01KA			
	1DG174	Control Cable For 1DG01KA			
	1DG200	Control Cable For 1DG01KA			
1FI-0121A	1CV421	Instrument Cable For 1FI-0121A and 1FI-0121B			
1FI-0121B	1CV421	Instrument Cable For 1FI-0121A and 1FI-0121B			
1FI-SX031	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031			
	1SX376	Instrument Cable For 1FI-SX031			
	1SX377	Instrument Cable For 1FI-SX031			
1IP01J	1NR197	Control Cable For 1NI-NR005B, 1NI-NR005D, 1IP01J, and 1NI-0031B			
	1NR198	Control Cable For 1IP01J and 1NI-0031B			
1LI-0459A	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B			
1LI-0459B	1RC371	Instrument Cable For 1LI-0459B			
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B			
1LI-0501	1FW025	Instrument Cable For 1LI-0501			
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			
1LI-0501A	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			
1LI-0504	1FW028	Instrument Cable For 1LI-0504			
1LI-0930	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1LL-SI075A	1SI234	Control Cable For 1LL-SI075A			
1MS001A-DIV11	1MS272	Control Cable For 1MS001A-DIV11			
	1MS275	Control Cable For 1MS001A-DIV11			
	1MS518	Control Cable For 1MS001A-DIV11			
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11			
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11			
1MS001B-DIV11	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
	1MS285	Control Cable For 1MS001B-DIV11			
	1MS288	Control Cable For 1MS001B-DIV11			
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11			
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11			
1MS001C-DIV11	1AF121	Control Cable For 1MS001C-DIV11			
	1MS298	Control Cable For 1MS001C-DIV11			
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11			
	1MS524	Control Cable For 1MS001C-DIV11			
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11			
1MS001D-DIV11	1MS311	Control Cable For 1MS001D-DIV11			
	1MS527	Control Cable For 1MS001D-DIV11			
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11			
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11			
1MS018A	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
	1MS581	Control Cable For 1MS018A and 1MS018D			
	1MS583	Control Cable For 1MS018A and 1MS018D			
	1MS585	Control Cable For 1MS018A			
	1MS588	Instrument Cable For 1MS018A			
	1MS589	Instrument Cable For 1MS018A			
	1MS590	Instrument Cable For 1MS018A			
	1MS591	Instrument Cable For 1MS018A			
	1MS592	Instrument Cable For 1MS018A			
	1MS593	Instrument Cable For 1MS018A			
	1MS640	Instrument Cable For 1MS018A			
1MS018D	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
	1MS581	Control Cable For 1MS018A and 1MS018D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
	1MS583	Control Cable For 1MS018A and 1MS018D			
	1MS597	Control Cable For 1MS018D			
	1MS600	Instrument Cable For 1MS018D			
	1MS601	Instrument Cable For 1MS018D			
	1MS602	Instrument Cable For 1MS018D			
	1MS603	Instrument Cable For 1MS018D			
	1MS604	Instrument Cable For 1MS018D			
	1MS605	Instrument Cable For 1MS018D			
	1MS649	Instrument Cable For 1MS018D			
1MS101A	1MS321	Control Cable For 1MS101A			
1MS101B	1MS326	Control Cable For 1MS101B			
1MS101C	1MS331	Control Cable For 1MS101C			
1MS101D	1MS336	Control Cable For 1MS101D			
1NI-0031B	1NR133	Instrument Cable For 1NI-0031B			
	1NR146	Control Cable For 1NI-0031B			
	1NR147	Control Cable For 1NI-0031B			
	1NR197	Control Cable For 1NI-NR005B, 1NI-NR005D, 1IP01J, and 1NI-0031B			
	1NR198	Control Cable For 1IP01J and 1NI-0031B			
1NI-NR005B	1NR197	Control Cable For 1NI-NR005B, 1NI-NR005D, 1IP01J, and 1NI-0031B			
1NI-NR005D	1NR197	Control Cable For 1NI-NR005B, 1NI-NR005D, 1IP01J, and 1NI-0031B			
	1NR297	Instrument Cable For 1NI-NR005D			
1PI-0405	1CV663	Instrument Cable For 1PI-0405			
1PI-0455A	1RC489	Instrument Cable For 1PI-0455A, 1TI-RC005A, and 1TI-RC006A			
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B			
1PI-0455B	1RC370	Instrument Cable For 1PI-0455B			
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B			
1PI-0457	1MS047	Instrument Cable For 1PI-0457			
1PI-0514A	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
1PI-0514B	1MS099	Instrument Cable For 1PI-0514B			
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B			
1PI-0524A	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B			
1PI-0524B	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B			
	1MS103	Instrument Cable For 1PI-0524B			
1PI-0534A	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B			
1PI-0534B	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B			
	1MS107	Instrument Cable For 1PI-0534B			
1PI-0544A	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
1PI-0544B	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
	1MS111	Instrument Cable For 1PI-0544B			
1PI-CC107	1CC314	Control Cable For 1PI-CC107			
	1CC315	Instrument Cable For 1PI-CC107			
	1CC330	Instrument Cable For 1PI-CC107			
	1LV002	Control Cable For 1PI-CC107			
1RC014A	1RC622	Control Cable For 1RC014A			
1RC014C	1RC628	Control Cable For 1RC014C			
1RH610	1RH017	Control Cable For 1RH610			
1RH8701A	1RH030	Control Cable For 1RH8701A			
1RH8716A	1RH069	Control Cable For 1RH8716A			
1RY455A	1RY486	Control Cable For 1RY455A			
1SI8801A	1SI035	Control Cable For 1SI8801A			
1SI8806	1SI077	Control Cable For 1SI8806			
1SI8807A	1SI081	Control Cable For 1SI8807A			
1SI8809A	1SI134	Control Cable For 1SI8809A			
1SI8811A	1SI152	Control Cable For 1SI8811A			
1SI8812A	1SI170	Control Cable For 1SI8812A			
1SI8840	1SI211	Control Cable For 1SI8840			
1SI8923A	1SI199	Control Cable For 1SI8923A			
1SX001A	1SX033	Control Cable For 1SX001A			
1SX004	1SX041	Control Cable For 1SX004			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
1SX016A	1SX053	Control Cable For 1SX016A			
1SX01PA	1EF031	Control Cable For 1CV01PA and 1SX01PA			
	1SX008	Control Cable For 1SX01PA			
1SX01PA-C	1SX312	Control Cable For 1SX01PA-C			
	1SX313	Control Cable For 1SX01PA-C			
1SX027A	1SX059	Control Cable For 1SX027A			
1SX033	1SX065	Control Cable For 1SX033			
1SX147A	1LV033	Control Cable For 1SX147A			
	1SX178	Control Cable For 1SX147A			
1SX169A	1SX295	Control Cable For 1SX169A			
1TI-0413A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
1TI-0423A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
1TI-0433A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
1TI-0443A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
1TI-IT001	1IT275	Instrument Cable For 1TI-IT001			
	1IT276	Instrument Cable For 1TI-IT001			
	1IT277	Instrument Cable For 1TI-IT001			
	1IT278	Instrument Cable For 1TI-IT001			
	1IT279	Instrument Cable For 1TI-IT001			
	1IT280	Instrument Cable For 1TI-IT001			
	1IT281	Instrument Cable For 1TI-IT001			
	1IT282	Instrument Cable For 1TI-IT001			
	1IT283	Instrument Cable For 1TI-IT001			
	1IT284	Instrument Cable For 1TI-IT001			
	1IT285	Instrument Cable For 1TI-IT001			
	1IT286	Instrument Cable For 1TI-IT001			
	1IT287	Instrument Cable For 1TI-IT001			
	1IT288	Instrument Cable For 1TI-IT001			
	1IT289	Instrument Cable For 1TI-IT001			
	1IT290	Instrument Cable For 1TI-IT001			
	1IT291	Instrument Cable For 1TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
	1IT292	Instrument Cable For 1TI-IT001			
	1IT293	Instrument Cable For 1TI-IT001			
	1IT294	Instrument Cable For 1TI-IT001			
	1IT295	Instrument Cable For 1TI-IT001			
	1IT296	Instrument Cable For 1TI-IT001			
	1IT297	Instrument Cable For 1TI-IT001			
	1IT298	Instrument Cable For 1TI-IT001			
	1IT299	Instrument Cable For 1TI-IT001			
	1IT300	Instrument Cable For 1TI-IT001			
	1IT301	Instrument Cable For 1TI-IT001			
	1IT302	Instrument Cable For 1TI-IT001			
	1IT303	Instrument Cable For 1TI-IT001			
	1IT304	Instrument Cable For 1TI-IT001			
	1IT305	Instrument Cable For 1TI-IT001			
	1IT306	Instrument Cable For 1TI-IT001			
	1IT307	Instrument Cable For 1TI-IT001			
	1IT345	Instrument Cable For 1TI-IT001			
	1IT346	Instrument Cable For 1TI-IT001			
	1IT424	Instrument Cable For 1TI-IT001			
	1RC648	Control Cable For 1TI-IT001			
1TI-RC005A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
	1RC489	Instrument Cable For 1PI-0455A, 1TI-RC005A, and 1TI-RC006A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC006A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
	1RC489	Instrument Cable For 1PI-0455A, 1TI-RC005A, and 1TI-RC006A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC007A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
	1RC488	Instrument Cable For 1TI-RC007A and 1TI-RC008A			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC008A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
	1RC488	Instrument Cable For 1TI-RC007A and 1TI-RC008A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1UL-AN012-A7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-B7	1AN166	Control Cable For 1UL-AN012-B7			
	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-C7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1VD01CA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VP016	Control Cable For 1VP01CA			
	1VP019	Control Cable For 1VP01CA			
	1VP021	Control Cable For 1VP01CA			
	1VP060	Control Cable For 1VP01CC			
1VP01CC	1VP063	Control Cable For 1VP01CC			
	1VP065	Control Cable For 1VP01CC			
	1VX004	Control Cable For 1VX04C			
1VX04C	1VX004	Control Cable For 1VX04C			
1VX04Y	1VE039	Control Cable For 1VX04Y and 1VX05Y			
1VX05Y	1VE039	Control Cable For 1VX04Y and 1VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-1					
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
Unit 0 (Common) Components					
0AB03P(2)	2AB005	Control Cable For 0AB03P(2) and 2AB03P			NONE
	2AB006	Control Cable For 0AB03P(2) and 2AB03P			
0CC01E-B	2CC006	Control Cable For 0CC01E-B and 2CC01PA			
	2CC023	Control Cable For 0CC01E-B			
	2CC174	Control Cable For 0CC01E-B			
	2EF027	Control Cable For 0CC01E-B			
0SX162C	2SX158	Control Cable For 0SX162C			
	2SX345	Control Cable For 0SX162C			
0VA01CC	2VA002	Control Cable For 0VA01CC			
	2VA003	Control Cable For 0VA01CC			
	2VA013	Control Cable For 0VA01CC and 0VA02CC			
0VA02CC	2VA028	Control Cable For 0VA01CC and 0VA476Y			
	2VA013	Control Cable For 0VA01CC and 0VA02CC			
	2VA017	Control Cable For 0VA02CC			
0VA476Y	2VA024	Control Cable For 0VA02CC and 0VA476Y			
	2VA024	Control Cable For 0VA02CC and 0VA476Y			
	2VA025	Control Cable For 0VA476Y			
	2VA027	Control Cable For 0VA476Y			
	2VA028	Control Cable For 0VA01CC and 0VA476Y			
	2VA033	Control Cable For 0VA476Y			
	2VA254	Control Cable For 0VA476Y			
	2VA652	Control Cable For 0VA476Y			
	2VA757	Control Cable For 0VA476Y			
	2VA758	Control Cable For 0VA476Y			
	2VA759	Control Cable For 0VA476Y			
	2VA760	Control Cable For 0VA476Y			
	2VA761	Control Cable For 0VA476Y			
	2VA763	Control Cable For 0VA476Y			
	2VA793	Control Cable For 0VA476Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
	2VA795	Control Cable For 0VA476Y			
Unit 1 Components					
NONE				NONE	
Unit 2 Components					
2AB03P	2AB005	Control Cable For 0AB03P(2) and 2AB03P			NONE
	2AB006	Control Cable For 0AB03P(2) and 2AB03P			
2AF005A	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF081	Instrument Cable For 2AF005A			
	2AF170	Instrument Cable For 2AF005A			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF005B	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF083	Instrument Cable For 2AF005B			
	2AF179	Instrument Cable For 2AF005B			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF005C	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF085	Instrument Cable For 2AF005C			
	2AF180	Instrument Cable For 2AF005C			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF005D	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF087	Instrument Cable For 2AF005D			
	2AF181	Instrument Cable For 2AF005D			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF006A	2AF057	Control Cable For 2AF006A and 2AF017A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
	2AF058	Control Cable For 2AF006A			
	2AF295	Control Cable For 2AF006A and 2AF017A			
	2AF332	Control Cable For 2AF006A and 2AF01PA			
2AF013A	2AF024	Control Cable For 2AF013A			
2AF013B	2AF028	Control Cable For 2AF013B			
2AF013C	2AF032	Control Cable For 2AF013C			
2AF013D	2AF036	Control Cable For 2AF013D			
2AF017A	2AF057	Control Cable For 2AF006A and 2AF017A			
	2AF097	Control Cable For 2AF017A			
	2AF295	Control Cable For 2AF006A and 2AF017A			
2AF01PA	2AF008	Control Cable For 2AF01PA			
	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			
	2AF293	Control Cable For 2AF01PA			
	2AF332	Control Cable For 2AF006A and 2AF01PA			
2AF01PA-A	2AF019	Control Cable For 2AF01PA-A			
	2EF011	Control Cable For 2AF01PA-A			
2AP05ED	2AP395	Control Cable For 2AP05ED			
2AP05EE	2AP180	Control Cable For 2AP05EE			
2AP05EP	2CS004	Control Cable For 2AP05EP			
	2CS006	Control Cable For 2AP05EP			
	2CS025	Control Cable For 2AP05EP			
	2CS041	Control Cable For 2AP05EP			
	2CS042	Control Cable For 2AP05EP			
	2CS055	Control Cable For 2AP05EP and 2CS009A			
2AP05ER	2AP056	Control Cable For 2AP05ER			
2AP05ET	2AP311	Control Cable For 2AP05ET			
	2AP661	Control Cable For 2AP05ET			
2AP05EV	2SI005	Control Cable For 2AP05EV			
2AP07EE	2AP142	Control Cable For 2AP07EE			
2AP14E	2AP376	Control Cable For 2AP14E			
2AP21EA	2SI517	Control Cable For 2AP21EA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2AP93E	2DC244	Control Cable For 2AP99E and 2AP93E			
2AP99E	2DC244	Control Cable For 2AP99E and 2AP93E			
2CC01PA	2CC002	Control Cable For 2CC01PA			
	2CC004	Control Cable For 2CC01PA			
	2CC006	Control Cable For 0CC01E-B and 2CC01PA			
	2EF028	Control Cable For 2CC01PA			
2CC9412A	2CC045	Control Cable For 2CC9412A			
2CC9413A	2CC051	Control Cable For 2CC9413A			
	2CC053	Control Cable For 2CC9413A			
2CC9415	2CC067	Control Cable For 2CC9415			
2CC9416	2CC059	Control Cable For 2CC9416			
	2CC061	Control Cable For 2CC9416			
2CC9438	2CC036	Control Cable For 2CC9438			
	2CC037	Control Cable For 2CC9438			
2CC9473A	2CC127	Control Cable For 2CC9473A			
2CS009A	2CS055	Control Cable For 2AP05EP and 2CS009A			
2CV01PA	2CV009	Control Cable For 2CV01PA			
	2EF031	Control Cable For 2CV01PA and 2SX01PA			
2CV112B	2CV067	Control Cable For 2CV112B			
	2CV068	Control Cable For 2CV112B			
2CV112D	2CV079	Control Cable For 2CV112D			
	2CV080	Control Cable For 2CV112D			
	2CV081	Control Cable For 2CV112D			
	2CV059	Control Cable For 2CV8110			
2CV8114	2CV641	Control Cable For 2CV8114			
	2CV645	Control Cable For 2CV8114			
2CV8355A	2CV611	Control Cable For 2CV8355A			
2CV8355D	2CV614	Control Cable For 2CV8355D			
2CV8804A	2CV407	Control Cable For 2CV8804A			
2DG01KA	2DG153	Control Cable For 2DG01KA			
	2DG154	Control Cable For 2DG01KA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2ESFComp21 2FI-SX031	2DG157	Control Cable For 2DG01KA			
	2DG175	Control Cable For 2DG01KA			
	2EF012	Control Cable For 2ESFComp21			
	2LV057	Control Cable For 2FI-SX031			
	2SX376	Instrument Cable For 2FI-SX031			
	2SX377	Instrument Cable For 2FI-SX031			
	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR198	Control Cable For 2IP01J and 2NI-0031B			
2LI-0459A	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2LI-0459B	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
	2RC371	Instrument Cable For 2LI-0459B			
	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
	2FW025	Instrument Cable For 2LI-0501			
2LI-0501	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0501A	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2LI-0504	2FW028	Instrument Cable For 2LI-0504			
2LI-0930	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2LL-SI075A 2MS001A-DIV21	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2SI234	Control Cable For 2LL-SI075A			
	2MS272	Control Cable For 2MS001A-DIV21			
	2MS275	Control Cable For 2MS001A-DIV21			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001B-DIV21	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			
	2MS285	Control Cable For 2MS001B-DIV21			
	2MS288	Control Cable For 2MS001B-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001C-DIV21	2AF121	Control Cable For 2MS001C-DIV21			
	2MS298	Control Cable For 2MS001C-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS524	Control Cable For 2MS001C-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS001D-DIV21	2MS311	Control Cable For 2MS001D-DIV21			
	2MS527	Control Cable For 2MS001D-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS018A	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS574	Instrument Cable For 2MS018A			
	2MS581	Control Cable For 2MS018A and 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS585	Control Cable For 2MS018A			
	2MS588	Instrument Cable For 2MS018A			
	2MS589	Instrument Cable For 2MS018A			
	2MS590	Instrument Cable For 2MS018A			
	2MS591	Instrument Cable For 2MS018A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2MS018D	2MS592	Instrument Cable For 2MS018A			
	2MS593	Instrument Cable For 2MS018A			
	2MS639	Instrument Cable For 2MS018A			
	2MS640	Instrument Cable For 2MS018A			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS575	Instrument Cable For 2MS018D			
	2MS581	Control Cable For 2MS018A and 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS597	Control Cable For 2MS018D			
	2MS600	Instrument Cable For 2MS018D			
	2MS601	Instrument Cable For 2MS018D			
	2MS602	Instrument Cable For 2MS018D			
	2MS603	Instrument Cable For 2MS018D			
	2MS604	Instrument Cable For 2MS018D			
	2MS605	Instrument Cable For 2MS018D			
	2MS648	Instrument Cable For 2MS018D			
	2MS649	Instrument Cable For 2MS018D			
2MS101A	2MS321	Control Cable For 2MS101A			
2MS101B	2MS326	Control Cable For 2MS101B			
2MS101C	2MS331	Control Cable For 2MS101C			
2MS101D	2MS336	Control Cable For 2MS101D			
2NI-0031B	2NR133	Instrument Cable For 2NI-0031B			
	2NR146	Control Cable For 2NI-0031B			
	2NR147	Control Cable For 2NI-0031B			
	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR198	Control Cable For 2IP01J and 2NI-0031B			
	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR246	Instrument Cable For 2NI-NR005B			
2NI-NR005B					

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2NI-NR005D	2NR197	Control Cable For 2NI-NR005B, 2NI-NR005D, 2IP01J, and 2NI-0031B			
	2NR297	Instrument Cable For 2NI-NR005D			
2PI-0405	2CV663	Instrument Cable For 2PI-0405			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0455A	2RC489	Instrument Cable For 2PI-0455A, 2TI-RC005A, and 2TI-RC006A			
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0455B	2RC370	Instrument Cable For 2PI-0455B			
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0457	2MS047	Instrument Cable For 2PI-0457			
2PI-0514A	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0514B	2MS099	Instrument Cable For 2PI-0514B			
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
2PI-0524A	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0524B	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
	2MS103	Instrument Cable For 2PI-0524B			
2PI-0534A	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2PI-0534B	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
	2MS107	Instrument Cable For 2PI-0534B			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2PI-0544A	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
	2RY322				
2PI-0544B	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
	2MS111	Instrument Cable For 2PI-0544B			
2PI-CC107	2CC314	Control Cable For 2PI-CC107			
	2CC315	Instrument Cable For 2PI-CC107			
	2CC330	Instrument Cable For 2PI-CC107			
	2LV002	Control Cable For 2PI-CC107			
2RC014A	2RC622	Control Cable For 2RC014A			
2RC014C	2RC628	Control Cable For 2RC014C			
2RH01PA	2RH003	Control Cable For 2RH01PA			
	2RH091	Control Cable For 2RH01PA			
2RH610	2RH017	Control Cable For 2RH610			
2RH8701A	2RH030	Control Cable For 2RH8701A			
	2RH031	Control Cable For 2RH8701A			
	2SI168	Control Cable For 2RH8701A			
2RH8702A	2RH054	Control Cable For 2RH8702A			
	2RH055	Control Cable For 2RH8702A			
2RH8716A	2RH069	Control Cable For 2RH8716A			
2RY455A	2RY418	Control Cable For 2RY455A			
2RY8000A	2RY394	Control Cable For 2RY8000A			
2SI8801A	2SI017	Control Cable For 2SI8801A			
	2SI035	Control Cable For 2SI8801A			
2SI8806	2SI077	Control Cable For 2SI8806			
2SI8807A	2SI081	Control Cable For 2SI8807A			
2SI8809A	2SI134	Control Cable For 2SI8809A			
2SI8811A	2SI152	Control Cable For 2SI8811A			
	2SI513	Control Cable For 2SI8811A			
	2SI521	Control Cable For 2SI8811A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2SI8812A	2SI170	Control Cable For 2SI8812A			
2SI8840	2SI211	Control Cable For 2SI8840			
2SI8923A	2SI199	Control Cable For 2SI8923A			
2SX001A	2SX033	Control Cable For 2SX001A			
2SX004	2SX041	Control Cable For 2SX004			
2SX016A	2SX053	Control Cable For 2SX016A			
2SX01PA	2EF031	Control Cable For 2CV01PA and 2SX01PA			
	2SX008	Control Cable For 2SX01PA			
2SX01PA-C	2SX312	Control Cable For 2SX01PA-C			
	2SX313	Control Cable For 2SX01PA-C			
2SX027A	2SX059	Control Cable For 2SX027A			
2SX033	2SX065	Control Cable For 2SX033			
2SX147A	2LV033	Control Cable For 2SX147A			
	2SX178	Control Cable For 2SX147A			
2TI-0413A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0423A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0433A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			
2TI-0443A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
	2RY322	Instrument Cable For 2LI-0459A, 2LI-0501A, 2LI-0930, 2PI-0405, 2PI-0514A, 2PI-0524A, 2PI-0534A, 2PI-0544A, 2TI-0413A, 2TI-0423A, 2TI-0433A, and 2TI-0443A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2TI-IT001	2IT275	Instrument Cable For 2TI-IT001			
	2IT276	Instrument Cable For 2TI-IT001			
	2IT277	Instrument Cable For 2TI-IT001			
	2IT278	Instrument Cable For 2TI-IT001			
	2IT279	Instrument Cable For 2TI-IT001			
	2IT280	Instrument Cable For 2TI-IT001			
	2IT281	Instrument Cable For 2TI-IT001			
	2IT282	Instrument Cable For 2TI-IT001			
	2IT283	Instrument Cable For 2TI-IT001			
	2IT284	Instrument Cable For 2TI-IT001			
	2IT285	Instrument Cable For 2TI-IT001			
	2IT286	Instrument Cable For 2TI-IT001			
	2IT287	Instrument Cable For 2TI-IT001			
	2IT288	Instrument Cable For 2TI-IT001			
	2IT289	Instrument Cable For 2TI-IT001			
	2IT290	Instrument Cable For 2TI-IT001			
	2IT291	Instrument Cable For 2TI-IT001			
	2IT292	Instrument Cable For 2TI-IT001			
	2IT293	Instrument Cable For 2TI-IT001			
	2IT294	Instrument Cable For 2TI-IT001			
	2IT295	Instrument Cable For 2TI-IT001			
	2IT296	Instrument Cable For 2TI-IT001			
	2IT297	Instrument Cable For 2TI-IT001			
	2IT298	Instrument Cable For 2TI-IT001			
	2IT299	Instrument Cable For 2TI-IT001			
	2IT300	Instrument Cable For 2TI-IT001			
	2IT301	Instrument Cable For 2TI-IT001			
	2IT302	Instrument Cable For 2TI-IT001			
	2IT303	Instrument Cable For 2TI-IT001			
	2IT304	Instrument Cable For 2TI-IT001			
	2IT305	Instrument Cable For 2TI-IT001			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
	2IT306	Instrument Cable For 2TI-IT001			
	2IT307	Instrument Cable For 2TI-IT001			
	2IT345	Instrument Cable For 2TI-IT001			
	2IT346	Instrument Cable For 2TI-IT001			
	2IT424	Instrument Cable For 2TI-IT001			
2TI-RC005A	2RC648	Control Cable For 2TI-IT001			
	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
	2RC489	Instrument Cable For 2PI-0455A, 2TI-RC005A, and 2TI-RC006A			
2TI-RC006A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
	2RC489	Instrument Cable For 2PI-0455A, 2TI-RC005A, and 2TI-RC006A			
2TI-RC007A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
	2RC488	Instrument Cable For 2TI-RC007A and 2TI-RC008A			
2TI-RC008A	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
	2RC488	Instrument Cable For 2TI-RC007A and 2TI-RC008A			
2UL-AN012-A7	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2AN166	Control Cable For 2UL-AN012-B7			
2UL-AN012-B7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2VD01CA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.3D-2					
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP016	Control Cable For 2VP01CA			
	2VP019	Control Cable For 2VP01CA			
	2VP021	Control Cable For 2VP01CA			
	2VP060	Control Cable For 2VP01CC			
2VP01CC	2VP065	Control Cable For 2VP01CC			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
Unit 0 (Common) Components			NONE		
0AB03P(1)	1AB005	Control Cable For 0AB03P(1) and 1AB03P			
	1AB006	Control Cable For 0AB03P(1) and 1AB03P			
0CC01E-A	1CC006	Control Cable For 0CC01E-A and 1CC01PA			
	1CC023	Control Cable For 0CC01E-A			
	1CC174	Control Cable For 0CC01E-A			
	1EF027	Control Cable For 0CC01E-A			
	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031			
0FI-SX044	1SX172	Control Cable For 0SX02PA			
0SX02PA	1SX205	Control Cable For 0SX02PA			
	1SX206	Control Cable For 0SX02PA			
	1SX258	Control Cable For 0SX02PA			
	1SX079	Control Cable For 0SX158A			
0SX158A	1SX158	Control Cable For 0SX162A			
0SX162A	1VA002	Control Cable For 0VA01CA			
0VA01CA	1VA017	Control Cable For 0VA02CA			
0VA02CA	1VA027	Control Cable For 0VA474Y			
	1VA083	Control Cable For 0VA474Y			
	1VA254	Control Cable For 0VA474Y			
	1VA757	Control Cable For 0VA474Y			
	1VA758	Control Cable For 0VA474Y			
	1VA759	Control Cable For 0VA474Y			
	1VA760	Control Cable For 0VA474Y			
	1VA761	Control Cable For 0VA474Y			
	1VA763	Control Cable For 0VA474Y			
	1VA793	Control Cable For 0VA474Y			
0VC01CA	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
0VC02CA	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
0VC033Y	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC032	Control Cable For 0VC281Y and 0VC02CA			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC043Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
0VC17Y	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC18Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
0VC19Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC20Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
0VC281Y	1VC015	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC016	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC020	Control Cable For 0VC01CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC022	Control Cable For 0VC02CA, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC023	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
	1VC025	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC026	Control Cable For 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC032	Control Cable For 0VC281Y and 0VC02CA			
	1VC034	Control Cable For 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
	1VC623	Control Cable For 0VC02CA, 0VC20Y, 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, 0VC18Y, and 0VC19Y			
Unit 1 Components					
1AB03P	1AB005	Control Cable For 0AB03P(1) and 1AB03P	NONE		
	1AB006	Control Cable For 0AB03P(1) and 1AB03P			
1AF005A	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF081	Instrument Cable For 1AF005A			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005B	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF083	Instrument Cable For 1AF005B			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005C	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF085	Instrument Cable For 1AF005C			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			
1AF005D	1AF077	Instrument Cable For 1AF005A, 1AF005B, 1AF005C, and 1AF005D			
	1AF087	Instrument Cable For 1AF005D			
	1LV052	Control Cable For 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS018A, and 1MS018D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
1AF006A	1AF057	Control Cable For 1AF006A and 1AF017A			
	1AF295	Control Cable For 1AF006A and 1AF017A			
	1AF324	Control Cable For 1AF006A and 1AF01PA			
1AF013A	1AF024	Control Cable For 1AF013A			
1AF013B	1AF028	Control Cable For 1AF013B			
1AF013C	1AF032	Control Cable For 1AF013C			
1AF013D	1AF036	Control Cable For 1AF013D			
1AF017A	1AF057	Control Cable For 1AF006A and 1AF017A			
	1AF295	Control Cable For 1AF006A and 1AF017A			
1AF01PA	1AF008	Control Cable For 1AF01PA			
	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11			
	1AF324	Control Cable For 1AF006A and 1AF01PA			
1AF01PA-A	1AF019	Control Cable For 1AF01PA-A			
1AP05EA	1AP401	Control Cable For 1AP05EA			
1AP05EF	1DG019	Control Cable For 1DG01KA and 1AP05EF			
1AP05EJ	1CS006	Control Cable For 1AP05EJ			
	1CS025	Control Cable For 1AP05EJ			
	1CS041	Control Cable For 1AP05EJ			
	1CS042	Control Cable For 1AP05EJ			
	1CS055	Control Cable For 1AP05EJ and 1CS009A			
1AP05EP	1AP075	Control Cable For 1AP05EP			
1AP05ER	1AP050	Control Cable For 1AP05ER			
	1AP312	Control Cable For 1AP05ER			
1AP05EU	1AP082	Control Cable For 1AP05EU			
	1AP395	Control Cable For 1AP05EU			
1AP07EL	1AP142	Control Cable For 1AP07EL			
1AP14E	1AP376	Control Cable For 1AP14E			
1AP21EA	1SI517	Control Cable For 1AP21EA			
1CC01PA	1CC002	Control Cable For 1CC01PA			
	1CC004	Control Cable For 1CC01PA			
	1CC006	Control Cable For 0CC01E-A and 1CC01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
	1EF028	Control Cable For 1CC01PA			
1CC9412A	1CC045	Control Cable For 1CC9412A			
1CC9413A	1CC051	Control Cable For 1CC9413A			
1CC9416	1CC059	Control Cable For 1CC9416			
1CC9438	1CC036	Control Cable For 1CC9438			
1CS009A	1CS055	Control Cable For 1AP05EJ and 1CS009A			
1CV01PA	1CV009	Control Cable For 1CV01PA			
	1EF031	Control Cable For 1CV01PA and 1SX01PA			
1CV112B	1CV067	Control Cable For 1CV112B			
	1CV068	Control Cable For 1CV112B			
1CV112D	1CV079	Control Cable For 1CV112D			
	1CV080	Control Cable For 1CV112D			
1CV8110	1CV059	Control Cable For 1CV8110			
1CV8114	1CV645	Control Cable For 1CV8114			
1CV8355A	1CV611	Control Cable For 1CV8355A			
1CV8355D	1CV614	Control Cable For 1CV8355D			
1CV8804A	1CV407	Control Cable For 1CV8804A			
1DG01KA	1DG017	Control Cable For 1DG01KA			
	1DG018	Control Cable For 1DG01KA			
	1DG019	Control Cable For 1DG01KA and 1AP05EF			
	1DG153	Control Cable For 1DG01KA			
	1DG154	Control Cable For 1DG01KA			
	1DG174	Control Cable For 1DG01KA			
	1DG200	Control Cable For 1DG01KA			
1FI-SX031	1LV057	Control Cable For 0FI-SX044 and 1FI-SX031			
	1SX376	Instrument Cable For 1FI-SX031			
	1SX377	Instrument Cable For 1FI-SX031			
1LI-0459A	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B			
1LI-0459B	1RC371	Instrument Cable For 1LI-0459B			
	1RY432	Instrument Cable For 1LI-0459A and 1LI-0459B			
1LI-0501	1FW025	Instrument Cable For 1LI-0501			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			
1LI-0501A	1FW919	Instrument Cable For 1LI-0501 and 1LI-0501A			
1LI-0504	1FW028	Instrument Cable For 1LI-0504			
1LI-0930	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1LL-SI075A	1SI234	Control Cable For 1LL-SI075A			
1MS001A-DIV11	1MS272	Control Cable For 1MS001A-DIV11			
	1MS275	Control Cable For 1MS001A-DIV11			
	1MS518	Control Cable For 1MS001A-DIV11			
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11			
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11			
1MS001B-DIV11	1AF009	Control Cable For 1AF01PA and 1MS001B-DIV11			
	1MS285	Control Cable For 1MS001B-DIV11			
	1MS288	Control Cable For 1MS001B-DIV11			
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11			
	1MS531	Control Cable For 1MS001A-DIV11 and 1MS001B-DIV11			
1MS001C-DIV11	1AF121	Control Cable For 1MS001C-DIV11			
	1MS298	Control Cable For 1MS001C-DIV11			
	1MS519	Control Cable For 1MS001A-DIV11 and 1MS001C-DIV11			
	1MS524	Control Cable For 1MS001C-DIV11			
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11			
1MS001D-DIV11	1MS311	Control Cable For 1MS001D-DIV11			
	1MS527	Control Cable For 1MS001D-DIV11			
	1MS529	Control Cable For 1MS001B-DIV11 and 1MS001D-DIV11			
	1MS532	Control Cable For 1MS001C-DIV11 and 1MS001D-DIV11			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
	1RY433	Instrument Cable For 1PI-0455A and 1PI-0455B			
1PI-0514A	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B			
1PI-0514B	1MS099	Instrument Cable For 1PI-0514B			
	1MS666	Instrument Cable For 1PI-0514A and 1PI-0514B			
1PI-0524A	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B			
1PI-0524B	1MS102	Instrument Cable For 1PI-0524A and 1PI-0524B			
	1MS103	Instrument Cable For 1PI-0524B			
1PI-0534A	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B			
1PI-0534B	1MS106	Instrument Cable For 1PI-0534A and 1PI-0534B			
	1MS107	Instrument Cable For 1PI-0534B			
1PI-0544A	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
1PI-0544B	1MS110	Instrument Cable For 1PI-0544A and 1PI-0544B			
	1MS111	Instrument Cable For 1PI-0544B			
1PI-CC107	1CC314	Control Cable For 1PI-CC107			
	1CC315	Instrument Cable For 1PI-CC107			
	1LV002	Control Cable For 1PI-CC107			
1RC014A	1RC622	Control Cable For 1RC014A			
1RC014C	1RC628	Control Cable For 1RC014C			
1RH610	1RH017	Control Cable For 1RH610			
1RH8701A	1RH030	Control Cable For 1RH8701A			
1RH8716A	1RH069	Control Cable For 1RH8716A			
1RY455A	1RY486	Control Cable For 1RY455A			
1SI8801A	1SI035	Control Cable For 1SI8801A			
1SI8806	1SI077	Control Cable For 1SI8806			
1SI8807A	1SI081	Control Cable For 1SI8807A			
1SI8809A	1SI134	Control Cable For 1SI8809A			
1SI8811A	1SI152	Control Cable For 1SI8811A			
1SI8812A	1SI170	Control Cable For 1SI8812A			
1SI8840	1SI211	Control Cable For 1SI8840			
1SI8923A	1SI199	Control Cable For 1SI8923A			
1SX001A	1SX033	Control Cable For 1SX001A			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
1SX004	1SX041	Control Cable For 1SX004			
1SX016A	1SX053	Control Cable For 1SX016A			
1SX01PA	1EF031	Control Cable For 1CV01PA and 1SX01PA			
	1SX008	Control Cable For 1SX01PA			
1SX01PA-C	1SX312	Control Cable For 1SX01PA-C			
	1SX313	Control Cable For 1SX01PA-C			
1SX027A	1SX059	Control Cable For 1SX027A			
1SX033	1SX065	Control Cable For 1SX033			
1SX147A	1LV033	Control Cable For 1SX147A			
	1SX178	Control Cable For 1SX147A			
1SX169A	1SX295	Control Cable For 1SX169A			
1TI-0413A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
1TI-0423A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
1TI-0433A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
1TI-0443A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
1TI-IT001	1IT275	Instrument Cable For 1TI-IT001			
	1IT276	Instrument Cable For 1TI-IT001			
	1IT277	Instrument Cable For 1TI-IT001			
	1IT278	Instrument Cable For 1TI-IT001			
	1IT279	Instrument Cable For 1TI-IT001			
	1IT280	Instrument Cable For 1TI-IT001			
	1IT281	Instrument Cable For 1TI-IT001			
	1IT282	Instrument Cable For 1TI-IT001			
	1IT283	Instrument Cable For 1TI-IT001			
	1IT284	Instrument Cable For 1TI-IT001			
	1IT285	Instrument Cable For 1TI-IT001			
	1IT286	Instrument Cable For 1TI-IT001			
	1IT287	Instrument Cable For 1TI-IT001			
	1IT288	Instrument Cable For 1TI-IT001			
	1IT289	Instrument Cable For 1TI-IT001			
	1IT290	Instrument Cable For 1TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
	1IT291	Instrument Cable For 1TI-IT001			
	1IT292	Instrument Cable For 1TI-IT001			
	1IT293	Instrument Cable For 1TI-IT001			
	1IT294	Instrument Cable For 1TI-IT001			
	1IT295	Instrument Cable For 1TI-IT001			
	1IT296	Instrument Cable For 1TI-IT001			
	1IT297	Instrument Cable For 1TI-IT001			
	1IT298	Instrument Cable For 1TI-IT001			
	1IT299	Instrument Cable For 1TI-IT001			
	1IT300	Instrument Cable For 1TI-IT001			
	1IT301	Instrument Cable For 1TI-IT001			
	1IT302	Instrument Cable For 1TI-IT001			
	1IT303	Instrument Cable For 1TI-IT001			
	1IT304	Instrument Cable For 1TI-IT001			
	1IT305	Instrument Cable For 1TI-IT001			
	1IT306	Instrument Cable For 1TI-IT001			
	1IT307	Instrument Cable For 1TI-IT001			
	1IT345	Instrument Cable For 1TI-IT001			
	1IT346	Instrument Cable For 1TI-IT001			
	1RC648	Control Cable For 1TI-IT001			
1TI-RC005A	1RC350	Instrument Cable For 1TI-0413A and 1TI-RC005A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC006A	1RC355	Instrument Cable For 1TI-0423A and 1TI-RC006A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC007A	1RC360	Instrument Cable For 1TI-0433A and 1TI-RC007A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			
1TI-RC008A	1RC365	Instrument Cable For 1TI-0443A and 1TI-RC008A			
	1RC612	Instrument Cable For 1TI-RC005A, 1TI-RC006A, 1TI-RC007A, and 1TI-RC008A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-1					
1UL-AN012-A7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-B7	1AN166	Control Cable For 1UL-AN012-B7			
	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1UL-AN012-C7	1SI467	Instrument Cable For 1LI-0930, 1UL-AN012-A7, 1UL-AN012-B7, and 1UL-AN012-C7			
1VD01CA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VP016	Control Cable For 1VP01CA			
	1VP019	Control Cable For 1VP01CA			
	1VP021	Control Cable For 1VP01CA			
1VP01CC	1VP060	Control Cable For 1VP01CC			
	1VP063	Control Cable For 1VP01CC			
	1VP065	Control Cable For 1VP01CC			
1VX04C	1VX004	Control Cable For 1VX04C			
1VX04Y	1VE039	Control Cable For 1VX04Y and 1VX05Y			
1VX05Y	1VE039	Control Cable For 1VX04Y and 1VX05Y			
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
2AF005A	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF081	Instrument Cable For 2AF005A			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF005B	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF083	Instrument Cable For 2AF005B			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF005C	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF085	Instrument Cable For 2AF005C			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF005D	2AF077	Instrument Cable For 2AF005A, 2AF005B, 2AF005C, and 2AF005D			
	2AF087	Instrument Cable For 2AF005D			
	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
2AF006A	2AF057	Control Cable For 2AF006A and 2AF017A			
	2AF058	Control Cable For 2AF006A			
	2AF295	Control Cable For 2AF006A and 2AF017A			
	2AF332	Control Cable For 2AF006A and 2AF01PA			
2AF013A	2AF024	Control Cable For 2AF013A			
2AF013B	2AF028	Control Cable For 2AF013B			
2AF013C	2AF032	Control Cable For 2AF013C			
2AF013D	2AF036	Control Cable For 2AF013D			
2AF017A	2AF057	Control Cable For 2AF006A and 2AF017A			
	2AF097	Control Cable For 2AF017A			
	2AF295	Control Cable For 2AF006A and 2AF017A			
2AF01PA	2AF008	Control Cable For 2AF01PA			
	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			
	2AF293	Control Cable For 2AF01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
	2AF332	Control Cable For 2AF006A and 2AF01PA			
2AF01PA-A	2AF019	Control Cable For 2AF01PA-A			
2AP05ED	2AP395	Control Cable For 2AP05ED			
2AP05EE	2AP180	Control Cable For 2AP05EE			
2AP05EP	2CS004	Control Cable For 2AP05EP			
	2CS006	Control Cable For 2AP05EP			
	2CS025	Control Cable For 2AP05EP			
	2CS041	Control Cable For 2AP05EP			
	2CS042	Control Cable For 2AP05EP			
	2CS055	Control Cable For 2AP05EP and 2CS009A			
2AP05ER	2AP056	Control Cable For 2AP05ER			
2AP05ET	2AP311	Control Cable For 2AP05ET			
2AP05EV	2SI005	Control Cable For 2AP05EV			
2AP07EE	2AP142	Control Cable For 2AP07EE			
2AP14E	2AP376	Control Cable For 2AP14E			
2AP21EA	2SI517	Control Cable For 2AP21EA			
2AP93E	2DC244	Control Cable For 2AP99E and 2AP93E			
2AP99E	2DC244	Control Cable For 2AP99E and 2AP93E			
2CC01PA	2CC002	Control Cable For 2CC01PA			
	2CC004	Control Cable For 2CC01PA			
	2CC006	Control Cable For 0CC01E-B and 2CC01PA			
	2EF028	Control Cable For 2CC01PA			
2CC9412A	2CC045	Control Cable For 2CC9412A			
2CC9413A	2CC051	Control Cable For 2CC9413A			
2CC9415	2CC067	Control Cable For 2CC9415			
2CC9416	2CC059	Control Cable For 2CC9416			
2CC9438	2CC036	Control Cable For 2CC9438			
2CC9473A	2CC127	Control Cable For 2CC9473A			
2CS009A	2CS055	Control Cable For 2AP05EP and 2CS009A			
2CV01PA	2CV009	Control Cable For 2CV01PA			
	2EF031	Control Cable For 2CV01PA and 2SX01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
2CV112B	2CV067	Control Cable For 2CV112B			
	2CV068	Control Cable For 2CV112B			
2CV112D	2CV079	Control Cable For 2CV112D			
	2CV080	Control Cable For 2CV112D			
2CV8110	2CV059	Control Cable For 2CV8110			
2CV8114	2CV645	Control Cable For 2CV8114			
2CV8355A	2CV611	Control Cable For 2CV8355A			
2CV8355D	2CV614	Control Cable For 2CV8355D			
2CV8804A	2CV407	Control Cable For 2CV8804A			
2DG01KA	2DG153	Control Cable For 2DG01KA			
	2DG154	Control Cable For 2DG01KA			
	2DG157	Control Cable For 2DG01KA			
	2DG175	Control Cable For 2DG01KA			
2FI-SX031	2LV057	Control Cable For 2FI-SX031			
	2SX376	Instrument Cable For 2FI-SX031			
	2SX377	Instrument Cable For 2FI-SX031			
2LI-0459A	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
2LI-0459B	2RC371	Instrument Cable For 2LI-0459B			
	2RY432	Instrument Cable For 2LI-0459A and 2LI-0459B			
2LI-0501	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0501A	2FW919	Instrument Cable For 2LI-0501 and 2LI-0501A			
2LI-0504	2FW028	Instrument Cable For 2LI-0504			
2LI-0930	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2LL-SI075A	2SI234	Control Cable For 2LL-SI075A			
2MS001A-DIV21	2MS272	Control Cable For 2MS001A-DIV21			
	2MS275	Control Cable For 2MS001A-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001B-DIV21	2AF009	Control Cable For 2AF01PA and 2MS001B-DIV21			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
	2MS285	Control Cable For 2MS001B-DIV21			
	2MS288	Control Cable For 2MS001B-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS531	Control Cable For 2MS001A-DIV21 and 2MS001B-DIV21			
2MS001C-DIV21	2AF121	Control Cable For 2MS001C-DIV21			
	2MS298	Control Cable For 2MS001C-DIV21			
	2MS519	Control Cable For 2MS001A-DIV21 and 2MS001C-DIV21			
	2MS524	Control Cable For 2MS001C-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS001D-DIV21	2MS311	Control Cable For 2MS001D-DIV21			
	2MS527	Control Cable For 2MS001D-DIV21			
	2MS529	Control Cable For 2MS001B-DIV21 and 2MS001D-DIV21			
	2MS532	Control Cable For 2MS001C-DIV21 and 2MS001D-DIV21			
2MS018A	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS581	Control Cable For 2MS018A and 2MS018D			
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS585	Control Cable For 2MS018A			
	2MS588	Instrument Cable For 2MS018A			
	2MS589	Instrument Cable For 2MS018A			
	2MS590	Instrument Cable For 2MS018A			
	2MS591	Instrument Cable For 2MS018A			
	2MS592	Instrument Cable For 2MS018A			
	2MS593	Instrument Cable For 2MS018A			
	2MS640	Instrument Cable For 2MS018A			
2MS018D	2LV052	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS018A, and 2MS018D			
	2MS581	Control Cable For 2MS018A and 2MS018D			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
	2MS583	Control Cable For 2MS018A and 2MS018D			
	2MS597	Control Cable For 2MS018D			
	2MS600	Instrument Cable For 2MS018D			
	2MS601	Instrument Cable For 2MS018D			
	2MS602	Instrument Cable For 2MS018D			
	2MS603	Instrument Cable For 2MS018D			
	2MS604	Instrument Cable For 2MS018D			
	2MS605	Instrument Cable For 2MS018D			
	2MS649	Instrument Cable For 2MS018D			
2MS101A	2MS321	Control Cable For 2MS101A			
2MS101B	2MS326	Control Cable For 2MS101B			
2MS101C	2MS331	Control Cable For 2MS101C			
2MS101D	2MS336	Control Cable For 2MS101D			
2NI-NR005B	2NR246	Instrument Cable For 2NI-NR005B			
2NI-NR005D	2NR297	Instrument Cable For 2NI-NR005D			
2PI-0405	2CV663	Instrument Cable For 2PI-0405			
2PI-0455A	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0455B	2RC370	Instrument Cable For 2PI-0455B			
	2RY433	Instrument Cable For 2PI-0455A and 2PI-0455B			
2PI-0514A	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
2PI-0514B	2MS099	Instrument Cable For 2PI-0514B			
	2MS666	Instrument Cable For 2PI-0514A and 2PI-0514B			
2PI-0524A	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
2PI-0524B	2MS102	Instrument Cable For 2PI-0524A and 2PI-0524B			
	2MS103	Instrument Cable For 2PI-0524B			
2PI-0534A	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
2PI-0534B	2MS106	Instrument Cable For 2PI-0534A and 2PI-0534B			
	2MS107	Instrument Cable For 2PI-0534B			
2PI-0544A	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
2PI-0544B	2MS110	Instrument Cable For 2PI-0544A and 2PI-0544B			
	2MS111	Instrument Cable For 2PI-0544B			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
2PI-CC107	2CC314	Control Cable For 2PI-CC107			
	2CC315	Instrument Cable For 2PI-CC107			
	2LV002	Control Cable For 2PI-CC107			
2RC014A	2RC622	Control Cable For 2RC014A			
2RC014C	2RC628	Control Cable For 2RC014C			
2RH01PA	2RH003	Control Cable For 2RH01PA			
	2RH091	Control Cable For 2RH01PA			
2RH610	2RH017	Control Cable For 2RH610			
2RH8701A	2RH030	Control Cable For 2RH8701A			
	2RH031	Control Cable For 2RH8701A			
	2SI168	Control Cable For 2RH8701A			
2RH8702A	2RH054	Control Cable For 2RH8702A			
	2RH055	Control Cable For 2RH8702A			
2RH8716A	2RH069	Control Cable For 2RH8716A			
2RY8000A	2RY394	Control Cable For 2RY8000A			
2SI8801A	2SI035	Control Cable For 2SI8801A			
2SI8806	2SI077	Control Cable For 2SI8806			
2SI8807A	2SI081	Control Cable For 2SI8807A			
2SI8809A	2SI134	Control Cable For 2SI8809A			
2SI8811A	2SI152	Control Cable For 2SI8811A			
2SI8812A	2SI170	Control Cable For 2SI8812A			
2SI8840	2SI211	Control Cable For 2SI8840			
2SI8923A	2SI199	Control Cable For 2SI8923A			
2SX001A	2SX033	Control Cable For 2SX001A			
2SX004	2SX041	Control Cable For 2SX004			
2SX016A	2SX053	Control Cable For 2SX016A			
2SX01PA	2EF031	Control Cable For 2CV01PA and 2SX01PA			
	2SX008	Control Cable For 2SX01PA			
2SX01PA-C	2SX312	Control Cable For 2SX01PA-C			
	2SX313	Control Cable For 2SX01PA-C			
2SX027A	2SX059	Control Cable For 2SX027A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
2SX033	2SX065	Control Cable For 2SX033			
2SX147A	2LV033	Control Cable For 2SX147A			
	2SX178	Control Cable For 2SX147A			
2TI-0413A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
2TI-0423A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
2TI-0433A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
2TI-0443A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
2TI-IT001	2IT275	Instrument Cable For 2TI-IT001			
	2IT276	Instrument Cable For 2TI-IT001			
	2IT277	Instrument Cable For 2TI-IT001			
	2IT278	Instrument Cable For 2TI-IT001			
	2IT279	Instrument Cable For 2TI-IT001			
	2IT280	Instrument Cable For 2TI-IT001			
	2IT281	Instrument Cable For 2TI-IT001			
	2IT282	Instrument Cable For 2TI-IT001			
	2IT283	Instrument Cable For 2TI-IT001			
	2IT284	Instrument Cable For 2TI-IT001			
	2IT285	Instrument Cable For 2TI-IT001			
	2IT286	Instrument Cable For 2TI-IT001			
	2IT287	Instrument Cable For 2TI-IT001			
	2IT288	Instrument Cable For 2TI-IT001			
	2IT289	Instrument Cable For 2TI-IT001			
	2IT290	Instrument Cable For 2TI-IT001			
	2IT291	Instrument Cable For 2TI-IT001			
	2IT292	Instrument Cable For 2TI-IT001			
	2IT293	Instrument Cable For 2TI-IT001			
	2IT294	Instrument Cable For 2TI-IT001			
	2IT295	Instrument Cable For 2TI-IT001			
	2IT296	Instrument Cable For 2TI-IT001			
	2IT297	Instrument Cable For 2TI-IT001			
	2IT298	Instrument Cable For 2TI-IT001			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
	2IT299	Instrument Cable For 2TI-IT001			
	2IT300	Instrument Cable For 2TI-IT001			
	2IT301	Instrument Cable For 2TI-IT001			
	2IT302	Instrument Cable For 2TI-IT001			
	2IT303	Instrument Cable For 2TI-IT001			
	2IT304	Instrument Cable For 2TI-IT001			
	2IT305	Instrument Cable For 2TI-IT001			
	2IT306	Instrument Cable For 2TI-IT001			
	2IT307	Instrument Cable For 2TI-IT001			
	2IT424	Instrument Cable For 2TI-IT001			
	2RC648	Control Cable For 2TI-IT001			
2TI-RC005A	2RC350	Instrument Cable For 2TI-0413A and 2TI-RC005A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC006A	2RC355	Instrument Cable For 2TI-0423A and 2TI-RC006A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC007A	2RC360	Instrument Cable For 2TI-0433A and 2TI-RC007A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2TI-RC008A	2RC365	Instrument Cable For 2TI-0443A and 2TI-RC008A			
	2RC612	Instrument Cable For 2TI-RC005A, 2TI-RC006A, 2TI-RC007A, and 2TI-RC008A			
2UL-AN012-A7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-B7	2AN166	Control Cable For 2UL-AN012-B7			
	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2UL-AN012-C7	2SI467	Instrument Cable For 2LI-0930, 2UL-AN012-A7, 2UL-AN012-B7, and 2UL-AN012-C7			
2VD01CA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 3.4A-2					
2VD09YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YB	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VP01CA	2VP016	Control Cable For 2VP01CA			
	2VP019	Control Cable For 2VP01CA			
	2VP021	Control Cable For 2VP01CA			
2VP01CC	2VP060	Control Cable For 2VP01CC			
	2VP065	Control Cable For 2VP01CC			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 4.1-1					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
1FI-0121A	1CV421	Instrument Cable For 1FI-0121A and 1FI-0121B	1NI-0032B	1NR151	Instrument Cable For 1NI-0032B
1FI-0121B	1CV421	Instrument Cable For 1FI-0121A and 1FI-0121B	1NI-NR006D	1NR298	Instrument Cable For 1NI-NR006D
1NI-0031B	1NR133	Instrument Cable For 1NI-0031B	1PI-0456	1RC495	Instrument Cable For 1PI-0456, 1TI-RC007B, and 1TI-RC008B
1NI-NR005D	1NR297	Instrument Cable For 1NI-NR005D	1PI-0458	1MS054	Instrument Cable For 1PI-0458
1PI-0455A	1RC489	Instrument Cable For 1PI-0455A, 1TI-RC005A, and 1TI-RC006A	1TI-RC005B	1MS037	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1PI-0457	1MS047	Instrument Cable For 1PI-0457	1TI-RC006B	1MS037	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1PI-CC107	1CC330	Instrument Cable For 1PI-CC107	1TI-RC007B	1MS037	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1TI-RC005A	1RC489	Instrument Cable For 1PI-0455A, 1TI-RC005A, and 1TI-RC006A		1RC495	Instrument Cable For 1PI-0456, 1TI-RC007B, and 1TI-RC008B
1TI-RC006A	1RC489	Instrument Cable For 1PI-0455A, 1TI-RC005A, and 1TI-RC006A	1TI-RC008B	1MS037	Instrument Cable For 1TI-RC005B, 1TI-RC006B, 1TI-RC007B, and 1TI-RC008B
1TI-RC007A	1RC488	Instrument Cable For 1TI-RC007A and 1TI-RC008A		1RC495	Instrument Cable For 1PI-0456, 1TI-RC007B, and 1TI-RC008B
1TI-RC008A	1RC488	Instrument Cable For 1TI-RC007A and 1TI-RC008A			
Unit 2 Components					
NONE			NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 4.1-2					
Unit 0 (Common) Components					
NONE			NONE		
Unit 1 Components					
NONE			NONE		
Unit 2 Components					
2NI-0031B	2NR133	Instrument Cable For 2NI-0031B	2FI-0121A	2CV421	Instrument Cable For 2FI-0121A and 2FI-0121B
2NI-NR005D	2NR297	Instrument Cable For 2NI-NR005D	2FI-0121B	2CV421	Instrument Cable For 2FI-0121A and 2FI-0121B
2PI-0455A	2RC489	Instrument Cable For 2PI-0455A, 2TI-RC005A, and 2TI-RC006A	2NI-0032B	2NR151	Instrument Cable For 2NI-0032B
2PI-0457	2MS047	Instrument Cable For 2PI-0457	2NI-NR006D	2NR298	Instrument Cable For 2NI-NR006D
2PI-CC107	2CC330	Instrument Cable For 2PI-CC107	2PI-0456	2RC495	Instrument Cable For 2PI-0456, 2TI-RC007B, and 2TI-RC008B
2TI-RC005A	2RC489	Instrument Cable For 2PI-0455A, 2TI-RC005A, and 2TI-RC006A	2PI-0458	2MS054	Instrument Cable For 2PI-0458
2TI-RC006A	2RC489	Instrument Cable For 2PI-0455A, 2TI-RC005A, and 2TI-RC006A	2TI-RC005B	2MS037	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
2TI-RC007A	2RC488	Instrument Cable For 2TI-RC007A and 2TI-RC008A	2TI-RC006B	2MS037	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
2TI-RC008A	2RC488	Instrument Cable For 2TI-RC007A and 2TI-RC008A	2TI-RC007B	2MS037	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
				2RC495	Instrument Cable For 2PI-0456, 2TI-RC007B, and 2TI-RC008B
			2TI-RC008B	2MS037	Instrument Cable For 2TI-RC005B, 2TI-RC006B, 2TI-RC007B, and 2TI-RC008B
				2RC495	Instrument Cable For 2PI-0456, 2TI-RC007B, and 2TI-RC008B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
Unit 0 (Common) Components					
NONE			0CC01E-C	1CC027 1CC029 1CC031 1CC277 1DC039	Power Cable For 0CC01E-C Control Cable For 0CC01E-C Control Cable For 0CC01E-C Control Cable For 0CC01E-C Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
			0CC01P	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
			0SX02PB	1SX268	Control Cable For 0SX02PB
			0SX157A	1SX085	Control Cable For 0SX157A
			0SX162B	1SX169	Control Cable For 0SX162B

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1SX346	Control Cable For 0SX162B
			0SX163E	1SX161	Control Cable For 0SX163E
			0SX163F	1SX165	Control Cable For 0SX163F
			0VA01CB	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1VA009	Power Cable For 0VA01CB
				1VA010	Control Cable For 0VA01CB
			0VA02CB	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1VA019	Power Cable For 0VA02CB
				1VA020	Control Cable For 0VA02CB
				1VA799	Control Cable For 0VA02CB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1			0VA475Y	1DC039	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1VA025	Control Cable For 0VA475Y
				1VA031	Control Cable For 0VA475Y
				1VA794	Control Cable For 0VA475Y
			0VC01CB	1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VC059	Power Cable For 0VC01CB
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
				1VC064	Control Cable For 0VC01CB
			0VC01Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1			0VC02CB	1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			0VC03Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			0VC044Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			0VC16Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			0VC172Y	1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
	0VC175Y			1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
	0VC182Y			1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
	0VC217Y			1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
			0VC282Y	1VC063	Control Cable For 0VC01CB, 0VC217Y, 0VC282Y, 0VC01Y, 0VC02CB, 0VC03Y, 0VC044Y, 0VC16Y, 0VC172Y, 0VC175Y, and 0VC182Y
Unit 1 Components					
-	1VX16Y	Division 12 ESF Swgr Room Fire Damper	-	1AP06EC	Division 12 ACB (for Safety Injection Pump 1SI01PB)
	1VX17Y	Division 12 ESF Swgr Room Fire Damper		1AP06EE	Division 12 4160V ESF Switchgear Bus 142 Undervoltage Cubicle
				1AP06EF	Division 12 ACB 1423 (Feed from Diesel Generator 1B)
				1AP06EG	Division 12 ACB 1421 (Bus Tie to 4160V Swgr Bus 144)
				1AP06EH	Division 12 ACB (for Containment Spray Pump 1CS01PB)
				1AP06EL	Division 12 ACB (for Control Room Refrig'n Unit 0WO01CB)
				1AP06EN	Division 12 ACB 1425Z (4160-480V ESW Clg Twr Transformer 132Z)
				1AP06EP	Division 12 ACB 1425X (4160-480V ESF Transformer 1AP13E)
				1AP06EQ	Division 12 ACB 1424 (Reserve Feed from 4160V Swgr Bus 242)
				1AP06ES	Division 12 ACB1422 (SAT Feed from Transformer 142-2)
				1AP12E	Division 12 480V ESF Switchgear Bus 132X

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1VX02Y	Division 12 ESF Swgr Room Return Air Damper
			1AF01PB-C	1AF291	Control Cable For 1AF01PB-C
				1AF292	Control Cable For 1AF01PB-C
			1AP06EC	1SI008	Power Cable For 1AP06EC
				1SI011	Control Cable For 1AP06EC
			1AP06EE	1AP313	Control Cable For 1AP06EE
				1AP662	Control Cable For 1AP06EE
				1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DG166	Control Cable For 1AP06EE and 1DG01KB
			1AP06EF	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DG038	Control Cable For 1AP06EF and 1DG01KB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1DG039	Control Cable For 1AP06EF
				1DG106	Control Cable For 1AP06EF and 1DG01KB
				1DG148	Control Cable For 1AP06EF
				1DG149	Control Cable For 1AP06EF
				1DG217	Control Cable For 1AP06EF and 1DG01KB
				1DG225	Control Cable For 1DG01KB and 1AP06EF
				1DG229	Control Cable For 1AP06EF
				1DGBBU	Power Cable For 1AP06EF and 1DG01KB
			1AP06EG	1AP053	Control Cable For 1AP06EG
				1AP155	Control Cable For 1AP06EG
				1AP176	Control Cable For 1AP06EG
				1APBU4	Power Cable For 1AP06EG
			1AP06EH	1CS011	Control Cable For 1AP06EH
				1CS013	Control Cable For 1AP06EH
				1CS018	Power Cable For 1AP06EH
				1CS123	Control Cable For 1AP06EH
				1EF087	Control Cable For 1AP06EH
			1AP06EL	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1WO027	Power Cable For 1AP06EL
				1WO029	Control Cable For 1AP06EL
				1WO030	Control Cable For 1AP06EL

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
			1AP06EN	1WO140 1AP183 1AP185 1AP406 1DC039	Control Cable For 1AP06EL Power Cable For 1AP06EN Control Cable For 1AP06EN Control Cable For 1AP06EN Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
			1AP06EP	1AP117 1AP119 1AP120 1DC039	Power Cable For 1AP06EP Control Cable For 1AP06EP Control Cable For 1AP06EP Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
			1AP06EQ	1AP077 1AP078	Power Cable For 1AP06EQ and 2AP06ED Power Cable For 1AP06EQ and 2AP06ED

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1AP080	Control Cable For 1AP06EQ
				1AP323	Power Cable For 1AP06EQ and 2AP06ED
				1AP324	Power Cable For 1AP06EQ and 2AP06ED
				1AP325	Power Cable For 1AP06EQ and 2AP06ED
				1AP326	Power Cable For 1AP06EQ and 2AP06ED
				2AP588	Control Cable For 1AP06EQ and 2AP06ED
			1AP06ES	1AP044	Control Cable For 1AP06ES
				1AP045	Control Cable For 1AP06ES
				1AP314	Control Cable For 1AP06ES
				1AP587	Control Cable For 1AP06ES and 2AP06EF
				1APBU3	Power Cable For 1AP06ES
				1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DG213	Control Cable For 1AP06ES
				1DG214	Control Cable For 1AP06ES
			1AP12E	1AP420	Power Cable For 1AP12E
				1AP421	Power Cable For 1AP12E
				1AP422	Power Cable For 1AP12E
				1AP423	Power Cable For 1AP12E
				1AP424	Power Cable For 1AP12E
				1AP425	Power Cable For 1AP12E
				1AP426	Power Cable For 1AP12E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1AP427	Power Cable For 1AP12E
				1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1AP23E			1AP149	Power Cable For 1AP23E
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1AP24E			1AP152	Power Cable For 1AP24E and 1AP32E
				1AP154	Power Cable For 1AP24E and 1AP32E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1AP690	Power Cable For 1AP24E and 1AP32E
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1AP27E			1AP150	Power Cable For 1AP27E
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1AP28E			1AP153	Power Cable For 1AP28E
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1AP32E			1AP152	Power Cable For 1AP24E and 1AP32E
				1AP154	Power Cable For 1AP24E and 1AP32E
				1AP690	Power Cable For 1AP24E and 1AP32E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1AP92E			1DC243	Control Cable For 1AP98E and 1AP92E
				1DC245	Control Cable For 1AP98E and 1AP92E
	1AP98E			1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC243	Control Cable For 1AP98E and 1AP92E
				1DC245	Control Cable For 1AP98E and 1AP92E
	1CC01PB			1CC010	Power Cable For 1CC01PB
				1CC012	Control Cable For 1CC01PB
				1CC284	Control Cable For 1CC01PB

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
	1CV01PB			1CV011	Power Cable For 1CV01PB
				1CV012	Control Cable For 1CV01PB
				1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
	1DC04E			1DC023	Power Cable For 1DC04E
				1DC062	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1DG01KB			1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DG038	Control Cable For 1AP06EF and 1DG01KB
				1DG106	Control Cable For 1AP06EF and 1DG01KB
				1DG151	Control Cable For 1DG01KB
				1DG159	Control Cable For 1DG01KB
				1DG166	Control Cable For 1AP06EE and 1DG01KB
				1DG177	Control Cable For 1DG01KB
				1DG195	Control Cable For 1DG01KB
				1DG217	Control Cable For 1AP06EF and 1DG01KB
				1DG224	Control Cable For 1DG01KB
				1DG225	Control Cable For 1DG01KB and 1AP06EF
				1DGBBU	Power Cable For 1AP06EF and 1DG01KB
	1DO01PB			1DO006	Power Cable For 1DO01PB
	1DO01PD			1DO009	Power Cable For 1DO01PD
	1IP04J			1EF052	Control Cable For 1IP04J
	1NI-0032B			1NR257	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1NR263	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
	1NI-NR006B			1NR257	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR263	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
	1NI-NR006D			1NR257	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
				1NR263	Control Cable For 1NI-0032B, 1NI-NR006B, and 1NI-NR006D
	1RH01PB			1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1RH008	Power Cable For 1RH01PB
				1RH010	Control Cable For 1RH01PB
				1RH092	Control Cable For 1RH01PB
	1RY8000B			1RY397	Control Cable For 1RY8000B
	1SX016B			1SX474	Control Cable For 1SX016B and 1SX027B
	1SX01PB			1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1SX012	Power Cable For 1SX01PB
				1SX016	Control Cable For 1SX01PB
				1SX017	Control Cable For 1SX01PB-C and 1SX01PB
				1SX038	Control Cable For 1SX01PB
				1SX144	Control Cable For 1SX01PB
				1SX286	Control Cable For 1SX01PB
			1SX01PB-C	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1SX017	Control Cable For 1SX01PB-C and 1SX01PB
			1SX027B	1SX474	Control Cable For 1SX016B and 1SX027B
			1SX169B	1SX301	Control Cable For 1SX169B
			1VA01CE	1DC039	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1DC040	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
	1VA01CH			1VA115	Control Cable For 1VA01CE
				1DC039	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
	1VA02CC			1VA170	Control Cable For 1VA01CH
				1DC039	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1VA105	Control Cable For 1VA02CC

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1			1VA02CD	1DC039	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1VA154	Control Cable For 1VA02CD
	1VA06CC			1DC039	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1DC040	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
				1VA057	Control Cable For 1VA06CC
	1VA06CD			1DC039	Power Cable For OCC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, OCC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1DC040	Power Cable For 0CC01E-C, 0VA01CB, 0VA02CB, 1AP06EE, 1AP06EF, 1AP06EL, 1AP06EN, 1AP06EP, 1AP06ES, 1CC01PB, 1CV01PB, 1RH01PB, 1SX01PB, 0CC01P, 0VA475Y, 1AP12E, 1AP98E, 1DG01KB, 1SX01PB-C, 1VA01CE, 1VA01CH, 1VA02CC, 1VA02CD, 1VA06CC, and 1VA06CD
	1VD01CB		1VA141		Control Cable For 1VA06CD
			1DC062		Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
			1DC240		Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
	1VD01YA		1VD007		Power Cable For 1VD01CB
			1VD008		Control Cable For 1VD01CB
			1VD012		Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD012		Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD066		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD076		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD081		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD086		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD090		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD095		Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1			1VD01YB	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD076	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD02YA	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD076	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
			1VD02YB	1VD012	Control Cable For 1VD01CB, 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD066	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD076	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD081	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1VD086	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD090	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
				1VD095	Control Cable For 1VD01YA, 1VD01YB, 1VD02YA, and 1VD02YB
	1VE01C		1VE008	1VE008	Control Cable For 1VE01C, 1VE01Y, and 1VE02Y
	1VE01Y		1VE008	1VE008	Control Cable For 1VE01C, 1VE01Y, and 1VE02Y
			1VE014		Control Cable For 1VE01Y and 1VE02Y
	1VE02Y		1VE008	1VE008	Control Cable For 1VE01C, 1VE01Y, and 1VE02Y
			1VE014		Control Cable For 1VE01Y and 1VE02Y
	1VP01CB		1DC062		Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VP025	Power Cable For 1VP01CB
				1VP041	Control Cable For 1VP01CB
				1VP042	Control Cable For 1VP01CB
				1VP043	Control Cable For 1VP01CB
	1VP01CD		1DC062		Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1				1DC240	Power Cable For 0VC01CB, 1AP12E, 1VD01CB, 1VP01CB, 1VP01CD, 0VC02CB, 0VC172Y, 0VC175Y, 0VC182Y, 0VC217Y, 1AP23E, 1AP24E, 1AP27E, 1AP28E, 1AP32E, and 1DC04E
				1VP069	Power Cable For 1VP01CD
				1VP085	Control Cable For 1VP01CD
				1VP086	Control Cable For 1VP01CD
				1VP087	Control Cable For 1VP01CD
	1VX01C			1VX008	Control Cable For 1VX01C
				1VX066	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX070	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX105	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX113	Power Cable For 1VX01C
	1VX01Y			1VX023	Instrument Cable For 1VX01Y and 1VX02Y
				1VX025	Instrument Cable For 1VX01Y and 1VX02Y
				1VX026	Instrument Cable For 1VX01Y and 1VX02Y
				1VX038	Control Cable For 1VX01Y and 1VX02Y
				1VX066	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX067	Control Cable For 1VX01Y and 1VX02Y
				1VX068	Control Cable For 1VX01Y and 1VX02Y
				1VX069	Control Cable For 1VX01Y and 1VX02Y
				1VX070	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX072	Control Cable For 1VX01Y and 1VX02Y
				1VX074	Control Cable For 1VX01Y and 1VX02Y
				1VX075	Control Cable For 1VX01Y and 1VX02Y
				1VX076	Control Cable For 1VX01Y and 1VX02Y
				1VX099	Control Cable For 1VX01Y and 1VX02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-1					
				1VX105	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
			1VX02Y	1VX023	Instrument Cable For 1VX01Y and 1VX02Y
				1VX025	Instrument Cable For 1VX01Y and 1VX02Y
				1VX026	Instrument Cable For 1VX01Y and 1VX02Y
				1VX038	Control Cable For 1VX01Y and 1VX02Y
				1VX066	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX067	Control Cable For 1VX01Y and 1VX02Y
				1VX068	Control Cable For 1VX01Y and 1VX02Y
				1VX069	Control Cable For 1VX01Y and 1VX02Y
				1VX070	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
				1VX072	Control Cable For 1VX01Y and 1VX02Y
				1VX074	Control Cable For 1VX01Y and 1VX02Y
				1VX075	Control Cable For 1VX01Y and 1VX02Y
				1VX076	Control Cable For 1VX01Y and 1VX02Y
				1VX099	Control Cable For 1VX01Y and 1VX02Y
				1VX105	Control Cable For 1VX01C, 1VX01Y, and 1VX02Y
			1VX06C	1VX049	Control Cable For 1VX06C
Unit 2 Components					
NONE			2AP06ED	1AP077	Power Cable For 1AP06EQ and 2AP06ED
				1AP078	Power Cable For 1AP06EQ and 2AP06ED
				1AP323	Power Cable For 1AP06EQ and 2AP06ED
				1AP324	Power Cable For 1AP06EQ and 2AP06ED
				1AP325	Power Cable For 1AP06EQ and 2AP06ED
				1AP326	Power Cable For 1AP06EQ and 2AP06ED
				2AP588	Control Cable For 1AP06EQ and 2AP06ED
			2AP06EF	1AP587	Control Cable For 1AP06ES and 2AP06EF

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2					
Unit 0 (Common) Components					
NONE			0CC01E-D	2CC027 2CC029 2CC031 2CC277 2DC039	Power Cable For 0CC01E-D Control Cable For 0CC01E-D Control Cable For 0CC01E-D Control Cable For 0CC01E-D Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
			0CC01P	2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
			0SX162D	2SX346	Control Cable For 0SX162D

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			0VA01CD	2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA009	Power Cable For 0VA01CD
				2VA010	Control Cable For 0VA01CD
			0VA02CD	2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA019	Power Cable For 0VA02CD
				2VA020	Control Cable For 0VA02CD
				2VA799	Control Cable For 0VA02CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2AP06EP	Division 22 ACB (for Containment Spray Pump 2CS01PB)
				2AP06EQ	Division 22 ACB 2421 (Bus Tie to 4160V Swgr Bus 244)
				2AP06ER	Division 22 ACB 2423 (Feed from Diesel Generator 2B)
				2AP06ES	Division 22 4160V ESF Switchgear Bus 242 Undervoltage Cubicle
				2AP06EU	Division 22 ACB (for Safety Injection Pump 2SI01PB)
				2AP06EV	Division 22 ACB 2425Z (4160-480V ESW Clg Twr Transformer 232Z)
				2AP12E	Division 22 480V ESF Switchgear Bus 232X
				2VX02Y	Division 22 ESF Swgr Room Return Air Damper
			2AF005E	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2AF005F	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2AF005G	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2AF005H	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			2AF01PB	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2AF01PB-A	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2AF01PB-C	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2AP06ED	1AP077	Power Cable For 1AP06EQ and 2AP06ED
				1AP078	Power Cable For 1AP06EQ and 2AP06ED
				1AP323	Power Cable For 1AP06EQ and 2AP06ED
				1AP324	Power Cable For 1AP06EQ and 2AP06ED
				1AP325	Power Cable For 1AP06EQ and 2AP06ED
				1AP326	Power Cable For 1AP06EQ and 2AP06ED
				2AP080	Control Cable For 2AP06ED
				2AP588	Control Cable For 1AP06EQ and 2AP06ED
			2AP06EF	1AP587	Control Cable For 1AP06ES and 2AP06EF
				2AP044	Control Cable For 2AP06EF
				2AP045	Control Cable For 2AP06EF
				2AP314	Control Cable For 2AP06EF
				2APBU3	Power Cable For 2AP06EF
				2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
	2AP06EH			2DG213	Control Cable For 2AP06EF and 2AP06ER
				2DG214	Control Cable For 2AP06EF and 2AP06ER
				2AP117	Power Cable For 2AP06EH
				2AP119	Control Cable For 2AP06EH
				2AP120	Control Cable For 2AP06EH
				2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
	2AP06EP			2CS011	Control Cable For 2AP06EP
				2CS013	Control Cable For 2AP06EP
				2CS018	Power Cable For 2AP06EP
				2CS123	Control Cable For 2AP06EP
	2AP06EQ			2EF087	Control Cable For 2AP06EP
				2AP053	Control Cable For 2AP06EQ
				2AP155	Control Cable For 2AP06EQ
				2AP176	Control Cable For 2AP06EQ
				2APBU4	Power Cable For 2AP06EQ

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			2AP06ER	2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DG038	Control Cable For 2AP06ER and 2DG01KB
				2DG039	Control Cable For 2AP06ER
				2DG106	Control Cable For 2AP06ER and 2DG01KB
				2DG148	Control Cable For 2AP06ER
				2DG149	Control Cable For 2AP06ER
				2DG213	Control Cable For 2AP06EF and 2AP06ER
				2DG214	Control Cable For 2AP06EF and 2AP06ER
				2DG217	Control Cable For 2AP06ER and 2DG01KB
				2DG225	Control Cable For 2DG01KB and 2AP06ER
				2DG229	Control Cable For 2AP06ER
				2DG8BU	Power Cable For 2AP06ER and 2DG01KB
			2AP06ES	2AP313	Control Cable For 2AP06ES
				2AP662	Control Cable For 2AP06ES
				2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DG166	Control Cable For 2AP06ES and 2DG01KB
	2AP06EU			2SI008	Power Cable For 2AP06EU
				2SI011	Control Cable For 2AP06EU
	2AP06EV			2AP183	Power Cable For 2AP06EV
				2AP185	Control Cable For 2AP06EV
				2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
	2AP12E			2AP420	Power Cable For 2AP12E
				2AP421	Power Cable For 2AP12E
				2AP422	Power Cable For 2AP12E
				2AP423	Power Cable For 2AP12E
				2AP424	Power Cable For 2AP12E
				2AP425	Power Cable For 2AP12E
				2AP426	Power Cable For 2AP12E
				2AP427	Power Cable For 2AP12E

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
	2AP23E			2AP149	Power Cable For 2AP23E
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
	2AP24E			2AP152	Power Cable For 2AP24E
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
	2AP27E			2AP150	Power Cable For 2AP27E
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2					
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
	2AP28E			2AP153	Power Cable For 2AP28E
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
	2AP32E			2AP154	Power Cable For 2AP32E
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
	2AP98E			2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
	2CC01PB			2CC010	Power Cable For 2CC01PB
				2CC012	Control Cable For 2CC01PB
				2CC284	Control Cable For 2CC01PB

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
	2CV01PB			2CV011	Power Cable For 2CV01PB
				2CV012	Control Cable For 2CV01PB
				2CV016	Control Cable For 2CV01PB
				2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
	2DC04E			2DC023	Power Cable For 2DC04E
				2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			2DG01KB	2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DG038	Control Cable For 2AP06ER and 2DG01KB
				2DG106	Control Cable For 2AP06ER and 2DG01KB
				2DG151	Control Cable For 2DG01KB
				2DG159	Control Cable For 2DG01KB
				2DG166	Control Cable For 2AP06ES and 2DG01KB
				2DG177	Control Cable For 2DG01KB
				2DG178	Control Cable For 2DG01KB
				2DG195	Control Cable For 2DG01KB
				2DG217	Control Cable For 2AP06ER and 2DG01KB
				2DG224	Control Cable For 2DG01KB
				2DG225	Control Cable For 2DG01KB and 2AP06ER
				2DG8BU	Power Cable For 2AP06ER and 2DG01KB
			2DO01PD	2DO009	Power Cable For 2DO01PD
				2DO010	Control Cable For 2DO01PD
			2IP02E	2IP020	Power Cable For 2IP02E
			2IP04E	2IP044	Power Cable For 2IP04E
			2IP04J	2EF052	Control Cable For 2IP04J

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			2MS001A-DIV22	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2MS001B-DIV22	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2MS001C-DIV22	2MS286 2DC184	Control Cable For 2MS001B-DIV22 Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2MS001D-DIV22	2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2MS018B	2MS614	Control Cable For 2MS018B
			2MS018C	2MS626	Control Cable For 2MS018C
			2RH01PB	2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2RH008	Power Cable For 2RH01PB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2					
				2RH010	Control Cable For 2RH01PB
				2RH092	Control Cable For 2RH01PB
			2SX016B	2SX474	Control Cable For 2SX016B and 2SX027B
			2SX01PB	2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2SX012	Power Cable For 2SX01PB
				2SX016	Control Cable For 2SX01PB
				2SX017	Control Cable For 2SX01PB-C and 2SX01PB
				2SX038	Control Cable For 2SX01PB
				2SX144	Control Cable For 2SX01PB
				2SX209	Control Cable For 2SX01PB
				2SX286	Control Cable For 2SX01PB
			2SX01PB-C	2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2SX017	Control Cable For 2SX01PB-C and 2SX01PB
	2SX027B			2SX474	Control Cable For 2SX016B and 2SX027B
	2SX173			2DC184	Control Cable For 2AF005E, 2AF005F, 2AF005G, 2AF005H, 2AF01PB, 2MS001A-DIV22, 2MS001B-DIV22, 2MS001C-DIV22, 2MS001D-DIV22, 2AF01PB-A, 2AF01PB-C, and 2SX173
			2VA01CE	2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA115	Control Cable For 2VA01CE
			2VA01CH	2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2					
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA170	Control Cable For 2VA01CH
	2VA02CC			2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA105	Control Cable For 2VA02CC
	2VA02CD			2DC039	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For 0CC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, 0CC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA154	Control Cable For 2VA02CD

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			2VA06CC	2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
			2VA06CD	2VA057	Control Cable For 2VA06CC
				2DC039	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2DC040	Power Cable For OCC01E-D, 0VA01CD, 0VA02CD, 2AP06EF, 2AP06EH, 2AP06ER, 2AP06ES, 2AP06EV, 2CC01PB, 2CV01PB, 2RH01PB, 2SX01PB, OCC01P, 0VA477Y, 2AP12E, 2AP98E, 2DG01KB, 2SX01PB-C, 2VA01CE, 2VA01CH, 2VA02CC, 2VA02CD, 2VA06CC, and 2VA06CD
				2VA141	Control Cable For 2VA06CD
			2VD01CB	2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2VD007	Power Cable For 2VD01CB
				2VD008	Control Cable For 2VD01CB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2					
				2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD01YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD01YB	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
			2VD02YA	2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD066	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VD02YB			2VD012	Control Cable For 2VD01CB, 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD076	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD081	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD086	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD090	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
				2VD095	Control Cable For 2VD01YA, 2VD01YB, 2VD02YA, and 2VD02YB
	2VE01Y			2VE042	Control Cable For 2VE01Y and 2VE02Y
	2VE02Y			2VE042	Control Cable For 2VE01Y and 2VE02Y
	2VP01CB			2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2VP025	Power Cable For 2VP01CB
				2VP041	Control Cable For 2VP01CB
				2VP042	Control Cable For 2VP01CB
				2VP043	Control Cable For 2VP01CB

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2			2VP01CD	2DC061	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2DC062	Power Cable For 2AP12E, 2VD01CB, 2VP01CB, 2VP01CD, 2AP23E, 2AP24E, 2AP27E, 2AP28E, 2AP32E, and 2DC04E
				2VP069	Power Cable For 2VP01CD
				2VP085	Control Cable For 2VP01CD
				2VP086	Control Cable For 2VP01CD
				2VP087	Control Cable For 2VP01CD
			2VX01C	2VX008	Control Cable For 2VX01C
				2VX066	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
				2VX070	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
				2VX113	Power Cable For 2VX01C
				2VX114	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
			2VX01Y	2VX023	Instrument Cable For 2VX01Y and 2VX02Y
				2VX025	Instrument Cable For 2VX01Y and 2VX02Y
				2VX026	Instrument Cable For 2VX01Y and 2VX02Y
				2VX038	Control Cable For 2VX01Y and 2VX02Y
				2VX066	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
				2VX067	Control Cable For 2VX01Y and 2VX02Y
				2VX068	Control Cable For 2VX01Y and 2VX02Y
				2VX069	Control Cable For 2VX01Y and 2VX02Y
				2VX070	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
				2VX072	Control Cable For 2VX01Y and 2VX02Y
				2VX074	Control Cable For 2VX01Y and 2VX02Y
				2VX075	Control Cable For 2VX01Y and 2VX02Y
				2VX076	Control Cable For 2VX01Y and 2VX02Y
				2VX099	Control Cable For 2VX01Y and 2VX02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.1-2					
				2VX114	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
	2VX02Y			2VX023	Instrument Cable For 2VX01Y and 2VX02Y
				2VX025	Instrument Cable For 2VX01Y and 2VX02Y
				2VX026	Instrument Cable For 2VX01Y and 2VX02Y
				2VX038	Control Cable For 2VX01Y and 2VX02Y
				2VX066	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
				2VX067	Control Cable For 2VX01Y and 2VX02Y
				2VX068	Control Cable For 2VX01Y and 2VX02Y
				2VX069	Control Cable For 2VX01Y and 2VX02Y
				2VX070	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y
				2VX072	Control Cable For 2VX01Y and 2VX02Y
				2VX074	Control Cable For 2VX01Y and 2VX02Y
				2VX075	Control Cable For 2VX01Y and 2VX02Y
				2VX076	Control Cable For 2VX01Y and 2VX02Y
				2VX099	Control Cable For 2VX01Y and 2VX02Y
				2VX114	Control Cable For 2VX01C, 2VX01Y, and 2VX02Y

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
Unit 0 (Common) Components					
0CC01E-A	1CC019	Power Cable For 0CC01E-A			NONE
	1CC022	Control Cable For 0CC01E-A			
	1CC025	Control Cable For 0CC01E-A			
	1CC276	Control Cable For 0CC01E-A			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
0CC01P	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
0SX02PA	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
	1SX258	Control Cable For 0SX02PA			
0SX158A	1SX079	Control Cable For 0SX158A			
0SX162A	1SX157	Control Cable For 0SX162A			
	1SX345	Control Cable For 0SX162A			
0SX163A	1SX149	Control Cable For 0SX163A			
0SX163B	1SX153	Control Cable For 0SX163B			
0VA01CA	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1VA001	Power Cable For 0VA01CA			
	1VA002	Control Cable For 0VA01CA			
0VA02CA	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
OVA474Y	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1VA016	Power Cable For OVA02CA			
	1VA017	Control Cable For OVA02CA			
	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
OVC01CA	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1VA027	Control Cable For OVA474Y			
	1VA793	Control Cable For OVA474Y			
	1DC057	Power Cable For OVC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, OVC02CA, OVC033Y, OVC094Y, OVC095Y, OVC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For OVC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, OVC02CA, OVC033Y, OVC094Y, OVC095Y, OVC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1VC013	Power Cable For 0VC01CA			
	1VC018	Control Cable For 0VC01CA			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC02CA	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC033Y	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
0VC043Y	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC157	Control Cable For 0VC033Y and 0VC281Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC571	Control Cable For 0VC033Y and 0VC281Y			
	1PR065	Power Cable For 0VC281Y and 0VC043Y			
	1PR066	Power Cable For 0VC281Y and 0VC043Y			
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1PR314	Power Cable For 0VC281Y and 0VC043Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC159	Control Cable For 0VC043Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
	1VC573	Control Cable For 0VC043Y			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
0VC094Y	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
0VC095Y	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
0VC133Y	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
0VC17Y	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC490	Control Cable For 0VC281Y, 0VC033Y, 0VC043Y, 0VC17Y, and 0VC19Y			
0VC18Y	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
	1VC572	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			
0VC19Y	1PR313	Power Cable For 0VC20Y, 0VC281Y, 0VC043Y, 0VC18Y, and 0VC19Y			
	1VC019	Control Cable For 0VC01CA, 0VC281Y, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, and 0VC19Y			
	1VC115	Control Cable For 0VC01CA, 0VC02CA, 0VC033Y, 0VC043Y, 0VC094Y, 0VC095Y, 0VC133Y, 0VC17Y, 0VC18Y, 0VC19Y, 0VC20Y, and 0VC281Y			
	1VC158	Control Cable For 0VC17Y, 0VC18Y, 0VC19Y, and 0VC20Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
OVC20Y	1VC490	Control Cable For OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
	1VC572	Control Cable For OVC17Y, OVC18Y, OVC19Y, and OVC20Y			
	1PR313	Power Cable For OVC20Y, OVC281Y, OVC043Y, OVC18Y, and OVC19Y			
	1VC115	Control Cable For OVC01CA, OVC02CA, OVC033Y, OVC043Y, OVC094Y, OVC095Y, OVC133Y, OVC17Y, OVC18Y, OVC19Y, OVC20Y, and OVC281Y			
OVC281Y	1VC158	Control Cable For OVC17Y, OVC18Y, OVC19Y, and OVC20Y			
	1VC572	Control Cable For OVC17Y, OVC18Y, OVC19Y, and OVC20Y			
	1PR065	Power Cable For OVC281Y and OVC043Y			
	1PR066	Power Cable For OVC281Y and OVC043Y			
	1PR313	Power Cable For OVC20Y, OVC281Y, OVC043Y, OVC18Y, and OVC19Y			
	1PR314	Power Cable For OVC281Y and OVC043Y			
	1VC019	Control Cable For OVC01CA, OVC281Y, OVC02CA, OVC033Y, OVC043Y, OVC094Y, OVC095Y, OVC133Y, OVC17Y, and OVC19Y			
	1VC115	Control Cable For OVC01CA, OVC02CA, OVC033Y, OVC043Y, OVC094Y, OVC095Y, OVC133Y, OVC17Y, OVC18Y, OVC19Y, OVC20Y, and OVC281Y			
	1VC157	Control Cable For OVC033Y and OVC281Y			
	1VC490	Control Cable For OVC281Y, OVC033Y, OVC043Y, OVC17Y, and OVC19Y			
Unit 1 Components	1VC571	Control Cable For OVC033Y and OVC281Y			
	1AP05EA	Division 11 ACB 1415Z (4160-480V ESW Clg Twr Transformer 131Z)	1PI-0515A	1MS115	Instrument Cable For 1PI-0515A
			1PI-0516A	1MS127	Instrument Cable For 1PI-0516A
			1PI-0535A	1MS121	Instrument Cable For 1PI-0535A

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1AP05EC	Division 11 ACB (for Safety Injection Pump 1SI01PA)	1PI-0545A	1MS124	Instrument Cable For 1PI-0545A
	1AP05EE	Division 11 4160V ESF Switchgear Bus 141 Undervoltage Cubicle	1PI-0546A	1MS128	Instrument Cable For 1PI-0546A
	1AP05EF	Division 11 ACB 1413 (Feed from Diesel Generator 1A)			
	1AP05EG	Division 11 ACB 1411 (Bus Tie to 4160V Swgr Bus 143)			
	1AP05EJ	Division 11 ACB (for Containment Spray Pump 1CS01PA)			
	1AP05EK	Division 11 ACB (for Control Room Refrig'n Unit 0WO01CA)			
	1AP05EP	Division 11 ACB 1414 (Reserve Feed from 4160V Swgr Bus 241)			
	1AP05ER	Division 11 ACB 1412 (SAT Feed from Transformer 142-1)			
	1AP05EU	Division 11 ACB 1415X (4160-480V ESF Transformer 1AP11E)			
	1AP07E	Division 11 4160 Non-ESF Switchgear Bus 143			
	1AP07EK	4160V Bus 143 Feed From Bus 141			
	1AP07EL	Transformers 133X and 133Y Feed			
	1AP10E	Division 11 480V ESF Switchgear Bus 131X			
	1VX05Y	D1vision 11 ESF Swgr Room Return Air Damper			
	1VX20Y	Division 11 ESF Swgr Room Fire Damper			
	1VX22Y	Division 11 ESF Swgr Room Fire Damper			
1AF005A	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1AF005B	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AF005C	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1AF005D	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1AF006A	1AF056	Control Cable For 1AF006A and 1AF01PA			
	1AF058	Control Cable For 1AF006A			
1AF017A	1AF097	Control Cable For 1AF017A			
1AF01PA	1AF001	Power Cable For 1AF01PA			
	1AF006	Control Cable For 1AF01PA			
	1AF007	Control Cable For 1AF01PA			
	1AF013	Control Cable For 1AF01PA-A and 1AF01PA			
	1AF056	Control Cable For 1AF006A and 1AF01PA			
	1AF064	Control Cable For 1AF01PA-A and 1AF01PA			
	1AF276	Control Cable For 1AF01PA			
	1AF293	Control Cable For 1AF01PA			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1EF026	Control Cable For 1AF01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AF01PA-A	1AF004	Control Cable For 1AF01PA-A			
	1AF013	Control Cable For 1AF01PA-A and 1AF01PA			
	1AF064	Control Cable For 1AF01PA-A and 1AF01PA			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1AP05EA	1AP178	Power Cable For 1AP05EA			
	1AP180	Control Cable For 1AP05EA			
	1AP401	Control Cable For 1AP05EA			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP05EC	1SI001	Power Cable For 1AP05EC			
	1SI004	Control Cable For 1AP05EC			
	1SI005	Control Cable For 1AP05EC			
1AP05EE	1AP311	Control Cable For 1AP05EE			
	1AP661	Control Cable For 1AP05EE			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1AP05EF	1DG165	Control Cable For 1AP05EE and 1DG01KA			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP05EG	1DG002	Control Cable For 1AP05EF			
	1DG005	Control Cable For 1AP05EF			
	1DG019	Control Cable For 1DG01KA and 1AP05EF			
	1DG105	Control Cable For 1AP05EF and 1DG01KA			
	1DG147	Control Cable For 1AP05EF and 1DG01KA			
	1DG152	Control Cable For 1AP05EF			
	1DG216	Control Cable For 1AP05EF and 1DG01KA			
	1DG223	Control Cable For 1DG01KA and 1AP05EF			
	1DG228	Control Cable For 1AP05EF			
	1DGABU	Power Cable For 1AP05EF and 1DG01KA			
	1AP056	Control Cable For 1AP05EG			
	1AP255	Control Cable For 1AP05EG			
	1AP257	Control Cable For 1AP05EG			
	1AP634	Control Cable For 1AP05EG			
	1APBU2	Power Cable For 1AP05EG, 1AP07EK, and 1AP07E			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1AP05EJ	1CS001	Power Cable For 1AP05EJ			
	1CS002	Control Cable For 1AP05EJ			
	1CS004	Control Cable For 1AP05EJ			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP05EK	1CS122	Control Cable For 1AP05EJ			
	1EF086	Control Cable For 1AP05EJ			
	1DC037	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1AP05EP	1DC038	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1WO021	Power Cable For 1AP05EK			
	1WO023	Control Cable For 1AP05EK			
	1WO024	Control Cable For 1AP05EK			
	1AP072	Power Cable For 1AP05EP and 2AP05EJ			
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP075	Control Cable For 1AP05EP			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
1AP05ER	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
	1AP049	Control Cable For 1AP05ER			
	1AP050	Control Cable For 1AP05ER			
	1AP312	Control Cable For 1AP05ER			
	1AP585	Control Cable For 1AP05ER and 2AP05EG			
	1APBU1	Power Cable For 1AP05ER			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP05EU	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DG211	Control Cable For 1AP05ER			
	1DG212	Control Cable For 1AP05ER			
	1AP081	Power Cable For 1AP05EU			
	1AP082	Control Cable For 1AP05EU			
	1AP395	Control Cable For 1AP05EU			
	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP07E	1APBU2	Power Cable For 1AP05EG, 1AP07EK, and 1AP07E			
1AP07EK	1APBU2	Power Cable For 1AP05EG, 1AP07EK, and 1AP07E			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1AP07EL	1AP093	Power Cable For 1AP07EL			
	1AP095	Power Cable For 1AP07EL			
	1AP098	Control Cable For 1AP07EL			
	1DC053	Power Cable For 1AP07EL and 1AP14E			
	1DC054	Power Cable For 1AP07EL and 1AP14E			
1AP10E	1AP414	Power Cable For 1AP10E			
	1AP415	Power Cable For 1AP10E			
	1AP416	Power Cable For 1AP10E			
	1AP417	Power Cable For 1AP10E			
	1AP418	Power Cable For 1AP10E			
	1AP419	Power Cable For 1AP10E			
	1AP428	Power Cable For 1AP10E			
	1AP429	Power Cable For 1AP10E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DC037	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
1AP14E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
	1DC053	Power Cable For 1AP07EL and 1AP14E			
	1DC054	Power Cable For 1AP07EL and 1AP14E			
1AP21E	1AP143	Power Cable For 1AP21E			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP22E	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1AP147	Power Cable For 1AP22E			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
1AP25E	1AP144	Power Cable For 1AP25E			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
1AP26E	1AP146	Power Cable For 1AP26E			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1AP30E	1AP148	Power Cable For 1AP30E			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
1AP38E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1AP42E	1DC041	Power Cable For 1AP14E, 1AP38E, and 1AP42E			
1AP99E	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1CC01PA	1CC001	Power Cable For 1CC01PA			
	1CC003	Control Cable For 1CC01PA			
	1CC283	Control Cable For 1CC01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1CC9415	1CC067	Control Cable For 1CC9415			
1CC9416	1CC059	Control Cable For 1CC9416			
1CC9438	1CC036	Control Cable For 1CC9438			
1CC9473A	1CC127	Control Cable For 1CC9473A			
1CS009A	1CS079	Control Cable For 1CS009A			
1CV01PA	1CV001	Power Cable For 1CV01PA			
	1CV006	Control Cable For 1CV01PA			
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DC038	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1CV8804A	1CV413	Control Cable For 1CV8804A and 1RH8701A			
	1CV468	Control Cable For 1CV8804A			
1DC03E	1DC021	Power Cable For 1DC03E			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
1DG01KA	1DC037	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For OCC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DG017	Control Cable For 1DG01KA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DG018	Control Cable For 1DG01KA			
	1DG019	Control Cable For 1DG01KA and 1AP05EF			
	1DG105	Control Cable For 1AP05EF and 1DG01KA			
	1DG147	Control Cable For 1AP05EF and 1DG01KA			
	1DG153	Control Cable For 1DG01KA			
	1DG154	Control Cable For 1DG01KA			
	1DG157	Control Cable For 1DG01KA			
	1DG165	Control Cable For 1AP05EE and 1DG01KA			
	1DG174	Control Cable For 1DG01KA			
	1DG175	Control Cable For 1DG01KA			
	1DG194	Control Cable For 1DG01KA			
	1DG200	Control Cable For 1DG01KA			
	1DG216	Control Cable For 1AP05EF and 1DG01KA			
	1DG222	Control Cable For 1DG01KA			
	1DG223	Control Cable For 1DG01KA and 1AP05EF			
	1DGABU	Power Cable For 1AP05EF and 1DG01KA			
1DO01PA	1DO001	Power Cable For 1DO01PA			
	1DO002	Control Cable For 1DO01PA			
1DO01PC	1DO004	Power Cable For 1DO01PC			
	1DO005	Control Cable For 1DO01PC			
1IP01E	1IP004	Power Cable For 1IP01E			
1IP01J	1EF037	Control Cable For 1IP01J			
1IP03E	1IP032	Power Cable For 1IP03E			
1IP05E	1IP002	Power Cable For 1IP05E			
1IP07E	1IP030	Power Cable For 1IP07E			
1MS001A-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS001B-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1MS001C-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS001D-DIV11	1DC183	Control Cable For 0SX02PA, 1AF005A, 1AF005B, 1AF005C, 1AF005D, 1MS001A-DIV11, 1MS001B-DIV11, 1MS001C-DIV11, and 1MS001D-DIV11			
1MS018A	1MS594	Power Cable For 1MS018A			
1MS018D	1MS606	Power Cable For 1MS018D			
1RH01PA	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1RH001	Power Cable For 1RH01PA			
	1RH091	Control Cable For 1RH01PA			
1RH8701A	1CV413	Control Cable For 1CV8804A and 1RH8701A			
	1RH029	Control Cable For 1RH8701A and 1SI8811A			
	1RH031	Control Cable For 1RH8701A			
	1SI168	Control Cable For 1RH8701A			
1RH8702A	1RH050	Control Cable For 1RH8702A			
	1RH051	Control Cable For 1RH8702A			
	1RH054	Control Cable For 1RH8702A			
	1RH055	Control Cable For 1RH8702A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1RY8000A	1RY394	Control Cable For 1RY8000A			
1SI8811A	1RH029	Control Cable For 1RH8701A and 1SI8811A			
1SX016A	1SX472	Control Cable For 1SX016A and 1SX027A			
1SX01PA	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1SX001	Power Cable For 1SX01PA			
	1SX005	Control Cable For 1SX01PA			
	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			
	1SX034	Control Cable For 1SX01PA			
	1SX143	Control Cable For 1SX01PA			
	1SX280	Control Cable For 1SX01PA			
1SX01PA-C	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1SX006	Control Cable For 1SX01PA-C and 1SX01PA			
1SX027A	1SX472	Control Cable For 1SX016A and 1SX027A			
1SX101A	1AF002	Control Cable For 1SX101A			
	1AF003	Control Cable For 1SX101A			
	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1SX471	Control Cable For 1SX101A			
1SX169A	1SX295	Control Cable For 1SX169A			
1VA01CA	1DC037	Power Cable For OCC01E-A, OVA01CA, OVA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, OCC01P, OVA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1VA111	Control Cable For 1VA01CA			
1VA01CD	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
1VA02CA	1VA165 1DC037	Control Cable For 1VA01CD Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1VA02CB	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA		1VA104	Control Cable For 1VA02CA
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA		1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA
				1VA149	Control Cable For 1VA02CB
	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1VA053	Control Cable For 1VA06CA			
1VA06CB	1DC037	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1DC038	Power Cable For 0CC01E-A, 0VA01CA, 0VA02CA, 1AF01PA, 1AP05EA, 1AP05EE, 1AP05EF, 1AP05EG, 1AP05EK, 1AP05ER, 1AP05EU, 1CC01PA, 1CV01PA, 1RH01PA, 1SX01PA, 0CC01P, 0VA474Y, 1AF01PA-A, 1AP07EK, 1AP10E, 1AP99E, 1DG01KA, 1SX01PA-C, 1SX101A, 1VA01CA, 1VA01CD, 1VA			
	1VA822	Control Cable For 1VA06CB			
1VD01CA	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1VD001	Power Cable For 1VD01CA			
	1VD002	Control Cable For 1VD01CA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1VD09YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD09YB	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VD10YA	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1VD10YB	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD006	Control Cable For 1VD01CA, 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD014	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD017	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD060	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD071	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1VD084	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
1VP01CA	1VD096	Control Cable For 1VD09YA, 1VD09YB, 1VD10YA, and 1VD10YB			
	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1VP003	Power Cable For 1VP01CA			
	1VP019	Control Cable For 1VP01CA			
	1VP020	Control Cable For 1VP01CA			
	1VP021	Control Cable For 1VP01CA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1					
1VP01CC	1DC057	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1DC239	Power Cable For 0VC01CA, 1AP10E, 1VD01CA, 1VP01CA, 1VP01CC, 0VC02CA, 0VC033Y, 0VC094Y, 0VC095Y, 0VC133Y, 1AP21E, 1AP22E, 1AP25E, 1AP26E, 1AP30E, and 1DC03E			
	1VP047	Power Cable For 1VP01CC			
	1VP063	Control Cable For 1VP01CC			
	1VP064	Control Cable For 1VP01CC			
1VX04C	1VP065	Control Cable For 1VP01CC			
	1VX001	Power Cable For 1VX04C			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX004	Control Cable For 1VX04C			
	1VX059	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
1VX04Y	1VX063	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VE018	Control Cable For 1VX04Y and 1VX05Y			
	1VE031	Control Cable For 1VX04Y and 1VX05Y			
	1VE039	Control Cable For 1VX04Y and 1VX05Y			
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX018	Instrument Cable For 1VX04Y and 1VX05Y			
	1VX020	Instrument Cable For 1VX04Y and 1VX05Y			
	1VX021	Instrument Cable For 1VX04Y and 1VX05Y			
	1VX059	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y			
	1VX061	Control Cable For 1VX04Y and 1VX05Y			
	1VX062	Control Cable For 1VX04Y and 1VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21

Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-1		
1VX05C 1VX05Y	1VX063	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y
	1VX064	Control Cable For 1VX04Y and 1VX05Y
	1VX102	Control Cable For 1VX04Y and 1VX05Y
	1VX044	Control Cable For 1VX05C
	1VE018	Control Cable For 1VX04Y and 1VX05Y
	1VE031	Control Cable For 1VX04Y and 1VX05Y
	1VE039	Control Cable For 1VX04Y and 1VX05Y
	1VX003	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y
	1VX018	Instrument Cable For 1VX04Y and 1VX05Y
	1VX020	Instrument Cable For 1VX04Y and 1VX05Y
	1VX021	Instrument Cable For 1VX04Y and 1VX05Y
	1VX059	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y
	1VX061	Control Cable For 1VX04Y and 1VX05Y
	1VX062	Control Cable For 1VX04Y and 1VX05Y
	1VX063	Control Cable For 1VX04C, 1VX04Y, and 1VX05Y
	1VX064	Control Cable For 1VX04Y and 1VX05Y
	1VX102	Control Cable For 1VX04Y and 1VX05Y
Unit 2 Components		
2AP05EG	1AP585	Control Cable For 1AP05ER and 2AP05EG
2AP05EJ	1AP072	Power Cable For 1AP05EP and 2AP05EJ
	1AP073	Power Cable For 1AP05EP and 2AP05EJ
	1AP319	Power Cable For 1AP05EP and 2AP05EJ
	1AP320	Power Cable For 1AP05EP and 2AP05EJ
	1AP321	Power Cable For 1AP05EP and 2AP05EJ
	1AP322	Power Cable For 1AP05EP and 2AP05EJ
	2AP586	Control Cable For 1AP05EP and 2AP05EJ

Division 12/22

Affected Equipment	Equipment In Zone	Equipment Description
NONE		

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
Unit 0 (Common) Components.					
0CC01E-B	2CC019	Power Cable For 0CC01E-B	NONE		
	2CC022	Control Cable For 0CC01E-B			
	2CC025	Control Cable For 0CC01E-B			
	2CC276	Control Cable For 0CC01E-B			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
0CC01P	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
0SX162C	2SX345	Control Cable For 0SX162C			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
0VA01CC	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2VA001	Power Cable For 0VA01CC			
0VA02CC	2VA002	Control Cable For 0VA01CC			
	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2VA016	Power Cable For 0VA02CC			
	2VA017	Control Cable For 0VA02CC			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
0VA476Y	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2VA025	Control Cable For 0VA476Y			
	2VA027	Control Cable For 0VA476Y			
	2VA793	Control Cable For 0VA476Y			
Unit 1 Components					
1AP05EP	1AP072	Power Cable For 1AP05EP and 2AP05EJ	1AP06ES	1AP587	Control Cable For 1AP06ES and 2AP06EF
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			
	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
1AP05ER	1AP585	Control Cable For 1AP05ER and 2AP05EG			
Unit 2 Components					
-	2AP05ED	Division 21 ACB 2415X (4160-480V ESF Transformer 2AP11E)	2AP06EF	1AP587	Control Cable For 1AP06ES and 2AP06EF
			2PI-0516A	2MS127	Instrument Cable For 2PI-0516A
	2AP05EE	Division 21 ACB 2415Z (4160-480V ESW Cig Twr Transformer 231Z)	2PI-0525A	2MS667	Instrument Cable For 2PI-0525A and 2PI-MS194
			2PI-0546A	2MS128	Instrument Cable For 2PI-0546A

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
	2AP05EG	Division 21 ACB 2412 (SAT Feed from Transformer 242-1)	2PI-MS194	2MS667	Instrument Cable For 2PI-0525A and 2PI-MS194
	2AP05EJ	Division 21 ACB 2414 (Reserve Feed from 4160V Swgr Bus 141)			
	2AP05EP	Division 21 ACB (for Containment Spray Pump 2CS01PA)			
	2AP05ER	Division 21 ACB 2411 (Bus Tie to 4160V Swgr Bus 243)			
	2AP05ES	Division 21 ACB 2413 (Feed from Diesel Generator 2A)			
	2AP05ET	Division 21 4160V ESF Switchgear Bus 241 Undervoltage Cubicle			
	2AP05EV	Division 21 ACB (for Safety Injection Pump 2SI01PA)			
	2AP07E	Division 21 4160 Non-ESF Switchgear Bus 243			
	2AP07EE	Transformers 233X and 233Y Feed			
	2AP07EF	4160V Bus 243 Feed From Bus 241			
	2AP10E	Division 21 480V ESF Switchgear Bus 231X			
	2VX05Y	D1vision 21 ESF Swgr Room Return Air Damper			
	2VX20Y	Division 21 ESF Swgr Room Fire Damper			
	2VX22Y	Division 21 ESF Swgr Room Fire Damper			
2AF005A	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2AF005B	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2AF005C	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2AF005D	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2AF006A	2AF056	Control Cable For 2AF006A and 2AF01PA			
2AF01PA	2AF001	Power Cable For 2AF01PA			
	2AF006	Control Cable For 2AF01PA			
	2AF007	Control Cable For 2AF01PA			
	2AF013	Control Cable For 2AF01PA-A and 2AF01PA			
	2AF056	Control Cable For 2AF006A and 2AF01PA			
	2AF064	Control Cable For 2AF01PA-A and 2AF01PA			
	2AF276	Control Cable For 2AF01PA			
	2AF293	Control Cable For 2AF01PA			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2EF026	Control Cable For 2AF01PA			
	2AF004	Control Cable For 2AF01PA-A			
	2AF013	Control Cable For 2AF01PA-A and 2AF01PA			
	2AF064	Control Cable For 2AF01PA-A and 2AF01PA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2AP05ED	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2AP081	Power Cable For 2AP05ED			
	2AP082	Control Cable For 2AP05ED			
	2AP395	Control Cable For 2AP05ED			
	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
2AP05EE	2AP178	Power Cable For 2AP05EE			
	2AP180	Control Cable For 2AP05EE			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2AP05EG	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	1AP585	Control Cable For 1AP05ER and 2AP05EG			
	2AP049	Control Cable For 2AP05EG			
	2AP050	Control Cable For 2AP05EG			
	2AP312	Control Cable For 2AP05EG			
	2APBU1	Power Cable For 2AP05EG			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DG211	Control Cable For 2AP05EG and 2AP05ES			
	2DG212	Control Cable For 2AP05EG and 2AP05ES			
2AP05EJ	1AP072	Power Cable For 1AP05EP and 2AP05EJ			
	1AP073	Power Cable For 1AP05EP and 2AP05EJ			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2AP05EP	1AP319	Power Cable For 1AP05EP and 2AP05EJ			
	1AP320	Power Cable For 1AP05EP and 2AP05EJ			
	1AP321	Power Cable For 1AP05EP and 2AP05EJ			
	1AP322	Power Cable For 1AP05EP and 2AP05EJ			
	2AP075	Control Cable For 2AP05EJ			
	2AP586	Control Cable For 1AP05EP and 2AP05EJ			
2AP05ER	2CS001	Power Cable For 2AP05EP			
	2CS002	Control Cable For 2AP05EP			
	2CS004	Control Cable For 2AP05EP			
	2CS122	Control Cable For 2AP05EP			
	2EF086	Control Cable For 2AP05EP			
	2AP056	Control Cable For 2AP05ER			
	2AP255	Control Cable For 2AP05ER			
	2AP257	Control Cable For 2AP05ER			
	2AP634	Control Cable For 2AP05ER			
	2APBU2	Power Cable For 2AP05ER, 2AP07EF, and 2AP07E			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2AP05ES	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DG002	Control Cable For 2AP05ES			
	2DG005	Control Cable For 2AP05ES			
	2DG019	Control Cable For 2DG01KA and 2AP05ES			
	2DG105	Control Cable For 2AP05ES and 2DG01KA			
	2DG147	Control Cable For 2AP05ES and 2DG01KA			
	2DG152	Control Cable For 2AP05ES			
	2DG211	Control Cable For 2AP05EG and 2AP05ES			
	2DG212	Control Cable For 2AP05EG and 2AP05ES			
	2DG216	Control Cable For 2AP05ES and 2DG01KA			
	2DG223	Control Cable For 2DG01KA and 2AP05ES			
	2DG228	Control Cable For 2AP05ES			
	2DGABU	Power Cable For 2AP05ES and 2DG01KA			
2AP05ET	2AP311	Control Cable For 2AP05ET			
	2AP661	Control Cable For 2AP05ET			
	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2AP05EV	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DG165	Control Cable For 2AP05ET and 2DG01KA			
	2SI001	Power Cable For 2AP05EV			
	2SI004	Control Cable For 2AP05EV			
2AP07E	2SI005	Control Cable For 2AP05EV			
	2APBU2	Power Cable For 2AP05ER, 2AP07EF, and 2AP07E			
2AP07EE	2AP093	Power Cable For 2AP07EE			
	2AP095	Power Cable For 2AP07EE			
	2AP098	Control Cable For 2AP07EE			
2AP07EF	2DC053	Power Cable For 2AP07EE and 2AP14E			
	2DC054	Power Cable For 2AP07EE and 2AP14E			
	2APBU2	Power Cable For 2AP05ER, 2AP07EF, and 2AP07E			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
2AP10E	2AP414	Power Cable For 2AP10E			
	2AP415	Power Cable For 2AP10E			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
	2AP416	Power Cable For 2AP10E			
	2AP417	Power Cable For 2AP10E			
	2AP418	Power Cable For 2AP10E			
	2AP419	Power Cable For 2AP10E			
	2AP428	Power Cable For 2AP10E			
	2AP429	Power Cable For 2AP10E			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2AP14E	2DC053	Power Cable For 2AP07EE and 2AP14E			
	2DC054	Power Cable For 2AP07EE and 2AP14E			
2AP21E	2AP143	Power Cable For 2AP21E			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2AP22E	2AP147	Power Cable For 2AP22E			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2AP25E	2AP144	Power Cable For 2AP25E			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2AP26E	2AP146	Power Cable For 2AP26E			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2AP30E	2AP148	Power Cable For 2AP30E			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2AP93E	2DC244	Control Cable For 2AP99E and 2AP93E			
2AP99E	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2CC01PA	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC244	Control Cable For 2AP99E and 2AP93E			
	2CC001	Power Cable For 2CC01PA			
	2CC003	Control Cable For 2CC01PA			
	2CC283	Control Cable For 2CC01PA			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2CV001	Power Cable For 2CV01PA			
	2CV006	Control Cable For 2CV01PA			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
2DC03E	2DC021	Power Cable For 2DC03E			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
2DG01KA	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DG017	Control Cable For 2DG01KA			
	2DG018	Control Cable For 2DG01KA			
	2DG019	Control Cable For 2DG01KA and 2AP05ES			
	2DG105	Control Cable For 2AP05ES and 2DG01KA			
	2DG147	Control Cable For 2AP05ES and 2DG01KA			
	2DG153	Control Cable For 2DG01KA			
	2DG154	Control Cable For 2DG01KA			
	2DG157	Control Cable For 2DG01KA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
	2DG165	Control Cable For 2AP05ET and 2DG01KA			
	2DG174	Control Cable For 2DG01KA			
	2DG194	Control Cable For 2DG01KA			
	2DG200	Control Cable For 2DG01KA			
	2DG216	Control Cable For 2AP05ES and 2DG01KA			
	2DG222	Control Cable For 2DG01KA			
	2DG223	Control Cable For 2DG01KA and 2AP05ES			
	2DGABU	Power Cable For 2AP05ES and 2DG01KA			
2DO01PA	2DO002	Control Cable For 2DO01PA			
2DO01PC	2DO004	Power Cable For 2DO01PC			
	2DO005	Control Cable For 2DO01PC			
2IP01E	2IP004	Power Cable For 2IP01E			
2IP01J	2EF037	Control Cable For 2IP01J			
2IP03E	2IP032	Power Cable For 2IP03E			
2IP05E	2IP002	Power Cable For 2IP05E			
2IP07E	2IP030	Power Cable For 2IP07E			
2MS001A-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2MS001B-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2MS001C-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			
2MS001D-DIV21	2DC183	Control Cable For 2AF005A, 2AF005B, 2AF005C, 2AF005D, 2MS001A-DIV21, 2MS001B-DIV21, 2MS001C-DIV21, and 2MS001D-DIV21			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2RH01PA	2DC037	Power Cable For OCC01E-B, OVA01CC, OVA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, OVA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, OVA01CC, OVA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, OVA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2RH001	Power Cable For 2RH01PA			
	2RH003	Control Cable For 2RH01PA			
	2RH091	Control Cable For 2RH01PA			
	2SX016A	Control Cable For 2SX016A and 2SX027A			
	2SX01PA	Power Cable For OCC01E-B, OVA01CC, OVA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, OVA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, OVA01CC, OVA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, OVA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2SX001	Power Cable For 2SX01PA			
	2SX005	Control Cable For 2SX01PA			
2SX01PA	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
	2SX034	Control Cable For 2SX01PA			
	2SX143	Control Cable For 2SX01PA			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2SX01PA-C	2SX280	Control Cable For 2SX01PA			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2SX006	Control Cable For 2SX01PA-C and 2SX01PA			
2SX027A	2SX472	Control Cable For 2SX016A and 2SX027A			
2SX101A	2AF002	Control Cable For 2SX101A			
	2AF003	Control Cable For 2SX101A			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2SX471	Control Cable For 2SX101A			
2SX169A	2SX295	Control Cable For 2SX169A			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2VA01CA	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2VA111	Control Cable For 2VA01CA			
2VA01CD	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2VA165	Control Cable For 2VA01CD			
2VA02CA	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2VA02CB	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2VA104	Control Cable For 2VA02CA			
	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
2VA06CA	2VA149	Control Cable For 2VA02CB			
	2VA150	Control Cable For 2VA02CB			
	2DC037	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For OCC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, OCC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2VA06CB	2VA053	Control Cable For 2VA06CA			
	2DC037	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
	2DC038	Power Cable For 0CC01E-B, 0VA01CC, 0VA02CC, 2AF01PA, 2AP05ED, 2AP05EE, 2AP05EG, 2AP05ER, 2AP05ES, 2AP05ET, 2CC01PA, 2CV01PA, 2RH01PA, 2SX01PA, 0CC01P, 0VA476Y, 2AF01PA-A, 2AP07EF, 2AP10E, 2AP99E, 2DG01KA, 2SX01PA-C, 2SX101A, 2VA01CA, 2VA01CD, 2VA02CA, 2VA			
2VD01CA	2VA822	Control Cable For 2VA06CB			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2VD001	Power Cable For 2VD01CA			
	2VD002	Control Cable For 2VD01CA			
	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD09YA	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2VD09YB	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YA	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
2VD10YB	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD006	Control Cable For 2VD01CA, 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD014	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			

TABLE 2.4-4 (Cont'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2VP01CA	2VD017	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD060	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD071	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD084	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2VD096	Control Cable For 2VD09YA, 2VD09YB, 2VD10YA, and 2VD10YB			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2VP003	Power Cable For 2VP01CA			
	2VP019	Control Cable For 2VP01CA			
	2VP020	Control Cable For 2VP01CA			
2VP01CC	2VP021	Control Cable For 2VP01CA			
	2DC057	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2DC058	Power Cable For 2AP10E, 2VD01CA, 2VP01CA, 2VP01CC, 2AP21E, 2AP22E, 2AP25E, 2AP26E, 2AP30E, and 2DC03E			
	2VP047	Power Cable For 2VP01CC			
	2VP063	Control Cable For 2VP01CC			
2VX04C	2VP064	Control Cable For 2VP01CC			
	2VP065	Control Cable For 2VP01CC			
	2VX001	Power Cable For 2VX04C			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX004	Control Cable For 2VX04C			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
2VX04Y	2VX059	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX063	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VE018	Control Cable For 2VX04Y and 2VX05Y			
	2VE031	Control Cable For 2VX04Y and 2VX05Y			
	2VE039	Control Cable For 2VX04Y and 2VX05Y			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX018	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX020	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX021	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX059	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
2VX05Y	2VX061	Control Cable For 2VX04Y and 2VX05Y			
	2VX062	Control Cable For 2VX04Y and 2VX05Y			
	2VX063	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			
	2VE018	Control Cable For 2VX04Y and 2VX05Y			
	2VE031	Control Cable For 2VX04Y and 2VX05Y			
	2VE039	Control Cable For 2VX04Y and 2VX05Y			
	2VX003	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX018	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX020	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX021	Instrument Cable For 2VX04Y and 2VX05Y			
	2VX059	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			
	2VX061	Control Cable For 2VX04Y and 2VX05Y			
	2VX062	Control Cable For 2VX04Y and 2VX05Y			
	2VX063	Control Cable For 2VX04C, 2VX04Y, and 2VX05Y			

TABLE 2.4-4 (Cont 'd)

Division 11/21			Division 12/22		
Affected Equipment	Equipment In Zone	Equipment Description	Affected Equipment	Equipment In Zone	Equipment Description
Fire Zone Number: 5.2-2					
	2VX064	Control Cable For 2VX04Y and 2VX05Y			
	2VX102	Control Cable For 2VX04Y and 2VX05Y			