



FLORIDA POWER  
A Progress Energy Company

# CRYSTAL RIVER NUCLEAR PLANT SUPERINTENDENT SHIFT OPERATIONS ' LOG



Tuesday, January 1, 2002  
Martin Wolf / Dave Schulker  
2300-0700

PLANT STATUS: Mode 1, 100% Power, 2544 MW<sub>TH</sub>, 887 MW<sub>E</sub>  
Primary: 579 T<sub>AVE</sub>, 1602 ppmb, PZR 220", 75 gpm Letdown,  
Secondary: 78/75% OTSG, 1.4" Hga Vacuum, 58°F UHS  
Rx Bldg.: 116°F Ave., -0.2 psig, AHF-1C; Low, AHF-1B; Low & SW Cooled

Init.	Time*	Item	Description
MGW	2330	Relief	Martin Wolf assumes the duties of the Superintendent Shift Operations [2224]. Dave Schulker assumes the duties of Control Room Supervisor [2235].
MGW	2344	Turtle	Received notification from Site Security that a healthy turtle has been rescued from the intake and transported to the Mariculture Center. The Natural Resources Unit Staff will identify the species and evaluate notification requirements to the National Marine Fisheries Service later this morning. An NCR has been generated.
MGW	0030	RM-A2	The Auxiliary and Fuel Handling Building Radiation Monitor was removed from service to support Chemistry sampling activities [2353-0004]. The compensatory actions of the ODCM, Table 2-3, were applicable during this time.
MGW	0350	SP-157A	Meteorological System Surveillance (Daily & Monthly) has been completed satisfactorily [0150].
MGW	0351	SP-312A	Daily Heat Balance Power Comparison has been completed satisfactorily [0206].
MGW	0352	SP-310	LPMS Channels Assessment (Daily) has been completed satisfactorily.
MGW	0420	ENS	NRC phone/status check completed satisfactorily.

(No Additional Log Entries This Shift)

B116

SSO

\* Indicates time log entry was initiated