



FLORIDA POWER
A Progress Energy Company

CRYSTAL RIVER NUCLEAR PLANT SUPERINTENDENT SHIFT OPERATIONS' LOG



Tuesday, January 1, 2002

Leon Gagne/Max Hime

0700-1500

PLANT STATUS: Mode 1, 100% Power, 2544 MW_{TH}, 888 MW_E

Primary: 579°F Tave, 2160 psig, 1602 ppmb, PZR 222"

Secondary: 4 CWP's, OTSG's: 78/75 %, 58°F UHS, 1.3"Hga Vacuum

Rx Bldg.: 115°F Ave., -0.3 psig, AHF-1B/1C on SW Cooling

Init.	Time*	Item	Description
LAG	0809	Relief	Assumed the duties of the Superintendent Shift Operations. [0630] M. Hime assumes the duties of the Control Room Supervisor. [0630]
LAG	1050	Reportable Turtle	Received notification from Mariculture Center Staff (E. Latimer) that the turtle rescued from the intake area last night was a Green Sea Turtle. [0919] A 4 Hour Non-Emergency report has been made to the NRC per 10 CFR 50.72 for the offsite notification that is required (NMFS) related to capture of the latest turtle (#62) this biennial period. (NRC Event# 37902 Updated) [1008] This condition is documented on an NCR hard copy that will be added to the system when the system is returned to service. Notifications have been made to: NRC ENS, NRC Resident (S. Sanchez), PGM (D. Roderick), MSO (L. Clewett), and the Regulatory representative (J. Lind).
LAG	1150	WDGA-1	The H ₂ /O ₂ Monitor was out of service to support sampling of the MUT gas space by Chemistry. The compensatory actions of the ODCM, Section 2.16, were applicable during this time. [1012-1103] Face-to-face notification of valve alignment verification and return-to-service was performed by the Chemistry Technician (R. Vaughan).
LAG	1245	ENS Update	Received a return call from ENS stating that the Event # for the latest and future turtle reports has been changed from #37902 to #38602. [1145]

(No Additional Entries This Shift)

B/17

SSO

* Indicates time log entry was initiated