



CRYSTAL RIVER UNIT #3 SUPERINTENDENT SHIFT OPERATIONS' LOG



Friday, March 1, 2002

Shawn Simon/ Ricky Rawls

0700-1500

PLANT STATUS: Mode I, 100% Power, 2544 MW_{TH}, 888 MW_E,
Primary: 579F T_{avg}/ 2148 psig/ 1536 ppmb/ 218" PZR/ 4 RCPs/ 68 gpm letdown,
Secondary: 79/75% OTSGs/ 899 psig MS/ 1.4" Hga cond. press/ 58F UHS/ 4 CWP's,
RB: 118F avg/ -0.1 psig/ AHF-1A in low and AHF-1B in high & cooled by SW.

Init	Time	Item	Description
SMS	0815	Relief	Assumed the duties of the Superintendent Shift Operations [0630]. Ricky Rawls assumed the duties of the Control Room Supervisor[0703].
SMS	0950	BS-90-PT SP-162	Calibration has been authorized per the maintenance schedule. The actions of ITS 3.3.17 Condition A became applicable [0931].
SMS	1132	Fire Drill	A scheduled drill was held for the crew [0945].
SMS	1144	Turtle Reportable	Received notification from Site Security that a healthy turtle has been rescued from the intake and transported to the Mariculture Center. The turtle is approximately 20 inches in diameter and weighs around 15 pounds. The Mariculture Staff (E. Olsen) has identified the species as a Green Sea Turtle. A 4 Hour Non-Emergency report has been made to the NRC per 10 CFR 50.72 for the offsite notification (NMFS) related to capture of the latest turtle (#66) this biennial period (NRC Event# 38602 Updated) [1122]. This condition has been documented on NCR 56669. Notifications have been made to: NRC ENS (G. Waig), NRC Resident (S. Stewart), PGM (D. Roderick), MSO (D. Jones), and the Regulatory representative (R. Bright).
SMS	1150	SP-323	Evacuation and Fire Alarm Demonstration has been completed satisfactorily.
SMS	1155	RM-G26 RM-G27	Radiation Monitoring Instrumentation Functional Test RMG's has been completed satisfactorily for RM-G26 and RM-G27 only [1144]. Further maintenance and calibration is required. This has restored functionality (Maintenance Rule available) to the monitors.

SSO _____

* Indicates time log entry was initiated

B/21
Page 2