



FLORIDA POWER
A Progress Energy Company

CRYSTAL RIVER NUCLEAR PLANT SUPERINTENDENT SHIFT OPERATIONS' LOG



Thursday, March 07, 2002

Ronald D. Tyrie / Curtis D. Mckeown

0700-1500

(continued)

Init.	Time*	Item	Description
RDT	1125	NCR 56999 Reportable Turtle	Received notification from Mariculture Center Staff that the two turtles rescued from the CR3 intake area (last night) were Green Sea Turtles [0835]. A 4 Hour Non-Emergency report has been made to the NRC per 10 CFR 50.72 for the offsite notification (NMFS) related to capture of the latest turtles (#67 and 68) this biennial period (NRC Event# 38602 Updated) [1114]. This condition is documented on NCR 56999. Notifications have been made to: NRC ENS (M. Norris), NRC Resident (S. Sanchez), PGM (D. Roderick), MO & MSO (D. Jones), and the Regulatory representative (P. Infanger).
CDM	1059	SP-365B	Diesel Fire Service Pump, FSP-2A Operability has been completed satisfactorily.
RDT	1200	FSCP-3, Zone 22	Corrective maintenance has been completed on FSCP-3, Zone 22 (Intermediate Building). Exit the actions of the FPP Table 6.5a [1130].
RDT	1345	SP-113G	Power Range Nuclear Instrumentation Gain Adjustment has been performed on NI-5 through NI-8. The actions of ITS 3.3.1, Condition A, were applicable during the time the channels were in 'Bypass' for the performance of this surveillance. <ul style="list-style-type: none"> • A-RPS channel [1037-1123] • B-RPS channel [1127-1143] • C-RPS channel [1240-1304] • D-RPS channel [1305-1328] SP-312A, Daily Heat Balance Power Comparison, and SP-312B, Monthly NI Imbalance Comparison, were completed satisfactorily following the calibration.
RDT	1346	SP-162	SP-162 has been completed satisfactorily for BWST level instruments DH-7-LI and DH-7-LI2. Exit the actions of ITS 3.3.17, Condition A [1340].

(continued next page)

SSO _____

* Indicates time log entry was initiated

B/23