



FLORIDA POWER
A Progress Energy Company

CRYSTAL RIVER UNIT #3 SUPERINTENDENT SHIFT OPERATIONS' LOG



Tuesday, March 19, 2002
Martin Wolf / Dave Schulker
1500-2300

PLANT STATUS: Mode 1, 100% Power, 2544 MW_{TH}, 887 MW_E
Primary: 579 T_{AVE}, 1520 ppmb, PZR 220", 71 gpm Letdown,
Secondary: 79/75% OTSG, 2.1" Hga Vacuum, 77°F UHS
Rx Bldg.: 113°F Ave., 0.0 psig, AHF-1C: Low, AHF-1B; High & SW Cooled

Int	Time*	Item	Description
MGW	1645	Relief	Assumed the duties of the Superintendent Shift Operations [1440]. Dave Schulker]assumes the duties of the Control Room Supervisor [1501].
MGW	1700	SP-132C DHV-4 ACIS	Informed by the Maintenance Supervisor that SP-132C, Engineered Safeguards Channel 3 Calibration is complete satisfactorily. An IWCC was performed on the procedure to expand the tolerance for the reset of the bistable based upon an Engineering Disposition completed by EC 48768. The actions of ITS 3.4.13 Condition C are no longer applicable [1653].
MGW	1938	Turtle	Received notification from Site Security (L. Lee) that a healthy turtle has been rescued from the intake and transported to the Mariculture Center [1930]. The turtle weighs approximately 12 pounds. The turtle is in a holding tank at the Mariculture Center IAW AI-571. The Natural Resources Unit Staff will identify the species and evaluate notification requirements to the National Marine Fisheries Service in the morning. NCR 57794 has been generated on the rescue.

(No Additional Log Entries This Shift)

SSO

* Indicates time log entry was initiated