



# CRYSTAL RIVER UNIT #3 SUPERINTENDENT SHIFT OPERATIONS' LOG



Wednesday, March 20, 2002  
Martin Wolf / Chuck Morris / Dave Schulker  
1200-2300

PLANT STATUS: Mode 1, 100% Power, 2544 MW<sub>TH</sub>, 888 MW<sub>E</sub>  
Primary: 579 T<sub>AVE</sub>, 1518 ppmb, PZR 220", 72 gpm Letdown,  
Secondary: 79/75% OTSG, 2.0" Hga Vacuum, 77°F UHS  
Rx Bldg.: 114°F Ave., 0.0 psig, AHF-1C: Low, AHF-1B; High & SW Cooled

Init	Time*	Item	Description
MGW	1245	Relief	Assumed the duties of the Superintendent Shift Operations [1205]. Chuck Morris assumes the duties of the Control Room Supervisor [1157].
MGW	1515	Relief	Dave Schulker assumes the duties of the Control Room Supervisor [1510].
MGW	1800	Turtle Update	Received notification from Pete Ezzell that the turtle transported to the Mariculture Center last evening was dead when the Natural Resources Unit Staff arrived to identify the species. A necropsy of the turtle will be performed to evaluate reportability requirements.
MGW	2220	SP-348A	Auxiliary Feedwater Pump (FWP-7) Testing and MTDG-1 Surveillance Test has been completed satisfactorily. A Dedicated Operator was stationed while the FWP-7 full-flow recirculation valve FWV-226 was open so no Maintenance Rule unavailability was accumulated during the SP.

(No Additional Log Entries This Shift)

SSO

\* Indicates time log entry was initiated

B/25  
Page 3