

## Crystal River Nuclear Facility

## Summary Report - NCRs Initiated Since 10/18/02

Sorted by Origination Date, Ar Number, Priority

Selection Criteria. AR Type = NCR and AR Status not = Canceled with Attribute of 1A POT'L OPER/REPORT

AR #	Originator	AR Subject	Orig. Date	AR Status	Priority	Potential Oper/Report	NCR Owner
00075219	ANDREW BARNES	RM-A11 SOURCE CHECK NOT PERFORMED PRIOR TO RELEASE	20021024	H/APPR		Y	CR3 UNIT EVAL GROUP

AFTER THE INITIATION OF THE "B" WGD T RELEASE, THE AB OPERATOR WAS REVIEWING THE RELEASE PERMIT AND QUESTIONED WHY THE SOURCE CHECK FOR RM-A11 WAS NOT SIGNED OFF. IN REVIEWING THE OP-412B HE IDENTIFIED THE STEP WAS N/A. THE AB OPERATOR BROUGHT THIS INFORMATION TO THE CRS AND SSO AND THE RELEASE WAS SECURED IAW OP-412B TO SOURCE CHECK RM-A11.

00075237	JOHN WILCOX	PASSPORT DATA BASE HAD WRONG DESCRIPTOR.	20021024	H/APPR		N	CR3 UNIT EVAL GROUP
----------	-------------	--	----------	--------	--	---	---------------------

THE WRONG DESCRIPTION WAS GIVEN BY PASSPORT DATA BASE FOR M TMC-19-4D. THE DESCRIPTION READ "WDT-1B B WASTE GAS COMPRESSOR" IT SHOULD HAVE READ "WDP-1B B WASTE GAS COMPRESSOR". AN ECCMU WAS GENERATED (1517) TO FIX THE DISCREPANCY. THIS WAS CAUGHT DURING THE HANGING OF C/O 44100

00075276	RONALD TYRIE	DHP-1B BREAKER MISTAKENLY RACKED OUT DURING CLEARANCE HANG	20021024	H/APPR			CR3 UNIT EVAL GROUP
----------	--------------	--	----------	--------	--	--	---------------------

WHILE HANGING A CLEARANCE ORDER TO CLEAN DCHE-1B, THE OPERATOR OPENED THE KNIFE SWITCH FOR RWP-3B AND AFTER RETRIEVING THE TOOL TO RACK OUT THE BREAKER, HE MISTAKENLY RACKED OUT THE BREAKER FOR DHP-1B. THIS RESULTED IN ITS 3.5.2, CONDITION A ENTRY FOR TWO MINUTES (1208-1210). THIS ALSO IS A SAFETY NEAR MISS AS THE BREAKER WAS RACKED OUT WITHOUT DISABLING THE CONTROL CIRCUIT BY OPENING THE KNIFE SWITCH. IF DHP-1B HAD BEEN RUNNING, THE BREAKER WOULD HAVE BEEN OPENED WITH THE OPERATORS HAND INSIDE THE CUBICLE. DHP-1B WAS SUBJECT TO AUTO-START AND WAS PLANNED TO BE STARTED FOR SP-340 E DURING THIS SAME TIME PERIOD.

00075280	PETER EZZELL	SEA TURTLE MORTALITY	20021024	H/APPR		Y	CR3 UNIT EVAL GROUP
----------	--------------	----------------------	----------	--------	--	---	---------------------

A GREEN SEA TURTLE WAS RECOVERED FROM THE CR3 BAR RACK AT APPROXIMATELY 01:00. THE TURTLE WAS OBSERVED TO BE IN A WEAKENED STATE AND COVERED WITH TUMORS. THE RECOVERY PERSON CALLED OUT A STAFF BIOLOGIST TO EXAMINE THE TURTLE. THE TURTLE WAS EXAMINED AT ABOUT 01:45 AND DETERMINED TO BE EITHER DEAD OR COMATOSE. AFTER SUBSEQUENT EXAMINATION IT WAS DETERMINED TO HAVE DIED. AFTER CONSULTATION WITH THE FLORIDA FISH AND WILDLIFE COMMISSION, (AT 12:25 PM) IT WAS DETERMINED THAT THE DEATH WAS CAUSALLY RELATED TO CREC'S OPERATIONS. THIS REQUIRES THAT A 4 HOUR REPORT TO THE NRC BE MADE, AND THAT A REPORT TO THE NATIONAL MARINE FISHERIES SERVICES BE SUBMITTED WITHIN 30 DAYS.

00075287	JEFFREY SELVIDIO	IAP-4 BATTERY CHARGER NOT IN THE CORRECT MODE	20021024	H/APPR		N	CR3 UNIT EVAL GROUP
----------	------------------	---	----------	--------	--	---	---------------------

BATTERY CHARGER FOR IAP-4 WAS IN THE AUTOMATIC POSITION. PER PM-110 IT SHOULD REMAIN IN MAINTAIN POSITION.

02/20

minor