

Crystal River Nuclear Facility

Summary Report - NCRs Initiated Since 9/16/02

Sorted by Origination Date, Ar Number, Priority

Selection Criteria: AR Type = NCR and AR Status not = Canceled with Attribute of 1A POT'L OPER/REPORT

AR #	Originator	AR Subject	Orig. Date	AR Status	Priority	Potential Oper/Report	NCR Owner
00071988	GEORGE CADWELL III	SFV-25 & 26 CONTAMINATION CONTROL TECHNIQUES	20020919	REJECTED		N	CR3 UNIT EVALUATORS

THE RADIOACTIVE CONTAMINATION CONTROL TECHNIQUES AND PRE-JOB COMMUNICATIONS ASSOCIATED WITH SFV-25 AND SFV-26 REPAIRS WERE VERY GOOD. THESE ACTIVITIES AND ASSOCIATED ENGINEERING CONTROLS ARE THE FIRST REAL TEST OF THE CORRECTIVE ACTIONS TAKEN AFTER THE DHV-32 UPTAKE.

00072037	GENE EYE	CONTAMINATED TOOL ON SPENT FUEL FLOOR	20020919	H/APPR		N	CR3 UNIT EVALUATORS
----------	----------	---------------------------------------	----------	--------	--	---	---------------------

WHILE PERFORMING ROUTINE SURVEY OF SPENT FUEL FLOOR A SMEAR OF LONG HANDLED TOOL WAS 5000 DPM/100CM². BOTH ENDS OF TOOL WERE BAGGED AND TAGGED INDICATING 10,000 DPM/100CM². SMEAR WAS TAKEN ON BARE METAL ON MIDDLE OF TOOL. THERE APPEARED TO BE LEACHING OF RADIOACTIVE MATERIAL FROM METAL SURFACES. THE TOOL WAS WRAPPED COMPLETELY AND SUBSEQUENT SMEARS TAKEN ON TOOL AND MISSILE SHIELDS WERE <1000 DPM/100CM². SEE SURVEY 02-09-0152 FOR DETAILS.

00072039	RICHARD SWEENEY	TURTLE CAPTURE #76.	20020919	H/APPR		Y	CR3 UNIT EVALUATORS
----------	-----------------	---------------------	----------	--------	--	---	---------------------

A GREEN SEA TURTLE WAS CAPTURED AT THE INTAKE. THIS IS TURTLE #76

8/27