



A Progress Energy Company

CRYSTAL RIVER NUCLEAR PLANT SUPERINTENDENT SHIFT OPERATIONS' LOG



Thursday, September 19, 2002

Blair P. Wunderly/ Max E. Hime
1500-2300

PLANT STATUS: Mode 1, 100 % Power, 2544MW_{TH}, and 881 MW_E
Primary: 579 °F T_{AVE}, 2130 psig, 1077 ppmb, PZR 222 ”
Secondary: OTSGs: 79/75 %, 2.9 ”Hga Vacuum, 87.4 °F UHS, 4 CWP
Rx Bldg.: 116 °F Ave., 0.0 psig, AHF-1B in high and AHF-1C in high & cooled by CI

Init	Time*	Item	Description
BPW	1526	Relief	Assumed the duties of the Superintendent Shift Operations [1432]. Max Hime assumes the duties of the Control Room Supervisor [1500].
BPW	1700	C-303	Fire Door C-303 has been removed from service for scheduled maintenance on the doors. The actions of FPP, Table 6.7a are applicable [1630]. Detectors on both sides of the door have been verified operable and Security notified to provide an hourly roving fire watch of this area on the Control Complex 124' elevation.
BPW	1902	Turtle	Nuclear Security reported the rescue of a live turtle from the CR-3 intake area [1715]. The turtle has been transported to the Mariculture Center and placed in a holding tank until Mariculture Center staff can identify the species. D. Bruzek has subsequently notified the Control Room that the turtle is a green sea turtle requiring follow-up medical assistance [1740]. Notification to National Marine Fisheries is required and will be made 09/20/02 in the morning. A 4 Hour Non-Emergency report was made to the NRC per 10 CFR 50.72 for offsite notification (NRC Event# 38602 Updated) [1835]. This condition is documented on NCR 72039. Notifications have been made to: NRC ENS (Laura), NRC Resident (Stewart), PGM (Franke), MSO (Jones), and Licensing (Herrin).

(No Additional Entries This Shift)

B/50

SSO _____

* Indicates time log entry was initiated