

values from licensee risk studies except as noted	SGTR
Browns Ferry*	N/A
Brunswick	N/A
Catawba#	1E-4
Crystal River	2E-4
Farley	2.6E-5
Harris	2E-4
Hatch	N/A
McGuire#	1E-4
North Anna	2E-4
Oconee	5E-5
Robinson	3E-4
Sequoyah*	3E-4 (8E-4*)
St. Lucie	7E-5
Summer	2.5E-5
Surry	2E-5
Turkey Point	1E-5
Vogtle	2E-5
Watts Bar*	2E-4 (8E-4*)

- ASSUMES NO EQUIPMENT OUT FOR MAINTENANCE

A/1

EX 2

Estimated Conditional Core Damage Probability (CCDP)				
CCDP <1E-6	1E-6 → 1E-5	1E-5 → 1E-4	1E-4 → 1E-3	CCDP >1E-3
No additional reactive inspection				
		Special Inspection		
		AIT		
			IIT	