

January 9, 2003

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Beaver Valley Power Station, Units 1 and 2

SUBJECT: SUMMARY OF DECEMBER 11, 2002, MEETING REGARDING AN APPLICATION FOR A LICENSE AMENDMENT TO ALLOW FENOC TO CONVERT THE BEAVER VALLEY POWER STATION CONTAINMENTS TO OPERATE AT ATMOSPHERIC PRESSURE (TAC NOS. MB5303 AND MB5304)

On December 11, 2002, the U.S. Nuclear Regulatory Commission (NRC) staff, with support from a contractor, held a meeting at NRC headquarters in Rockville, Maryland, with representatives from FirstEnergy Nuclear Operating Company (FENOC), the licensee for the Beaver Valley Power Station, Units 1 and 2 (BVPS-1 and 2); Westinghouse Electric Company (W), Fauske & Associates, Inc. (FAI); and Stone & Webster. The list of meeting attendees is included as Enclosure 1. Enclosures 2 and 3 are copies of the slides presented at the meeting by the licensee's consultant, FAI, and the NRC's contractor, Mr. Jack Tills, respectively. The presentations closely followed information presented in the slides.

By letter dated June 5, 2002, FENOC submitted an amendment request to allow plant operation of BVPS-1 and 2 with containments at atmospheric pressure. The application relies on WCAP-15844, "Topical Report on Modular Accident Analysis Program Version 5 (MAAP5) Pressurized Water Reactor (PWR) Large Dry Containment Model," which was submitted separately by W and is being reviewed in parallel with the NRC staff's review of FENOC's application. By letters dated November 22, 2002 (ADAMS Accession Nos. ML023250506 and ML023250519), the NRC staff issued requests for additional information (RAIs) to FENOC and W regarding the application and the topical report respectively. FENOC responded to the RAI by letter dated December 2, 2002, (ADAMS Accession No. ML023430155) and W responded to the RAI by letter dated December 4, 2002 (ADAMS Accession No. ML023520323).

FAI, the licensee's consultant, presented responses to the NRC staff's RAIs as docketed in the December 2, and December 4, 2002, letters. The NRC staff asked several questions during the presentation to seek clarification on various aspects of the responses.

The NRC's contractor presented an overview of preliminary findings from review of FENOC's application and the WCAP on which the application relies. The NRC staff stated that they have concerns with some of the proposed models included in the MAAP5 code that yield non-conservative results when applied to BVPS-1 and 2. The staff's concerns regarding the WCAP-15844 methodology must be adequately addressed before the NRC staff can approve the topical report for use in containment analyses and before the NRC staff can approve FENOC's amendment request.

The attendees from FENOC, W, FAI, and Stone & Webster stated that they understood the NRC staff's concerns regarding the WCAP and that they will conduct further internal discussions to develop supplemental submittals that address the NRC staff's concerns. FENOC also stated that they may evaluate other methods, such as a containment structural analysis, of demonstrating the containments' abilities to safely operate at higher pressures without having to rely on the WCAP-15844 methodology.

/RA/

Daniel S. Collins, Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosures: 1. List of Meeting Attendees
2. FAI Meeting Slides
3. NRC Contractor's Meeting Slides

cc w/encls: See next page

The attendees from FENOC, W, FAI, and Stone & Webster stated that they understood the NRC staff's concerns regarding the WCAP and that they will conduct further internal discussions to develop supplemental submittals that address the NRC staff's concerns. FENOC also stated that they may evaluate other methods, such as a containment structural analysis, of demonstrating the containments' abilities to safely operate at higher pressures without having to rely on the WCAP-15844 methodology.

/RA/

Daniel S. Collins, Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosures: 1. List of Meeting Attendees
2. FAI Meeting Slides
3. NRC Contractor's Meeting Slides

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	S. Richards	OGC	T. Bergman, EDO, RI Plants
PDI-1 Reading	R. Laufer	ACRS	J. Rogge, RGN-I
J. Zwolinski/T. Marsh	R. Lobel	D. Collins	B. Platchek, RGN-I
M. Kotzalas	S. LaVie	E. Thom	S. Weerakkody
	M. O'Brien	J. Hannon	A. Notafrancesco

C:\ORPCheckout\FileNET\ML030090622.wpd

Accession No.: ML030090622

OFFICE	PM:PDI-1	LA:PDI-2	SC:SPLB	SC:PDI-1
NAME	DCollins	MO'Brien	SWeerakkody	R. Laufer
DATE	01/02/03	01/02/03	01/03/03	01/08/03

Official Record Copy

Beaver Valley Power Station, Units 1 and 2

Mary O'Reilly, Attorney
FirstEnergy Nuclear Operating Company
FirstEnergy Corporation
76 South Main Street
Akron, OH 44308

FirstEnergy Nuclear Operating Company
Regulatory Affairs/Performance
Improvement
Larry R. Freeland, Manager
Beaver Valley Power Station
Post Office Box 4, BV-A
Shippingport, PA 15077

Commissioner James R. Lewis
West Virginia Division of Labor
749-B, Building No. 6
Capitol Complex
Charleston, WV 25305

Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, OH 43266-0573

Director, Pennsylvania Emergency
Management Agency
2605 Interstate Dr.
Harrisburg, PA 17110-9364

Ohio EPA-DERR
ATTN: Zack A. Clayton
Post Office Box 1049
Columbus, OH 43266-0149

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

J. H. Lash, Plant Manager (BV-IPAB)
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

Rich Janati, Chief
Division of Nuclear Safety
Bureau of Radiation Protection
Department of Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Mayor of the Borough of
Shippingport
P O Box 3
Shippingport, PA 15077

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, PA 15077

FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
ATTN: M. P. Pearson, Director
Services and Projects (BV-IPAB)
Post Office Box 4
Shippingport, PA 15077

FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Mr. B. F. Sepelak
Post Office Box 4, BV-A
Shippingport, PA 15077

Mr. Mark B. Bezilla
Vice President
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

MEETING ATTENDEES

FIRSTENERGY NUCLEAR OPERATING COMPANY

BEAVER VALLEY POWER STATION, UNITS 1 AND 2

DECEMBER 11, 2002

Participants:

<u>Name</u>	<u>Organization</u>
D. Collins	NRC/NRR/Division of Licensing Project Management
R. Lobel	NRC/NRR/Division of Systems Safety and Analysis
E. Throm	NRC/NRR/Division of Systems Safety and Analysis
S. LaVie	NRC/NRR/Division of Systems Safety and Analysis
A. Notafrancesco	NRC/RES/Division of Systems Analysis and Regulatory Effectiveness
J. Tills	NRC Contractor
B. Sepelak	FirstEnergy Nuclear Operating Company
S. Sarver	FirstEnergy Nuclear Operating Company
M. Testa	FirstEnergy Nuclear Operating Company
K. Frederick	FirstEnergy Nuclear Operating Company
F. Twogood	FirstEnergy Nuclear Operating Company
J. DeBlasio	Westinghouse Electric Company
L. Smith	Westinghouse Electric Company
B. Henry	Fauske & Associates, Inc.
B. Hammersley	Fauske & Associates, Inc.
C. Paik	Fauske & Associates, Inc.
D. Graves	Stone & Webster