



Nuclear Management Company, LLC
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, WI 54241

NRC 2003-0003

GL 97-02

January 6, 2003


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Dockets 50-266 And 50-301
Point Beach Nuclear Plant, Units 1 And 2
Monthly Operating Reports

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of December 2002.

Sincerely,



A. J. Cayia
Site Vice President

KML

Attachment

cc: J. D. Loock, PSCW
NRC Region III
NRC Senior Resident Inspector
NRC Project Manager

IE24

OPERATING DATA REPORT

DOCKET NO. 50-266
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1
DATE 01/03/03
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD December - 2002

1. DESIGN ELECTRICAL RATING (MWE-NET) 515.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 510.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	7,989.6	231,599.4
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	7,964.5	228,058.5
5. UNIT RESERVER SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	374,218.0	3,975,789.0	105,551,309.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-266
 UNIT NAME: Point Beach, Unit 1
 DATE: 1/06/2003
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: December 2002
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination F. Administrative
- G. Operational Error (Explain) H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5. Other (Explain)

SUMMARY:

Unit 1 average daily power for the month of December was 503.0 MWe.
 Licensee Event Reports (LERs) submitted to the NRC in December:
 2002-003-00 Possible Common Mode Failure of AFW due to Partial Clogging of Recirculation Orifices

OPERATING DATA REPORT

DOCKET NO. 50-301
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2
DATE 01/03/03
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD December - 2002

1. DESIGN ELECTRICAL RATING (MWE-NET)	515.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	512.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	7,971.4	225,753.1
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	7,935.6	222,765.7
5. UNIT RESERVER SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	380,438.0	4,004,295.0	104,787,803.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-301
 UNIT NAME: Point Beach, Unit 2
 DATE: 1/06/2003
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: December 2002
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5. Other (Explain)

SUMMARY:

Unit 2 average daily power for the month of December was 511.3 MWe.
 Licensee Event Reports (LERs) submitted to the NRC December:
 2002-003-00 Possible Common Mode Failure of AFW due to Partial Clogging of Recirculation Orifices