



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc
Vermont Yankee
322 Governor Hunt Rd
PO Box 157
Vernon, VT 05354
Tel 802-257-7711

January 09, 2003
BVY-03-01

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Reference: (a) License No. DPR-28 (Docket No. 50-271)

In accordance with section 6.6.B of the Vermont Yankee Technical Specifications, submitted herewith is the Monthly Statistical Report for the Vermont Yankee Nuclear Power Station for the month of December, 2002.

Sincerely,

A handwritten signature in cursive script that reads "Kevin H. Bronson".

Kevin H. Bronson
General Manager, Plant Operations

cc: USNRC Region I Administrator
USNRC Resident Inspector
USNRC Project Manager

IE24

VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 02-12


FOR THE MONTH OF DECEMBER 2002

OPERATING DATA REPORT

DOCKET NO. 50-271
 DATE 030109
 COMPLETED BY G.A. WALLIN
 TELEPHONE (802)258-5414

OPERATING STATUS

1. Unit Name: Vermont Yankee
2. Reporting Period: December
3. Licensed Thermal Power(MWt): 1593
4. Nameplate Rating(Gross MWe): 540
5. Design Electrical Rating(Net MWe): 522
6. Maximum Dependable Capacity(Gross MWe): 535
7. Maximum Dependable Capacity(Net MWe): 510
8. If changes, occur in capacity ratings(Items Number 3 through 7) since last report, give reasons:



9. Power level to which restricted, if any(Net MWe): N/A
10. Reasons for restrictions, if any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744.00	8760.00	262968.00
12. Number Of Hours Reactor was Critical	744.00	8033.41	223148.83
13. Reactor Reserve Shutdown Hours	0.00	0.00	0.00
14. Hours Generator On-Line	744.00	7967.34	219513.78
15. Unit Reserve Shutdown Hours	0.00	0.00	0.00
16. Gross Thermal Energy Generated(MWH)	1184510.30	12190332.61	332380416.79
17. Gross Electrical Energy Generated(MWH)	410233.00	4151341.00	111580930.00
18. Net Electrical Energy Generated(MWH)	394389.00	3962616.00	106182359.00
19. Unit Service Factor	100.00	91.00	82.50
20. Unit Availability Factor	100.00	91.00	82.50
21. Unit Capacity Factor(Using MDC Net)	103.90	88.70	78.90
22. Unit Capacity Factor(Using DER Net)	101.60	86.70	77.30
23. Unit Forced Outage Rate	0.00	0.00	3.94
24. Shutdowns scheduled over next 6 months(Type, Date, and Duration of Each: <u>N/A</u>)			

25. If shut down at end of report period, estimated date of startup: N/A
26. Units In Test Status(prior to commercial operation): N/A

Forecast Achieved

INITIAL CRITICALITY _____
 INITIAL ELECTRICITY _____
 COMMERCIAL OPERATION _____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-271
 UNIT Vermont Yankee
 DATE 030109
 COMPLETED BY G.A. WALLIN
 TELEPHONE (802)258-5414

MONTH December

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	530	17.	530
2.	529	18.	530
3.	529	19.	530
4.	530	20.	530
5.	530	21.	530
6.	530	22.	530
7.	530	23.	530
8.	530	24.	530
9.	530	25.	530
10.	530	26.	530
11.	530	27.	530
12.	530	28.	530
13.	530	29.	530
14.	532	30.	530
15.	530	31.	530
16.	530		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH DECEMBER

DOCKET NO 50-271
 UNIT NAME Vermont Yankee
 DATE 030109
 COMPLETED BY G.A. Wallin
 TELEPHONE (802)258-5414

No.	Date	1 Type	Duration (hours)	2 Reason	3 Method of Shutting Down Reactor	License Event Report #	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
(None)									

1 F: Forced
 S: Scheduled

2 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and
 License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-(Explain)-

3 Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Other (Explain)

4 Exhibit G- Instructions
 for Preparation of Data
 Entry Sheets for License
 Event Report (LER) File
 (NUREG 0161)

5 Exhibit I - Same Source

DOCKET NO. 50-271
DATE 030109
COMPLETED BY G.A. WALLIN
TELEPHONE (802)258-5414

REPORT MONTH December

SUMMARY OF OPERATING EXPERIENCES

Highlights

Vermont Yankee operated at 99.9 of rated thermal power for the month. Gross electrical generation was 410,233 MWh or 101.0% design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 99.9% of rated thermal power.

There were no items of interest to report for this month.

At the end of the reporting period the plant was operating at 99.9% of rated thermal power.

VYDPF 0411.04 (Sample)
DP 0411 Rev. 8
Page 1 of 1
RT No. 13.F01.18X