



Kewaunee Nuclear Power Plant
N490 Highway 42
Kewaunee, WI 54216-9511
920.388.2560

Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, WI 54241
920.755.2321

Kewaunee / Point Beach Nuclear
Operated by Nuclear Management Company, LLC

NRC-03-002

January 9, 2003

10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Monthly Operating Report

The monthly operating report for the Kewaunee Nuclear Power Plant for December 2002 is enclosed in accordance with Technical Specification 6.9.a.3.

Sincerely,

Thomas Coutu
Site Vice President

MLA

Enclosure

cc - US NRC - Region III
NRC Senior Resident Inspector
INPO Records Center
PSCW - Sharon Henning

IE24

OPERATING DATA REPORT

DOCKET NO. 50-305
UNIT NAME Kewaunee
DATE January 9, 2003
COMPLETED BY Mary Anderson
TELEPHONE (920) 388-8453

Notes: Unit continues to operate at 100% power.

REPORTING PERIOD December, 2002

1. DESIGN ELECTRICAL RATING (MWE-NET) 535
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 511

	<u>MONTH</u>	<u>YEAR-TO-DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	8528.8	213494.7
4. NUMBER OF HOURS GENERATOR WAS ON LINE	744.0	8514.7	211293.3
5. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	10.0
6. NET ELECTRICAL ENERGY (MWH)	390843	4468734	105642231

UNIT SHUTDOWNS

DOCKET NO. 50-305
UNIT NAME Kewaunee
DATE January 9, 2003
COMPLETED BY Mary Anderson
TELEPHONE (920) 388-8453

REPORTING PERIOD December, 2002

NO.	DATE	Type ¹	DURATION (Hours)	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	CAUSE/CORRECTIVE ACTIONS
5	12/07/02	S	22.55	B	5	Performance of SP54-086, Turbine Stop and Governor Valve Operability Test, and other reduced power procedures

- | | | |
|--|--|---|
| <p>(1)</p> <p>F: Forced
S: Scheduled</p> | <p>(2)</p> <p>Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)</p> | <p>(3)</p> <p>Method:
 1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Other (Explain)
 Continuation
 5 - Load Reductions
 9 - Other</p> |
|--|--|---|

SUMMARY:

The unit continues to operate at 100% steady state power