



# Progress Energy

Docket No. 50-302  
Operating License No. DPR-72

Ref: ITS 5.7.1.2

January 8, 2003  
3F0103-01

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001


Subject: Crystal River Unit 3 - Monthly Operating Report

Dear Sir:

Florida Power Corporation hereby submits the Crystal River Unit 3 (CR-3) December 2002 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,



J. A. Franke  
Plant General Manager

JAF/ff

Attachment

xc: Regional Administrator, Region II  
Senior Resident Inspector  
NRR Project Manager

IE24

## APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-302  
UNIT NAME FLCRP-3  
DATE January 2, 2003  
COMPLETED BY J. E. Lane *JEL* *JB*  
TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD (Month/Year):

December 2002

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	825		
2 MAXIMUM DEPENDABLE CAPACITY (Mwe-Net)	834		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	8,707.9	158,115
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	8,692.4	155,815
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	634,766	7,300,308	121,269,571

## APPENDIX B UNIT SHUTDOWNS

**DOCKET NO.** 50-302  
**UNIT NAME** FLCRP-3  
**DATE** January 2, 2003  
**COMPLETED BY** J. E. Lane  
**TELEPHONE** (352) 795-6486 x3698

**REPORTING PERIOD:** December 2002

No.	Date	Type	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
		F: Forced S: Scheduled				Comments
None						

### SUMMARY:

Crystal River Unit 3 operated the entire month without an outage.

#### (1) Reason:

A-EQUIPMENT FAILURE (Explain)  
 B-MAINTENANCE OR TEST  
 C-REFUELING  
 D-REGULATORY RESTRICTION  
 E-OPERATOR TRAINING / LICENSE EXAMINATION  
 F-ADMINISTRATIVE  
 G-OPERATIONAL ERROR (Explain)  
 H-OTHER (Explain)

#### (2) Method

1-MANUAL  
 2-MANUAL TRIP / SCRAM  
 3-AUTO TRIP / SCRAM  
 4-CONTINUATION  
 5-OTHER (Explain)