

TABLE 3.3-14 (Continued)

TABLE NOTATIONS

- When steam generators are being used for decay heat removal.
- # Atmospheric steam relief valve(s) may be in manual operation and open, or in automatic operation, to maintain secondary side pressure at or below an indicated steam generator pressure of 1225 psig.

ACTION STATEMENTS

- ACTION 1 - With the number of OPERABLE channels less than the required number of channels, declare the affected valve(s) inoperable and apply Technical Specification 3.7.1.6.
- ACTION 2 -
- a. With one less than the required number of OPERABLE channels, restore the inoperable channel to OPERABLE status within 7 days; or be in at least HOT STANDBY within the next 6 hours.
  - b. With two less than the required number of OPERABLE channels, restore at least three channels to OPERABLE status within 72 hours; or be in at least HOT STANDBY within the next 6 hours.