

DR. KAHN'S OPINION ON APPROPRIATE CONTACT STIFFNESS

- ◆ "Based on my experience, it is my opinion that a more appropriate contact stiffness value for unanchored casks, is 1×10^6 lbs/inch." (Dec. 7, 2001, Joint Declaration at Paragraph 67)
- ◆ "It is my opinion that a more appropriate contact stiffness value for unanchored casks could be in the range of 1×10^6 lbs/inch to 10×10^6 pounds per inch." (April 1, 2002, Testimony at Q/A 32)

ASLB HEARINGS-Spring, 2002

Template = SECY-028

DOCKETED
USNRC

2003 JAN 13 PM 2:44

OFFICE OF THE SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

SECY-02

2 CLEAR REGULATORY COMMISSION

Docket No. _____ Official Ex. No. 90
In the matter of _____
Staff _____ IDENTIFIED ✓
Applicant X _____ RECEIVED ✓
Intervenor _____ REJECTED _____
Other _____ WITHDRAWN _____
DATE 5-7-92 Witness _____
Clerk [Signature] _____