

January 16, 2003

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Timothy G. Colburn, Senior Project Manager, Section 1 /RA/
Project Directorate I
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE (TAC NOS. MB6452 AND MB6453)

PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric
Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: September 23, 2002.

Brief description of amendments: These amendments revised Technical Specification (TS) Section 2.6.2.4, "Residual Heat Removal [RHR] Suppression Pool Cooling," to adopt TS Task Force (TF) change 230, Revision 1 (TSTF-230, Revision 1). This change to Required Action B of Limiting Condition for Operation 3.6.2.3 allows two RHR suppression pool cooling subsystems to be inoperable for up to 8 hours.

Date of issuance: January 16, 2003

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment Nos.: 207, 181

Facility Operating License Nos. NPF-14 and NPF-22: The amendments revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: October 29, 2002 (67 FR 66012).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 16, 2003.

No significant hazards consideration comments received: No

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE (TAC NOS. MB6452 AND MB6453)

PPL Susquehanna, LLC, Docket Nos. 50-387 and 50-388, Susquehanna Steam Electric
Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: September 23, 2002.

Brief description of amendments: These amendments revised Technical Specification (TS)
Section 2.6.2.4, "Residual Heat Removal [RHR] Suppression Pool Cooling," to adopt TS
Task Force (TF) change 230, Revision 1 (TSTF-230, Revision 1). This change to Required
Action B of Limiting Condition for Operation 3.6.2.3 allows two RHR suppression pool
cooling subsystems to be inoperable for up to 8 hours.

Date of issuance: January 16, 2003

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment Nos.: 207, 181

Facility Operating License Nos. NPF-14 and NPF-22: The amendments revised the
Technical Specifications.

Date of initial notice in FEDERAL REGISTER: October 29, 2002 (67 FR 66012).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation
dated January 16, 2003.

No significant hazards consideration comments received: No

DISTRIBUTION:

Nonpublic PDI-1 R/F RLaufer MO'Brien RGuzman TColburn

DOCUMENT NAME: C:\ORPCheckout\FileNETML030170002.wpd
ACCESSION NO. ML030170002

OFFICE	PDI-1/PM	PDI-1/PM	PDI-2/LA	OGC	PDI-1/SC
NAME	RGuzman	TColburn	MO'Brien	AHodgdon	RLaufer
DATE	1/8/03	1/8/03	1/16/03	1/10/03	1/16/03