

January 21, 2003

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-03-002

This preliminary notification constitutes **EARLY** notice of events of **POSSIBLE** safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility

D.C. Cook
Indiana Michigan Power Company
Bridgman, MI 49106
Docket: 50-315; 50-316
License: DPR-58; DPR-74

Licensee Emergency Classification

☒ Notification of Unusual Event
☐ Alert
☐ Site Area Emergency
☐ General Emergency
☐ Not Applicable

SUBJECT: REACTOR TRIP DUE TO MAIN TRANSFORMER FIRE

DESCRIPTION:

At about 8:10 p.m. (EST) on January 15, 2003, a fault in the Unit 1 main power transformer resulted in a fire, which caused a trip of the main turbine and an automatic reactor trip. All control rods fully inserted. The reactor coolant pumps are running with offsite power available. Offsite fire assistance was called to the plant but was not needed because the plant's fire brigade extinguished the fire by 8:35 p.m. (EST) prior to their arrival.

One individual received a minor injury due to a fall and smoke inhalation and was transported to a local hospital for medical attention. The individual was treated and released from the hospital. The fire also resulted in a transformer oil spill, which the licensee is in the process of cleaning up.

The licensee declared an **UNUSUAL EVENT** at 8:25 p.m. (EST), due to a fire in the protected area that was not extinguished within 15 minutes. The **UNUSUAL EVENT** was terminated at 10:20 p.m. (EST). NRC Region III (Lisle, IL) and Headquarters Offices monitored the situation.

Appropriate state and local officials were notified of the event and the resulting transformer oil spill.

The licensee is investigating the cause of the transformer fire. The resident inspectors are monitoring the licensee's investigation, maintenance, and repair activities. The information in this preliminary notification has been reviewed with licensee management.

A one-hour notification report was made to the NRC Headquarters Operations Officer on January 15, 2003 at 9:01 p.m. (EST). A notification update was made on January 15, 2003 at 11:39 p.m. (EST). This information is current as of January 21, 2003 at 8:00 a.m. (CST).

CONTACTS:

Laura Collins
(630)-829-9604

Brian Kemker
(269)-465-6775