

March 20, 2003

Mr. A. Christopher Bakken III, Senior Vice President
and Chief Nuclear Officer
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 2 - ISSUANCE OF AMENDMENT
(TAC NOS. MB5699 AND MB6948)

Dear Mr. Bakken:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. 255 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Unit 2. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated July 23, 2002, as supplemented November 15, 2002, and January 24, 2003.

The amendment consists of changes to the Donald C. Cook Nuclear Plant (D. C. Cook) Unit 2 TSs related to the reactor pressure vessel (RPV) operating limits at low temperatures. The November 15, 2002, and January 24, 2003, supplemental letters contain clarifying information and did not expand the scope of the *Federal Register* notice published on October 29, 2002.

The amendment approves revised pressure-temperature (P-T) limits for the RPV to be applicable for a maximum of 32 effective full-power years of facility operation. These changes were based, in part, on the use of American Society of Mechanical Engineers (ASME) *Boiler and Pressure Vessel Code* (Code) Case N-641.

In addition, your letter dated July 23, 2002, as supplemented, requested an exemption from the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, Appendix G, to allow application of ASME Code Case N-641. This Code case permits the use of an alternate reference fracture toughness for reactor vessel materials in determining the revised P-T curves, to maintain operator flexibility and safety during heatup and cooldown conditions. Based upon review of the information provided, the NRC staff has determined that application of ASME Code Case N-641 is acceptable for D. C. Cook Unit 2. Accordingly, the NRC staff, pursuant to 10 CFR 50.12(a), has issued an exemption from the requirements of Appendix G of 10 CFR Part 50 for D. C. Cook Unit 2.

A. Bakken

- 2 -

A copy of our related Safety Evaluation supporting the amendment, and a copy of the exemption are also enclosed. The exemption and the Notice of Issuance for the amendment will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-316

Enclosures: 1. Amendment No. 255 to DPR-74
2. Safety Evaluation
3. Exemption

cc w/encls: See next page

A. Bakken

- 2 -

A copy of our related Safety Evaluation supporting the amendment, and a copy of the exemption are also enclosed. The exemption and the Notice of Issuance for the amendment will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-316

- Enclosures: 1. Amendment No. 255 to DPR-74
- 2. Safety Evaluation
- 3. Exemption

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	GHill(2)	WBeckner
PDIII-1 Reading	OGC	ACRS
AVegel, RIII	JMedoff	LLois

ADAMS Accession No. ML030220073

*Provided SE input by memo

OFFICE	PM:PDIII-1	LA:PDIII-1	SC:SRXB	SC:EMCB	OGC	SC:PDIII-1	D:DLPM
NAME	JStang	THarris	FAkstulewicz*	SCoffin*	SUttal	DHood for LRaghavan	JZwolinski
DATE	03/11/03	03/11/03	11/21/02	12/23/02	03/07/03	03/17/03	03/20/03

OFFICIAL RECORD COPY

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Drinking Water and Radiological
Project Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr. Blvd.
P. O. Box 30630, CPH Mailroom
Lansing, MI 48909-8130

Scot A. Greenlee
Director, Nuclear Technical Services
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

Michael J. Finissi
Plant Manager
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Joseph E. Pollock
Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

INDIANA MICHIGAN POWER COMPANY

DOCKET NO. 50-316

DONALD C. COOK NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 255
License No. DPR-74

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana Michigan Power Company (the licensee) dated July 23, 2002, as supplemented November 15, 2002, and January 24, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-74 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 255, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented prior to startup from Unit 2 refueling outage 14.

FOR THE NUCLEAR REGULATORY COMMISSION

/Darl S. Hood for/

L. Raghavan, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: March 20, 2003

ATTACHMENT TO LICENSE AMENDMENT NO. 255

FACILITY OPERATING LICENSE NO. DPR-74

DOCKET NO. 50-316

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE

3/4 4-25

3/4 4-26

B 3/4 4-6

B 3/4 4-10

INSERT

3/4 4-25

3/4 4-26

B 3/4 4-6

B 3/4 4-10

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 255 TO FACILITY OPERATING LICENSE NO. DPR-74

INDIANA MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT, UNIT 2

DOCKET NO. 50-316

1.0 INTRODUCTION

By application dated July 23, 2002, as supplemented November 15, 2002, and January 24, 2003, the Indiana Michigan Power Company (the licensee or IMP) requested an amendment to the Technical Specifications (TSs) for the Donald C. Cook Nuclear Plant, Unit 2. The proposed amendment would revise the Unit 2 reactor coolant system (RCS) pressure-temperature (P-T) curves in TS Figures 3.4-2 and 3.4-3 and associated Bases.

The proposed changes to the P-T limits were based, in part, on the use of American Society of Mechanical Engineers (ASME) *Boiler and Pressure Vessel Code* (Code) Case N-641. The licensee also requested an exemption from the requirements of Appendix G to Title 10 of the *Code of Federal Regulations* Part 50 (10 CFR Part 50), which mandates use of Appendix G to Section XI of the ASME Code for developing reactor pressure vessel (RPV) P-T limits, in order to utilize ASME Code Case N-641.

2.0 REGULATORY EVALUATION

2.1 10 CFR Part 50, Appendix G - Requirements for Generating P-T Limits for Light-Water Reactors

The U.S. Nuclear Regulatory Commission (NRC) has established requirements in Appendix G of Part 50 to Title 10, *Code of Federal Regulations* (10 CFR Part 50, Appendix G), to protect the integrity of the reactor coolant pressure boundary in nuclear power plants. 10 CFR Part 50, Appendix G, requires that the P-T limits for an operating light-water nuclear reactor be at least as conservative as those that would be generated if the methods of Appendix G to Section XI of the ASME Code (henceforth Appendix G to Section XI) were used to generate the P-T limits. The methods of Appendix G to Section XI postulate the existence of a sharp surface flaw in the RPV that is normal to the direction of the maximum applied stress. For materials in the beltline and upper and lower head regions of the RPV, the maximum flaw size is postulated to have a depth that is equal to one-fourth of the thickness and a length equal to 1.5 times the thickness. For the case of evaluating an RPV nozzle, the surface flaw is postulated to propagate parallel to the axis of the nozzle's corner radius.

The basic parameter used in Appendix G to Section XI for calculating P-T limit curves is the stress intensity factor, K_I factor, which is a function of the stress state at the crack-tip and flaw

configuration. The methods of Appendix G to Section XI require, in part, that licensees calculate the maximum allowable stress intensities (K_I factors) and pressures for the RPV as a function of temperature and based on use of the lower bound crack arrest fracture toughness equation (K_{Ia} equation) for the limiting adjusted reference temperature value (RT_{NDT} value) material in the RPV. Thus, the critical locations in the RPV beltline and head regions are the 1/4-thickness (1/4T) and 3/4-thickness (3/4T) locations, which correspond to the points of the crack tips if the flaws are initiated and grown from the inside and outside surfaces of the vessel, respectively. Regulatory Guide (RG) 1.99, "Radiation Embrittlement of Reactor Vessel Materials," Revision 2, provides an acceptable method of calculating RT_{NDT} values for ferritic RPV materials. The methods of RG 1.99, Revision 2, include methods for adjusting the RT_{NDT} values of materials in the beltline region of the RPV, where the effects of neutron irradiation may induce an increased level of embrittlement in the materials.

The methods of Appendix G to Section XI also require that P-T curves must satisfy a safety factor of 2.0 on stress intensities arising from primary membrane stresses and primary bending stresses during normal plant operations (including heatups, cooldowns, and transient operating conditions), and a safety factor of 1.5 on stress intensities arising from primary membrane stresses and primary bending stresses when leak rate or hydrostatic pressure tests are performed on the RCS.

Table 1 to 10 CFR Part 50, Appendix G provides the NRC staff's criteria for meeting the P-T limit requirements of Appendix G to Section XI and as well as the minimum temperature requirements of the rule for bolting up the vessel during normal and pressure testing operations.

2.2 Exemptions to the Requirements of 10 CFR Part 50, Appendix G

In the license's amendment request dated July 23, 2002, the licensee also requested NRC approval of an exemption to use Code Case N-641 as an alternative to the specific requirements in 10 CFR Part 50, Appendix G, for generating the P-T limit curves. Pursuant to 10 CFR 50.60(b), licensees may use alternatives to the requirements of 10 CFR Part 50, Appendix G, if an exemption to use the alternatives is granted by the Commission pursuant to 10 CFR 50.12. According to 10 CFR 50.12(a)(1), the Commission may, upon request, grant exemptions to the requirements of 10 CFR Part 50, if the exemptions are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. In considering the exemptions, the Commission will not consider granting exemptions unless a special circumstance is present. The special circumstances in 10 CFR 50.12 include, but are not limited to, the following special case:

- pursuant to 10 CFR 50.12(a)(2)(ii), the case that application of the regulation in the particular circumstances would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule.

3.0 TECHNICAL EVALUATION

The licensing basis for the P-T limit curves at D. C. Cook Unit 2, as given in the TS, includes two figures:

- TS Figure 3.4-2, which provides the P-T limit curves for normal operations of the reactor, including heatups at 60 °F/hr, operations with the core critical, and leak test operations, and which include requirements for minimum boltup temperatures.
- TS Figure 3.4-3, which provides the P-T limit curves for normal cooldown operations of the reactor at cooldown rates of 0 °F/hr (i.e., the steady state cooldown rate), 20 °F/hr, 40 °F/hr, 60 °F/hr, and 100 °F/hr.

In the license amendment request of July 23, 2002, the licensee submitted the following updated P-T curves for NRC staff review and approval:

- new P-T limit curves (TS Figure 3.4-2) effective to 32 effective full power years (EFPY) for normal operations of the reactor, including heatups at 60 °F/hr, operations with the core critical, and leak test operations, and including requirements for minimum boltup temperatures.
- new P-T limit curves (TS Figure 3.4-3) effective to 32 EFPY for normal cooldown operations of the reactor at cooldown rates of 0 °F/hr (i.e., the steady state cooldown rate), 20 °F/hr, 40 °F/hr, 60 °F/hr, and 100 °F/hr.

Section IV.A.2 of 10 CFR Part 50, Appendix G, requires the P-T limit curves to be at least as conservative as if the methods and criteria in Appendix G to Section XI were used to generate the P-T limit curves.⁽¹⁾ The new P-T limit curves (i.e., the new unirradiated beltline P-T limit curves and new P-T limit curves for the region of the reactor vessel remote from the beltline) in TS Figures 3.4-2 and 3.4-3 are based on use of ASME Code Case N-641 and the lower bound static initiation fracture toughness value equation (K_{Ic} equation) given in Paragraph G-2110 of 2001 Edition of Appendix G to Section XI. Code Case N-641 permits application of the K_{Ic} equation as the basis for establishing the P-T limit curves in lieu of using the K_{Ia} equation, which is the method currently invoked by the 1995 edition of Appendix G to Section XI and which is based on crack arrest and dynamic loading test data. However, since the 2001 Edition of Appendix G to ASME Section XI is not currently an acceptable edition of the ASME Code that is endorsed by reference in 10 CFR 50.55a, and since use of Code Case N-641 will generate P-T limit curves that are less conservative than would be generated if methods of Appendix G to Section XI were used, licensees must be granted exemptions to use the Code Case methods if they seek to apply the Code Case methods to the generation of their P-T limits. The NRC staff has approved the exemption permitting the use of the ASME Code Case N-641 methods for the generation of the D.C. Cook 2 P-T limit curves which is enclosed. The enclosed exemption also includes the staff's technical basis for granting the exemption pursuant to the staff's exemption criterion given in 10 CFR 50.12(a)(2)(ii).

(1) Acceptable editions of Appendix G to Section XI of the ASME Boiler and Pressure Vessel Code, as currently endorsed by reference in 10 CFR 50.55a, "Codes and Standards," are editions through the 1995 Edition of the Code, inclusive of the 1996 Addenda.

To ensure that the new irradiated P-T limit curves for D.C. Cook 2 would still comply with the requirements of Section IV.A.2 of 10 CFR Part 50, Appendix G,⁽²⁾ the NRC staff requested that the licensee to provide additional P-T limit thermal stress intensity data for the D.C. Cook 2 RV effective to 32 effective full-power year (EFPY). The licensee provided this information in a November 15, 2002, letter. In order to verify compliance with intent of Section IV.A.2 of 10 CFR Part 50, Appendix G,⁽²⁾ the NRC staff performed an independent assessment of the irradiated P-T limit data for heatups and cooldowns of the reactor at heatup/cooldown rates of 60 °F/hr. The NRC staff confirmed that use of 200 °F and 169 °F as the 1/4T and 3/4T RT_{NDT} input values for the generation of the irradiated P-T limit curves was valid for operations of the reactor effective to 32 EFPY and acceptable when evaluated against the recommended guidelines of RG 1.99, Revision 2. The staff also confirmed that the proposed irradiated P-T limit curves that were generated by the licensee were at least as conservative as those that would be generated if the criteria and methods in the 1995 Edition of Appendix G to Section XI, as modified by the criteria and evaluation methods in ASME Code Case N-641, were used to generate the curves. The NRC staff also confirmed that the licensee's P-T limit curves included appropriate minimum temperature requirements that were at least as conservative as those required in Table 1 to 10 CFR Part 50, Appendix G. Based on this independent confirmation, the NRC staff concludes that the licensee's calculational methods for the P-T limit curves for normal and leak test operations generates P-T limits that meet the intent of 10 CFR Part 50, Appendix G.(2), as exempted, to apply ASME Code Case N-461 to the calculations of the P-T limits (refer to Footnote 2 on page 4 of this safety evaluation).

The fluence calculational methodology was described in the licensee's November 15, 2002, letter. The methodology used approximations, geometrical description, and cross sections in accordance with the guidance in RG 1.190 "Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence." Comparison of the recalculated fluence value with the original value indicated the magnitude and direction of the expected changes. The changes reflected the change in cross sections and the new low leakage loadings proposed for the remaining term of the Unit 2 license. In projecting the fluence value to 32 EFPYs, the licensee incorporated a 10 percent increase in anticipation of a 10 percent future power uprate. Accordingly, the projected fluence at this time is conservative by 10 percent. During the review of the licensee fluence calculations, the NRC staff discovered an apparent typographical error in the values of the U-238 γ -fission correction factors in the table on page 6 of the November 15, 2002, letter. By letter dated January 24, 2003, the licensee revised the table correcting the error.

Figures 3.4-2 and 3.4-3 of TS 3.4, "Reactor Coolant System Pressure," have been modified to reflect the revised PT curve applicability limits. The revised fluence value was used for the recalculation of RT_{PTS}. The proposed TS changes and the revised RT_{PTS} reflect the recalculated fluence to 32 EFPYs and are acceptable. The NRC staff review finds that the methodology used by the licensee, adheres to the guidance of RG 1.190; therefore, the results of the fluence calculation are acceptable.

(2) Note: Since the exemption permits the licensee to deviate from strict compliance with the requirements of 10 CFR Part 50, Appendix G, application of Code Case N-641 to the generation of the P-T limits, while not being in strict compliance with the requirements of 10 CFR Part 50, Appendix G, meets the intent of the regulation as discussed in the text. This is consistent with the exemption criterion specified in 10 CFR 50.12(a)(2)(ii).

4.0 SUMMARY

Based on the staff's review and evaluation of the licensee's proposed P-T limit curves for D. C. Cook Unit 2, the NRC staff has determined that the proposed P-T limit curves are consistent with the alternate assessment criteria and methods of ASME Code Case N-641, and satisfy the requirements of 10 CFR 50.60(a), "Acceptance Criteria for Fracture Prevention Measures for Lightwater Nuclear Power Reactors for Normal Operation;" Appendix G to 10 CFR Part 50, "Fracture Toughness Requirements;" and Appendix G to Section XI (1995 Edition), as exempted by the methods of analyses in the code case. The NRC staff finds that the proposed fluence value are acceptable because they were derived using methodologies which adhere to the guidance in RG 1.190. The proposed curves for D.C. Cook 2 are, therefore, approved for incorporation into the TSs.

5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Michigan State official was notified of the proposed issuance of the amendment. The State official had no comments.

6.0 ENVIRONMENTAL CONSIDERATION

The amendment changes the requirements with respect to installation or the use of a facility component located within the restricted area as defined in 10 CFR Part 20 or change the surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding (67 FR 66010). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

7.0 CONCLUSION

The NRC staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: J. Medoff
L. Lois

Date: March 20, 2003

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
INDIANA MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT, UNIT 2
DOCKET NO. 50-316
EXEMPTION

1.0 BACKGROUND

Indiana Michigan Power Company (the licensee) is the holder of Facility Operating License No. DPR-74 which authorizes operation of the Donald C. Cook (D. C. Cook) Nuclear Plant, Unit 2. The licensee provides, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (NRC, the Commission) now or hereafter in effect.

The facility consists of a pressurized water reactor located in Stevensville, Michigan.

2.0 REQUEST/ACTION

Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Appendix G requires that pressure-temperature (P-T) limits be established for reactor pressure vessels (RPVs) during normal operating and hydrostatic or leak rate testing conditions. Specifically, Appendix G to 10 CFR Part 50 states that “[t]he appropriate requirements on...the pressure-temperature limits and minimum permissible temperature must be met for all conditions.” Further, Appendix G of 10 CFR Part 50 specifies that the requirements for these limits are based on the application of evaluation procedures given in Appendix G to Section XI of the American Society of Mechanical Engineers (ASME) *Boiler and Pressure Vessel Code* (Code). In this exemption, consistent with

the current provisions of 10 CFR 50.55(a), all references to the ASME Code denote the 1995 Edition through the 1996 Addenda of the ASME Code.

In order to address provisions of amendments to the D. C. Cook Unit 2 Technical Specification (TS) P-T limit curves, the licensee requested in its submittal dated July 23, 2002, that the NRC staff exempt D. C. Cook Unit 2 from application of specific requirements of Appendix G to 10 CFR Part 50, and substitute the use of ASME Code Case N-641. ASME Code Case N-641 permits the use of an alternate reference fracture toughness curve for RPV materials and permits the postulation of a circumferentially-oriented flaw for the evaluation of circumferential RPV welds when determining the P-T limits. The proposed exemption request is consistent with, and is needed to support, the D. C. Cook Unit 2 TS amendment that was contained in the same submittal. The proposed D. C. Cook Unit 2 TS amendment will revise the P-T limits for heatup, cooldown, and inservice test limitations for the reactor coolant system (RCS) through 32 effective full power years of operation.

Code Case N-641

The licensee has proposed an exemption to allow the use of ASME Code Case N-641 in conjunction with Appendix G to ASME Section XI, 10 CFR 50.60(a) and 10 CFR Part 50, Appendix G, to establish the P-T limits for the D. C. Cook 2 RPV.

The proposed TS amendment to revise the P-T limits for D. C. Cook Unit 2 relies in part, on the requested exemption. These revised P-T limits have been developed using the lower bound K_{IC} fracture toughness curve shown in ASME Section XI, Appendix A, Figure A-2200-1, in lieu of the lower bound K_{IA} fracture toughness curve of ASME Section XI, Appendix G, Figure G-2210-1, as the basis fracture toughness curve for defining the D. C. Cook Unit 2 P-T limits. In addition, the revised P-T limits have been developed based on the use of a postulated circumferentially-oriented flaw for the evaluation of RPV circumferential welds in lieu of the axially-oriented flaw which would be required by Appendix G to Section XI of the ASME Code.

The other margins involved with the ASME Section XI, Appendix G process of determining P-T limit curves remain unchanged.

Use of the K_{IC} curve as the basis fracture toughness curve for the development of P-T operating limits is more technically correct than use of the K_{IA} curve. The K_{IC} curve appropriately implements the use of a relationship based on static initiation fracture toughness behavior to evaluate the controlled heatup and cooldown process of a RPV, whereas the K_{IA} fracture toughness curve codified into Appendix G to Section XI of the ASME Code was developed from more conservative crack arrest and dynamic fracture toughness test data. The application of the K_{IA} fracture toughness curve was initially codified in Appendix G to Section XI of the ASME Code in 1974 to provide a conservative representation of RPV material fracture toughness. This initial conservatism was necessary due to the limited knowledge of RPV material behavior in 1974. However, additional information has been gained about RPV materials which demonstrates that the lower bound on fracture toughness provided by the K_{IA} fracture toughness curve is well beyond the margin of safety required to protect the public health and safety from potential RPV failure.

Likewise, the use of a postulated circumferentially-oriented flaw in lieu of an axially-oriented one for the evaluation of a circumferential RPV weld is more technically correct. The flaw size required to be postulated for P-T limit determination has a depth of one-quarter of the RPV wall thickness and a length six times the depth. Based on the direction of welding during the fabrication process, the only technically reasonable orientation for such a large flaw is for the plane of the flaw to be circumferentially-oriented (i.e., parallel to the direction of welding). Prior to the development of ASME Code Case N-641 (and the similar ASME Code Case N-588), the required postulation of an axially-oriented flaw for the evaluation of a circumferential RPV weld provided an additional, unnecessary level of conservatism to the overall evaluation.

In addition, P-T limit curves based on the K_{IC} fracture toughness curve and postulation of a circumferentially-oriented flaw for the evaluation of RPV circumferential welds will enhance overall plant safety by opening the P-T operating window with the greatest safety benefit in the region of low temperature operations. The operating window through which the operator heats up and cools down the RCS is determined by the difference between the maximum allowable pressure determined by Appendix G of ASME Section XI, and the minimum required pressure for the reactor coolant pump seals adjusted for instrument uncertainties. A narrow operating window could potentially have an adverse safety impact by increasing the possibility of inadvertent overpressure protection system actuation due to pressure surges associated with normal plant evolutions such as RCS pump starts and swapping operating charging pumps with the RCS in a water-solid condition.

Since application of ASME Code Case N-641 provides appropriate procedures to establish maximum postulated defects and to evaluate those defects in the context of establishing RPV P-T limits, this application of the Code Case maintains an adequate margin of safety for protecting RPV materials from brittle failure. Therefore, the licensee concluded that these considerations were special circumstances pursuant to 10 CFR 50.12(a)(2)(ii), “[a]pplication of the regulation in the particular circumstances would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule.”

In summary, the ASME Section XI, Appendix G, procedure was conservatively developed based on the level of knowledge existing in 1974 concerning reactor coolant pressure boundary materials and the estimated effects of operation. Since 1974, the level of knowledge about the fracture mechanics behavior of RCS materials has been greatly expanded, especially regarding the effects of radiation embrittlement and the understanding of fracture toughness properties under static and dynamic loading conditions. The NRC staff concurs that this increased knowledge permits relaxation of the ASME Section XI, Appendix G

requirements by application of ASME Code Case N-641, while maintaining, pursuant to 10 CFR 50.12(a)(2)(ii), the underlying purpose of the ASME Code and the NRC regulations to ensure an acceptable margin of safety against brittle failure of the RPV.

The NRC staff has reviewed the exemption request submitted by the licensee and has concluded that an exemption should be granted to permit the licensee to utilize the provisions of ASME Code Case N-641 for the purpose of developing D. C. Cook Unit 2 RPV P-T limit curves.

3.0 DISCUSSION

Pursuant to 10 CFR 50.12, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR Part 50 when (1) the exemptions are authorized by law, will not present an undue risk to public health or safety, and are consistent with the common defense and security; and (2) when special circumstances are present.

Special circumstances, pursuant to 10 CFR 50.12(a)(2)(ii), are present in that continued operation of D. C. Cook Unit 2 with the P-T curves developed in accordance with ASME Section XI, Appendix G, without the relief provided by ASME Code Case N-641 is not necessary to achieve the underlying purpose of Appendix G to 10 CFR Part 50. Application of ASME Code Case N-641 in lieu of the requirements of ASME Code Section XI, Appendix G provides an acceptable alternative methodology which will continue to meet the underlying purpose of Appendix G to 10 CFR Part 50. The underlying purpose of the regulations in Appendix G to 10 CFR Part 50 is to provide an acceptable margin of safety against brittle failure of the RCS during any condition of normal operation to which the pressure boundary may be subjected over its service lifetime.

The NRC staff examined the licensee's rationale to support the exemption request, and agrees within the licensee's determination that an exemption would be required to approve the use of Code Case N-641. The NRC staff agree that the use of ASME Code Case N-641 would

meet the underlying intent of Appendix G to 10 CFR Part 50. The NRC staff concludes that the application of the technical provisions of ASME Code Case N-641 provided sufficient margin in the development of RPV P-T limit curves such that the underlying purpose of the regulations (Appendix G to 10 CFR Part 50) continued to be met such that the specific conditions required by the regulations; i.e., use of all provisions in Appendix G to Section XI of the ASME Code, were not necessary. Therefore, the NRC staff concludes that the exemption requested by the licensee is justified based on the special circumstances of 10 CFR Part 50(a)(2)(ii), “[a]pplication of the regulation in the particular circumstances would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule.”

Based upon a consideration of the conservatism that is explicitly incorporated into the methodologies of Appendix G to 10 CFR Part 50; Appendix G to Section XI of the ASME Code; and Regulatory Guide 1.99, Revision 2; the staff concludes that application of ASME Code Case N-641 as described would provide an adequate margin of safety against brittle failure of the RPV. This is also consistent with the determination that the staff has reached for other licensees under similar conditions based on the same considerations. Therefore, the NRC staff concludes that requesting the exemption under the special circumstances of 10 CFR 50.12(a)(2)(ii) is appropriate, and that the methodology of Code Case N-641 may be used to revise the P-T limits for the D. C. Cook Unit 2 RPV.

4.0 CONCLUSION

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12(a), the exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. Also, special circumstances are present. Therefore, the Commission hereby grants the licensee an exemption from the requirements of 10 CFR 50.60 and 10 CFR Part 50, Appendix G, to allow application of ASME

Code Case N-641 in establishing TS requirements for the reactor vessel pressure limits at low temperatures for D. C. Cook Unit 2.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (68 FR 13336).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 19th day of March 2003.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Zwolinski, Director
Division of Licensing Project Management
Office of Nuclear Reactor Regulation