


NOTE:
ALL VENT HOODS TO BE ADJUSTED TO MAINTAIN
A VELOCITY OF 100 LINEAR FEET PER MINUTE.



REVISION	DATE	DESCRIPTION
FIGURE 4-3C CHEM A BUILDING 3rd FLOOR LAB DECOMMISSIONING PLAN FANSTEEL, INC. MUSKOGEE, OKLAHOMA		
PREPARED FOR FANSTEEL, INC. MUSKOGEE, OKLAHOMA		
APPROVED	<i>[Signature]</i>	
CHECKED	<i>[Signature]</i>	
DRAWN	DEB/08/15/02	
DRAWING NUMBER		
6473412		 Earth Sciences Consultants, Inc.

REFERENCE
FANSTEEL DRAWING "OMF-CHEMA-007".