



444 South 16th Street Mall  
Omaha NE 68102-2247

January 12, 2003  
LIC-03-0003

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001


Reference: Docket No. 50-285

**SUBJECT: December 2002 Monthly Operating Report (MOR)**

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for December 2002. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,



R. T. Ridenoure  
Division Manager  
Nuclear Operations

RTR/EPM/epm

Attachments

c: E. W. Merschoff, NRC Regional Administrator, Region IV  
A. B. Wang, NRC Project Manager  
J. G. Kramer, NRC Senior Resident Inspector  
INPO Records Center  
Winston & Strawn

IE24

**ATTACHMENT 1  
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>January 02, 2003</u>
COMPLETED BY	<u>E. P. Matzke</u>
TELEPHONE	<u>(402) 533-6855</u>

**REPORT PERIOD: December 2002**

1. Design Electrical Rating	<u>(MWe-Net):</u>	<u>478</u>
2. Maximum Dependable Capacity	<u>(MWe-Net):</u>	<u>478</u>

**OPERATING STATUS**

	<b>MONTH</b>	<b>YEAR TO DATE</b>	<b>CUMULATIVE</b>
3. Number of Hours Reactor was Critical:	744	8,082	207,962
4. Number of Hours Generator was On-line:	744	8,061	205,928
5. Unit Reserve Shutdown Hours:			
6. Net Electrical Energy Generated (MWh):	364,577	3,808,519	89,016,030

**ATTACHMENT 2  
 UNIT SHUTDOWNS  
 REPORT MONTH December 2002**

DOCKET NO. 50-285  
 UNIT NAME Fort Calhoun Station  
 DATE January 02, 2003  
 COMPLETED BY E. P. Matzke  
 TELEPHONE (402) 533-6855

No.	Date (YY/MM/DD)	Type F: Forced S: Scheduled	Duration (Hours)	Reason <sup>1</sup>	Method of Shutting Down Reactor <sup>2</sup>	Cause & Corrective Action to Prevent Recurrence

**(1) Reason:**

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

**(2) Method:**

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

**OPERATIONS SUMMARY**

The Fort Calhoun Station operated at a nominal 100% power for the entire month.

**SAFETY VALVE OR PORV CHALLENGES/FAILURES**

No failures or challenges to safety valves or PORVs occurred during the month.