


809.13-1



**Environmental Quality Control
Bureau of Air Quality
Inspection/Investigation Report**

**Central Midlands District
Building 5
State Park, SC 29147
(803) 935-7015 Fax (803) 935-6724**

...Promoting Health, Protecting the Environment

Source(Project): SCE&G Summer Nuclear	Date/Time: 97/06/25 @ 1100
Source No.: 1000-0012	Type: Annual
Mailing Address: P. O. Box 88 Jenkinsville, SC 29065	Owner/Operator: Susan Reese, Env. Manager
Source Address: Hwy 215 North Jenkinsville, SC 29065	Person Contacted: Chuck McKinney
County: Fairfield	Source Telephone: 803-345-4591
	Code: MA01X
	Inspector: Robert W. Hudson

Chuck McKinney, Operations Manager with SCE&G accompanied me on a scheduled annual inspection at this facility. Upon inspection we found the 112 MMBTU #2 oil boiler operating at approximately 28 % full load, with no visible emissions. Steam Pressure was 150 PSI and oil pressure at the burner was 30 PSIG. All steam produced during this test firing run was vented to the atmosphere. This boiler is only used during nuclear plant shutdown. The boiler is tested for at least 2 hours each week. According to Mr. Kinney the waste oil burner has been fired for only two days during the last year. Overall record keeping was good and source is considered in compliance.

RECOMMENDATIONS: Notify this office of any upsets or unusual conditions that result in excess emissions.

RECEIVED
JUL 15 1997
M. & OE