



2600 Bull Street  
Columbia, SC 29201-1708

COMMISSIONER:  
C. Earl Hunter

BOARD:  
Bradford W. Wyche  
Chairman

October 31, 2002

Mark B. Kent  
Vice Chairman

CERTIFIED MAIL - 7001 2510 0008 8170 4749  
RETURN RECEIPT REQUESTED

Howard L. Brilliant, MD  
Secretary

Mr. Stephen Byrne

Carl L. Brazell

Senior Vice President

Louisiana W. Wright

Nuclear Operations

L. Michael Blackmon

SCE&G

Lawrence R. Chewning, Jr., DMD

Post Office Box 88

Jenksville, SC 29065

RE: Notice of Violation 02-39-30856-455  
SSE&G/V.C. Summer Nuclear Station  
NPDES Permit SC0030856  
Fairfield County

Dear Mr. Byrne:

A review of the discharge monitoring report (DMR) submitted to the Department for the September 2002 monitoring period has revealed the following violations:

PIPE	PARAMETER	DATE	LIMIT	DMR	MAX/MIN
014	TCP3B C.Tox, % Effect	09/30/2002	20	52.9	LCMOAV
014	TCP3B C.Tox, % Effect	09/30/2002	50	52.9	LCDAMX
014	TJP3B C.Tox, % Mort.	09/30/2002	20	70	LCMOAV
014	TJP3B C.Tox, % Mort.	09/30/2002	50	70	LCDAMX


You are hereby notified that failure to comply with the effluent limits of the NPDES Permit is a violation of the Pollution Control Act, S.C. Code Ann. 48-1-110(d) (1987) and Water Pollution Control Permits, 24 S.C. Code Ann. Regs. 61-9.122.41(a) (1998). The violations make SCE&G subject to further enforcement action, which may include assessment of civil penalties as set forth in the Pollution Control Act, S.C. Code Ann. 48-1-330 (1987).

Since a letter of explanation was submitted with the DMR, a written response to this notice is not required. The explanation will not, however, relieve SCE&G of responsibility for the violations cited.

*J. Bacon*  
*Judy Collins*

If you have any questions concerning this notice, you may call me at (803) 898-4181. I will be glad to assist you.

Sincerely,

A handwritten signature in cursive script that reads "Sandra L. Hursey".

Sandra L. Hursey  
Compliance Officer  
Water Pollution Enforcement Section  
Bureau of Water

cc: Central Midlands EQC District Office