

South Carolina
DHEC
Department of Health and Environmental Control
2600 Bull Street, Columbia, SC 29201-1708

Commissioner: Douglas E. Bryant

Board: John H. Burriss, Chairman
William M. Hull, Jr., MD, Vice Chairman
Roger Leaks, Jr., Secretary

Richard E. Jabbour, DDS
Cyndi C. Mosteller
Brian K. Smith
Rodney L. Grandy

Promoting Health, Protecting the Environment

April 10, 1997

RECEIVED

APR 14 1997

M & OF

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Gary J. Taylor
Vice President
Nuclear Operations
South Carolina Electric & Gas
Post Office Box 88
Jenkinsville, S.C. 29065

RE: Notice of Violation 97-39-30856-169
SCE&G/V.C. Summer Nuclear Station
NPDES Permit SC0030856
Fairfield County

Dear Mr. Taylor:

A review of the discharge monitoring reports (DMRs) submitted to the Department for the February 1997 monitoring period has revealed the following violations:

PIPE#	PARAMETER	DATE	LIMIT	DMR	MAX/AVG
014	01042 Copper, T.	02/28/1997	0.028	0.10	LCAV
014	01042 Copper, T.	02/28/1997	0.039	0.10	LCMX

Please be aware that failure to comply with the conditions of the NPDES Permit is a violation of the Pollution Control Act, S.C. Code Ann. Section 48-1-10 et seq. (1987) and makes SCE&G subject to further enforcement action, which may include civil penalties as set forth in Section 48-1-330 of the Act.

You are requested to submit a written response within ten (10) days of receipt of this notice. Your response should include an explanation for the violations cited above, and measures that have been or will be taken to ensure compliance with permit conditions. This response will not relieve SCE&G of responsibility for the violations cited.

If you have any questions concerning this notice, you may call me at (803) 734-5297. I will be glad to assist you.

Sincerely,

Sandra L. Hursey
Sandra L. Hursey
Environmental Quality Manager
Enforcement Section
Bureau of Water

cc: NOV File
Central Midlands EQC District Office

NL & OE
COMPLETION FORM

RTS# : EPA 970001 ISSUE MANAGER: Susan B. Reese

TITLE /SUBJECT: NPDES Permit No. SC0030856 - Notice of Violation (Outfall 014)

ACTION COMPLETED: 5/12/97
Date

POSITION/STATUS * : A Notice of Violation was issued on 4/10/97 by SCDHEC for Outfall 014 exceeding the permitted limit for Copper. A review of the data revealed that the value of <0.10 mg/l for the daily average and the daily maximum was incorrect. The value should have been <0.010 mg/l. A letter dated 4/16/97 was submitted to SCDHEC with a corrected Discharge Monitoring Report. This item requires no further action and therefore may be closed.

* Attach additional pages as necessary.

OB Reese
Issue Manager

5/12/97
Date

[Signature]
Approval Authority

5/12/97
Date

Route:
RTS: da 5/13/97
File: 809.02-17

This electronic form has been verified to contain the information on the Master Control Copy. SR Initial 5/12/97 Date