



2600 Bull Street
Columbia, SC 29201-1708

COMMISSIONER:
Douglas E. Bryant

BOARD:
John H. Burriss
Chairman

William M. Hull, Jr., MD
Vice Chairman

Roger Leaks, Jr.
Secretary

Mark B. Kent

Cyndi C. Mosteller

Brian K. Smith

Rodney L. Grandy

May 17, 1999

RECEIVED

MAY 18 1999

NL&OE

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Gary J. Taylor
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Post Office Box 88
Jenkinsville, SC 29065

RE: Notice of Violation 99-39-30856-205
SCE&G/V .C. Summer Nuclear Station
NPDES Permit SC0030856
Fairfield County

Dear Mr. Taylor:

A review of the discharge monitoring reports (DMRs) submitted to the Department for the March 1999 monitoring period has revealed the following violations:

PIPE#	PARAMETER	DATE	LIMIT	DMR	MAX/MIN
014	50060 T.Resid.Cl	03/31/1999	0.011	0.050	LCAV
014	50060 T.Resid.Cl	03/31/1999	0.019	0.100	LCMX


Please be aware that failure to comply with the conditions of the NPDES Permit is a violation of the Pollution Control Act, S.C. Code Ann. Section 48-1-10 et seq. (1976, as amended) and makes SCE&G subject to further enforcement action, which may include civil penalties as set forth in Section 48-1-330 of the Act.

Since an explanation for the violations was provided with the DMR, a written response to this notice is not required. The explanation does not, however, relieve SCE&G of responsibility for the violations cited.

Notice of Violation
SCE&G/V.C. Summer Nuclear Station
May 17, 1999
Page Two

If you have any questions concerning this notice, you may call me at (803) 898-4181. I will be glad to assist you.

Sincerely,

A handwritten signature in cursive script, reading "Sandra L. Hursey".

Sandra L. Hursey
Environmental Health Manager
Water Pollution Enforcement Section
Bureau of Water

cc: Central Midlands EQC District Office