Stephen A. Byrne Senior Vice President, Nuclear Operations 803.345.4622



January 29, 2003 RC-03-0027

Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 20555

Ladies and Gentlemen:

- Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS) DOCKET NO. 50/395 OPERATING LICENSE NO. NPF-12 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING REQUEST TO USE ALTERNATIVES TO ASME BOILER AND PRESSURE VESSEL CODE, SECTION XI, RELIEF REQUEST RR-II-08 (0-C-02-3202)
- Reference: 1. SCE&G Letter to NRC (Document Control Desk), RC-02-0191, October 30, 2002, Request to Use Alternatives to ASME Boiler and Pressure Vessel Code, Section XI
 - NRC (K. R. Cotton) Letter to VCSNS January 22, 2003, Request for Additional Information ISI Relief Request RR-II-08 (TAC NO. MB6647)

South Carolina Electric & Gas Company (SCE&G) hereby submits the attached response to the referenced request for additional information (RAI) regarding relief request RR-II-08 submitted by Reference 1 on October 30, 2002.

Should you have any questions, please call Mr. Mel Browne at (803) 345-4141.

Very truly yours,

Sta Eno

Stephen A. Byrne

JT/SAB/dr Attachment

A047

Document Control Desk 0-C-02-3202 RC-03-0027 Page 2 of 2

. م

> c: N. O. Lorick N. S. Cams T. G. Eppink (w/o Attachment) R. J. White L. A. Reyes K. R. Cotton K. M. Sutton General Managers NRC Resident Inspector A. R. Caban NSRC RTS (0-C-02-3202) File (810.19-2) DMS (RC-03-0027)

> > ۰.

Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 1 of 9

South Carolina Electric & Gas Company (SCE&G) Virgil C. Summer Nuclear Station (VCSNS) Response to NRC Request for Additional Information (RAI) Regarding Inservice Inspection Relief Request RR-II-08

- 1. The submittal states that the relief is being requested in accordance with Title 10, Code of Federal Regulations (10 CFR), Sections 50.55a(a)(3)(i) and 50.55a(a)(3)(ii). Relief such as this has been authorized using 10 CFR 50.55a(a)(3)(ii), the American Society of Mechanical Engineers Boiler and Pressure Vessel Code since (the Code) requirements reflect hardship upon the licensee. To build a case for such hardship, please provide:
 - a. A comparison of worker radiation dosage between the ultrasonic and visual examination techniques.

Response 1.a:

The ultrasonic examination of the Steam Generator nozzle inner radius is performed in a radiation area of approximately 200 mr/hr. Each examination requires the following items to complete the task:

- 1. Mirror insulation removal, approximately 2 man-hours. This task is typically done in respirators.
- 2. Cleaning and or buffing of the surface, approximately 4 man-hours. This task is typically done in respirators.
- 3. Ultrasonic examination, approximately 2 man-hours.
- 4. Mirror insulation installation, approximately 2 man-hours.
- 5. Health Physics support, approximately ½ man hour (using remote surveillance).

This evolution of 10 ½ man-hours should be expected to cause an exposure of 2100 mr per nozzle. There are six nozzles to be inspected for a total of 12,600 mr for completion of all ultrasonic examinations each Interval.

Visual examination, VT-1, of the Steam Generator nozzle inner radius is performed by remotely utilizing either a robotic camera or utilization of the Eddy Current tooling end effectors for a robotic camera. Each visual examination requires approximately 1 man-hour to complete the task. Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 2 of 9

The least dose efficient method is expected to cause an exposure of 200 mr per nozzle. There are six nozzles to be inspected for a total of 1200 mr for completion of all visual examinations each Interval. The preferred method is the use of the Eddy Current tooling to perform this visual inspection. With the use of this tooling, the expected total dose associated with the Visual inspection should be ZERO mr.

b. The drawings (or pictorial discussion) showing the type and location of interferences with the Code-required ultrasonic examination. The drawing number was provided in the submittal but not the drawing itself. Identify the percent coverage that is able to be achieved on these nozzles using Code-required ultrasonic examinations.

Response 1.b:

The drawing and the Preservice data are attached for reference.

The ultrasonic examinations performed for the detection of corner flaws per IWB-2500-7(d) consists of two circumferential scans, one clockwise and one counterclockwise. Both exams are performed with a specially designed 28 degree longitudinal wave alternative style transducer. This examination technique has scan interferences from manufacturing pads and the internally fabricated primary head drain hole. The combination of these interferences has limited the maximum achievable coverage to 80.4 per-cent of the examination volume.

c. A material description (cast carbon steel, cast stainless steel, cast nickelbased alloys, etc.) and dimensions (nozzle nominal inside diameter, nominal wall-thicknesses).

Response 1.c:

The material properties of the nozzle are:

- Material type Cast nickel based alloy steel, SA-508 CI 3a, with integrally cast nozzles
- o Nozzle Inside diameter at the safe-end weld 31.8 inches
- Nozzle nominal thickness at the safe-end weld 3.2 inches

Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 3 of 9

It should be noted that the nozzle has an approximate 9 degree taper toward the scan area for the inner radius. This makes the wall thickness at the area of the inner radius to be approximately 6 inches.

- 2. The staff has been authorizing an enhanced VT-1 with demonstrated capabilities of resolving a 1-mil wire or equivalent flaw for the specified inner nozzle radii. This is in keeping with the current rule published in the *Federal Register*, 67 FR 60541, dated September 26, 2002, regarding 10 CFR 50.55a(a)(b)(2)(xxi). The proposed alternative is relying only on the Code-requirements for VT-1 of ensuring the detection of cracks.
 - a. Discuss the demonstration used for comparing the effectiveness of the enhanced VT-1 and UT.

Response 2.a:

SCE&G has not performed a physical comparative demonstration. It is believed that a direct visual inspection,VT-1, of the component surface would be at least equal to the ultrasonic examination of a cast high nickel based alloy in the thickness range of 6 inches. The visual examination resolution will be verified at the beginning of each component inspection to ensure the remote camera optics are capable of minor flaw detection. The use of a standard one-millimeter bare wire gauge at the inspection surface is typically used to qualify this type of system.

b. Explain the process used for selecting flaw types and sizes used for demonstrating effectiveness.

Response 2.b:

SCE&G has not performed a physical comparative demonstration and no comparative flaws were utilized.

c. Provide a description of the flaws.

Response 2.c:

SCE&G has not performed a physical comparative demonstration and no comparative flaws are represented.

Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 4 of 9

d. Discuss the variations with respect to true values.

Response 2.d:

SCE&G has not performed a physical comparative demonstration and no comparative flaws are represented.

3. Discuss the percentage of Code-required surface coverage that will be examined with the alternate VT examination for each nozzle inner radius.

Response 3:

Essentially 100 per-cent of the component surface, as shown on Figure IWB-2500-7(d), will be inspected every time the component is opened for maintenance, repair, or eddy current examination.

4. Discuss the procedure for examination of the steam generator primary nozzle inner radius done during the first Inservice Inspection Interval for V. C. Summer Nuclear Station.

See 1

Response 4:

The Steam Generator primary nozzle inner radius was not required to be inspected during Interval I. The current Steam Generators were put into service in 1994 during the first refueling outage of Interval II.

Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 5 of 9



SOUTH CAROLINA ELECTRIC and GAS COMPANY VIRGIL C. SUMMER NUCLEAR STATION Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 6 of 9

CE DIVISION Serricoum. <u>Milant V. C. SUMMER</u> Serricoum. <u>Milant Not a cold les</u> <u>mocedure SGE-151-247 REV.0</u> DATA DATA DATA MEAMTY AND CAL ONECE <u>BAT/1145</u> CAL REOCK THICHORE 4	100.76 FAX MAX, 100 5, MAX, 100 5, MAX, 60,55 FRAM M. TO 6446, M. TO 7406, M. TO 7440, M. TO 7440, DR. 20195.2 WELD SLIPE. Resudents PPL 745, AMPL 745, MAX, 740 7, M. TO 7440, DR. 20195.2 WELD SLIPE. 7	4.8 Ø1900 100% 280% 231 386 123 386 Anna Aublus section 4.8 Ø1900 100% 357 123 366 120% 120%	(1) The wheth of scan Area MT varying sweep Locations, see general indication sheet.	(2) M BOTH CINCUMPTENENTIAL DIRECTIONS.					
MEDE AN	ANOLE	ž ž	ANG BWY	N.S.					
AMER W WOZZE	N 00 X		NT VA	DARCT					_
PRIMA PRIMA	YW -		A AR	E UII					-
CONF.	× 1 8 8 8 1 8 1 8 1 8			COMIT	 				W
PLANT SWET.		x x				<u> </u>		+ - + - + - + - + - + - + - + - +	-
	4 4 4 4 4 9	8 8		R R				┝╌╎╼┼╴	
N				$\left - \right $					-
	2 2 2 2							┝╌┠╌┞╸	-
RVICE CES NN DA1	NN	+			noria	 			
AR SEI SERVI	X 0			. The man	<u>}</u>				
C INDI	NIN IN		┝╌┼╴╡		┟╼╍╉╼╼╸				
OUSE N INSPEC	но <u>х</u> нор						·		
/ESTINGH	MOIGATON LE	E E							
3	, tradicional de la construcción de	바-7							REVIEW

and the second second

.

.

-C- IC- Pag	-0 0(e	2- 3-(7	32 00 01	202)27 f 9	2																										
ET DH	12150	OCTOURS	400101347 MEV. 0	115 7-31-84	CALIBRATION CHECK	TULIA							1440					CAL FLOCK SHARFOR	THEERE 12	TEMPERATURE 78-1	ertestra		STE INDICATION DATA SHEET FOR	OF OWETING INDICATIONS							
ă		E		ð						-	ANDE FROM	Frees bre 10	LOCATIONS									N I IWN		•						-	
			IJ									BUNK	TEAK									Ÿ	×	X							
Line .	Σ		DTI EN IOOFI									PORTION						·			1	EAS	HUG	htod						ۍ ا	Ŕ
	ADDUR, HO				╏		Ť						T								ž	ž				60	C. Leville				
	¢.		ARY NOZZLE WIDE I	init.	2011)		8		- Hu		TANCE FROM	ELECTION IN DAG	LOCATIONS					÷					Arrow sweet	A TION SHEET			~ *				
	o, summe	Ţ.	Ē				Ĩ	X -2		- 2 94	đ		TAN									Na in benefitikalan		SCE LENT							
EMP.	×.	PNR1, / -00		Le la								Line a		98	3	1.0			Ŧ	E											-
- N													-	Į	E	X.		-	Ŕ	2			YEA	ţ	 						┝
E DIVISIO			ATTON		T BEAM				T	ĺ		ŧ	LUGI I LOU		T																
A SERVIC	FINICES		EXAMINI	B	ETRAIGHT							MONAL Abral														-			_		
INUCLEA	ECTION S	I	RABONIC	PRESERV		L LAVER L						Notra	MOLTON		-	U			A AMI	MAG	3		+						<u> </u>		-
WESTINGHOUSE	LSN	•	wed ult			FOULTWENT 110	BONG-136 9.1M	156-4064	¥	NEACT AND	t,	DANTING BAI		FILTER	LUN. CHECK	12	4. U. CANE	Per min To and		BALDOT CAL		11 ·····	F.	4							

쁥

NINE

Document Control Desk Attachment 0 R P

-

.

				» č
	WES	TINGHOUSE NUCLEAR SERVIC INSPECTION SERVICES	E DIVISION	Je 8
		LIMITATION TO EXAMINAT	ION	of
PLANT V.C. SUMME	R	UNIT	t SKETCH 12150	9
SYST (COMP. PRIMARY	NOZZLE INSIDE RADIUS. H		PROCEDURE \$GE-I\$I-247 REV.	.0
	A Monie			-31-94
July 1				
RELATED TO: UT X	PTNT	VT (DENT, NO	J-IR / V-IR	
PROVIDE GENERAL INFORMA	TION TO DESCRIE APPROXIMATE	BIZE, LOCATION AND TYPE OF LIMITATION.	No la	
×			"IOTINATA	
			"Only	
	· ·		· · · · · · · · · · · · · · · · · · ·	
FATE FMD WELD			an a	
0 •	8 0 *	180 *	270 ⁴	
				¢ (
ACHO DEGNEC IS ENGLIED P				
			STE BENEMAL INDICATION DATA SHEET FOR SIDE VIEW OF SET UP PAD	r
				1

Document Control Desk

ω,

£

10

12. M. S. 1

Document Control Desk Attachment 0-C-02-3202 RC-03-0027 Page 9 of 9

r 'e

è

. .

	WESTINGHOUSE NUCLEAR SERVICE DIVISION INSPECTION SERVICES
	GENERAL - INDICATION DATA
PLANT V. C. SUMMER	UNIT #1 SKETCH 12150
SYST./COMP. PRIMARY NOZZLE	ENSIDE MADRIS MOTICOLOLEGPROCEDURESGE-ISI-247 REV. 0
EXAMINER ferret	DATE 7-31-94
DETECTED BY UT X	PT MIT VT IDENT. NO. U-IR & V-IR
PROVIDE SUFFICIENT INFORMATION T USED FOR RIZING OR REPORTING. IF	ig describe bize, location and type of indication. Describe extra or special equipment if Necessary include sketch showing general confiduration of item or area.
\$.\$*4.C] 12.5*6.5*~~~	
	For Information Control
	Remander Three Relevant Street
NOTE: REFERENCE DRAW HOLE IN HOT AND COLD L	ING 6145E22 SHEET 5 OF 7. SHOWING DRAIN EGS RESPONSABLE FOR GEOMETRIC REFLECTOR.
REVIEW	ASPI