

Stephen A. Byrne
Senior Vice President, Nuclear Operations
803.345.4622



January 29, 2003
RC-03-0027

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Ladies and Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION
REGARDING REQUEST TO USE ALTERNATIVES TO ASME BOILER
AND PRESSURE VESSEL CODE, SECTION XI, RELIEF REQUEST
RR-II-08 (0-C-02-3202)

Reference: 1. SCE&G Letter to NRC (Document Control Desk), RC-02-0191,
October 30, 2002, Request to Use Alternatives to ASME Boiler
and Pressure Vessel Code, Section XI

2. NRC (K. R. Cotton) Letter to VCSNS January 22, 2003, Request
for Additional Information ISI Relief Request RR-II-08
(TAC NO. MB6647)

South Carolina Electric & Gas Company (SCE&G) hereby submits the attached response to the referenced request for additional information (RAI) regarding relief request RR-II-08 submitted by Reference 1 on October 30, 2002.

Should you have any questions, please call Mr. Mel Browne at (803) 345-4141.

Very truly yours,

A handwritten signature in black ink, appearing to read "Stephen A. Byrne", written in a cursive style.

Stephen A. Byrne

JT/SAB/dr
Attachment

A047

Document Control Desk
0-C-02-3202
RC-03-0027
Page 2 of 2

c: N. O. Lorick
N. S. Cams
T. G. Eppink (w/o Attachment)
R. J. White
L. A. Reyes
K. R. Cotton
K. M. Sutton
General Managers
NRC Resident Inspector
A. R. Caban
NSRC
RTS (0-C-02-3202)
File (810.19-2)
DMS (RC-03-0027)

**South Carolina Electric & Gas Company (SCE&G)
Virgil C. Summer Nuclear Station (VCSNS)
Response to NRC Request for Additional Information (RAI)
Regarding Inservice Inspection Relief Request
RR-II-08**

1. The submittal states that the relief is being requested in accordance with Title 10, Code of Federal Regulations (10 CFR), Sections 50.55a(a)(3)(i) and 50.55a(a)(3)(ii). Relief such as this has been authorized using 10 CFR 50.55a(a)(3)(ii), the American Society of Mechanical Engineers Boiler and Pressure Vessel Code since (the Code) requirements reflect hardship upon the licensee. To build a case for such hardship, please provide:
 - a. A comparison of worker radiation dosage between the ultrasonic and visual examination techniques.

Response 1.a:

The ultrasonic examination of the Steam Generator nozzle inner radius is performed in a radiation area of approximately 200 mr/hr. Each examination requires the following items to complete the task:

1. Mirror insulation removal, approximately 2 man-hours. This task is typically done in respirators.
2. Cleaning and or buffing of the surface, approximately 4 man-hours. This task is typically done in respirators.
3. Ultrasonic examination, approximately 2 man-hours.
4. Mirror insulation installation, approximately 2 man-hours.
5. Health Physics support, approximately ½ man hour (using remote surveillance).

This evolution of 10 ½ man-hours should be expected to cause an exposure of 2100 mr per nozzle. There are six nozzles to be inspected for a total of 12,600 mr for completion of all ultrasonic examinations each Interval.

Visual examination, VT-1, of the Steam Generator nozzle inner radius is performed by remotely utilizing either a robotic camera or utilization of the Eddy Current tooling end effectors for a robotic camera. Each visual examination requires approximately 1 man-hour to complete the task.

The least dose efficient method is expected to cause an exposure of 200 mr per nozzle. There are six nozzles to be inspected for a total of 1200 mr for completion of all visual examinations each Interval. The preferred method is the use of the Eddy Current tooling to perform this visual inspection. With the use of this tooling, the expected total dose associated with the Visual inspection should be ZERO mr.

- b. The drawings (or pictorial discussion) showing the type and location of interferences with the Code-required ultrasonic examination. The drawing number was provided in the submittal but not the drawing itself. Identify the percent coverage that is able to be achieved on these nozzles using Code-required ultrasonic examinations.**

Response 1.b:

The drawing and the Preservice data are attached for reference.

The ultrasonic examinations performed for the detection of corner flaws per IWB-2500-7(d) consists of two circumferential scans, one clockwise and one counterclockwise. Both exams are performed with a specially designed 28 degree longitudinal wave alternative style transducer. This examination technique has scan interferences from manufacturing pads and the internally fabricated primary head drain hole. The combination of these interferences has limited the maximum achievable coverage to 80.4 per-cent of the examination volume.

- c. A material description (cast carbon steel, cast stainless steel, cast nickel-based alloys, etc.) and dimensions (nozzle nominal inside diameter, nominal wall-thicknesses).**

Response 1.c:

The material properties of the nozzle are:

- o Material type - Cast nickel based alloy steel, SA-508 Cl 3a, with integrally cast nozzles
- o Nozzle Inside diameter at the safe-end weld - 31.8 inches
- o Nozzle nominal thickness at the safe-end weld - 3.2 inches

It should be noted that the nozzle has an approximate 9 degree taper toward the scan area for the inner radius. This makes the wall thickness at the area of the inner radius to be approximately 6 inches.

2. **The staff has been authorizing an enhanced VT-1 with demonstrated capabilities of resolving a 1-mil wire or equivalent flaw for the specified inner nozzle radii. This is in keeping with the current rule published in the *Federal Register*, 67 FR 60541, dated September 26, 2002, regarding 10 CFR 50.55a(a)(b)(2)(xxi). The proposed alternative is relying only on the Code-requirements for VT-1 of ensuring the detection of cracks.**
 - a. **Discuss the demonstration used for comparing the effectiveness of the enhanced VT-1 and UT.**

Response 2.a:

SCE&G has not performed a physical comparative demonstration. It is believed that a direct visual inspection, VT-1, of the component surface would be at least equal to the ultrasonic examination of a cast high nickel based alloy in the thickness range of 6 inches. The visual examination resolution will be verified at the beginning of each component inspection to ensure the remote camera optics are capable of minor flaw detection. The use of a standard one-millimeter bare wire gauge at the inspection surface is typically used to qualify this type of system.

- b. **Explain the process used for selecting flaw types and sizes used for demonstrating effectiveness.**

Response 2.b:

SCE&G has not performed a physical comparative demonstration and no comparative flaws were utilized.

- c. **Provide a description of the flaws.**

Response 2.c:

SCE&G has not performed a physical comparative demonstration and no comparative flaws are represented.

d. Discuss the variations with respect to true values.

Response 2.d:

SCE&G has not performed a physical comparative demonstration and no comparative flaws are represented.

3. Discuss the percentage of Code-required surface coverage that will be examined with the alternate VT examination for each nozzle inner radius.

Response 3:

Essentially 100 per-cent of the component surface, as shown on Figure IWB-2500-7(d), will be inspected every time the component is opened for maintenance, repair, or eddy current examination.

4. Discuss the procedure for examination of the steam generator primary nozzle inner radius done during the first Inservice Inspection Interval for V. C. Summer Nuclear Station.



Response 4:

The Steam Generator primary nozzle inner radius was not required to be inspected during Interval I. The current Steam Generators were put into service in 1994 during the first refueling outage of Interval II.

SOUTH CAROLINA ELECTRIC and GAS COMPANY
 VIRGIL C. SUMMER NUCLEAR STATION

ILLUSTRATIVE ONLY

CGE-1-3100



BOTTOM VIEW

WELD NUMBER EXAMPLE:
 CGE-1-3100-14 A
 CGE-1-3100-121R B
 CGE-1-3100-BOLT C
 RE NOMINAT WELD LOOP

CHANGES THIS REVISION:
 WELD 1 DELETED PER MRF 90,001
 NEW BOLTING PER MRF 90,001

| REVISION | DATE |
|-----------------|---------|
| DRAWN / Alex | 12-2-92 |
| CHECKED | |
| APPROVED / Alex | 12-3-92 |

| WESTINGHOUSE NUCLEAR SERVICE DIVISION INSPECTION SERVICES | | | | | | | | | | PLANT V. O. SUMNER | | UNIT A1 | | BOSTON 12150 | | | | | |
|---|--|--|--|--|--|--|--|--|--|---|--|--------------------|--|-------------------|--|---------|--|---------|--|
| WELD ULTRASONIC EXAMINATION PRESERVICE | | | | | | | | | | BYST. / COMP. | | PROCEDURE | | DATE | | | | | |
| EXAMINER LEVEL III <i>Raymond M...</i> | | | | | | | | | | PRIMARY NOZZLE INSIDE RADIUS, HOT/RECOOLING | | 80R-MIL-347 REV. 0 | | 7-31-84 | | | | | |
| CIRCUMFERENTIAL SCANS | | | | | | | | | | INITIAL | | 0948 | | CALIBRATION CHECK | | | | | |
| ATRAIGHT BEAM | | | | | | | | | | SCAN DIRECTION 0 | | SWEEP POSITION | | DISTANCE FROM | | | | | |
| TRANSDUCER | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| REFLECTOR | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| ANGLE | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| DAMPING | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| BOGOMAS | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| FILTER | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| CALIBRATION REFLECTION LOCATION | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| CAL. GAIN | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| TEMP. | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| BASE METAL SCAN | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| SCAN DIRECTION | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| TEMP. | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| Y-R | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| Y-R | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| REMARKS | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| CAL. BLOCK | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| THICKNESS | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| TEMPERATURE | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| REMARKS | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| SEE INDICATION DATA SHEET FOR | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| CORRECTING INDICATIONS | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | | | | |
| <p style="text-align: center; font-size: 2em; opacity: 0.5;">For Information Only</p> | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |
| | | | | | | | | | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | | 80% 2.0 | |

REV/EN


WESTINGHOUSE NUCLEAR SERVICE DIVISION
INSPECTION SERVICES

GENERAL - INDICATION DATA

PLANT V. C. SUMMER UNIT #1 SKETCH 12150
SYST./COMP. PRIMARY NOZZLE INSIDE RADIUS HOT/COLD LEG PROCEDURE SGE-ISI-247 REV. 0
EXAMINER George Martin DATE 7-31-94

DETECTED BY UT X FT _____ MT _____ VT _____ IDENT. NO. U-IR & V-IR

PROVIDE SUFFICIENT INFORMATION TO DESCRIBE SIZE, LOCATION AND TYPE OF INDICATION. DESCRIBE EXTRA OR SPECIAL EQUIPMENT IF USED FOR SIZING OR REPORTING. IF NECESSARY INCLUDE SKETCH SHOWING GENERAL CONFIGURATION OF ITEM OR AREA.



NOTE: REFERENCE DRAWING 6145E22 SHEET 5 OF 7. SHOWING DRAIN HOLE IN HOT AND COLD LEGS RESPONSIBLE FOR GEOMETRIC REFLECTOR.

REVIEW

AM